PROJECT DETAILS		
PV Modules	35 x rec 365AA Black	
Optimizers	35 x P370	
Inverter	1 x SE11400H-US	
Roof Type	Asphalt Shingles	
Racking	IronRidge XR10	
Mounting Type	Flashfoot 2	
DC SIZE	12.775 kW	
AC SIZE	11.4 kVA	

DRAWING INDEX			
Item	Drawing #	Rev	Description
1	21140JM00-0	Α	Drawing Index
2	21140JM00-1	Α	Sit e La yout
3	21140JM00-2	Α	String Mapping
4	21140JM00-3	Α	Electrical One Line Diagram
5	21140JM00-4	Α	Detailed Electrical Wiring Schematic
6	21140JM00-5	Α	PV Labels
7	21140JM00-6	Α	Bill of Materials



1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474 E: info@8ms olar.com

Juliane Main

1320 Rawls Church Rd. Angier, NC 27501



Ali Buttar PVIP #031310-32

1	06/08/2021	Α	
JOB NUMBER			
	21-140-JM00		
DATE ISSUED			
06/08/2021			
PROJECT STATUS			
PERMITTING			
SHEET			

JM 21140JM00-0

DRAWING INDEX

TOP VIEW OF BUILDING






PV System Dead Load

(Panel + Racking weight) / PV System Area

(35 modules x 43 lbs./panel + 273 ft. of racking x 1.15 lb.ft) / (35 panels x 68.5" x 40.6") = 2.76 psf

The roof is located in 115mph wind zone

There is one layer of shingles Roofing material is a sphalt shingles



Module Dimension	1,016mm	
Roofs	Pitch	Azimuth
А	45°	180°
В	45°	180°
С	25°	180°

1,721mm /


SYSTEM DETAILS

NUMBER OF PANELS: 35


PANELS MODEL: REC 365AA BLACK

DC SIZE: 12.775 kW AC SIZE: 11.4 kVA











Roof C 08 Modules





1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8ms olar.com

Juliane Main

1320 Rawls Church Rd. Angier, NC 27501



Ali Buttar PVIP #031310-32


06/08/2021	_A			
JOB NUMBER				
21-140-JM00				
DATE ISSUED				
06/08/2021				
TATUS PERMITTING				
	21-140-JM00 ED 06/08/2021			

SHEET SITE LAYOUT

> JM 21140JM00-1

6" clearance from each side of the roof

String Layout					
Inverter SE11400H-US (RGM)					
Strings #	No. of Modules	Color Code	Strings #	No. of Modules	Color Code
String 1	14				
String 2	13				
String 3	08				



1,016mm	21mm /
Pitch	Azimuth
45°	180°
45°	180°
25°	180°
	Pitch 45°



1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8ms olar.com

Juliane Main

1320 Rawls Church Rd Angier, NC 27501


SYSTEM DETAILS

NUMBER OF PANELS: 35


PANELS MODEL: REC 365AA BLACK


DC SIZE: 12.775 kW AC SIZE: 11.4 kVA

Roof A 18 Modules



Roof B 09 Modules





Roof C 08 Modules






Ali Buttar PVIP #031310-32

1	06/08/2021	_A_	
			
			
			
JOB NUMBER			
	21-140-JM00		
DATE ISSUED			
06/08/2021			
PROJECT STATUS			
PERMITTING			
SHEET			

STRING MAPPING

JM 21140JM00-2

6" clearance from each side of the roof





1600 Heritage Commerce Ct, Ste 104 Wake Forest NC 27587 O: 919.948.6474

E: info@8ms olar.com

Juliane Main 1320 Rawls Church Rd

Angier, NC 27501



Ali Buttar PVIP #031310-32

<u>1</u> <u>06/08/2021</u> A	_
	-
	-
	-
	-
	-
	-
	-
	_

JOB NUMBER 21-140-JM00


DATE ISSUED 06/08/2021

PROJECT STATUS

PERMITTING

SHEET

ELECTRICAL ONE LINE DIAGRAM





1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8ms olar.com


Juliane Main 1320 Rawls Church Rd. Angier, NC 27501



Ali Buttar PVIP #031310-32

1	06/08/2021	Α	
JOB NUMBER			
21-140-JM00			
DATE ISSUED			
06/08/2021			
PROJECT STATUS			
PERMITTING			
SHEET			

DETAILED ELECTRICAL WIRING SCHEMATIC



A. PURPOSE

PROVIDE EMERGENCY RESPONDERS WITH APPROPRIATE WARNING AND GUIDANCE WITH RESPECT TO ISOLATING THE SOLAR ELECTRIC SYSTEM. THIS CAN FACILITATE IDENTIFYING ENERGIZED ELECTRICAL LINES THAT CONNECT THE SOLAR PANELS TO THE INVERTER, AS SHOULD NOT BE CUT WHEN VENTING FOR SMOKE REMOVAL.

B. MAIN SERVICE DISCONNECT:

- 1. RESIDENTIAL BUILDINGS-THE MARKING MAY BE PLACED WITHIN THE MAIN SERVICE DISCONNECT. THE MARKING SHALL BE PLACED ON THE OUTSIDE COVER IF THE MAIN SERVICE DISCONNECT IS OPERABLE WITH THE SERVICE PANEL CLOSED.
- 2. COMMERCIAL BUILDINGS- THE MARKINGS SHALL BE PLACED ADJACENT TO THE MAIN SERVICE DISCONNECTCLEARLY VISIBLE FROM THE LOCATION WHERE THE LEVER IS O PERATED
- 3. MARKINGS, VERBIAGE, FORMATAND TYPE OF MATERIAL
 - a. VERBIAGE: CAUTION; SOLAR ELECTRIC SYSTEM CONNECTED b. FORMAT:
 - (1) WHITE LETTERING ON A RED BACKGROUND
 - (2) MINIMUM 3/8 INCH LETTER HEIGHT
 - (3) ALL LETTERS SHALL BE CAPITALIZED
 - (4) ARIAL OR SIMILAR FONT, NON-BOLD

c. MATERIAL:

- (1) REFLECTIVE, WEATHER RESISTANT MATERIAL SUITABLE FOR THE ENVIRONMENT (USE UL-969) AS STANDARD FOR WEATHER RATING): DURABLE ADHESIVE MATERIALS MEET THIS REQUIREMENT.
- C. MARKING REQUIREMENTS ON DC CONDUIT, RACEWAYS, ENCLOSURES, CABLE ASSEMBLIES, DC COMBINERS AND JUNCTION BOXES;
 - 1. MARKING: PLACEMENT, VERBIAGE, FORMATAND TYPE OF MATERIAL.
 - a. PLACEMENT: MARKINGS SHALL BE PLACED EVERY 10 (TEN)
 FEET ON ALL INTERIOR AND EXTERIOR DC CONDUITS, RACEWAYS,
 ENCLOSURES AND CABLE ASSEMBLIES, ATTURNS ABOVE AND/OR
 BELOW PENETRATIONS, ALL DC COMBINERS AND JUNCTION BOXES.
 b. VERBIAGE: CAUTION SOLAR CIRCUIT
 - c. THE FORMAT AND TYPE OF MATERIAL SHALL ADHERE TO SECTION B-3.B & C ABOVE
- D. INVERTERS ARE NOT REQUIRED TO HAVE CAUTION MARKINGS





#3 PHOTOVOLTAIC

AC DISCONNECT ...

#4 RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

#5 MAXIMUM VOLTAGE

MAXIMUM GROUIT GURRENT

MAX. RATED OUTPUT GURRENT
OF THE CHARGE CONTROLLER OR
DO-TO-DO CONNETTER (F) INSTALLED)

#6 PHOTOVOLTAIC POWER SOURCE OPERATING AC VOLTAGE V MAXIMUM OPERATING

AC OUTPUT CURRENT

#7 AC DISCONNECT
PHOTOVOLTAIC SYSTEM
POWER SOURCE
RATED AC
OUTPUT CURRENT
NOMINAL OPERATING
AC VOLTAGE
VOLTAGE

#8 AWARNING

#9 **△WARNING**

DUAL POWER SUPPLY SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

#10 **WARNING**

THIS SERVICE METER IS ALSO SERVED BY A PHOTOVOLTAIC SYSTEM

#11 **↑** WARNING

TURN OFF PHOTOVOLTAIC AC DISCONNECT PRIOR TO WORKING INSIDE PANEL

DISCONNECTION OF NEUTRAL GROUNDED CONDUCTORS MAY RESULT IN OVERVOLTAGE ON ARRAY OR INVERTER

#13 AWARNING
SOLAR ELECTRIC CIRCUIT BREAKER IS BACKFED

#16

#14

SOLAR AC DISCONNECT LOCATED AT SOUTH SIDE WALL OF THE HOUSE BESIDE THE UTILITY METER

THIS EQUIPMENT FED BY MULTIPLE

SOURCES. TOTAL RATING OF ALL

OVERCURRENT DEVICES, EXCLUDING

MAIN SUPPLY OVERCURRENT

DEVICE, SHALL NOT EXCEED

AMPACITY OF BUSBAR

WITH RAPID SHUTDOWN

#15 SOLAR PV SYSTEM EQUIPPED

TURN RAPID SHUTDOWN SWITCH TO THE

'OFF' POSITION TO

AND REDUCE

SHOCK HAZARD

IN THE ARRAY

SHUT DOWN PV SYSTEM

#17

SERVICE DISCONNECT LOCATED IN METER COMBINATION PANEL



1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8ms olar.com

Juliane Main 1320 Rawls Church Rd.


Angier, NC 27501



Ali Buttar PVIP #031310-32

1	06/08/2021	A
		-
JOB NUM	1BER	
	21-140-JM00	
DATE ISS		
	06/08/2021	
PROJECT		
	PERMITTING	
SHEET		
PV LAB	ELS	

Rails and Splices: XR10	Roof Attachment : Flashfoot2	
Rafter Spacing : 16 in	There is one layer of shingles Roofing material is a sphalt shingles	
Attachment Span: 4ft	The roof is located in 115mph wind zone	



1,016mm	
Pitch	Azimuth
45°	180°
45°	180°
25°	180°
	Pitch 45° 45°

1,721mm /




1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

O: 919.948.6474 E: info@8ms olar.co m


Juliane Main


1320 Rawls Church Rd.

Roof A 18 Modules



Roof B 09 Modules





Roof C 08 Modules

6" clearance from each side of the roof

RAILS AND SPLICES 04 x XR-10-20 17 x XR-10-16

- 04 x XR-10-204: XR10, Rail 204" (17 Feet) Black
- 17 x XR-10-168B: XR10, Rail 168" (14 Feet) Black
- 10 x XR-10-BOSS-01-M1: XR10 Bonded Splice (Incl. Self-tapping Screws)

CLAMPS & GROUNDING

- 54 x UFO-CL-01-B1: Universal Module Clamp, Black
- 32 x CAMO-01-M1: Hid den End Cam (universal clamp)
- 10 x XR-LUG-03-A1: Grounding Lug, Low Profile

ATTACHMENTS

- 78 x FF2-01-M2: FlashFoot 2, Black
- 78 x BHW-SQ-02-A1: Square-Bolt Bonding Hardware

ACCESSORIE

- 02 x XR-10-CAP: Kit, End Cap XR10 (10 sets per bag)
- 35 x BHW-MI-01-A1: Microin verter Bonding Hardware, T-Bolt
- 70 x Heyco Clips

SOLAR MODULES

35 x REC365AA BLACK

INVERTER & SUPPORTING ITEMS

- 01 x SolarEdge SE11400H-US (with Cons. Meter SE11400H-US000BNI4)
- 35 x SolarEdge Power Optimizer P370
- 01 x SE-WFGW-B-S1-NA with Antenna Kit
- 01 x PV Labels Kit
- 01 x 250A SolarEdge Flex CT
- 01 x DC Power Supply 10-30V DC, 200mA
- 01 x SolarEdge Smart EV Charger (PN:SE-EV-SA-KIT-LJ40P)
- 01 x SolarEdge SE Smart EV Charger boost kit (PN:SE-EV-KIT-V3UPG-01)

WIRE & DISCONNECTS

500 ft x PV WIRE BLK (Cu)

Row: 10'3" (1 x 14') = 14'	
Mounts = 4 (Cantilever 1'1")	
Row: 22'10" (1 x 17' + 1 x 7') = 24'	
Mounts = 6 (Cantilever 1'5")	






Ali Buttar PVIP #031310-32

1	06/08/2021	_ A
JOB NUM		
	21-140-JM00	
DATE ISSU		
	06/08/2021	
PRO JECT :	STATUS PERMITTING	
SHEET		
DIII OF	MATERIAL	
DILL UF	MATERIAL	









REC ALPHX BLACK SERIES


375 W_P POWER

20 YEAR PRODUCT WARRANTY

25 YEAR POWER OUTPUT WARRANTY



C ALPHO BLACK SERIES



GENERAL DATA

Cell type:	120 half-cut cells with REC heterojunction cell technology 6 strings of 20 cells in series
Glass:	0.13 in (3.2 mm) solar glass with anti-reflection surface treatment
Backsheet:	Highly resistant polymeric construction
Frame:	Anodized aluminum (black)

Junction box:	3-part, 3 bypass diodes, IP67 rated in accordance with IEC 62790
Cable:	12 AWG (4 mm²) PV wire, 39 + 47 in (1 + 1.2 m) in accordance with EN 50618
Connectors:	Stäubli MC4PV-KBT4/KST4,12AWG (4mm²) in accordance with IEC 62852 IP68 only when connected
Origin:	Made in Singapore

Product Code*: RECxxxAA Black

ELECTRICAL DATA @ STC

Nominal Power - P _{MPP} (Wp)	355	360	365	370	375
Watt Class Sorting - (W)	-0/+5	-0/+5	-0/+5	-0/+5	-0/+5
Nominal Power Voltage - V _{MPP} (V)	37.4	37.7	38.0	38.3	38.7
Nominal Power Current - I _{MPP} (A)	9.50	9.55	9.60	9.66	9.72
Open Circuit Voltage - V _{oc} (V)	44.0	44.1	44.3	44.5	44.6
Short Circuit Current - I _{SC} (A)	10.19	10.23	10.26	10.30	10.40
Panel Efficiency (%)	20.3	20.6	20.9	21.2	21.4
V. 1	AAA1E: 1: 10.7E.W.			n= (n=ne)	

Values at standard test conditions (STC: air mass AM1.5, irradiance 10.75 W/sq ft (1000 W/m²), temperature 77°F (25°C), based on a production spread with a tolerance of V_{oc} & I_{sc} ±3% within one watt class. *Where xxx indicates the nominal power class (P_{MPP}) at STC above.

ELECTRICAL DATA @ NMOT	Product Code*: RECxxxAA Black				
Nominal Power - P _{MPP} (Wp)	270	274	278	282	286
Nominal Power Voltage - V _{MPP} (V)	35.2	35.5	35.8	36.1	36.4
Nominal Power Current - I _{MPP} (A)	7.67	7.71	7.76	7.80	7.85
Open Circuit Voltage - V _{oc} (V)	41.4	41.6	41.7	41.9	42.0
Short Circuit Current - I _{SC} (A)	8.23	8.26	8.29	8.32	8.40
No. 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1	A A A 1 F	00141/3 1	COSE (200C)		/. /1 /.\ *

Nominal module operating temperature (NMOT: air mass AM 1.5, irradiance $800 \, \text{W/m}^2$, temperature 68°F (20°C), windspeed $3.3 \, \text{ft/s}$ ($1 \, \text{m/s}$). Where xxx indicates the nominal power class (P_{MPP}) at STC above.

CERTIFICATIONS

IEC 61215:2016, IEC 61730:2016, UL 1703, UL 61730		
IEC 62804	PID	
IEC 61701	Salt Mist	
IEC 62716	Ammonia Resistance	
UL 1703	Fire Type Class 2	
IEC 62782	Dynamic Mechanical Load	
IEC 61215-2:2016	Hailstone (35mm)	
AS4040.2 NCC 2016	Cyclic Wind Load	
150110010001150010015015015151515001500		

ISO 14001:2004, ISO 9001:2015, OHSAS 18001:2007









WARRANTY

20 year product warranty 25 year linear power output warranty Maximum annual power degression of 0.25% p.a. Guarantees 92% of power after 25 years See warranty conditions for further details.

MECHANICAL DATA

Dimensions:	67.8 x 40 x 1.2 in (1721 x 1016 x 30 mm)
Area:	18.8 sq ft (1.75 m²)
Weight:	43 lbs (19.5 kg)

MAXIMUM RATINGS

Operational temperature:	-40+85°C
Maximum system voltage:	1000 V
Design load (+): snow Maximum test load (+):	4666 Pa (97.5 lbs/sq ft)* 7000 Pa (146 lbs/sq ft)*
Design load (-): wind Maximum test load (-):	2666 Pa (55.6 lbs/sq ft)⁺ 4000 Pa (83.5 lbs/sq ft)*
Max series fuse rating:	25 A
Max reverse current:	25 A

*Calculated using a safety factor of 1.5
*See installation manual for mounting instructions


TEMPERATURE RATINGS*

Nominal Module Operating Temperature:	44°C (±2°C)
Temperature coefficient of P_{MPP} :	-0.26 %/°C
Temperature coefficient of $V_{\rm oc}$:	-0.24 %/°C
Temperature coefficient of I _{sc} :	0.04 %/°C

*The temperature coefficients stated are linear values

LOW LIGHT BEHAVIOUR

Typical low irradiance performance of module at STC:





Founded in Norway in 1996, REC is a leading vertically integrated solar energy company. Through integrated manufacturing from silicon to wafers, cells, high-quality panels and extending to solar solutions, REC provides the world with a reliable source of clean energy. REC's renowned product quality is supported by the lowest warranty claims rate in the industry. REC is a Bluestar Elkem company with headquarters in Norway and operational headquarters in Singapore. REC employs around 2,000 people worldwide, producing 1.5 GW of solar panels annually.





Single Phase Inverter with HD-Wave Technology

for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US





Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking 99% weighted efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12

UL1741 SA certified, for CPUC Rule 21 grid compliance

NVERTE

- Small, lightweight, and easy to install both outdoors or indoors
- Built-in module-level monitoring
- Optional: Faster installations with built-in consumption metering (1% accuracy) and production revenue grade metering (0.5% accuracy, ANSI C12.20)



Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US		
APPLICABLE TO INVERTERS WITH PART NUMBER	SEXXXXH-XXXXXBXX4								
OUTPUT	'								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
AC Output Voltage MinNomMax. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	√	Vac	
AC Output Voltage MinNomMax. (183 - 208 - 229)	-	√	-	✓	-	-	✓	Vac	
AC Frequency (Nominal)				59.3 - 60 - 60.5 ⁽¹⁾				Hz	
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	А	
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	А	
Power Factor			1,	, Adjustable - 0.85 to	0.85				
GFDI Threshold				1				А	
Utility Monitoring, Islanding Protection, Country Configurable Thresholds		Yes							
INPUT									
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W	
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W	
Transformer-less, Ungrounded				Yes					
Maximum Input Voltage				480				Vdc	
Nominal DC Input Voltage		3	880			400		Vdc	
Maximum Input Current @240V ⁽²⁾	8.5	10.5	13.5	16.5	20	27	30.5	Adc	
Maximum Input Current @208V ⁽²⁾	-	9	-	13.5	-	-	27	Adc	
Max. Input Short Circuit Current				45				Adc	
Reverse-Polarity Protection				Yes					
Ground-Fault Isolation Detection		600kΩ Sensitivity							
Maximum Inverter Efficiency	99 99.2							%	
CEC Weighted Efficiency		99 99 99.5 @ 240V 98.5 @ 208V							
Nighttime Power Consumption		< 2.5							

 $^{^{\}mbox{\tiny (1)}}$ For other regional settings please contact SolarEdge support

⁽²⁾ A higher current source may be used; the inverter will limit its input current to the values stated

Single Phase Inverter with HD-Wave Technology for North America


SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US			
ADDITIONAL FEATURES	1		•	•						
Supported Communication Interfaces			RS485, Etherne	et, ZigBee (optional),	Cellular (optional)					
Revenue Grade Metering, ANSI C12.20				Optional ⁽³⁾						
Consumption metering										
Inverter Commissioning		With the SetApp mobile application using Built-in Wi-Fi Access Point for Local Connection								
Rapid Shutdown - NEC 2014 and 2017 690.12			Automatic Rap	id Shutdown upon A	C Grid Disconnect					
STANDARD COMPLIANCE										
Safety		UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07								
Grid Connection Standards		IEEE1547, Rule 21, Rule 14 (HI)								
Emissions		FCC Part 15 Class B								
INSTALLATION SPECIFICAT	TIONS									
AC Output Conduit Size / AWG Range		1" Maximum / 14-6 AWG 1" Maximum /14-4 AWG								
DC Input Conduit Size / # of Strings / AWG Range		1" Maximum / 1-2 strings / 14-6 AWG 1" Maximum / 1-3 strings / 14-6 AWG								
Dimensions with Safety Switch (HxWxD)		17.7 x 14.6 x 6.8 / 450 x 370 x 174 21.3 x 14.6 x 7.3 / 540 x 370 x 185						in / mm		
Weight with Safety Switch	22 /	10	25.1 / 11.4	26.2	/ 11.9	38.8 / 1	7.6	lb / kg		
Noise	< 25 < 50						dBA			
Cooling				Natural Convectio	n					
Operating Temperature Range		$-40 \text{ to } +140 \text{ / } -40 \text{ to } +60^{(4)}$						°F/°C		
Protection Rating			NEMA	4X (Inverter with Safe	ety Switch)					

⁽³⁾ Inverter with Revenue Grade Meter P/N: SExxxxH-US000BNC4; Inverter with Revenue Grade Production and Consumption Meter P/N: SExxxxH-US000BNI4 . For consumption metering, current transformers should be ordered separately. SEACT0750-200NA-20 or SEACT0750-400NA-20. 20 units per box

How to Enable Consumption Monitoring

By simply wiring current transformers through the inverter's existing AC conduits and connecting them to the service panel, homeowners will gain full insight into their household energy usage helping them to avoid high electricity bills





⁽⁴⁾ Full power up to at least 50°C / 122°F; for power de-rating information refer to: https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf

Power Optimizer

For North America

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505





POWER OPTIMIZER

PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization

- Fast installation with a single bolt
- Next generation maintenance with modulelevel monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety



/ Power Optimizer **For North America**

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high- power 60-cell modules)	P370 (for higher- power 60 and 72- cell modules)	P400 (for 72 & 96-cell modules)	P401 (for high power 60 and 72 cell modules)	P405 (for high- voltage modules)	P485 (for high- voltage modules)	P505 (for higher current modules)	
INPUT		<u>'</u>					•		
Rated Input DC Power ⁽¹⁾	320	340	370	4	00	405	485	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	48 60 80 60 125(2) 83(2)								Vdc
MPPT Operating Range	8 -	48	8 - 60	8 - 80	8-60	12.5	- 105	12.5 - 83	Vdc
Maximum Short Circuit Current (lsc)		11		10.1	11.75	1	1	14	Adc
Maximum DC Input Current		13.75		12.5	14.65	12	2.5	17.5	Adc
Maximum Efficiency				99.	5				%
Weighted Efficiency				98.8				98.6	%
Overvoltage Category				II					
OUTPUT DURING OPER	ATION (POV	VER OPTIMI	ZER CONNEC	TED TO OPE	RATING SOL	AREDGE IN	VERTER)		
Maximum Output Current				15	i				Adc
Maximum Output Voltage	60 85								Vdc
OUTPUT DURING STANI	DBY (POWER	OPTIMIZER	DISCONNECT	ED FROM SC	LAREDGE IN	IVERTER OR	SOLAREDGI	E INVERTER O	OFF)
Safety Output Voltage per Power Optimizer	1 ± 0.1								
STANDARD COMPLIAN	CE								
EMC			FCC Pa	rt15 Class B, IEC6	1000-6-2, IEC6100	0-6-3			
Safety	IEC62109-1 (class II safety), UL1741								
Material	UL94 V-0 , UV Resistant								
RoHS	Yes								
INSTALLATION SPECIFI	CATIONS								
Maximum Allowed System Voltage				100	00				Vdc
Compatible inverters			All SolarE	dge Single Phase	and Three Phase i	nverters			
Dimensions (W x L x H)	129 :	129 x 153 x 27.5 / 5.1 x 6 x 1.1						mm / in	
Weight (including cables)		630 / 1.4		750 / 1.7	655 / 1.5	845	/ 1.9	1064 / 2.3	gr/lb
Input Connector		$MC4^{(3)}$ Single or dual $MC4^{(3)}$ $MC4^{(3)}$							
Input Wire Length				0.16 /	0.52				m/ft
Output Wire Type / Connector				Double Insul	ated / MC4				
Output Wire Length	0.9 /	2.95			1.2 /	3.9			m/ft
Operating Temperature Range ⁽⁵⁾		-40 - +85 / -40 - +185							°C / °F
Protection Rating				IP68 / N	EMA6P				
Relative Humidity	0 - 100								%

⁽¹⁾ Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed

PV System Design Using a SolarEdge Inverter ⁽⁶⁾⁽⁷⁾		Single Phase Single phase		Three Phase for 208V grid	Three Phase for 277/480V grid	
Minimum String Length	P320, P340, P370, P400, P401	8		10	18	
(Power Optimizers)	P405, P485, P505	6	5	8	14	
Maximum String Length (Power Optimizers)		25		25	50(8)	
Maximum Power per String		5700 (6000 with SE7600-US - SE11400- US) 5250		6000 ⁽⁹⁾	12750 ⁽¹⁰⁾	W
Parallel Strings of Different Lengths	or Orientations	Yes				



⁽²⁾ NEC 2017 requires max input voltage be not more than 80V

⁽³⁾ For other connector types please contact SolarEdge
(4) For dual version for parallel connection of two modules use P485-4NMDMRM. In the case of an odd number of PV modules in one string, installing one P485 dual version power optimizer connected to one PV module. When connecting a single module seal the unused input connectors with the supplied pair of seals.

(5) For ambient temperature above +85°C / +185°F power de-rating is applied. Refer to Power Optimizers Temperature De-Rating Technical Note for more details.

⁽⁶⁾ For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string_sizing_na.pdf
(7) It is not allowed to mix P405/P485/P505 with P320/P340/P370/P400/P401 in one string
(8) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement

⁽⁹⁾ For 208V grid: it is allowed to install up to 6,500W per string when the maximum power difference between each string is 1,000W

⁽¹⁰⁾ For 277/480V grid: it is allowed to install up to 15,000W per string when the maximum power difference between each string is 2,000W



Intertek 3933 US Route 11 Cortland, NY 13045 Telephone: 607-753-7311 www.intertek.com

Subject: ETL Evaluation of SolarEdge Products to NEC 2017 Rapid Shutdown Requirements

To, whom it may concern

This letter represents the testing results of the below listed products to the requirements contained in the following standards:

The evaluation was done on the PV Rapid Shutdown System (PVRSS), and covers installations consisting of optimizers and inverters with part numbers listed below.

The testing done has verified that controlled conductors are limited to:

- Not more than 30 volts and 240 voltamperes within 30 seconds of rapid shutdown initiation outside the array.
- Not more than 80 volts and 240 voltamperes within 30 seconds of rapid shutdown initiation inside the array.

The rapid shutdown initiation is performed by either disconnecting the AC feed to the inverter, or – if the inverter DC Safety switch is readily accessible – by turning off the DC Safety switch.

Applicable products:

(1) Power optimizers:

PB followed by 001 to 350; followed by -AOB or -TFI. OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV. P followed by 001 to 860.

SP followed by 001 to 350.

When optimizers are connected to 2 or more modules in series, the max input voltage may exceed 80V. Following the implementation of the NEC 2017 rapid shutdown value of 80V max inside of the array at the beginning of 2019, modules exceeding this combined input max voltage will be required to use optimizers with parallel inputs.

(2) 1 -PH Inverters

 $SE3000A-US\ /\ SE3800A-US\ /\ SE5000A-US\ /\ SE6000A-US\ /\ SE7600A-US\ /\ SE10000A-US\ /\ SE11400A-US\ /\ SE3000H-US\ /\ SE5000H-US\ /\ SE5000H-US\ /\ SE5000H-US\ /\ SE11400H-US\ when the following label is labeled on the side of the inverter:$

Inverter part number may be followed by a suffix.

(3) 3 -PH Inverters

SE9KUS / SE10KUS / SE14.4KUS / SE20KUS / SE30KUS / SE33.3KUS / SE43.2KUS / SE66.6KUS / SE100KUS; when the following label is labeled on the side of the inverter:

Please note, this Letter Report does not represent authorization for the use of any Intertek certification marks.



Intertek 3933 US Route 11 Cortland, NY 13045 Telephone: 607-753-7311 www.intertek.com

Brand Name(s) SolarEdge

Relevant Standard(s) UL 1741, UL 1741 CRD for rapid shutdown

National Electric Code, 2017, Section 690.12 requirement for

rapid shutdown

Verification Issuing Office 3933 US Route 11, Cortland, NY 13045

NRTL Disclaimer, Different for each NRTL – Example: "This Verification is for the exclusive use of NRTL's Client and is provided pursuant to the agreement between NRTL and its Client. NRTL's responsibility and liability are limited to the terms and conditions of the agreement. NRTL assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the NRTL name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by NRTL. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an NRTL certification program."

Signature:

Name: Mukund Rana

Position: Engineering Team Leader

Date: 2/11/2020




XR Rail Family

Solar Is Not Always Sunny

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

Compatible with Flat & Pitched Roofs



XR Rails are compatible with FlashFoot and other pitched roof attachments.



IronRidge offers a range of tilt leg options for flat roof mounting applications.

Corrosion-Resistant Materials

All XR Rails are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



XR Rail Family

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



XR10

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves spans up to 6 feet, while remaining light and economical.

- · 6' spanning capability
- · Moderate load capability
- · Clear & black anodized finish
- · Internal splices available



XR100

XR100 is the ultimate residential mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 10 feet.

- · 10' spanning capability
- · Heavy load capability
- · Clear & black anodized finish
- · Internal splices available



XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications.

- · 12' spanning capability
- · Extreme load capability
- Clear anodized finish
- · Internal splices available

Rail Selection

The table below was prepared in compliance with applicable engineering codes and standards.* Values are based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed certification letters.

Lo	ad	Rail Span								
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'	10'	12'			
	90									
None	120									
None	140	XR10		XR100		XR1000				
	160									
	90									
20	120									
20	140									
	160									
30	90									
30	160									
40	90									
40	160									
80	160									
120	160	11.1								

^{*}Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved certification letters for actual design guidance.



FlashFoot2

The Strongest Attachment in Solar

IronRidge FlashFoot2 raises the bar in solar roof protection. The unique water seal design is both elevated and encapsulated, delivering redundant layers of protection against water intrusion. In addition, the twist-on Cap perfectly aligns the rail attachment with the lag bolt to maximize mechanical strength.

Three-Tier Water Seal

Twist-On Cap


FlashFoot2's unique Cap design encapsulates the lag bolt and locks into place with a simple twist. The Cap helps FlashFoot2 deliver superior structural strength, by aligning the rail and lag bolt in a concentric load path.



FlashFoot2's seal architecture utilizes three layers of protection. An elevated platform diverts water away, while a stack of rugged components raises the seal an entire inch. The seal is then fully-encapuslated by the Cap. FlashFoot2 is the first solar attachment to pass the TAS-100 Wind-Driven Rain Test.

Single Socket Size


A custom-design lag bolt allows you to install FlashFoot2 with the same 7/16" socket size used on other Flush Mount System components.



Water-Shedding Design

An elevated platform diverts water away from the water seal.

Installation Features



(A) Alignment Markers

Quickly align the flashing with chalk lines to find pilot holes.

B Rounded Corners

Makes it easier to handle and insert under the roof shingles.


C Reinforcement Ribs

Help to stiffen the flashing and prevent any bending or crinkling during installation.

Benefits of Concentric Loading

Traditional solar attachments have a horizontal offset between the rail and lag bolt, which introduces leverage on the lag bolt and decreases uplift capacity.

FlashFoot2 is the only product to align the rail and lag bolt. This concentric loading design results in a stronger attachment for the system.



Testing & Certification

Structural Certification

Designed and Certified for Compliance with the International Building Code & ASCE/SEI-7.

Water Seal Ratings

Water Sealing Tested to UL 441 Section 27 "Rain Test" and TAS 100-95 "Wind Driven Rain Test" by Intertek. Ratings applicable for composition shingle roofs having slopes between 2:12 and 12:12.

UL 2703

Conforms to UL 2703 Mechanical and Bonding Requirements. See Flush Mount Install Manual for full ratings.

PRE-INSTALLATION

□ Verify module compatibility. See Page 13 for info.

TOOLS REQUIRED

- ☐ Cordless Drill (non-impact)
- ☐ Impact Driver (for lag bolts)
- ☐ Torque Wrench (0-250 in-lbs)
- □ 5/16" Socket
- □ 7/16" Socket
- ☐ 1/2" Socket
- ☐ String Line

TORQUE VALUES

- ☐ FlashFoot2 Lag Bolts (7/16" Socket): Fully Seat
- ☐ Bonded Splice Screws (5/16" Socket): 20 in-lbs
- ☐ Grounding Lug Nuts (7/16" Socket): 80 in-lbs
- ☐ Grounding Lug Terminal Screws (7/16" Socket): 20 in-lbs
- ☐ Universal Fastening Object (7/16" Socket): 80 in-lbs
- □ Expansion Joint Nuts (7/16" Socket): 80 in-lbs
- ☐ Flush Standoffs (1/2" Socket): 132 in-lbs
- ☐ Microinverter Kit Nuts (7/16" Socket): 80 in-lbs
- ☐ Frameless Module Kit Nuts (7/16" Socket): 80 in-lbs
- □ 3/8" Bonding Hardware Nuts (7/16" Socket): 250 in-lbs
- ☐ All Tile Hook Lags (7/16" Socket): Fully Seat
- ☐ All Tile Hook Carriage Bolts (7/16" Socket): 132 in-lbs
- ☐ Knockout Tile Lags (1/2" Socket): Fully Seat
- ☐ Knockout Tile Nuts (1/2" Socket): 132 in-lbs
- ☐ Flat Roof Attachment Nuts (9/16" Socket): 250 in-lbs


IRONRIDGE COMPONENTS



XR Rail



Bonded Splice



L-Foot



FlashFoot2



UFO and Stopper Sleeve



CAMO



8" Bonding Jumper



Grounding Lug



Expansion Joint



End Cap



Wire Clip



Flush Standoff



Microinverter Kit




3/8" Bonding Hardware




Frameless Module Kit




Frameless End/Mid Clamp



All Tile Hook




All Tile Hook Flashing



Knockout Tile



Flat Roof Attachment



Membrane Flashing

If using FlashVue or previous version of: FlashFoot, Integrated Grounding Mid Clamps, Grounding Lug, End Clamps, and Expansion Joints please refer to Alternate Components Addendum (Version 1.3).





UL50 Type 3R Enclosure • Stamped 18 gauge gal. steel • Powder coated finish • Weather tight

Enclosure Includes:

- Dual ground lug
- · Universal DIN rail
- 1/2". 3/4" & 1" knockouts
- · Wire strain relief clip
- Complete hardware package



INTRODUCED AT SOLAR POWER 2007





PV Roof-Mount Combiner/Enclosure

Benefits

- •The ability to prep the building is now possible
- Replaces several parts used today
- Provides professional looking install
- · Saves time on install
- Allows for easy access
- Guaranteed seal to roof
- Low profile design

For product information contact us at [866] 367-7782

www.commdeck.com



RSTC Enterprises, Inc 2219 Heimstead Road Eau Claire, WI 54703 1 (866) 367 - 7782





SolaDeck Part # 780

Specifications:

18 Gauge Steel Base (1) and Cover (2)
Pre Punched 7 holes in base (1) for roof deck
Pre Punched 4 holes in base (1) and cover (2) for match
Draw Process both parts
Powder Coated to withstand 1000 hours Salt Spray (Primer Gray)
High UV resistance
15" x 15" flashing dimension
Cavity dimension 8"W x 9" L x 2.5"D
Approx. 162 Cubic inch equipment cavity
Norloked steel base plate (3) to drawn base (2)
Three knockout locations .5", .75" and 1"
3" DIN rail installed
Grounding Lug- Installed (In Equipment Cavity)
Wire Strain Relief Clip –Installed (In Equipment Cavity)
Hardware pack withstands 500 hours Salt Spray

- 7 2" Trusshead Screws
- 4 .5" 8-32 thread cutting screws
- 4 #10 Bonded Seal washers
- 1 Foam closed Cell Seal

ETL Listed UL50 Type 3R

Total Weight 6.9 pounds each

Packaging:

Individually bagged and boxed
Box dimension 15.5"w x 16" L x 3" D
White Carton labeled with Cut out template
Print One Color - Black

Master Cartons of 6 Units each
Master Carton dimension 18.75"x16"x16.375"
Master Carton Weight – 42 pounds
18 Master Cartons per skid Approx 800 pounds with skid

