



"Delivering the Greatest Value Per Gallon"

1709 N. MAIN ST | PO BOX 219 | FUQUAY-VARINA, NC 27526
(919)-552-5474 | WWW.KBJOHNSON.COM

August 27, 2021


Harnett County Inspections Department
420 McKinney Parkway
Lillington, NC 27546

Re: Howard Babbitt
70 Swan Lane
Angier, NC 27501

To Whom It May Concern,

The generator gas line located at 70 Swan Lane Angier, NC 27501 was installed according to the North Carolina Building & NC Fuel Gas Code. Gas Line was installed no less than 12" deep and was leak/pressure tested for 3 minutes with no pressure drop. Please contact me if you have any questions.

Thank you,


Hal Johnson