



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

1/21/2022

**SUBJECT: ERES2108-0036
ELECTRICAL RESIDENTIAL**

To: Marc Jones Construction LLC DBA Sunpro Solar

Here are the results of all Inspections located at **100 TRIPOLI DR:**

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 11/9/2021
Completed Date/Time: 11/9/2021
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG
Loose wiring in disconnect.

Inspection Type: FINAL**
Scheduled Date/Time: 1/20/2022
Completed Date/Time: 1/20/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/19/2022 12:47 PM Marc Jones Construction LLC DBA Sunpro Solar
Homeowner contact number is 803-319-0815
Contact Name: Marc Jones Construction LLC DBA Sunpro Solar
Site Address: 100 Tripoli Drive, Cameron
Phone: 9197457925
e-Mail: j.parks@theprocompanies.com

Inspector SBL changed the inspection assignment from SBL to SPG