


ABBREVIATIONS	ELECTRICAL NOTES	JURISDICTION NOTES	
<p>A AMPERE AC ALTERNATING CURRENT BLDG BUILDING CONC CONCRETE DC DIRECT CURRENT EGC EQUIPMENT GROUNDING CONDUCTOR (E) EXISTING EMT ELECTRICAL METALLIC TUBING FSB FIRE SET-BACK GALV GALVANIZED GEC GROUNDING ELECTRODE CONDUCTOR GND GROUND HDG HOT DIPPED GALVANIZED I CURRENT Imp CURRENT AT MAX POWER Isc SHORT CIRCUIT CURRENT kVA KILOVOLT AMPERE kW KILOWATT LBW LOAD BEARING WALL MIN MINIMUM (N) NEW NEUT NEUTRAL NTS NOT TO SCALE OC ON CENTER PL PROPERTY LINE POI POINT OF INTERCONNECTION PV PHOTOVOLTAIC SCH SCHEDULE S STAINLESS STEEL STC STANDARD TESTING CONDITIONS TYP TYPICAL UPS UNINTERRUPTIBLE POWER SUPPLY V VOLT Vmp VOLTAGE AT MAX POWER Voc VOLTAGE AT OPEN CIRCUIT W WATT 3R NEMA 3R, RAIN TIGHT</p>	<p>1. THIS SYSTEM IS GRID-INTERTIED VIA A UL-LISTED POWER-CONDITIONING INVERTER.  2. A NATIONALLY - RECOGNIZED TESTING LABORATORY SHALL LIST ALL EQUIPMENT IN COMPLIANCE WITH ART. 110.3.  3. WHERE ALL TERMINALS OF THE DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION, A SIGN WILL BE PROVIDED WARNING OF THE HAZARDS PER ART. 690.17.  4. EACH UNGROUNDED CONDUCTOR OF THE MULTIWIRED BRANCH CIRCUIT WILL BE IDENTIFIED BY PHASE AND SYSTEM PER ART. 210.5.  5. CIRCUITS OVER 250V TO GROUND SHALL COMPLY WITH ART. 250.97, 250.92(B).  6. DC CONDUCTORS EITHER DO NOT ENTER BUILDING OR ARE RUN IN METALLIC RACEWAYS OR ENCLOSURES TO THE FIRST ACCESSIBLE DC DISCONNECTING MEANS PER ART. 690.31(E).  7. ALL WIRES SHALL BE PROVIDED WITH STRAIN RELIEF AT ALL ENTRY INTO BOXES AS REQUIRED BY UL LISTING.  8. MODULE FRAMES SHALL BE GROUNDED AT THE UL - LISTED LOCATION PROVIDED BY THE MANUFACTURER USING UL LISTED GROUNDING HARDWARE.  9. MODULE FRAMES, RAIL, AND POSTS SHALL BE BONDED WITH EQUIPMENT GROUND CONDUCTORS.</p>	<h3>VICINITY MAP</h3> 	
<h3>LICENSE</h3>	<h3>GENERAL NOTES</h3>	<h3>INDEX</h3>	

<p>1. ALL WORK SHALL COMPLY WITH THE 2018 NORTH CAROLINA RESIDENTIAL CODE.  2. ALL ELECTRICAL WORK SHALL COMPLY WITH THE 2017 NATIONAL ELECTRIC CODE.</p>
<p>MODULE GROUNDING METHOD: ZEP SOLAR</p>
<p>AHJ: Harnett County</p>
<p>UTILITY: South River EMC</p>



Sheet 1	COVER SHEET
Sheet 2	SITE PLAN
Sheet 3	STRUCTURAL VIEWS
Sheet 4	UPLIFT CALCULATIONS
Sheet 5	THREE LINE DIAGRAM
Cutsheets Attached	

REV	BY	DATE	COMMENTS
REV A	ZR	3/10/2022	Module Swap/Tie-in Update
REV C	ZR	4/29/2022	Updated Tie-in to BUS in 2nd meter
*	*	*	*
*	*	*	*
*	*	*	*

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT TESLA INC., NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE THE RECIPIENT'S ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE TESLA EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF TESLA INC.

JOB NUMBER: JB-283301 00
MOUNTING SYSTEM: ZS Comp V4 w Flashing-Insert
MODULES: (33) Tesla # T395H
INVERTER: Multiple Inverters


<p>CUSTOMER:  Brent Ely  1195 Micahs Way N  Spring Lake, NC 28390</p>
<p>3344983272</p>

<p>DESCRIPTION:  13.035 KW PV ARRAY  27 KWH ENERGY STORAGE SYSTEM</p>
<p>PAGE NAME:  COVER SHEET</p>

<p>DESIGN:  Zach Rosen</p>
<p>SHEET: 1      REV: C      DATE: 4/29/2022</p>



PV ARRAY DEAD LOAD = 3 LBS/SF



MP1	PITCH: 30° (7:12) ARRAY PITCH: 30° (7:12) AZIMUTH: 177 ARRAY AZIMUTH: 177 MATERIAL: Comp Shingle STORY: 2 Stories
MP2	PITCH: 30° (7:12) ARRAY PITCH: 30° (7:12) AZIMUTH: 357 ARRAY AZIMUTH: 357 MATERIAL: Comp Shingle STORY: 2 Stories
MP3	PITCH: 30° (7:12) ARRAY PITCH: 30° (7:12) AZIMUTH: 267 ARRAY AZIMUTH: 267 MATERIAL: Comp Shingle STORY: 2 Stories
MP4	PITCH: 30° (7:12) ARRAY PITCH: 30° (7:12) AZIMUTH: 87 ARRAY AZIMUTH: 87 MATERIAL: Comp Shingle STORY: 2 Stories

### LEGEND

- (E) UTILITY METER & WARNING LABEL
- INVERTER W/ INTEGRATED DC DISCO & WARNING LABELS
- AUTOMATIC RELAY
- DC DISCONNECT & WARNING LABELS
- AC DISCONNECT & WARNING LABELS
- DC JUNCTION/COMBINER BOX & LABELS
- ENERGY STORAGE SYSTEM FOR STAND ALONE OPERATION
- DISTRIBUTION PANEL & LABELS
- LOAD CENTER & WARNING LABELS
- DEDICATED PV SYSTEM METER
- RAPID SHUTDOWN
- STANDOFF LOCATIONS
- CONDUIT RUN ON EXTERIOR
- CONDUIT RUN ON INTERIOR
- GATE/FENCE
- HEAT PRODUCING VENTS ARE RED
- INTERIOR EQUIPMENT IS DASHED

### SITE PLAN

Scale: 3/32" = 1'



CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT TESLA INC., NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE THE RECIPIENT'S ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE TESLA EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF TESLA INC.

JOB NUMBER: JB-283301 00

MOUNTING SYSTEM:  
ZS Comp V4 w Flashing-Insert

MODULES:  
(33) Tesla # T395H

INVERTER:  
Multiple Inverters

CUSTOMER:  
Brent Ely  
1195 Micahs Way N  
Spring Lake, NC 28390

3344983272


DESCRIPTION:  
13.035 KW PV ARRAY  
27 KWH ENERGY STORAGE SYSTEM

PAGE NAME:  
SITE PLAN


DESIGN:  
Zach Rosen

SHEET: 2 REV: C DATE: 4/29/2022





**SV** **TYPICAL PV SIDE VIEW**  
NTS



CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT TESLA INC., NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE THE RECIPIENT'S ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE TESLA EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF TESLA INC.

JOB NUMBER: JB-283301 00

MOUNTING SYSTEM: ZS Comp V4 w Flashing-Insert

MODULES: (33) Tesla # T395H

INVERTER: Multiple Inverters

CUSTOMER: Brent Ely  
1195 Micahs Way N  
Spring Lake, NC 28390

3344983272

DESCRIPTION: 13.035 KW PV ARRAY  
27 KWH ENERGY STORAGE SYSTEM

PAGE NAME: STRUCTURAL VIEWS

DESIGN: Zach Rosen

SHEET: 3 REV: c DATE: 4/29/2022



Jobsite Specific Design Criteria			
Design Code		ASCE 7-10	
Risk Category		II	Table 1.5-1
Ultimate Wind Speed	V-Ult	120	Fig. 1609A
Exposure Category		C	Section 26.7
Ground Snow Load	pg	20	Table 7-1
Edge Zone Width	a	6.4 ft	Fig. 30.4-2A to 30.4-2C

MP Specific Design Information			
MP Name	MP1	MP3	MP4
Roofing	Comp Shingle	Comp Shingle	Comp Shingle
Standoff	ZS Comp V4 w Flashing-Insert	ZS Comp V4 w Flashing-Insert	ZS Comp V4 w Flashing-Insert
Pitch	30	30	30
SL/RLL: PV	9.2	9.2	9.2
SL/RLL: Non-PV	17.0	17.0	17.0

Standoff Spacing and Layout			
MP Name	MP1	MP3	MP4
Landscape X-Spacing	72	72	72
Landscape X-Cantilever	24	24	24
Landscape Y-Spacing	41	41	41
Landscape Y-Cantilever	-	-	-
Portrait X-Spacing	48	48	48
Portrait X-Cantilever	20	20	20
Portrait Y-Spacing	74	74	74
Portrait Y-Cantilever	-	-	-
Layout	Staggered	Staggered	Staggered

X and Y are maximums that are always relative to the structure framing that supports the PV. X is across rafters and Y is along rafters.

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT TESLA INC., NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE THE RECIPIENT'S ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE TESLA EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF TESLA INC.

JOB NUMBER: JB-283301 00

MOUNTING SYSTEM:  
ZS Comp V4 w Flashing-Insert

MODULES:  
(33) Tesla # T395H

INVERTER:  
Multiple Inverters

CUSTOMER:  
Brent Ely  
1195 Micahs Way N  
Spring Lake, NC 28390

3344983272

DESCRIPTION:  
13.035 KW PV ARRAY  
27 KWH ENERGY STORAGE SYSTEM

PAGE NAME:  
UPLIFT CALCULATIONS


DESIGN:  
Zach Rosen

SHEET: 4 REV: C DATE: 4/29/2022

TESLA

	<b>MAIN PANEL SPECS</b> Panel Number: NoLabel Meter Number: 159218218 Underground Service Entrance	<b>GENERAL NOTES</b> Inv 1: DC Ungrounded Inv 2: DC Ungrounded	<b>PRODUCT SPECS</b> 1 - (1) Powerwall+ [240V] #1850000-00-C / PMI Assy. 1538000-35-F 2 - (1) Powerwall+ [240V] #1850000-00-C / PMI Assy. 1538000-25-F 3	<b>MODULE SPECS</b> - (33) Tesla # T395H PV Module, 395W, 366.7 PTC, 40MM, Black Frame, MC4/MC4-EV02, ZEP, 1000V Voc: 45.27 Vpmax: 36.88 Isc AND Imp ARE SHOWN IN THE DC STRINGS IDENTIFIER	<b>LICENSE</b>
--	---	--	---	---	----------------

(E) 200A MAIN SERVICE PANEL  
Multiple Main Breakers (6 or fewer)



Up to (3) Powerwall+ units can be wired to the emergency stop button (e-stop) for rapid shutdown initiation. Low voltage wiring of connection(s) to additional units is not shown.

Voc\* = MAX VOC AT MIN TEMP

<b>POI</b>	(1) Ground Rod 5/8" x 8", Copper (1) SQUARE D # HOM2200BB Breaker; 200A/2P, 4 Spaces	<b>7</b>	(1) AWG #8, THWN-2, Black (1) AWG #8, THWN-2, Red (1) AWG #8, THWN-2, Green (1) Conduit Kit; 3/4" EMT	(1) AWG #8, THWN-2, White EGC Vmp = 240 VAC Imp = 32 AAC	<b>V</b>	(1) SQUARE D #HOM3060M200PRB Load Center; 200A bus, 200A MB, NEMA3R, 30sp/40cir, 120v/240v, 22kAIC, Surface	<b>GD</b>	— Please see MCI wiring detail page for more information	<b>DC</b>	
<b>Z</b>	(1) 1624171-00-G Backup Switch (1) Eaton 204 MS68 B-Line Meter Socket, 200A, AW Hub top, Overhead, 4 jaws, Ring type (3) ILSCO # IPC 4/0-2/0 Insulation Piercing Connector; Main 4/0-2, Tap 2/0-6	<b>8</b>	(1) AWG #8, THWN-2, Black (1) AWG #8, THWN-2, Red (1) AWG #8, THWN-2, Green (1) Conduit Kit; 3/4" EMT	(1) AWG #8, THWN-2, White EGC Vmp = 240 VAC Imp = 32 AAC			<b>A</b>	(2) EE-000550-001 MC4 Y-Connector, Receptacle (2) EE-000550-000 MC4 Y-Connector, Plug		
<b>Y</b>	(1) CUTLER-HAMMER # DS36FK Class R Fuse Kit (2) FERRAZ SHAWMUT # TR100R Fuse; 100A, 250V, Class RK5 (1) CUTLER-HAMMER # DG100NB Ground/Neutral Kit; 60-100A, General Duty (DG) (1) CUTLER-HAMMER # DG223NRB Disconnect; 100A, 240VAC, Fusible, NEMA 3R	<b>9</b>	(3) AWG #3/0, THWN-2, Black (1) AWG #6, THWN-2, Green (1) Conduit 2" PVC; Schedule 80				<b>PV</b>	(13) Tesla MCI, 650V, 12A		
<b>X</b>	(1) SQUARE D #HOM1224L125PC Load Center; 125A, Convertible, NEMA1, 12sp/24cir, 120v/240v, Combo Cover (2) SQUARE D # HOM250 Breaker; 50A/2P, 2 Spaces	<b>10</b>	(1) AWG #3, THWN-2, White (1) AWG #3, THWN-2, Red (1) AWG #3, THWN-2, Black (1) AWG #8, THWN-2, Green (3) AWG #3/0, THWN-2, Black	(1) Conduit Kit; 1-1/4" EMT			<b>4</b>	(2) PV Wire, AWG 10 Voc* = 390.52VDC Isc = 22.2 ADC (1) AWG #10, Solid Bare Copper EGC Vmp = 295.04VDC Imp = 21.42 ADC (1) Conduit Kit; 3/4" EMT	<b>1</b>	(4) PV Wire, AWG 10 Voc* = 390.52VDC Isc = 11.1 ADC (1) AWG #10, THHN/THWN-2, Green EGC Vmp = 295.04VDC Imp = 10.71 ADC (1) Conduit Kit; 3/4" EMT
<b>W</b>	(1) UL 508 Emergency Stop Device - NEMA 4X	<b>11</b>	(1) AWG #6, THWN-2, Green (1) Conduit 2" PVC; Schedule 80				<b>5</b>	(2) PV Wire, AWG 10 Voc* = 195.26 VDC Isc = 22.2 ADC (1) AWG #10, Solid Bare Copper EGC Vmp = 147.52 VDC Imp = 21.42 ADC (1) Conduit Kit; 3/4" EMT	<b>2</b>	(2) PV Wire, AWG 10 Voc* = 439.33VDC Isc = 11.1 ADC (1) AWG #10, THHN/THWN-2, Green EGC Vmp = 331.92 VDC Imp = 10.71 ADC (1) Conduit Kit; 3/4" EMT
							<b>6</b>	(2) PV Wire, AWG 10 Voc* = 439.33VDC Isc = 11.1 ADC (1) AWG #10, Solid Bare Copper EGC Vmp = 331.92 VDC Imp = 10.71 ADC (1) Conduit Kit; 3/4" EMT	<b>3</b>	(4) PV Wire, AWG 10 Voc* = 195.26 VDC Isc = 11.1 ADC (1) AWG #10, THHN/THWN-2, Green EGC Vmp = 147.52 VDC Imp = 10.71 ADC (1) Conduit Kit; 3/4" EMT

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT TESLA INC. NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE THE RECIPIENT'S ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE TESLA EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF TESLA INC.

JOB NUMBER: JB-283301 00  
MOUNTING SYSTEM: ZS Comp V4 w Flashing-Insert  
MODULES: (33) Tesla # T395H  
INVERTER: Multiple Inverters

CUSTOMER: Brent Ely  
1195 Micahs Way N  
Spring Lake, NC 28390  
3344983272

DESCRIPTION: 13.035 KW PV ARRAY  
27 KWH ENERGY STORAGE SYSTEM  
PAGE NAME: THREE LINE DIAGRAM

DESIGN: Zach Rosen  
SHEET: 5 REV: DATE: C 4/29/2022



WARNING: PHOTOVOLTAIC POWER SOURCE

Label Location:  
(C)(CB)(JB)  
Per Code:  
NEC 690.31.G.3

**⚠ WARNING**

THIS EQUIPMENT FED BY  
MULTIPLE SOURCES. TOTAL  
RATING OF ALL OVER CURRENT  
DEVICES, EXCLUDING MAIN  
SUPPLY OVERCURRENT DEVICE,  
SHALL NOT EXCEED AMPACITY  
OF BUSBAR.


Label Location:  
(MSP)  
Per Code:  
NEC 705.12.B.2.3.C

**DC PHOTOVOLTAIC  
DISCONNECT**

Label Location:  
(DC)(INV)  
Per Code:  
NEC 690.13.B

MAXIMUM POWER-  
POINT CURRENT (I<sub>mp</sub>)  A  
MAXIMUM POWER-  
POINT VOLTAGE (V<sub>mp</sub>)  V  
MAXIMUM SYSTEM  
VOLTAGE (V<sub>oc</sub>)  V  
SHORT-CIRCUIT  
CURRENT (I<sub>sc</sub>)  A

Label Location:  
(DC) (INV)  
Per Code:  
NEC 690.53




Label Location:  
ABB/Delta Solivia Inverter  
Per Code:  
690.56(C)(1)(b)

**AC PHOTOVOLTAIC  
DISCONNECT**

Label Location:  
(AC)(POI)  
Per Code:  
NEC 690.13.B

MAXIMUM AC  
OPERATING CURRENT  A  
MAXIMUM AC  
OPERATING VOLTAGE  V

Label Location:  
(AC) (POI)  
Per Code:  
NEC 690.54



Label Location:  
SolarEdge and, Delta M-Series and, Telsa Inverter  
Per Code:  
690.56(C)(1)(a)

**⚠ WARNING**

ELECTRIC SHOCK HAZARD  
DO NOT TOUCH TERMINALS  
TERMINALS ON BOTH LINE  
AND LOAD SIDES MAY BE  
ENERGIZED IN THE OFF POSITION

Label Location:  
(AC)(POI)  
Per Code:  
690.13.B

**⚠ WARNING**

INVERTER OUTPUT  
CONNECTION  
DO NOT RELOCATE  
THIS OVERCURRENT  
DEVICE

Label Location:  
(POI)  
Per Code:  
NEC 705.12.B.2.3.B

(AC): AC Disconnect  
(C): Conduit  
(CB): Combiner Box  
(D): Distribution Panel  
(DC): DC Disconnect  
(IC): Interior Run Conduit  
(INV): Inverter With Integrated DC Disconnect  
(LC): Load Center  
(M): Utility Meter  
(POI): Point of Interconnection

BACKUP LOAD CENTER

Label Location:  
(BLC)  
Per Code:  
NEC 408.4

**CAUTION**  
TRI POWER SOURCE  
SECOND SOURCE IS PHOTOVOLTAIC SYSTEM  
THIRD SOURCE IS ENERGY STORAGE SYSTEM

Label Location:  
(MSP)  
Per Code:  
NEC 705.12(B)(3)

**CAUTION**  
DO NOT ADD NEW LOADS

Label Location:  
(BLC)  
Per Code:  
NEC 220

**WARNING**

THIS EQUIPMENT FED BY  
MULTIPLE SOURCES. TOTAL  
RATING OF ALL OVER CURRENT  
DEVICES, EXCLUDING MAIN  
SUPPLY OVERCURRENT DEVICE,  
SHALL NOT EXCEED AMPACITY  
OF BUSBAR.

Label Location:  
(MSP)  
Per Code:  
NEC 705.12.B.2.3.c

**CAUTION**  
THIS PANEL HAS SPLICED FEED-  
THROUGH CONDUCTORS.  
LOCATION OF DISCONNECT AT ENERGY  
STORAGE BACKUP LOAD PANEL

Label Location:  
(MSP)  
Per Code:  
NEC 312.8.A(3)

**NOMINAL ESS VOLTAGE: 120/240V**  
**MAX AVAILABLE SHORT-  
CIRCUIT FROM ESS: 32A**  
**ARC FAULT CLEARING  
TIME FROM ESS: 67ms**  
**DATE OF  
CALCULATION:**

Label Location:  
(MSP)  
Per Code:  
Per 706.7(D) label to be marked in field

**CAUTION**  
DUAL POWER SOURCE  
SECOND SOURCE IS  
ENERGY STORAGE SYSTEM

Label Location:  
(MSP)  
Per Code:  
NEC 705.12(B)(3)

ENERGY STORAGE SYSTEM ON SITE  
LOCATED WITHIN LINE OF SIGHT

Label Location:  
(MSP)  
Per Code:

ENERGY STORAGE SYSTEM ON SITE  
LOCATED ON ADJACENT WALL

Label Location:  
(MSP)  
Per Code:

ENERGY STORAGE SYSTEM ON SITE  
LOCATED ON OPPOSITE WALL

Label Location:  
(MSP)  
Per Code:

ENERGY STORAGE SYSTEM ON SITE  
LOCATED INSIDE

Label Location:  
(MSP)  
Per Code:

(AC): AC Disconnect  
(BLC): Backup Load Center  
(MSP): Main Service Panel

Label Set

# MCI WIRING DETAIL

## GENERAL NOTES


- DRAWING OF STANDARD MCI WIRING DETAIL FOR ANY GIVEN STRING LENGTH
- IF INITIATED, RAPID SHUTDOWN OCCURS WITHIN 30 SECONDS OF ACTIVATION AND LIMITS VOLTAGE ON THE ROOF TO NO GREATER THAN 165V (690.12.B.2.1)
- MID CIRCUIT INTERRUPTER (MCI) IS A UL 1741 PVRSE CERTIFIED RAPID SHUTDOWN DEVICE (RSD)

## RETROFIT PV MODULES

- MCIS ARE LOCATED AT ROOF LEVEL, JUST UNDER THE PV MODULES IN ACCORDANCE WITH 690.12 REQUIREMENTS
- THE QUANTITY OF MCIS PER STRING IS DETERMINED BY STRING LENGTH
  - NUMBER OF MODULES BETWEEN MCI UNITS = 0-3
  - MAXIMUM NUMBER OF MODULES PER MCI UNIT = 3
  - MINIMUM NUMBER MCI UNITS = MODULE COUNT/3

\*Exception: Tesla (Longi) modules installed in locations where the max Voc for 3 modules at low design temperature exceeds 165V shall be limited to 2 modules between MCIs.

PLEASE REFER TO MCI CUTSHEET AND PVRSA INSERT FOR MORE INFORMATION



① — (2) AWG, PV Wire, 600V, Black

DC




# MCI WIRING DETAIL

## GENERAL NOTES

- DRAWING OF STANDARD MCI WIRING DETAIL FOR ANY GIVEN STRING LENGTH
- IF INITIATED, RAPID SHUTDOWN OCCURS WITHIN 30 SECONDS OF ACTIVATION AND LIMITS VOLTAGE ON THE ROOF TO NO GREATER THAN 165V (690.12.B.2.1)
- MID CIRCUIT INTERRUPTER (MCI) IS A UL 1741 PVRSE CERTIFIED RAPID SHUTDOWN DEVICE (RSD)

## SOLAR ROOF TILES

- MCIS ARE LOCATED AT DECK LEVEL, JUST UNDER THE TILES IN ACCORDANCE WITH 690.12 REQUIREMENTS
- THE QUANTITY OF MCIS PER STRING IS DETERMINED BY STRING LENGTH
  - NUMBER OF TILES BETWEEN MCI UNITS = 0-10
  - MAXIMUM NUMBER OF TILES PER MCI UNIT = 10
  - MINIMUM NUMBER MCI UNITS = TILE COUNT/10



PLEASE REFER TO MCI CUTSHEET AND PVRSA INSERT FOR MORE INFORMATION

① (2) AWG, PV Wire, 600V, Black

DC

## BACKUP SWITCH

The Tesla Backup Switch controls connection to the grid in a Powerwall system, and can be easily installed behind the utility meter or in a standalone meter panel downstream of the utility meter.

The Backup Switch automatically detects grid outages, providing a seamless transition to backup power. It communicates directly with Powerwall, allowing home energy usage monitoring from any mobile device with the Tesla app.



## PERFORMANCE SPECIFICATIONS

<b>Model Number</b>	1624171-xx-y
<b>Continuous Load Rating</b>	200A, 120/240V Split phase
<b>Short Circuit Current Rating</b>	22 kA with breaker <sup>1</sup>
<b>Communication</b>	CAN
<b>Product Compatibility</b>	Powerwall 2 with Backup Gateway 2, Powerwall+
<b>Expected Service Life</b>	21 years
<b>Warranty</b>	10 years

<sup>1</sup> Breaker size must be equal to or greater than the available fault current.

## COMPLIANCE INFORMATION

<b>Safety Standards</b>	USA: UL 414, UL 2735, UL 916 CA Prop 65
<b>Emissions</b>	FCC, ICES


## ENVIRONMENTAL SPECIFICATIONS

<b>Operating Temperature</b>	-40°C to 50°C (-40°F to 122°F)
<b>Storage Temperature</b>	-40°C to 85°C (-40°F to 185°F)
<b>Enclosure Rating</b>	NEMA 3R
<b>Pollution Rating</b>	PD3

## MECHANICAL SPECIFICATIONS

<b>Dimensions</b>	176 mm x 205 mm x 74 mm (6.9 in x 8.1 in x 2.9 in)
<b>Weight</b>	2.8 lbs
<b>Meter and Socket Compatibility</b>	ANSI Type 2S, ringless or ring type
<b>External Service Interface</b>	Contactors manual override <sup>2</sup> Reset button
<b>Conduit Compatibility</b>	1/2-inch NPT

<sup>2</sup> Manually overrides the contactor position during a service event.





## POWERWALL+

Powerwall+ is an integrated solar battery system that stores energy from solar production. Powerwall+ has two separate inverters, one for battery and one for solar, that are optimized to work together. Its integrated design and streamlined installation allow for simple connection to any home, and improved surge power capability brings whole home backup in a smaller package. Smart system controls enable owners to customize system behavior to suit their renewable energy needs.

### KEY FEATURES

- Integrated battery, inverter, and system controller for a more compact install
- A suite of application modes, including self-powered, time-based control, and backup modes
- Wi-Fi, Ethernet, and LTE connectivity with easy over-the-air updates

NA 2022-04-21

## POWERWALL+

### PHOTOVOLTAIC (PV) AND BATTERY ENERGY STORAGE SYSTEM (BESS) SPECIFICATIONS

<b>Powerwall+ Model Number</b>	1850000-xx-y
<b>Solar Assembly Model Number</b>	1538000-xx-y
<b>Nominal Battery Energy</b>	13.5 kWh
<b>Nominal Grid Voltage (Input / Output)</b>	120/240 VAC
<b>Grid Voltage Range</b>	211.2 - 264 VAC
<b>Frequency</b>	60 Hz
<b>Phase</b>	240 VAC: 2W+N+GND
<b>Maximum Continuous Power On-Grid</b>	7.6 kVA full sun / 5.8 kVA no sun <sup>1</sup>
<b>Maximum Continuous Power Off-Grid</b>	9.6 kW full sun / 7 kW no sun <sup>1</sup>
<b>Peak Off-Grid Power (10 s)</b>	22 kW full sun / 10 kW no sun <sup>1</sup>
<b>Maximum Continuous Current On-Grid</b>	32 A output
<b>Maximum Continuous Current Off-Grid</b>	40 A output
<b>Load Start Capability</b>	98 - 118 A LRA <sup>2</sup>
<b>PV Maximum Input Voltage</b>	600 VDC
<b>PV DC Input Voltage Range</b>	60 - 550 VDC
<b>PV DC MPPT Voltage Range</b>	60 - 480 VDC
<b>MPPTs</b>	4
<b>Input Connectors per MPPT</b>	1-2-1-2
<b>Maximum Current per MPPT (<math>I_{mp}</math>)</b>	13 A <sup>3</sup>
<b>Maximum Short Circuit Current per MPPT (<math>I_{sc}</math>)</b>	17 A <sup>3</sup>
<b>Allowable DC/AC Ratio</b>	1.7
<b>Overcurrent Protection Device</b>	50 A breaker
<b>Maximum Supply Fault Current</b>	10 kA
<b>Output Power Factor Rating</b>	+/- 0.9 to 1 <sup>4</sup>
<b>Round Trip Efficiency</b>	90% <sup>5</sup>
<b>Solar Generation CEC Efficiency</b>	97.5% at 208 V 98.0% at 240 V
<b>Customer Interface</b>	Tesla Mobile App
<b>Internet Connectivity</b>	Wi-Fi, Ethernet, Cellular LTE/4G <sup>6</sup>
<b>PV AC Metering</b>	Revenue grade (+/-0.5%)
<b>Protections</b>	Integrated arc fault circuit interrupter (AFCI), PV Rapid Shutdown
<b>Warranty</b>	10 years


### COMPLIANCE INFORMATION

<b>PV Certifications</b>	UL 1699B, UL 1741, UL 3741, UL 1741 SA, UL 1998 (US), IEEE 1547, IEEE 1547.1
<b>Battery Energy Storage System Certifications</b>	UL 1642, UL 1741, UL 1741 PCS, UL 1741 SA, UL 1973, UL 9540, IEEE 1547, IEEE 1547.1, UN 38.3
<b>Grid Connection</b>	United States
<b>Emissions</b>	FCC Part 15 Class B
<b>Environmental</b>	RoHS Directive 2011/65/EU
<b>Seismic</b>	AC156, IEEE 693-2005 (high)

TESLA

### MECHANICAL SPECIFICATIONS

<b>Dimensions</b>	1596 x 755 x 160 mm (62.8 x 29.7 x 6.3 in)
<b>Total Weight</b>	140 kg (310 lb) <sup>7</sup>
<b>Battery Assembly</b>	118 kg (261 lb)
<b>Solar Assembly</b>	22 kg (49 lb)
<b>Mounting options</b>	Floor or wall mount



### ENVIRONMENTAL SPECIFICATIONS

<b>Operating Temperature</b>	-20°C to 50°C (-4°F to 122°F) <sup>8</sup>
<b>Recommended Temperature</b>	0°C to 30°C (32°F to 86°F)
<b>Operating Humidity (RH)</b>	Up to 100%, condensing
<b>Storage Conditions</b>	-20°C to 30°C (-4°F to 86°F) Up to 95% RH, non-condensing State of Energy (SoE): 25% initial
<b>Maximum Elevation</b>	3000 m (9843 ft)
<b>Environment</b>	Indoor and outdoor rated
<b>Enclosure Type</b>	Type 3R
<b>Solar Assembly Ingress Rating</b>	IP55 (Wiring Compartment)
<b>Battery Assembly Ingress Rating</b>	IP56 (Wiring Compartment) IP67 (Battery & Power Electronics)
<b>Noise Level @ 1 m</b>	< 40 db(A) optimal, < 50 db(A) maximum

<sup>1</sup>Values provided for 25°C (77°F).

<sup>2</sup>Load start capability may vary.

<sup>3</sup>Where the DC input current exceeds an MPPT rating, jumpers can be used to allow a single MPPT to intake additional DC current up to 26 A  $I_{mp}$  / 34 A  $I_{sc}$ .

<sup>4</sup>Power factor rating at max real power.

<sup>5</sup>AC to battery to AC, at beginning of life.

<sup>6</sup>Cellular connectivity subject to network service coverage and signal strength.

<sup>7</sup>The total weight does not include the Powerwall+ bracket, which weighs an additional 9 kg (20 lb).


<sup>8</sup>Performance may be de-rated at operating temperatures below 10°C (50°F) or greater than 43°C (109°F).

NA 2022-04-21

TESLA.COM/ENERGY

## SOLAR SHUTDOWN DEVICE

The Tesla Solar Shutdown Device is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with Powerwall+, solar array shutdown is initiated by turning the Powerwall+ Enable switch off, or by pushing the System Shutdown Switch if one is present.



### ELECTRICAL SPECIFICATIONS

Nominal Input DC Current Rating ( $I_{MP}$ )	12 A
Maximum Input Short Circuit Current ( $I_{SC}$ )	15 A
Maximum System Voltage	600 V DC

### RSD MODULE PERFORMANCE

Maximum Number of Devices per String	5
Control	Power Line Excitation
Passive State	Normally open
Maximum Power Consumption	7 W
Warranty	25 years

### COMPLIANCE INFORMATION


Certifications	UL 1741 PVRSE, UL 3741, PVRSA (Photovoltaic Rapid Shutdown Array)
RSD Initiation Method	External System Shutdown Switch
Compatible Equipment	See Compatibility Table below

### ENVIRONMENTAL SPECIFICATIONS

Ambient Temperature	-40°C to 50°C (-40°F to 122°F)
Storage Temperature	-30°C to 60°C (-22°F to 140°F)
Enclosure Rating	NEMA 4 / IP65

### MECHANICAL SPECIFICATIONS

Electrical Connections	MC4 Connector
Housing	Plastic
Dimensions	125 mm x 150 mm x 22 mm (5 in x 6 in x 1 in)
Weight	350 g (0.77 lb)
Mounting Options	ZEP Home Run Clip M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw



### UL 3741 PV HAZARD CONTROL (AND PVRSA) COMPATIBILITY


Tesla Solar Roof and Tesla/Zep ZS Arrays using the following modules are certified to UL 3741 and UL 1741 PVRSA when installed with the Powerwall+ and Solar Shutdown Devices. See the Powerwall+ Installation Manual for detailed instructions and for guidance on installing Powerwall+ and Solar Shutdown Devices with other modules.

Brand	Model	Required Solar Shutdown Devices
Tesla	Solar Roof V3	1 Solar Shutdown Device per 10 modules
Tesla	Tesla TxxxS (where xxx = 405 to 450 W, increments of 5)	1 Solar Shutdown Device per 3 modules <sup>1</sup>
Tesla	Tesla TxxxH (where xxx = 395 to 415 W, increments of 5)	1 Solar Shutdown Device per 3 modules
Hanwha	Q.PEAK DUO BLK-G5	1 Solar Shutdown Device per 3 modules
Hanwha	Q.PEAK DUO BLK-G6+	1 Solar Shutdown Device per 3 modules


<sup>1</sup>Exception: Tesla solar modules installed in locations where the max Voc for three modules at low design temperatures exceeds 165 V shall be limited to two modules between MCIs.

## SYSTEM LAYOUTS


Powerwall+ with Backup Switch Installed Behind Utility Meter




Powerwall+ with Backup Switch Installed Downstream of Utility Meter



Powerwall+ with Backup Gateway 2 for Whole Home Backup



Powerwall+ with Backup Gateway 2 for Partial Home Backup




# Tesla Photovoltaic Module

T395H, T400H, and T405H

The Tesla module is one of the most powerful residential photovoltaic modules available and exceeds industry engineering and quality standards. Featuring our proprietary Zep Groove design, the all-black module mounts close to your roof for a minimalist aesthetic. Modules are certified to IEC / UL 61730 - 1, IEC / UL 61730 - 2 and IEC 61215.



## Module Specifications




Electrical Characteristics						
Power Class	T395H		T400H		T405H	
Test Method	STC	NMOT	STC	NMOT	STC	NMOT
Max Power, $P_{MAX}$ (W)	395	296.3	400	300.1	405	303.8
Open Circuit Voltage, $V_{OC}$ (V)	45.27	42.69	45.30	42.72	45.34	42.76
Short Circuit Current, $I_{SC}$ (A)	11.10	8.95	11.14	8.97	11.17	9.00
Max Power Voltage, $V_{MP}$ (V)	36.88	35.03	37.13	35.25	37.39	35.46
Max Power Current, $I_{MP}$ (A)	10.71	8.46	10.77	8.51	10.83	8.57
Module Efficiency (%)	≥ 20.1		≥ 20.4		≥ 20.6	
STC	1000 W/m <sup>2</sup> , 25°C, AM1.5					
NOCT	800 W/m <sup>2</sup> , 20°C, AM1.5, wind speed 1 m/s					

Mechanical Loading		
Front Side Test Load	6120 Pa   128 lb/ft <sup>2</sup>	Refer to module and system installation manuals for allowable design loads, foot spacings, and cantilever specifications.
Rear Side Test Load	6120 Pa   128 lb/ft <sup>2</sup>	
Front Side Design Load	4080 Pa   85 lb/ft <sup>2</sup>	
Rear Side Design Load	4080 Pa   85 lb/ft <sup>2</sup>	
Hail Test	35 mm at 27.2 m/s	

Temperature Rating (STC)	
Temperature Coefficient of $I_{SC}$	+0.04% / °C
Temperature Coefficient of $V_{OC}$	-0.27% / °C
Temperature Coefficient of $P_{MAX}$ (W)	-0.34% / °C



Mechanical Parameters	
Cell Orientation	132 (6 x 22)
Junction Box	IP68, 3 diodes
Cable	4 mm <sup>2</sup>   12 AWG, 1325 mm   47.2 in. Length
Connector	Staubli MC4
Front Cover	0.13 in (3.2 mm) thermally pre-stressed glass
Frame	Black Anodized Aluminum Alloy
Weight	23.5 kg   51.8 lb
Dimension	1890 mm x 1046 mm x 40 mm 74.4 in x 41.2 in x 1.57 in



Operation Parameters	
Operational Temperature	-40°C up to +85°C
Power Output Tolerance	-0 / +5 W
$V_{OC}$ & $I_{SC}$ Tolerance	+/- 5%
Max System Voltage	DC 1000 V (IEC/UL)
Max Series Fuse Rating	20 A
NOCT	45.7 +/- 3 °C
Safety Class	Class II
Fire Rating	UL 61730 Type 2

Linear Power Warranty	
Materials and Processing	25 years
Extra Linear Power Output	25 years

At least 98% of nominal power during first year. Thereafter max. 0.5% degradation per year. At least 93.5% of nominal power up to 10 years. At least 86% of nominal power up to 25 years.




# ROOFING SYSTEM SPECIFICATIONS



<b>DESCRIPTION</b>	PV mounting solution for composition shingle roofs.
	Works with all Zep Compatible Modules.
	Auto bonding UL-listed hardware creates structural and electrical bond.
<b>SPECIFICATIONS</b>	Designed for pitched roofs.
	Installs in portrait and landscape orientations.
	Engineered for spans up to 72" and cantilevers up to 24".
	ZS Comp has a UL 1703 Class "A" Fire Rating when installed using modules from any manufacturer certified as "Type 1" or "Type 2".
	Attachment method UL listed to UL 2582 for Wind Driven Rain.
	ZS Comp supports 50 psf (2400 Pa) front and up to 72 psf (3450 Pa) rear side design load rating for Portrait module orientation per UL 2703.
	ZS Comp supports 50 psf (2400 Pa) front side and up to 72 psf (3450 Pa) rear side design load rating for Landscape module orientation.
	Engineered for compliance with ASCE 7-05, 7-10, and 7-16 wind load requirements.
	Zep wire management products listed to UL 1565 for wire positioning devices.
ZS Comp grounding products are listed to UL 2703 and UL 467.	
ZS Comp bonding products are listed to UL 2703.	


## MOUNTING BLOCK

Listed to UL 2703  
Part #850-1633



## FLASHING INSERT

Listed to UL 2703 and UL 2582 for Wind Driven Rain  
Part #850-1628




## CAPTURED WASHER LAG

Part #850-1631-002 and #850-1631-004




## GROUND ZEP

Listed to UL 2703  
Part #850-1511




## LEVELING FOOT

Listed to UL 2703  
Part #850-1397




## DC WIRE CLIP

Listed to UL 1565  
Part #850-1509




## HOME RUN CLIP

Listed to UL 1565  
Part #850-1510




## ARRAY SKIRT

Listed to UL 2703  
Part #850-1608




## END CAP

Listed to UL 2703  
Part #850-1586 (Left)  
Part #850-1588 (Right)




## SKIRT GRIP

Listed to UL 2703  
Part #850-1606



## INTERLOCK

Listed to UL 2703  
Part #850-1613



## HYBRID INTERLOCK

Listed to UL 2703  
Part #850-1281

