

1011 N Causeway Blvd, Suite 19 • Mandeville, Louisiana 70471 • Phone: 985.624.5001 • Fax: 985.624.5303

September 2021

Property Owner: Stephen Wright

Property Address: 101 Emma Court, Linden, NC 28356

RE: Photovoltaic System Roof Installations

I have reviewed the existing structure referenced above to determine the adequacy of the existing structure support the proposed installation of an array of solar panels on the roof.

Based on my review, the existing structure is adequate to support the proposed solar panel installation. This assessment is based on recent on-site inspection by SunPro Solar inspectors and photographs of the existing structure. The photovoltaic system is designed to withstand uplift and downward forces; our assessment is regarding the structure's support of the array. Stresses induced by the introduction of individual mount loads on the rafters are within acceptable limits as shown on the attached calculations. The structural considerations used in our review and assessment include the following:

""NETC 2018

Evaluation Criteria:

Applied Codes: ASCE 7-10 PEBC 2018 Risk Category: II Design Wind Speed (3-second gust): 119 MPH Wind Exposure Category: C Ground Snow Load: 10 PSF Seismic Design Category: D

Existing Structure:

Roof Material: Shingle Roofing Structure: 2x6 rafters @ 24" O.C. Roof Slope: 10/12

Connection of Array to Structure:



"""""PGE 2017

North Carolina Firm No. C4113 Principal Engineering, Inc.

Manufacturer: UNIRACPrincipal EngMount: Flashloc Comp KitMounting Connection: Flashloc Comp Kit 5/16" lag screw w/min 2.5" embedment into framingZone 1: 2 rails 4'-0" o.c. mountsZone 2: 2 rails 4'-0" o.c. mountsZone 3: 2 rails 4'-0" o.c. mountsZone 3: 2 rails 4'-0" o.c. mounts

PRINCIPAL Infrastructure®

Architecture

Engineering
Construction

www.pi-aec.com info@pi-aec.com

Effect of the Solar Array on Structure Loading:

Gravity Loads:

Per IBC Section 1607.12.5.1, the areas of the roof where solar panels are located are considered inaccessible, and therefore not subject to roof live loading. Live load in these areas is replaced by the dead load of the solar array, 3 psf. The total gravity load on the structure is therefore reduced and the structure may remain unaltered. Connections of the mounts to the underlying structure are to be installed in a staggered pattern, except at the array ends, to distribute the loading evenly to the roof structure. The stresses within the rafters due to the introduction of discrete mount loads are within acceptable limits, as shown on the attached calculations.

Wind Load:

The solar panel array will be flush mounted (no more than 6" above the surrounding roof surface, and parallel to the roof surface. Any additional wind loading on the structure due to the presence of the array is negligible. The array structure is designed by the manufacturer to withstand uplift and downward forces resulting from wind and snow loads. The attached calculations verify the capacity of the connection of the solar array to the roof to resist uplift due to wind loads, the governing load case.

Snow Load:

The reduced friction of the glass surface of the solar panels allows for the lower slope factor (C_s) per Section 7.4 of ASCE 7-10 resulting in a reduced design snow load for the structure. This analysis conservatively considered the snow load to be unchanged.

Seismic Load:

Analysis shows that additional seismic loads due to the array installation will be small. Even conservatively neglecting the wall materials, the solar panel installation represents an increase in the total weight of the roof and corresponding seismic load of less than 10%. This magnitude of additional forces meets the requirements of the exception in Section 11B.4 of ASCE 7-10. The existing lateral force resisting system of the structure is therefore allowed to remain unaltered.



Conclusion:

To the best of my professional knowledge and belief, the subject construction and photovoltaic system installation will be in compliance with all state and local building codes and guidelines in effect at the time of our review.

Limitations:

Engineer's assessment of the existing structure is based on recent field reports and current photographs of the elements of the structure that were readily accessible at the time of inspection. The design of the solar panel racking (mounts, rails, connectors, etc.), connections between the racking and panels, and electrical engineering related to the installation are the responsibility of others. The photovoltaic system installation must be by competent personnel in accordance with manufacturer recommendations and specifications and should meet or exceed industry standards for quality. The contractor is responsible for ensuring that the solar array is installed according to the approved plans and must notify the engineer of any undocumented damage or deterioration of the structure, or of discrepancies between the conditions depicted in the approved plans and those discovered on site so that the project may be reevaluated and altered as required. Engineer does not assume any responsibility for improper installation of the proposed photovoltaic system.



Uplift and Wind Downforce Calculation Summary (ASCE 7-10) Mount, Rack, & Panel Proportioning

Property Owner: Stephen Wright		Individual Panel Dimensions			
Project Address:	101 Emma Court	Length (in)	Width (in)	Area (sf)	
City, State:	Linden, NC 28356	77	39	20.85	

Wind Load Calculation Summary (ASCE 7-10 C&C Provisions)					
Building Chara	Building Characteristics, Design Input, and Adjustment Factors				
Roof Dimensions: Length (b):	55 ft.				
Width (w):	42 ft.	Least Dimension: 42 ft.			
Roof Height (h):	25 ft.	Must be less than 60 🗸			
Pitch: 10 on 12 =	39.8°	Must be less than 45° 🖌 🗸			
Roof Configuration	Gable				
Roof Structure:	2x Rafters				
Roof material:	Plywood				
Ultimate Wind Speed (mph):	119	From ASCE 7-10, Fig. 26.5			
Exposure Category:	С	Para 26.7.3			
Directionality Factor, K _d	0.85	Table 26.6-1			
Risk Category:	2	Table 1.5-2			
Exposure Coefficient, K _z	1.09	Table 30.3-1			
Topographic Adj., K _{zt}	1	Fig. 26.8-1			
Effective Wind Area (sf):	21	(Area per individual panel)			
Velocity Pressure (psf), q _h :	33.59	psf, Eq. 30.3-1			
Internal Pressure Coeff, GC _{pi}	0.18	Table 26.11-1			

Roof Zone Strip (a), in ft, Fig. 30.5-1, Note 5		
1 - Least Roof Horizontal Dimension (L or W) x 0.10	4.2	
2 - Roof Height x 0.4	10	
3 - Least Roof Horizontal Dimension (L or W) x 0.04		
4 - Lesser of (1) and (2)		
5 - Greater of (3) and (4)	4.2	
6 - Greater of (5) and 3 feet		
	-	



Net Design Wind Pressures					
(ASCE 7, Eq. 30.4.1; Load Factor for ASD = 0.6, per ASCE 7, 2.4.1)					
	Uplift (-psf)		Down (psf)		
	GC _p	Pressure	GC _p Pressure		Description of Zone
Zone 1	-0.95	-22.7	0.85	20.7	Interior Roof Area, >(a) ft from edge
Zone 2	-1.12	-26.2	0.85	20.7	Strip of (a) ft wide at roof edge
Zone 3	-1.12	-26.2	0.85	20.7	Corner intersection of Zone 2 strips

Snow Load			
Ground Snow Load, p _g	10.0	From ASCE 7 or AHJ	
Terrain Category:	С	Para 6.5.6.3	
Exposure	Fully		
Exposure FactorCe	0.9	Table 7-2	
Thermal Factor, Ct	1.0	Table 7-3	
Importance Factor, I _s	1.0	Table 1.5.2	
Roof Configuration	Gable		
Roof Slope	39.8°		
Distance from Eave to Ridge	21.0		
p _m , Minimum required Snow Load	N/A	Para. 7.3.4	
pf, Calculated Snow Load	6.30	Eq. 7.3-1	
pf, Design Snow Load	6.30 psf		



Mount Selection and Spacing				
Manufacturer:	Unirac	Perpendicular Panel Orientation		
Mount:	Flashloc Comp Kit	Allowable Arrangement by Uplift Pressure		
Substrate:	Wood Rafters	< 37 psf: 2 rails, mounts @ 4'-0" o.c.		
Connector:	5/16" x 4" Lag Screw	37 to 75 psf: 2 rails, mounts @ 2'-0" o.c.		
		75 to 112 psf: 3 rails, mounts @ 2'-0" o.c.		
Allowable Uplift:	480 max.	112 to 150 psf: 4 rails, mounts @ 2'-0" o.c.		
Required Mount Layout		> 150 psf : Mount capacity exceeded		
Zone 1 2 rails, mounts @ 4'-0" o.c.				
Zone 2 2 rails, mounts @ 4'-0" o.c.				
Zone 3 2 rails, mounts @ 4'-0" o.c.				
(Allowable loads are based on individual mount failure before rail failure)				



NEW PHOTOVOLTAIC SYSTEM 11.25 KW DC 101 EMMA CT, LINDEN, NC 28356

GENERAL NOTES

1.1.1 PROJECT NOTES:

1.1.2 THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURERS'S LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING

JURISDICTION'S (AHJ) APPLICABLE CODES.

1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION 1.1.4 GROUND FAULT DETECTION AND INTERRUPTION (GFDI) DEVICE IS INTEGRATED WITH THE MICRO-INVERTER IN ACCORDANCE WITH NEC 690.41(B)

1.1.5 ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4: PV MODULES: UL1703, IEC61730, AND IEC61215, AND NFPA 70 CLASS C FIRE INVERTERS: UL 1741 CERTIFIED, IEEE 1547, 929, 519 COMBINER BOX(ES): UL 1703 OR UL 1741 ACCESSORY 1.1.6 MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED

TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.

1.1.7 ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4. SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3]. 1.1.8 ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.

1.2.1 SCOPE OF WORK:

1.2.2 PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN. SPECIFY, AND INSTALL THE EXTERIOR ROOF-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS DOCUMENT

1.3.1 WORK INCLUDES:

1.3.2 PV RACKING SYSTEM INSTALLATION - UNIRAC SOLAR 1.3.3 PV MODULE/ INVERTER/ BATTERY INSTALLATION - LG ELECTRONICS LG375N1C-A6 / ENPHASE IQ7PLUS-72-2-US INVERTER/ ENPHASE ENCHARGE 10 BATTERY 1.3.4 PV EQUIPMENT ROOF MOUNT

1.3.5 PV SYSTEM WIRING TO A ROOF-MOUNTED JUNCTION BOX

1.3.6 PV LOAD CENTERS (IF INCLUDED)

1.3.7 PV METERING/MONITORING (IF INCLUDED)

1.3.8 PV DISCONNECTS

1.3.9 PV GROUNDING ELECTRODE & BONDING TO (E) GEC

1.3.10 PV FINAL COMMISSIONING

1.3.11 (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV

1.3.12 SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

PROJECT INFORMATION

OWNER NAME: STEPHEN WRIGHT

PROJECT MANAGER NAME: SHAHIN HAYNES PHONE: 8665071461

CONTRACTOR NAME

MARC JONES CONSTRUCTION, LLC DBA SUNPRO SOLAR PHONE: 5052180838

SCOPE OF WORK

SYSTEM SIZE: STC:30 X 375W= 11.25 kW DC PTC: 30 x 347.3W = 10.42 kW DC (30) LG ELECTRONICS LG375N1C-A6 (30) ENPHASE IQ7PLUS-72-2-US (01) ENPHASE ENCHARGE 10

ATTACHMENT TYPE: ROOF MOUNT MSP UPGRADE: NO UTILITY METER UPGRADE: NO

AUTHORITIES HAVING JURISDICTION


BUILDING: HARNETT COUNTY ZONING: HARNETT COUNTY UTILITY: DUKE ENERGY METER NO: 332 289 598

DESIGN SPECIFICATION

OCCUPANCY: CONSTRUCTION: SINGLE-FAMILY ZONING: RESIDENTIAL GROUND SNOW LOAD: REFER STRUCTURAL LETTER **REFER STRUCTURAL LETTER** WIND EXPOSURE: WIND SPEED: **REFER STRUCTURAL LETTER**

APPLICABLE CODES & STANDARDS

BUILDING: NCBC 2018, NCRC 2018 ELECTRICAL: NEC 2017 FIRE: NCFC 2018



SHE	ΞE
-001	COV
-002	NOT
-101	SITE
-102	ELE
-103	ATT
-104	STR
-601	LINE
-602	ELE
-603	PLA
-001	RES
-002	RES
-003	RES
-004	RES
-005	RES
-006	RES
-007	RES
-008	RES
-009	RES
-010	RES
	1

2.1.1 SITE NOTES:

2.1.2 A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH CONVENTION IF THREE PHASE PHASE C OR L3- BLUE, OSHA REGULATIONS.

2.1.3 THE PV MODULESARECONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH STORAGE BATTERIES. 2.1.4 THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING, 110.15]. MECHANICAL, OR BUILDING ROOF VENTS.

2.1.5 PROPERACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PERSECTION NEC 110.26.

2.1.6 ROOF COVERINGS SHALL BE DESIGNED. INSTALLED. AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.

2.2.1 EQUIPMENT LOCATIONS:

2.2.2 ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY 2.5.5 EQUIPMENT GROUNDING CONDUCTORS SHALLBE SIZED NEC 110.26.

2.2.3 WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED MANUFACTORERS' INSTRUCTIONS. FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 2.5.6 EACH MODULE WILL BE GROUNDED USING WEEB (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C). 2.2.4 JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.

2.2.5 ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT. 2.2.6 ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES. 2.2.7 ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

2.3.1 STRUCTURAL NOTES:

2.3.2 RACKING SYSTEM & PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES. AND RAILS MUSTALSO EXTEND A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAI MANUFACTURER'S INSTRUCTIONS.

2.3.3 JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED & SEALED PER LOCAL REQUIREMENTS.

2.3.4 ROOFTOP PENETRATIONS FOR PV RACEWAY WILLBE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.

2.3.5 ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.

2.3.6 WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.

2.4.1 WIRING & CONDUIT NOTES:

2.4.2 ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS AREBASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT **UP-SIZING**.

2.4.3 CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7. 2.4.4 VOLTAGE DROP LIMITED TO 1.5%.

2.4.5 DC WIRING LIMITED TO MODULE FOOTPRINT. MICROINVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.

2.4.6 AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK PHASE B OR L2- RED. OR OTHER

YELLOW, ORANGE**, OR OTHER CONVENTION NEUTRAL-WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH HIGHER VOLTAGE TO BE MARKED ORANGE [NEC

2.5.1 GROUNDING NOTES:

2.5.2 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVISES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.

2.5.3 PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.

2.5.4 METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURES CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).

ACCORDING TO NEC 690.45 AND MICROINVERTER

GROUNDING CLIPS AS SHOWN IN

MANUFACTURERDOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED. MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS. 2.5.7 THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OFA MODULE DOES NOT INTERRUPT A GROUNDING CONDUCTOR TO ANOTHER MODULE. 2.5.8 GROUNDING AND BONDING CONDUCTORS, IF INSULATED,

SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER [NEC 250.119] 2.5.9 THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS

INACCESSIBLE, OR INADEQUATE, A GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250, NEC 690.47 AND AHJ.

2.5.10 GROUND-FAULT DETECTION SHALL COMPLY WITH NEC 690.41(B)(1) AND (2) TO REDUCE FIRE HAZARDS

2.6.1 DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:

2.6.2 DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHENTHE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARECONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS). 2.6.3 DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH 2.6.4 PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS IN ACCORDANCE WITH 690.12(A) THROUGH (D).

2.6.5 ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.


2.6.6 MICROINVERTER BRANCHES CONNECTED TO A SINGLE BREAKER OR GROUPED FUSES IN ACCORDANCE WITH NEC 110.3(B).


2.6.7 IF REQUIRED BY AHJ, SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL1699B.


2.7.1 INTERCONNECTION NOTES:

2.7.2 LOAD-SIDE INTERCONNECTION SHALL BE IN ACCORDANCE WITH [NEC 705.12 (B)] 2.7.3 THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF BUSBAR RATING [NEC 705.12(B)(2)(3)(b)]. 2.7.4 THE SUM OF 125 PERCENT OF THE POWER SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR, PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD INEC 705.12(B)(2)(3)].


2.7.5 AT MULTIPLE ELECTRIC POWER SOURCES OUTPUT COMBINER PANEL. TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED AMPACITY OF BUSBAR. HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED ACCORDING TO NEC 705.12 (B)(2)(3)(C). 2.7.6 FEEDER TAP INTERCONECTION (LOADSIDE) ACCORDING TO NEC 705.12 (B)(2)(1) 2.7.7 SUPPLY SIDE TAP INTERCONNECTION ACCORDING TO NEC 705.12 (A) WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH NEC 230.42 2.7.8BACKFEEDING BREAKER FOR ELECTRIC POWER SOURCES OUTPUT IS EXEMPT FROM ADDITIONAL FASTENING [NEC 705.12 (B)(5)].








ROOF SECTION(S) CONTRACTOR TILT - 39° AZIMUTH - 127° MODULE - 15 22171 MCH RD SYSTEM SIZE (KW)- 5.63 MANDEVILLE, LA 70471 TILT - 39° PHONE: 9152011490 AZIMUTH - 127° MODULE - 6 **PROJECT NAME & ADDRESS** SYSTEM SIZE (KW)- 2.25 STEPHEN WRIGHT TILT - 39° AZIMUTH - 307° MODULE - 9 SYSTEM SIZE (KW)- 3.38 101 EMMA CT, LINDEN, NC 28356 COUNTY:-HARNETT COUNTY SYSTEM SIZE DC SIZE: 11.250 KW DC-(STC) AC SIZE: 8.700 KW AC ENGINEER: LEGEND SHEET TITLE **ELECTRICAL PLAN** DRAWN DATE 9/9/2021 DRAWN BY SH - SKYLIGHT (ROOF OBSTRUCTION) SHEET NUMBER - CHIMNEY (ROOF OBSTRUCTION) A-102 - VENT, ATTIC FAN (ROOF OBSTRUCTION)



```
- CLAMP
```

- UNIRAC FLASHLOC
- - RAIL
- ---- RAFTER

74 - TOTAL MOUNT





SOLAR MODULE SPECIFICATIONS		INVERTER SPECIFICATIONS			WIRE /CONDUI	
MANUFACTURER / MODEL #	LG ELECTRONICS LG375N1C-A6	MANUFACTURER / MODEL #	ENPHASE IQ7PLUS-72-2-US MICROINVERTER	TAG	DESCRIPT	
VMP	35.3V	MIN/MAX DC VOLT RATING	22V MIN/ 60V MAX			
IMP	10.63A	MAX INPUT POWER	235W-440W		#12/2 ROMEX IN ATTIC/#12 TH EXTERIOR & (1)#6 THWN -2 / (0	
VOC	41.8V	NOMINAL AC VOLTAGE RATING	240V/ 211-264V			
ISC	11.35A	MAX AC CURRENT	1.21A		#12 THWN-2 & (1)#6 THWN-2 G	
TEMP. COEFF. VOC	-0.26%/°C	MAX MODULES PER STRING	13 (SINGLE PHASE)		#6 THWN-2 & (1)#6 THWN-2 GR	
MODULE DIMENSION	68.50"L x 41.02"W x 1.57"D (In Inch)	MAX OUTPUT POWER	290 VA	4	#4 THWN-2 & (1)#6 THWN-2 GR	
				5	(1)#6 BARE GROUND	

DC SIZE 30 X 375W = 11.250 kW DC-STC AC SIZE 30X 290W = 8.700 kW AC

(GN) GENERAL CONDUIT NOTE : CONDUIT TO BE UL LISTED FOR WET LOCATIONS AND UV PROTECTED (EX. -EMT,SCH 80 PVC OR RMC) *FMC MAYBE USED IN INDOOR APPLICATIONS WHERE PERMITTED BY NEC ART .348

3	#6 THVVN-2 & (1)#6 TF
4	#4 THWN-2 & (1)#6 TH
5	(1)#6 BARE GROUND
6	#12 CT WIRES





AMBIENT TEMPERATURE SPECS		PERCENT OF	NUMBER OF CURRENT
RECORD LOW TEMP	-10°	VALUES	CARRYING CONDUCTORS
AMBIENT TEMP (HIGH TEMP 2%)	35°	.80	4-6
CONDUIT HEIGHT	0.5"	.70	7-9
CONDUCTOR TEMPERATURE RATE	90°	.50	10-20

CALCULATIONS:

1. CURRENT CARRYING CONDUCTOR

(A) <u>BEFORE IQ COMBINER PANEL (BACKUP MODULES)</u> AMBIENT TEMPERATURE - (35)°C ...NEC 310.15(B)(3)(c) TEMPERATURE DERATE FACTOR - 0.96 ...NEC 310.15(B)(2)(a) GROUPING FACTOR - 0.8...NEC 310.15(B)(3)(a)

CONDUCTOR AMPACITY

- = (INV O/P CURRENT) x 1.25 / A.T.F / G.F ...NEC 690.8(B) = [(10 x 1.21) x 1.25] / [0.96 x 0.8]
- = 19.69A

SELECTED CONDUCTOR - #12 THWN-2 ...NEC 310.15(B)(16)

(B) BEFORE RELAY JUNCTION BOX (NON-BACKUP MODULES)

AMBIENT TEMPERATURE - (35)°C ...NEC 310.15(B)(3)(c) TEMPERATURE DERATE FACTOR - 0.96 ...NEC 310.15(B)(2)(a) GROUPING FACTOR - 1..NEC 310.15(B)(3)(a)

CONDUCTOR AMPACITY

= (INV O/P CURRENT) x 1.25 / A.T.F / G.F ...NEC 690.8(B)

= [(11 x 1.21) x 1.25] / [0.96 x 1]

= 17.33A

SELECTED CONDUCTOR - #12 THWN-2 ...NEC 310.15(B)(16)

(C) AFTER IQ COMBINER PANEL TEMPERATURE DERATE FACTOR - 0.96 GROUPING FACTOR - 1

CONDUCTOR AMPACITY

- = (TOTAL INV O/P CURRENT) x 1.25 / 0.96/ 1 ... NEC 690.8(B)
- = [(30 x 1.21) x 1.25] / [0.96 x 1]
- = 47.27 A

SELECTED CONDUCTOR - #6 THWN-2 ... NEC 310.15(B)(16)


(D) <u>AFTER ENPHASE ENPOWER SWITCH</u> TEMPERATURE DERATE FACTOR - 0.96 GROUPING FACTOR - 1

CONDUCTOR AMPACITY

- = [(TOTAL INV O/P CURRENT) + BATTERY MAX
- CONTINUOUS CURRENT] x 1.25 / 0.96/ 1 ...NEC 690.8(B)
- = [[(30 x 1.21) + 16] x 1.25] / [0.96 x 1]
- = 68.10 A

SELECTED CONDUCTOR - #4 THWN-2 ...NEC 310.15(B)(16)

- 2. PV OVER CURRENT PROTECTION ... NEC 690.9(B)
- = TOTAL INVERTER O/P CURRENT x 1.25
- = (30 x 1.21) x 1.25 = 45.38 A
- SELECTED OCPD = 50 A ... NEC 240.6
- 3. <u>PV + BATTERY OVER CURRENT PROTECTION</u> ...NEC 690.9(B)
- = (TOTAL INVERTER O/P CURRENT + BATTERY MAX
- **CONTINUOUS CURRENT) x 1.25**
- = [(30 x 1.21) + 16] x 1.25 = 65.38 A
- **SELECTED OCPD = 70 A ...NEC 240.6**
- 4. <u>120% RULE FOR BACKFEED BREAKER</u> ...NEC 705.1
 - MCB + PV BREAKER <= (1.2 x BUS BAR RATING RATING RATING) (200 + 70) <= 1.2 x 225A 270.00 <= 270.00 HENCE OK





LABEL 1 ON ALL CONDUITS SPACED AT MAX 10FT


! WARNING ! ELECTRIC SHOCK HAZARD DO NOT TOUCH TERMINALS. TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL 5 AT EACH AC DISCONNECT

SOLAR POINT OF INTERCONNECTION



LABEL 2 AT INVERTER



LABEL 3 AT INVERTER



LABEL 4 AT DC DISCONNECT



LABEL 6 AT EACH AC DISCONNECT





MULTIPLE POWER SOURCES . SECOND SOURCE IS PV SYSTEM THIRD SOURCE IS ESS SYSTEM

LABEL 7 AT MEP

! WARNING ! SOLAR SYSTEM CONNECTED AND ENERGIZED LABEL 8







LG NeON[®]2

LG370N1C-A6 | LG375N1C-A6 | LG380N1C-A6

General Data	
Cell Properties (Material/Type)	Monocrystalline/N-type
Cell Maker	LG
Cell Configuration	60 Cells (6 x 10)
Module Dimensions (L x W x H)	1,740mm x 1,042mm x 40mm
Weight	18.6 kg
Glass (Material)	Tempered Glass with AR Coating
Backsheet (Color)	White
Frame (Material)	Anodized Aluminium
Junction Box (Protection Degree)	IP 68 with 3 Bypass Diodes
Cables (Length)	1,100mm x 2EA
Connector (Type/Maker)	MC 4/MC

Certifications and Warranty

	IEC 61215-1/-1-1/2 : 2016, IEC 61730-1/2 : 2016, UL 61730-1 : 2017, UL 61730-2 : 2017		
Certifications**	ISO 9001, ISO 14001, ISO 50001		
	OHSAS 18001		
Salt Mist Corrosion Test	IEC 61701:2012 Severity 6		
Ammonia Corrosion Test	IEC 62716 : 2013		
Module Fire Performance	Type 1 (UL 61730)		
Fire Rating	Class C (UL 790, ULC/ORD C 1703)		
Solar Module Product Warranty	25 Year Limited		
Solar Module Output Warranty	Linear Warranty*		
'Improved: 1st year 98.5%, from 2-24th year: 0.33%/year down, 90.6% at year 25			

Temperature Characteristics


NMOT*	[°C]	42 ± 3
Pmax	[%/°C]	-0.34
Voc	[%/°C]	-0.26
lsc	[%/°C]	0.03
*NMOT (Nominal Module Operating Ten	perature): In	radiance 800 W/m², Ambient temperature 20°C,

Wind speed 1 m/s, Spectrum AM 1.5

Electrical Properties (NMOT)

Nodel		LG370N1C-A6	LG375N1C-A6	LG380N1C-A6
Aaximum Power (Pmax)	[W]	277	281	285
/IPP Voltage (Vmpp)	[V]	32.8	33.2	33.5
/IPP Current (Impp)	[A]	8.46	8.48	8.49
Open Circuit Voltage (Voc)	[V]	39.3	39.4	39.4
hort Circuit Current (Isc)	[A]	9.09	9.13	9.16

I-V Curves



Product specifications are subject to change without notice. LG370-380N1C-A6_AUS.pdf 121520

© 2020 LG Electronics USA. Inc. All rights reserved.

Electrical Properties (STC*)

Model		LG370N1C-A6	LG375N1C-A6	LG380N1C-A6	
Maximum Power (Pmax)	[W]	370	375	380	
MPP Voltage (Vmpp)	[V]	34.9	35.3	35.7	
MPP Current (Impp)	[A]	10.61	10.63	10.65	
Open Circuit Voltage (Voc, ± 5%)	[V]	41.7	41.8	41.9	
Short Circuit Current (Isc, ± 5%)	[A]	11.31	11.35	11.39	
Module Efficiency	[%]	20.4	20.7	21.0	
Bifaciality Coefficient of Power	[%]		10		
Power Tolerance	[%]		0~+3		

*STC (Standard Test Condition): Irradiance 1000 W/m², cell temperature 25°C, AM 1.5

Operating Conditions

Operating Temperature	[°C]	-40 ~+85
Maximum System Voltage	[V]	1,000
Maximum Series Fuse Rating	[A]	20
Mechanical Test Load [*] (Front)	[Pa/psf]	5,400
Mechanical Test Load [*] (Rear)	[Pa/psf]	4,000

Decksoine Configuration

ackaging Configuration				
[EA]	25			
[EA]	650			
[EA]	850			
[mm]	1,790 x 1,120 x 1,213			
[in]	70.5 x 44.1 x 47.8			
[kg]	500			
[lb]	1,102			
	[EA] [EA] [mm] [in] [kg]			

Dimensions (mm/inch)

042.0 / 41.0 (Size of Short Side) 0 / 39.4 (Distance between Grounding & Mounting H 16 - 8.0 x 3.0 / 0. Drain Holes 8 - Ø4.3 / 0.2 Grounding Holes 8 - 8.5 x 12.0 / 0.3 x 0.5 Mounting Holes 1100 / 43.3 Cable Length

LG Electronics USA, Inc Solar Business Division 2000 Millbrook Drive Lincolnshire, IL 60069 www.lg-solar.com

LG Electronics is a global leader in electronic products in the clean energy markets by offering solar PV panels and energy storage systems. The company first embarked on a solar energy source research program in 1985, supported by LG Group's vast experience in the semi-conductor, LCD, chemistry and materials industries. In 2010, LG Solar successfully released its first MonoX[®] series to the market, which is now available in 32 countries. The NeON[®] (previous MonoX[®] NeON), NeON[®]2, NeON[®]2 BiFacial won the "Intersolar AWARD" in 2013, 2015 and 2016, which demonstrates LG's leadership and innovation in the solar industry.













Preliminary





Data Sheet Enphase Microinverters Region: AMERICAS

Enphase IQ 7 and IQ 7+ **Microinverters**

The high-powered smart grid-ready Enphase IQ 7 Micro[™] and Enphase IQ 7+ Micro[™] dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy™, Enphase IQ Battery™, and the Enphase Enlighten[™] monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.



Easy to Install

- · Lightweight and simple
- · Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

Productive and Reliable

- Optimized for high powered 60-cell and 72-cell* modules
- · More than a million hours of testing
- · Class II double-insulated enclosure

UL listed

Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- Remotely updates to respond to changing
- grid requirements
- Configurable for varying grid profiles
- · Meets CA Rule 21 (UL 1741-SA)

* The IQ 7+ Micro is required to support 72-cell modules.



έ.	loarn	more	about	Enghana	offoringo	winit-	enphase.com	
	leann.	Inore	about	chunase	onemus.	VISIL	enphase.com	



Enphase IQ 7 and IQ 7+ Microinverters

INPUT DATA (DC)	IQ7-60-2-US		IQ7PLUS-72-2	-US	
Commonly used module pairings1	235 W - 350 W	+	235 W - 440 W +		
Module compatibility	60-cell PV modules only		60-cell and 72-	cell PV mo	
Maximum input DC voltage	48 V		60 V		
Peak power tracking voltage	27 V + 37 V		27 V - 45 V		
Operating range	16 V - 48 V		16 V - 60 V		
Min/Max start voltage	22 V / 48 V		22 V / 60 V		
Max DC short circuit current (module isc)	15 A		15 A		
Overvoltage class DC port	ii .		н		
DC port backfeed current	0 A		0 A		
PV array configuration		ed array; No additio tion requires max 2			
OUTPUT DATA (AC)	IQ 7 Microinv	CONTRACTOR OF A DESCRIPTION OF A DESCRIP	IQ 7+ Microin	Laboration and the second second	
Peak output power	250 VA		295 VA		
Maximum continuous output power	240 VA		290 VA		
Nominal (L-L) voltage/range ²	240 V / 211-264 V	208 V / 183-229 V	240 V / 211-264 V	208 V / 183-229	
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V)	1.39 A (
Nominal frequency	60 Hz		60 Hz		
Extended frequency range	47 - 68 Hz		47-68 Hz		
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms		
Maximum units per 20 A (L-L) branch circuit*	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)	11 (208	
Overvoltage class AC port	in		III		
AC port backfeed current	0 A		0 A		
Power factor setting	1.0		1.0		
Power factor (adjustable)	0.85 leading	0.85 lagging	0.85 leading 1	0.85 laggi	
EFFICIENCY	@240 V	@208 V	@240 V	@208 \	
Peak efficiency	97.6%	97.6 %	97.5%	97.3 %	
CEC weighted efficiency	97.0 %	97.0 %	97.0%	97.0 %	
MECHANICAL DATA					
Ambient temperature range	-40°C to +65°C				
Relative humidity range	4% to 100% (co				
Connector type (IQ7-60-2-US & IQ7PLUS-72-2-US)			ditional O-DCC-5	adapter)	
Dimensions (WxHxD)	and the stand of the stand of the	mm x 30.2 mm (with		and the state of	
Weight	1.08 kg (2.38 lb	Contract in the contract of the second se			
Cooling	Natural convec	The second second second second			
Approved for wet locations	Yes				
Pollution degree	PD3				
Enclosure		-insulated, corrosio	n recistant noluma	ric anolos	
			riesisterit polyrne	no encios	
Environmental category / UV exposure rating FEATURES	NEMA Type 6 /	outdoor			
	December 201	and the same of the state			
Communication		nmunication (PLC)			
Monitoring	Both options re	ager and MyEnlighte quire installation of	an Enphase IQ En	voy,	
Disconnecting means		connectors have be ulred by NEC 690.	een evaluated and	approved	
Compliance	CAN/CSA-C22. This product is NEC-2017 sect	1741/IEEE1547, FCC	pid Shut Down Equ 1-2015 Rule 64-21	ipment a 8 Rapid Si	

No enforced DC/AC ratio. See the compatibility calculator at <u>https://enphase.com/en-us/support/module-compatibility</u>.
 Nominal voltage range can be extended beyond nominal if required by the utility.
 Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

To learn more about Enphase offerings, visit enphase.com

© 2019 Enphase Energy. All rights reserved. All trademarks or brands used are the property of Enphase Energy, Inc. 2019-3-26

	CONTRACTOR
	SUNPR
	22171 MCH RD MANDEVILLE, LA 70471
dules	PHONE: 9152011490 PROJECT NAME & ADDRESS
	STEPHEN WRIGHT
ed;	101 EMMA CT,LINDEN, NC 28356
	COUNTY:-HARNETT COUNTY
V 208 V)	SYSTEM SIZE DC SIZE: 11.250 KW DC-(STC) AC SIZE: 8.700 KW AC
VAC)	ENGINEER:
ng	
ute .	
by UL for use as the load-break	
Class B,	
d conforms with NEC-2014 and utdown of PV Systems, for AC istructions.	
	SHEET TITLE RESOURCE
	DOCUMENT
⊖ ENPHASE.	DRAWN DATE 9/9/2021
	DRAWN BY SH
	SHEET NUMBER
	R-002

Data Sheet Enphase Networking

Enphase IQ Combiner 3 (X-IQ-AM1-240-3)

The **Enphase IQ Combiner 3**[™] with Enphase IQ Envoy[™] consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.



Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption
 monitoring
- Supports Ensemble Communications Kit for communication with Enphase Encharge[™] storage and Enphase Enpower[™] smart switch

Simple

- · Reduced size from previous combiner
- Centered mounting brackets support single stud
 mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type
- 3R enclosure • Five-year limited warranty
- UL listed

To learn more about Enphase offerings, visit **enphase.com**

(\r

LISTED


🖯 ENPHASE.


Enphase IQ Combiner 3


IQ Combiner 3 with Enphase IQ Envoy™ printed circuit boa production metering (ANSI C12.20 +/- 0.5%) and optional
(not included, order separately)
Plug and play industrial grade cellular modem with data p microinverters. (Available in the US, Canada, Mexico, Pue in) where there is adequate cellular service in the installation Split core current transformers enable whole home consu
Installed at the IQ Envoy. For communications with Enphase Enpower [™] smart switch. Includes USB cable for connection and allows wireless communication with Encharge and Enp Supports Eaton BR210, BR215, BR220, BR230, BR240, BR Circuit breaker, 2 pole, 10A, Eaton BR210
Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220
Power line carrier (communication bridge pair), quantity -
Replace the default solar shield with this Ensemble Comb and feel of the Enphase Enpower™ smart switch and the E
Accessory receptacle for Power Line Carrier in IQ Combin
Replacement IQ Envoy printed circuit board (PCB) for Cor
Continuous duty
120/240 VAC. 60 Hz
125 A
65 A
90 A
Up to four 2-pole Eaton BR series Distributed Generation
64 A
80 A of distributed generation / 95 A with IQ Envoy breake
10A or 15A rating GE Q-line/Siemens Type QP /Eaton BR
200 A solid core pre-installed and wired to IQ Envoy
49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). Height is 21.
7.5 kg (16.5 lbs)
-40° C to +46° C (-40° to 115° F)
Natural convection, plus heat shield
Outdoor, NRTL-certified, NEMA type 3R, polycarbonate co
 20 A to 50 A breaker inputs: 14 to 4 AWG copper conduted of the seaker branch input: 4 to 1/0 AWG copper conducted with a seaker branch output: 10 to 2/0 AWG copper conducted of the seaker branch and ground: 14 to 1/0 copper conductors and a seaker branch and seaker branch
To 2000 meters (6,560 feet)
802.11b/g/n
Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not
CELLMODEM-M1 4G based LTE-M cellular modem (not in Connect cellular modem is required for all Ensemble insta
UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Part 15, Clas Production metering: ANSI C12.20 accuracy class 0.5 (PV
UL 60601-1/CANCSA 22.2 No. 61010-1


To learn more about Enphase offerings, visit enphase.com


© 2021 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 3, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2021-05-20

















Data Sheet Enphase Storage System

Enphase Encharge 10

The Enphase Encharge 10™ all-in-one AC-coupled storage system is reliable, smart, simple, and safe. It is comprised of three base Encharge 3™ storage units, has a total usable energy capacity of 10.08 kWh and twelve embedded grid-forming microinverters with 3.84 kW power rating. It provides backup capability and installers can quickly design the right system size to meet the needs of both new and retrofit solar customers.



Reliable

- Proven high reliability IQ Series Microinverters
- Ten-year limited warranty
- Three independent Encharge storage base units
- Twelve embedded IQ 8X-BAT Microinverters
- Passive cooling (no moving parts/fans)

Smart

- Grid-forming capability for backup operation
- Remote software and firmware upgrade
- · Mobile app-based monitoring and control
- Support for self consumption
- Utility time of use (TOU) optimization

Simple

- · Fully integrated AC battery system
- Quick and easy plug-and-play installation
- · Interconnects with standard household AC wiring

Safe

- Cells safety tested
- Lithium iron phosphate (LFP) chemistry for maximum safety and longevity

To learn more about Enphase offerings, visit enphase.com

ENPHASE.

Enphase Encharge 10

ENCHARGE-10-1P-NA	Encharge 10 battery storage system with integrated Enphase Mi
	management unit (BMU). Includes:
-	- Three Encharge 3.36 kWh base units (B3-A01-US001-1-3)
-	 One Encharge 10 cover kit with cover, wall mounting bracket, w interconnect kit for wiring between batteries (B10-C-1050-0)
ACCESSORIES	
ENCHARGE-HNDL-R1	One set of Encharge base unit installation handles
OUTPUT (AC)	@ 240 VAC1
Rated (continuous) output power ²	3.84 kVA
Peak output power	5.7 kVA (10 seconds)
Nominal voltage / range	240 / 211 - 264 VAC
Nominal frequency / range	60 / 57 — 61 Hz
Rated output current	16 A
Peak output current	24.6A (10 seconds)
Power factor (adjustable)	0.85 leading 0.85 lagging
Maximum units per 20 A branch circuit	1 unit (single phase)
	Single-phase
	69.6 Arms
Round trip efficiency ²	89%
BATTERY	
Total capacity	10.5 kWh
Usable capacity	10.08 kWh
Round trip efficiency	96%
Nominal DC voltage	67.2 V
Maximum DC voltage	73.5 V
Ambient operating temperature range	-15° C to 55° C (5° F to 131° F) non-condensing
Optimum operating temperature range	0° C to 30° C (32° F to 86° F)
Chemistry	Lithium iron phosphate (LFP)
MECHANICAL DATA	
Dimensions (WxHxD)	1070 mm x 664 mm x 319 mm (42.13 in x 26.14 in x 12.56 in)
Weight	Three individual 44.2 kg (97.4 lbs) base units plus 21.1 kg (48.7 l bracket; total 154.7 kg (341 lbs)
Enclosure	Outdoor – NEMA type 3R
IQ 8X-BAT microinverter enclosure	NEMA type 6
Cooling	Natural convection - No fans
Altitude	Up to 2500 meters (8200 feet)
Mounting	Wall mount
FEATURES AND COMPLIANCE	
Compatibility	Compatible with grid-tied PV systems. Compatible with Enphas Enpower, and Enphase IQ Envoy for backup operation.
Communication	Wireless 2.4 GHz
Services	Backup, self-consumption, TOU, Demand Charge, NEM Integrity
Monitoring	Enlighten Manager and MyEnlighten monitoring options; API int
Compliance	UL 9540, UN 38.3, UL 9540A, UL 1998, UL 991, NEMA Type 3R, A EMI: 47 CFR, Part 15, Class B, ICES 003 Cell Module: UL 1973, UN 38.3
	Inverters: UL 62109-1, IEC 62109-2, UL 1741SA, CAN/CSA C22.2
LIMITED WARRANTY	
Limited Warranty ^a	>70% capacity, up to 10 years or 4000 cycles

Supported in backup/off grid operations
 AC to Battery to AC at 50% power rating.
 Whichever occurs first. Restrictions apply.

To learn more about Enphase offerings, visit enphase.com

© 2020 Enphase Energy, All rights reserved. Enphase, the Enphase logo, Encharge 10, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2020-05-19

	CONT	RACTOR
	SUN	PR
		MCH RD LE, LA 70471
	PHONE: 9	152011490
Account of the Account of Account		ALE & ADDRESS
watertight conduit hubs, and	STEPHEN	WRIGHT
	101 EMMA (NC 2	CT,LINDEN, 8356
	COUNTY:-HAR	NETT COUNTY
	DC SIZE: 11.25	M SIZE 0 KW DC-(STC) .700 KW AC
	ENGINEER:	
7 lbs) cover and mounting		
ise IQ Series Micros, Enphase		
ty ntegration		
AC156		
2 No. 107.1-16		
	RESO	URCE
	DOCU	
	DRAWN DATE	9/9/2021
	DRAWN BY	SH
	SHEET N	NUMBER
	R-0	na

Data Sheet
Enphase Ensemble energy management system

Enphase Enpower

The Enphase Enpower™ smart switch connects the home to grid power, the Encharge storage system, and solar PV. It provides microgrid interconnection device (MID) functionality by automatically detecting and seamlessly transitioning the home energy system from grid power to backup power in the event of a grid failure. It consolidates interconnection equipment into a single enclosure and streamlines grid independent capabilities of PV and storage installations by providing a consistent, pre-wired solution for residential applications.

€ ENPHASE

Reliable

- Durable NEMA type 3R enclosure
- Ten-year limited warranty

Smart

- Controls safe connectivity to the grid
- Automatically detects grid outages
- Provides seamless transition to backup

Simple

- Connects to the load or service equipment¹ side of the main load panel
- Centered mounting brackets support single stud mounting
- Supports conduit entry from the bottom, bottom left side, and bottom right side
- Supports whole home and partial home backup and subpanel backup
- Up to 200A main breaker support
- Includes neutral-forming transformer for split phase 120/240V backup operation

 Enpower is not suitable for use as service equipment in Canada.

ENPHASE.

To learn more about Enphase offerings, visit enphase.com

Enphase Enpower

MODEL NUMBER		
EP200G101-M240US00	$\label{eq:end} \mbox{Enphase Enpower smart switch with neutral-forming transformer} (MID), breakers, and screws. Streamlines grid-independent capab$	
ACCESSORIES and REPLACEMENT PART	S	
XA-E3-PCBA-ENS	Replacement Enpower controller printed circuit board	
Circuit breakers (as needed) ^{2,3} BRK-100A-2P-240V BRK-125A-2P-240V BRK-150A-2P-240V BRK-75A-2P-240V BRK-200A-2P-240V BRK-20A-2P-240V-B BRK-30A-2P-240V BRK-40A-2P-240V BRK-60A-2P-240V BRK-80A-2P-240V	Not included, must order separately: • Main breaker, 2 pole, 100A, 25kAIC, CSR2100N or CSR2100 • Main breaker, 2 pole, 125A, 25kAIC, CSR2125N • Main breaker, 2 pole, 150A, 25kAIC, CSR2150N • Main breaker, 2 pole, 175A, 25kAIC, CSR2175N • Main breaker, 2 pole, 200A, 25kAIC, CSR2200N • Circuit breaker, 2 pole, 20A, 10kAIC, BR220B • Circuit breaker, 2 pole, 30A, 10kAIC, BR230B • Circuit breaker, 2 pole, 40A, 10kAIC, BR240B • Circuit breaker, 2 pole, 60A, 10kAIC, BR260 • Circuit breaker, 2 pole, 80A, 10kAIC, BR280	
EP200G-HNDL-R1	Enpower installation handle kit (order separately)	
ELECTRICAL SPECIFICATIONS		
Assembly rating	Continuous operation at 100% of its rating	
Nominal voltage / range (L-L)	240 VAC / 100 - 310 VAC	
Voltage measurement accuracy	±1% V nominal (±1.2V L-N and ±2.4V L-L)	
Nominal frequency / range	60 Hz / 56 - 63 Hz	
Frequency measurement accuracy	±0.1 Hz	
Maximum continuous current rating	160A	
Maximum output overcurrent protection device	200A	
Maximum input overcurrent protection device	200A	
Maximum overcurrent protection device rating for storage branch circuit ⁴	A08	
Maximum overcurrent protection device rating for PV combiner branch circuit ⁴	A08	
Neutral Forming Transformer (NFT)	Breaker rating (pre-installed): 40A between L1 and Neutral; 40A Continuous rated power: 3600VA Maximum continuous unbalance current: 30A @ 120V Peak rated power: 8800VA for 30 seconds Peak unbalanced current: 80A @ 120V for 30 seconds	betwee
MECHANICAL DATA	•	
Dimensions (WxHxD)	50cm x 91.6cm x 24.6cm (19.7 in x 36 in x 9.7 in)	
Weight	38.5 kg (85 lbs)	
Ambient temperature range	-40° C to +50° C (-40° F to 122° F)	
Cooling	Natural convection, plus heat shield	
Enclosure environmental rating	Outdoor, NEMA type 3R, polycarbonate construction	
Altitude	To 2500 meters (8200 feet)	
WIRE SIZES		
Connections	 Main lugs, backup load lugs, and CSR breakers BR breakers (wire provided) AC combiner lugs, Encharge lugs, and generator (reserved for future use) lugs Neutral (large lugs) 	Cu/AL 6 AWG 14 AW Cu/AL
Neutral and ground bars	Large holes (5/16-24 UNF) Small holes (10-32 UNF)	14 AW 14 AW
COMPLIANCE		
Compliance	UL 1741, UL 1741 SA, UL1998, UL869A ⁵ , UL67 ⁵ , UL508 ⁵ , UL50E ⁵ CSA 22.2 No. 107.1, 47 CFR, Part 15, Class B, ICES 003, AC156.	

The kAIC of Enpower is the same as the kAIC of the main breaker being installed as listed.
 Not included. Installer must provide properly rated breaker per circuit breaker list above.
 Sections from these standards were used during the safety evaluation and included in the UL 1741 listing.

To learn more about Enphase offerings, visit enphase.com

© 2020 Enphase Energy. All rights reserved. Enphase, the Enphase logo, Enpower, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2020-06-16

	CONT	RACTOR
	SUN	PR
		MCH RD LE, LA 70471
	PHONE: 9	152011490
, Microgrid Interconnect Device of PV and storage installations.	PROJECT NAM	/IE & ADDRESS
of the and storage installations.	STEPHEN	WRIGHT
	101 EMMA (NC 2	CT,LINDEN, 8356
	COUNTY:-HAR	NETT COUNTY
	DC SIZE: 11.25	M SIZE 0 KW DC-(STC) .700 KW AC
	ENGINEER:	
een L2 and Neutral		
L: 2 AWG - 300 KCMIL G NG - 2 AWG		
L: 6 AWG - 300 KCMIL		
NG – 1/0 AWG NG – 6 AWG		
	SHEET TITLE RESOURCE	
	DOCUMENT	
⊖ ENPHASE.	DRAWN DATE	9/9/2021
	DRAWN BY	SH
	R-010	