### SCOPE OF WORK

TO INSTALL A RESIDENTIAL ROOFTOP SOLAR PHOTOVOLTAIC (PV) SYSTEM.

THE POWER GENERATED BY THE PV SYSTEM WILL BE INTERCONNECTED WITH THE UTILITY GRID THROUGH THE EXISTING ELECTRICAL SERVICE EQUIPMENT.

THE PV SYSTEM DOES NOT INCLUDE BATTERIES.

### **ELECTRICAL NOTES**

- 1) ALL EQUIPMENT TO BE LISTED BY THE UL OR OTHER NRTL AND LABELED FOR ITS APPLICATION.
- 2) ALL CONDUCTORS SHALL BE COPPER, RATED FOR 600V AND 90°C WET ENVIRONMENT.
- 3) WIRING, CONDUIT, AND RACEWAYS MOUNTED ON ROOFTOPS SHALL BE ROUTED DIRECTLY TO, AND LOCATED AS CLOSE AS POSSIBLE TO THE NEAREST RIDGE, HIP, OR VALLEY.
- 4) WORKING CLEARANCES AROUND ALL NEW AND EXISTING ELECTRICAL EQUIPMENT SHALL COMPLY WITH NEC 110.26.
- 5) DRAWINGS INDICATE THE GENERAL ARRANGEMENT OF SYSTEMS. CONTRACTOR SHALL FURNISH ALL NECESSARY OUTLETS, SUPPORTS, FITTINGS AND ACCESSORIES TO FULFILL APPLICABLE CODES AND STANDARDS.
- 6) WHERE SIZES OF JUNCTION BOXES, RACEWAYS, AND CONDUITS ARE NOT SPECIFIED, THE CONTRACTOR SHALL SIZE THEM ACCORDINGLY.
- 7) ALL WIRE TERMINATIONS SHALL BE APPROPRIATELY LABELED AND READILY VISIBLE
- 8) MODULE GROUNDING CLIPS TO BE INSTALLED BETWEEN MODULE FRAME AND MODULE SUPPORT RAIL, PER THE GROUNDING CLIP MANUFACTURER'S INSTRUCTION.
- 9) MODULE SUPPORT RAIL TO BE BONDED TO CONTINUOUS COPPER G.E.C. VIA WEEB LUG OR THE ILSCO GBL-4DBT LAY-IN LUG.
- 10) THE POLARITY OF THE GROUNDED CONDUCTORS IS (positive/negative) OR THE DC SIDE OF THE PV SYSTEM IS UNGROUNDED AND SHALL COMPLY WITH NEC 690.35

# NCDOI REQUIREMENTS \*OPTION 2\*

WEIGHT OF PV SYSTEM ON ROOF:

2.6695 PSF

**EXISTING ROOF MATERIAL TYPE:** 


ASPHALT SHINGLE (SINGLE LAYER)

PROJECT LOCATION WIND ZONE:

115 MPH

### **SHEET INDEX GOVERNING CODES** GENERAL INFORMATION NFPA 70 NATIONAL ELECTRICAL CODE 2017 COVER 2018 INTERNATIONAL BUILDING CODE PV-1 SITE PLAN ROOF LAYOUT AND MOUNTING DETAIL 2018 NORTH CAROLINA BUILDING CODE PV-2 **ELECTRICAL SCHEMATIC** 2018 NORTH CAROLINA RESIDENTIAL CODE PV-3 AMPACITY CALCULATIONS AND WIRE SIZING UNDERWRITERS LABORATORIES (UL) STANDARDS PV-4 PV-5 LABELING SCHEDULE OSHA 29 CFR 1910.269 MANUFACTURER SPECIFICATION SHEETS NORTH CAROLINA DEPARTMENT OF INSURANCE CUTSHEETS

# **VICINITY MAP**



	DESIGN SPEC	IFICATIONS
	CONSTRUCTION TYPE	SINGLE-FAMILY
	ZONING	RESIDENTIAL
┨	GROUND SNOW LOAD	20 PSF
┥	WIND EXPOSURE CATEGORY	CATEGORY B
┥	WIND SPEED	115 MPH
┥	UTILITY PROVIDER	DUKE ENERGY
┥	OTILITITIOVIDEN	PROGRESS
긔		TOWN OF
	AHJ	FUQUAY-VARINA
		(HARNETT COUNTY)

		Ш		
SYSTEM SPECIFICATIONS				
SOLAR MODULES	(18) TWINPEAK REC365TP4 PANELS 365W			
POWER OPTIMIZERS	(18) SOLAREDGE P401			
INVERTER(S)	(1) SOLAREDGE SE6000H-US000BNI4	r		
SOLAR MOUNTS	SNAPNRACK SPEEDSEAL FOOT	Г		
SOLAR RACKING SYSTEM	SNAPNRACK ULTRA RAIL 40 WITH SNAPNRACK SKIRTING			
MONITORING	YES			
POINT OF INTERCONNECT	BUCHANAN BTC 4/0-10 TAP CONNECTORS IN M/M COMBO			

### CONTRACTOR



### Covenant Solar Tech

### DBA SUN DOLLAR ENERGY

3200 WELLINGTON COURT SUITE 101 RALEIGH, NC 27615 (919) 508-6907 NC ELE LICENSE #: 34789 NC GC LICENSE #: 84770

PROJECT & CLIENT INFORMATION

# DEBERRY RESIDENCE NEW SOLAR PV SYSTEM

SYSTEM SIZE: 6.57 KW DC SYSTEM SIZE: 6.0 KW AC

### **TERESA AMICK DEBERRY**

16 WOOD BARN CT FUQUAY-VARINA, NC 27526 (919) 961-0551

ENGINEER OF RECORD



### DRAWING BY

RJW

REVISIONS

DESCRIPTION	DATE	#	BY			
RELEASED FOR PERMITTING	12/27/2021	1	CST			
SHEET SIZE						

ANSI B

11" X 17"


12/27/2021


SHEET NAME


# GENERAL INFORMATION


SHEET NUMBER

**COVER** 









Inside Subpanel Data					
Manufacturer	Square D				
Model Type	Type QO Breakers				
Model Number	QOC42UF				
Voltage Rating	120/240				
Busbar Amp Rating	225A				
Main Breaker/Main Lug	Main Breaker				
Breaker Amp Rating	200A				
Phase	Single				
UL Listing	UL 6294				
Enclosure Rating	NEMA 3R				

	WIRE SCHEDULE												
TAG	CURRENT CARRYING CONDUCTORS				GROUNDING CONDUCTORS			CONDUIT/RACEWAY			NOTES		
	QTY.	SIZE	MATERIAL	INSULATION TYP.	QTY.	SIZE	MATERIAL	INSULATION TYP.	QTY.	SIZE	MATERIAL	LOCATION	NOTES
C1	4	10 AWG	COPPER	PV WIRE	1	8 AWG	BARE COPPER	N/A	-	-	-	FREE AIR	
C2	4	10 AWG	COPPER	THHN/THWN-2	1	10 AWG	COPPER	THHN/THWN-2	1	3/4"	LFMC/EMT	EXTERIOR/INTERIOR	
C3	3	8 AWG	COPPER	THHN/THWN-2	1	10 AWG	COPPER	THHN/THWN-2	1	3/4"	LFNC/EMT	EXTERIOR	
C4	3	8 AWG	COPPER	THHN/THWN-2	1	10 AWG	COPPER	THHN/THWN-2	1	3/4"	LFNC/EMT	EXTERIOR	
XC	-	-	-	-	-	-	-	-	-	-	-	-	

CONTRACTOR



### **Covenant Solar Tech**

DBA SUN DOLLAR ENERGY 3200 WELLINGTON COURT SUITE 101 RALEIGH, NC 27615

(919) 508-6907 NC ELE LICENSE #: 34789 NC GC LICENSE #: 84770

PROJECT & CLIENT INFORMATION

## DEBERRY RESIDENCE NEW SOLAR PV SYSTEM

SYSTEM SIZE: 6.57 KW DC SYSTEM SIZE: 6.0 KW AC

### **TERESA AMICK DEBERRY**

16 WOOD BARN CT FUQUAY-VARINA, NC 27526 (919) 961-0551

ENGINEER OF RECORD

RJW

DRAWING BY

REVISIONS

DESCRIPTION DATE # BY
RELEASED FOR PERMITTING 12/27/2021 1 CST

SHEET SIZE ANSI B

11" X 17"

DATE

12/27/2021

SHEET NAME

ELECTRICAL SCHEMATIC

SHEET NUMBER

PV-3

# **Ampacity Calculations**

Wiring Location: Module to Power Optimizer (Direct Current) Wiring Location: Inverter to Service Entrance (Alternating Current) All calculations show minimum sizing for ampacity Actual wire sizing may be larger for voltage drop or other factors All calculations are according to the 2017 National Electric Code

	Modules: Inverter:	REC SolarEdge		k REC365TI I-US	P4		
Initial Input Values							
Isc (Short Circuit Curr	ent)	11.32					
Number of circuits		11.32	х	1	=	11.32	
Maximum Circuit Cur	rent (NEC						
690.8 (A)(1+2)		11.32	х	156%	=	17.6592	
Minimum Overcurrer	nt Device	25	Α	Series Fus	e Rating by	Manufact	urer
		Size AWG #					
Chosen Conductor Ty	pe						
(THHN, RHW-2, or US	E-2)	10					
Conductor Derating NEC 690.31 © ref (NE 310.16)	EC						
Conductor 90°C Ampa	acity		40				
Conduit Fill Derating		1-3	40	х	1	=	40
Temperature Deratin	g (°F)	141-149	40	Х	0.65	=	26
Ampacity vs Overcurrent  Device							
Conductor Ampacity	Check		26		17.6592		ОК
Conductor to Overcui	rrent						
Check			26		25		OK

Input Data Into Yellow Fields Green Field must say OK

Use this calculation for over current protection and wire sizing for stringers coming from Solar Panels. Isc comes from manufacturer

# **Ampacity Calculations**

Wiring Location: Inverter to Service Entrance (Alternating Current) All calculations show minimum sizing for ampacity Actual wire sizing may be larger for voltage drop or other factors All calculations are according to the 2017 National Electric Code

**Modules:** REC TwinPeak REC365TP4 Inverter: SolarEdge SE6000H-US

vc.te.r	oolal Lage	32000011	03				
Initial Input Values							
Inverter Continuous AC							
Output Combined (Watts)	6000						
Minimum Operating Voltage	240						
		Watts		Volts		Amps	
		6000	/	240	=	25	
Inverter Continuous AC Amps		25					
Number of Inverters		25	х	1	=	25	
Overcurrent Device Rating							
NEC 690.8 (B)(3)		25	х	125%	=	31.25	
Minimum Overcurrent Device		40	Amps				
Circuit Breaker Size per NEC							
240.6(A)		40	Amps				
		Size AWG #	‡				
Chosen Conductor Type							
THHN,THWN,RHW-2 or USE-2		8					
Conductor Derating							
<del></del>							
NEC 690.31© ref (NEC 310.16)							
Conductor 90°C Ampacity			55				
Conduit Fill Derating		1-3	55	X	1	=	55
Temperature Derating (°F)		105-113	55	X	0.87	=	47.85
Ampacity vs Overcurrent							
<u>Device</u>							
Conductor Ampacity Check			47.85		31.25		OK
Conductor to Overcurrent							
Check			47.85		40		ОК
Input Data into Yellow Fields							
	l						

Use this calculation for over current protection and wire sizing for inverter

Green Fields must say OK



CONTRACTOR

# **Covenant Solar Tech**

**DBA SUN DOLLAR ENERGY** 3200 WELLINGTON COURT SUITE 101 RALEIGH, NC 27615 (919) 508-6907 NC ELE LICENSE #: 34789 NC GC LICENSE #: 84770

PROJECT & CLIENT INFORMATION

## **DEBERRY RESIDENCE NEW SOLAR PV SYSTEM**

SYSTEM SIZE: 6.57 KW DC SYSTEM SIZE: 6.0 KW AC

### **TERESA AMICK DEBERRY**

16 WOOD BARN CT FUQUAY-VARINA, NC 27526 (919) 961-0551

ENGINEER OF RECORD

DRAWING BY **RJW** 

REVISIONS

DESCRIPTION	DATE	#	ВҮ		
RELEASED FOR PERMITTING	12/27/2021	1	CS		
SHEET SIZE					

ANSI B

11" X 17" DATE

12/27/2021

SHEET NAME

**AMPACITY CALCULATIONS** 

SHEET NUMBER

# PV LABELS

# PHOTOVOLTAIC SYSTEM ↑ DC DISCONNECT ↑

RATED MMP CURRENT RATED MPP VOLTAGE VOLTS MAX SYSTEM VOLTAGE VDC MAX CIRCUIT CURRENT **AMPS** 

NEC 690.53 APPLY TO:

> **RAPID SHUTDOWN SWITCH FOR** SOLAR PV SYSTEM

NEC 690.56(C)(3)

**APPLY TO: INVERTERS** 

**INVERTER** 

# MAIN PV SYSTEM DISCONNECT

NEC 690.13 (B)

APPLY TO: MAIN AC DISCONNECT

5

### SIGNAGE REQUIREMENTS

- > WARNING SIGNS OR LABELS SHALL COMPLY WITH NEC 110.21(B)
- > MIN. 3/8" LETTER HEIGHT
- > ALL CAPITAL LETTERS > ARIAL OR SIMILAR FONT
- > REFLECTIVE, WEATHER RESISTANT MATERIAL, UL 969

## WARNING: PHOTOVOLTAIC POWER SOURCE

NEC 690.31(G)(3)(4)

2

6

APPLY TO: SOLAR DC RACEWAYS DC JUNCTION BOXES

# PHOTOVOLTAIC SYSTEM AC DISCONNECT A

**OPERATING VOLTAGE** VAC **AMPS OPERATING CURRENT** 

NEC 690.54

**APPLY TO:** AC DISCONNECT

# **SOLAR PV SYSTEM EQUIPPED** WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY

NEC 690.56(C)(1)(a)

**APPLY TO:** MAIN SERVICE DISCONNECT

# **WARNING**

THIS EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE. SHALL NOT EXCEED AMPACITY OF BUSBAR

NEC 705.12 (B)(2)(3)(c)

**APPLY TO:** SERVICE PANEL(S)

# / WARNING

**ELECTRIC SHOCK HAZARD** 

TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

4

8

NEC 690.13(B)

3

APPLY TO: DISCONNECTS **COMBINER BOXES** 

# **WARNING**

THE DISCONNECTION OF THE GROUNDED CONDUCTOR(S) MAY RESULT IN OVERVOLTAGE ON THE EQUIPMENT

NEC 690.31 (I)

APPLY TO: INVERTER(S) CONTRACTOR



# **Covenant Solar Tech**

**DBA SUN DOLLAR ENERGY** 3200 WELLINGTON COURT SUITE 101 RALEIGH, NC 27615 (919) 508-6907

NC ELE LICENSE #: 34789 NC GC LICENSE #: 84770

PROJECT & CLIENT INFORMATION

# DEBERRY RESIDENCE **NEW SOLAR PV SYSTEM**

SYSTEM SIZE: 6.57 KW DC SYSTEM SIZE: 6.0 KW AC

### **TERESA AMICK DEBERRY**

16 WOOD BARN CT FUQUAY-VARINA, NC 27526 (919) 961-0551

ENGINEER OF RECORD

DRAWING BY

**RJW** 

REVISIONS

DESCRIPTION	DATE	#	BY
RELEASED FOR PERMITTING	12/27/2021	1	CST

SHEET SIZE **ANSI B** 

11" X 17"

DATE 12/27/2021

SHEET NAME

LABELING **SCHEDULE** 

SHEET NUMBER

PV-5



# REC TWINPEAK 4 BLACK SERIES


# PREMIUM SOLAR PANELS WITH SUPERIOR PERFORMANCE

REC TwinPeak 4 Black Series solar panels feature an aesthetically-pleasing full-black design with high panel efficiency and power output, enabling customers to get the most out of the space used for the installation.

Combined with industry-leading product quality and the reliability of a strong and established European brand, REC TwinPeak 4 Black Series panels are ideal for residential and commercial rooftops worldwide.










**PID FREE** 





**GENERAL DATA** 

# REC TWINPEAK 4 BLACK SERIE



ELECTRICAL DATA @ STC	Product code	*: RECxxxTP4	Black	
Power Output-P <sub>MAX</sub> (Wp)	355	360	365	370
Watt Class Sorting - (W)	0/+5	0/+5	0/+5	0/+5
Nominal Power Voltage - V <sub>MPP</sub> (V)	33.5	33.9	34.3	34.7
Nominal Power Current - I <sub>MPP</sub> (A)	10.60	10.62	10.65	10.68
Open Circuit Voltage - V <sub>oc</sub> (V)	40.5	40.6	40.8	41.0
Short Circuit Current-I <sub>SC</sub> (A)	11.19	11.26	11.32	11.38
Panel Efficiency (%)	19.4	19.7	20.0	20.3

Values at standard test conditions (STC: air mass AM 1.5, irradiance 1000 W/m², temperature 25°C), based on a production spread with a tolerance of  $P_{MAX}$ ,  $V_{OC} \& I_{SC} \pm 3\%$  within one watt class. \*Where xxx indicates the nominal power class ( $P_{MAX}$ ) at STC above.

ELECTRICAL DATA @ NMOT	Product code*: RECxxxTP4 Black			
Power Output-P <sub>MAX</sub> (Wp)	269	272	276	280
Nominal Power Voltage - $V_{MPP}(V)$	31.4	31.7	32.1	32.5
Nominal Power Current - I <sub>MPP</sub> (A)	8.56	8.58	8.60	8.63
Open Circuit Voltage - $V_{OC}(V)$	37.9	38.0	38.2	38.4
Short Circuit Current-I <sub>sc</sub> (A)	9.04	9.10	9.15	9.19

Nominal module operating temperature (NMOT: air mass AM1.5, irradiance 800 W/m², temperature 20°C, windspeed 1 m/s). \*Where xxx indicates the nominal power class (P<sub>MAX</sub>) at STC indicated above

### **CERTIFICATIONS**

IEC 61215:2016, IEC 61730:2016, UL 61730 (Pending) ISO 14001:2004, ISO 9001:2015, OHSAS 18001:2007,





WARRANTT			
	Standard	REC	ProTrust
Installed by an REC Certified Solar Professional	No	Yes	Yes
System Size	Any	≤25 kW	25-500 kW
Product Warranty (yrs)	20	25	25
Power Warranty (yrs)	25	25	25
Labor Warranty (yrs)	0	25	10
Power in Year 1	98%	98%	98%
Annual Degradation	0.5%	0.5%	0.5%
Power in Year 25	86%	86%	86%

See warranty documents for details. Conditions apply.

Cell type: 120 half-cut mono c-Si p-type cells 6 strings of 20 cells in series Glass: 0.13" (3.2 mm) solar glass with anti-reflection surface treatment

Backsheet: Highly resistant polymeric construction (black) Frame: Anodized aluminum (black)

Junction box: 3-part, 3 bypass diodes, IP68 rated n accordance with IEC 62790

Cable: 12 AWG (4 mm<sup>2</sup>) PV wire, 43 + 47" (1.1 m + 1.2 m) in accordance with EN 50618

Stäubli MC4 PV-KBT4/KST4, 12 AWG(4 mm²)

in accordance with IEC 62852 IP68 only when connected

Origin: Made in Singapore

### **MECHANICAL DATA**

69.1 x 40.94 x 1.2 in (1755 x 1040 x 30 mm) Dimensions Area: 19.70 sq ft (1.83 m<sup>2</sup>) Weight: 44.0 lbs (20.0 kg)

### **MAXIMUM RATINGS**


Operational temperature: -40 ... +185°F (-40 ... +85°C) 1000 V Maximum system voltage: +7000 Pa (146 psf) Maximum test load (front) Maximum test load (rear): -4000 Pa (83.5 psf) Max series fuse rating 25 A Max reverse current:


See installation manual for mounting instructions Design load = Test load / 1.5 (safety factor)

### **TEMPERATURE RATINGS\***

Nominal Module Operating Temperature: 44.6°C(±2°C) Temperature coefficient of  $P_{MAX}$ : -0.34 %/°C Temperature coefficient of  $V_{oc}$ : -0.26 %/°C Temperature coefficient of I<sub>sc</sub>: 0.04 %/°C

\*The temperature coefficients stated are linear values







# Single Phase Inverter with HD-Wave Technology

# for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US





# Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12

- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Extremely small
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)



NVERTERS

# / Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
APPLICABLE TO INVERTERS WITH PART NUMBER				SEXXXXH-XXXXXBXX	4			
OUTPUT								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
AC Output Voltage MinNomMax. (211 - 240 - 264)	✓	✓	✓	✓	<b>√</b>	✓	✓	Vac
AC Output Voltage MinNomMax. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Vac
AC Frequency (Nominal)				59.3 - 60 - 60.5 <sup>(1)</sup>				Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	А
Maximum Continuous Output Current @208V	=	16	-	24	-	-	48.5	А
Power Factor			1,	adjustable -0.85 to 0	).85			
GFDI Threshold		1						
Utility Monitoring, Islanding Protection, Country Configurable Thresholds				Yes				
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W
Transformer-less, Ungrounded				Yes				
Maximum Input Voltage				480				Vdc
Nominal DC Input Voltage	380 400						Vdc	
Maximum Input Current @240V <sup>(2)</sup>	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Maximum Input Current @208V <sup>(2)</sup>	-	9	-	13.5	-	-	27	Adc
Max. Input Short Circuit Current	45							Adc
Reverse-Polarity Protection				Yes				
Ground-Fault Isolation Detection				600kΩ Sensitivity				
Maximum Inverter Efficiency	99			9	9.2			%
CEC Weighted Efficiency			g	9			99 @ 240V 98.5 @ 208V	%
Nighttime Power Consumption				< 2.5				W

 $<sup>^{\</sup>mbox{\tiny (1)}}$  For other regional settings please contact SolarEdge support

<sup>&</sup>lt;sup>(2)</sup> A higher current source may be used; the inverter will limit its input current to the values stated

# / Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
ADDITIONAL FEATURES								
Supported Communication Interfaces			RS485, Etherne	t, ZigBee (optional), C	ellular (optional)			
Revenue Grade Data, ANSI C12.20				Optional <sup>(3)</sup>				
Inverter Commissioning		with the Se	tApp mobile applicati	on using built-in Wi-F	i Access Point for loca	al connection		
Rapid Shutdown - NEC 2014 and 2017 690.12			Automatic Rap	id Shutdown upon AC	Grid Disconnect			
STANDARD COMPLIANCE								
Safety		UL1741	, UL1741 SA, UL1699B	. CSA C22.2, Canadiar	AFCI according to T.	I.L. M-07		
Grid Connection Standards			IEE	E1547, Rule 21, Rule 14	1 (HI)			
Emissions				FCC Part 15 Class B				
INSTALLATION SPECIFICAT	TIONS							
AC Output Conduit Size / AWG Range		1	'' Maximum / 14-6 AW	/G		1" Maximur	n /14-4 AWG	
DC Input Conduit Size / # of Strings / AWG Range		1" Maxi	mum / 1-2 strings / 14	-6 AWG		1" Maximum / 1-3	strings / 14-6 AWG	
Dimensions with Safety Switch (HxWxD)	17.7 x 14.6 x 6.8 / 450 x 370 x 174 21.3 x 14.6 x 7.3					/ 540 x 370 x 185	in / mm	
Weight with Safety Switch	22 .	/ 10	25.1 / 11.4	26.2	/ 11.9	38.8	/ 17.6	lb/kg
Noise		<	25			<50		dBA
Cooling				Natural Convection				
Operating Temperature Range	-40 to +140 / -40 to +60 <sup>(4)</sup>						°F/°C	
Protection Rating		NEMA 4X (Inverter with Safety Switch)						

<sup>&</sup>lt;sup>(3)</sup> Revenue grade inverter P/N: SExxxxH-US000BNC4



<sup>&</sup>lt;sup>(a)</sup> Full power up to at least 50°C /122°F; for power de-rating information refer to: https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf

# **Power Optimizer**

# For North America

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505







# PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization

- / Fast installation with a single bolt
- Next generation maintenance with modulelevel monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety



# / Power Optimizer

# **For North America**

# P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high- power 60-cell modules)	P370 (for higher- power 60 and 72- cell modules)	P400 (for 72 & 96-cell modules)	P401 (for high power 60 and 72 cell modules)	P405 (for high- voltage modules)	P485 (for high- voltage modules)	P505 (for higher current modules)	
INPUT									
Rated Input DC Power <sup>(1)</sup>	320	350	370	400	40	05	485	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	4	8	60	80	60	12	5(2)	83(2)	Vdc
MPPT Operating Range	8 -	48	8 - 60	8 - 80	8-60	12.5	- 105	12.5 - 83	Vdc
Maximum Short Circuit Current (lsc)	11	11.02	11	10.1	11.75	-	11	14	Adc
Maximum DC Input Current		13.75		12.5	14.65	12	2.5	17.5	Adc
Maximum Efficiency				99	.5				%
Weighted Efficiency				98.8				98.6	%
Overvoltage Category				II					
OUTPUT DURING OPER	ATION (POW	ER OPTIMIZ	ER CONNECT	ED TO OPE	RATING SOL	AREDGE INV	(ERTER)		
Maximum Output Current				15	)				Adc
Maximum Output Voltage	60						85		Vdc
<b>OUTPUT DURING STANI</b>	DBY (POWER	OPTIMIZER	DISCONNECT	ED FROM SC	LAREDGE IN	VERTER OR	SOLAREDGE	<b>INVERTER O</b>	FF)
Safety Output Voltage per Power Optimizer				1 ±	0.1				Vdc
STANDARD COMPLIANO	CE								
EMC			FCC Pa	art15 Class B, IEC6	1000-6-2, IEC6100	0-6-3			
Safety				IEC62109-1 (class	II safety), UL1741				
Material				UL94 V-0, U	V Resistant				
RoHS				Υe	S				
INSTALLATION SPECIFIC	CATIONS								
Maximum Allowed System Voltage				100	00				Vdc
Compatible inverters			All SolarE	dge Single Phase	and Three Phase i	nverters			
Dimensions (W x L x H)	129 :	× 153 x 27.5 / 5.1 x	6 x 1.1	129 x 153 x 33.5 / 5.1 x 6 x 1.3	129 x 153 x 29.5 / 5.1 x 6 x 1.16	129 x 159 x 49.5	5 / 5.1 x 6.3 x 1.9	129 x 162 x 59 / 5.1 x 6.4 x 2.3	mm / in
Weight (including cables)		630 / 1.4		750 / 1.7	655 / 1.5	845	/ 1.9	1064 / 2.3	gr / lb
Input Connector			MC	4(3)			Single or dual MC4 <sup>(3)(4)</sup>	MC4 <sup>(3)</sup>	
Input Wire Length		0.16 / 0.52					m/ft		
Output Wire Type / Connector				Double Insul	ated / MC4				
Output Wire Length	0.9 /	2.95			1.2 /	3.9			m / ft
Operating Temperature Range <sup>(6)</sup>				-40 to +85 /					°C / °F
Protection Rating				IP68 / N					
Relative Humidity			C Damas" Madulas	0 - 1	100				%

- (1) Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed
- (2) NEC 2017 requires max input voltage be not more than 80V
- (3) For other connector types please contact SolarEdge
- (4) For dual version for parallel connection of two modules use P485-4NMDMRM. In the case of an odd number of PV modules in one string, installing one P485 dual version power optimizer connected to one PV module. When connecting a single module seal the unused input connectors with the supplied pair of seals
- (5) Longer inputs wire length are available for use. For 0.9m input wire length order P401-xxx1xxx

  (6) For ambient temperature above +85°C / +185°F power de-rating is applied. Refer to Power Optimizers Temperature De-Rating Technical Note for more details

PV System Design Usir SolarEdge Inverter <sup>(7)(8)</sup>	ng a	Single Phase HD-Wave	Single phase	Three Phase for 208V grid	Three Phase for 277/480V grid	
Minimum String Length	P320, P340, P370, P400, P401	8		10	18	
(Power Optimizers) P405, P485, P505		6	5	8	14	
Maximum String Length (Power Optimizers)		2	5	25	50 <sup>(9)</sup>	
Maximum Power per String		5700 (6000 with SE7600-US - SE11400- US)	5250	6000(10)	12750(11)	W
Parallel Strings of Different Lengths or Orientations			\	Yes		

<sup>(7)</sup> For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string\_sizing\_na.pdf (8) It is not allowed to mix P405/P485/P505 with P320/P340/P370/P400/P401 in one string



<sup>(9)</sup> A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement (10) For 208V grid: it is allowed to install up to 6,500W per string when the maximum power difference between each string is 1,000W (11) For 277/480V grid: it is allowed to install up to 15,000W per string when the maximum power difference between each string is 2,000W

# **Energy Meter with Modbus Connection**

# for North America



# METERING

# **Energy Meter for Residential Installations:**

- Simple installations and connectivity
- Type NEMA 3R enclosure for outdoor protection
- Provides high accuracy meter readings
- Communicates over RS485 to provide monitoring data
- Suitable for export limitation, consumption monitoring and StorEdgeTM applications




# / Energy Meter with Modbus Connection for North America

SE-MTR240-NN-S-S1


SUPPORTED INVERTERS	SINGLE PHA	SINGLE PHASE INVERTERS				
ELECTRICAL SERVICE						
AC Input Voltage (Nominal)	2	240				
AC Frequency (Nominal)		60				
Max AC Input Current		100	mA			
Connector Type	Terminal blo	ock - 22 to 12	AWG			
Grids supported		/ N / PE L2 / PE				
Power Consumption (Nominal)		3	W			
METER ACCURACY (@ 77°F / 25°C, PF:0.	7- 1)					
1 - 100% of Rated Current CT	4	±1.0	%			
CURRENT TRANSFORMERS(1)						
Nominal Input (at CT Rated Current)	CT1, C	T2: 0.333	Vac RMS			
Rated RMS current <sup>(2)</sup>	200	400	А			
Dimensions (Internal / External)	0.8 x 0.8; 2.4 x 2.4 / 20 x 20; 61 x 61	1.26 x 1.83; 3.3 x 4.5 / 32 x 46.5; 83.4 x 114	in/mm			
STANDARD COMPLIANCE	·					
Safety	UL 1741:2010 Ed.2(Suppl	ement SA)+R: 07 Sep 2016				
Emmissions	FCC 47 CFR P	FCC 47 CFR Part 15 Subpart B				
ENVIRONMENTAL	•					
Operating Temperatures	-40 to +140	) / -40 to +60	°F / °C			
Relative Humidity (noncondensing)	5	5-90				
Enclosure type	High impact, ABS and/or AB	High impact, ABS and/or ABS/PC plastic UL 94V-0, IEC FV-0				
Protection Rating	NEMA	NEMA Type 3R				
INSTALLATION SPECIFICATIONS						
Dimensions (HxWxD)	8.1 x 12.4 x 4.6 /	8.1 x 12.4 x 4.6 / 206.6 x 316 x 117.5				
Weight	3.9	3.9 / 1.8				
Conduit Entry Diameters	0.75 or 1	0.75 or 1 / 19 or 25				
Mounting Type	Bracke	Bracket mount				

<sup>(1)</sup> Current Transformers should be ordered separately: SEACT0750-200NA-20 (200A) or SEACT1250-400NA-20 (400A), 20 per box

### **Current Transformer Dimensions**



### Connecting the Energy Meter



<sup>(2)</sup> For other ratings contact SolarEdge

 $<sup>^{\</sup>star}$  Current Transformers (CTs) should be ordered separately: SEACT0750-200NA-20 (200A); SEACT1250-400NA-20 (400A). Each comes in boxes of 20.

RSTC Enterprises, Inc. 2214 Heimstead Road Eau Claire, WI 54703 715-830-9997



# **Outdoor Photovoltaic Enclosures**

Composition/Cedar Roof System

## ETL listed and labeled

Report # 3171411PRT-002 Revised May, 2018

- UL50 Type 3R, 11 Edition Electrical equipment enclosures
- CSA C22.2 No. 290 Nema Type 3R
- Conforms to UL 1741 Standard

# 0799 Series Includes:

0799 - 2 Wire size 2/0-14 0799 - 5 Wire size 14-6 0799 - D Wire size 14-8

Models available in Grey, Black or Stainless Steel

# **Basic Specifications**

Material options:

- Powder coated, 18 gauge galvanized 90 steel (1,100 hours salt spray)
- Stainless steel

Process - Seamless draw (stamped) Flashing - 15.25" x 17.25" Height - 3" Cavity - 255 Cubic inches

## Base Plate:

- Fastened to base using toggle fastening system
- 5 roof deck knockouts
- Knockout sizes: (3) .5", (1) .75" and (1) 1"
- 8". 35mm slotted din rail
- Ground Block

Passthrough and combiner kits are available for either AC or DC applications.

# 0799 Series







# **Eaton general duty cartridge fuse safety switch**

## DG222NRB

UPC:782113144221

### **Dimensions:**

Height: 14.37 INLength: 7.35 INWidth: 8.4 IN

Weight:10 LB

**Notes:**Maximum hp ratings apply only when dual element fuses are used. 3-Phase hp rating shown is a grounded B phase rating, UL listed.

## Warranties:

• Eaton Selling Policy 25-000, one (1) year from the date of installation of the Product or eighteen (18) months from the date of shipment of the Product, whichever occurs first.

## **Specifications:**

• Type: General duty, cartridge fused

Amperage Rating: 60A
Enclosure: NEMA 3R

• Enclosure Material: Painted galvanized steel

Fuse Class Provision: Class H fuses
 Fuse Configuration: Fusible with neutral

Number Of Poles: Two-poleNumber Of Wires: Three-wire

• Product Category: General duty safety switch

Voltage Rating: 240V

## **Supporting documents:**

• Eatons Volume 2-Commercial Distribution

• Eaton Specification Sheet - DG222NRB

### **Certifications:**

UL Listed

Product compliance: No Data



\_\_\_\_\_

© 2016 Eaton. All rights reserved.



# **Array Skirt**



# Sleek Look. Attractive Design. Easily Mounted.



Skirt mounts attach to any standard module using single bolt with 1/2" socket



Splice provides snap-in attachment of skirt sections together



Skirt easily snaps onto mount providing a clean finished look



Can be installed at any time allowing easy retrofit of existing systems

# Start Installing the Array Skirt Today

RESOURCES
DESIGN
WHERE TO BUY

snapnrack.com/resources snapnrack.com/configurator snapnrack.com/where-to-buy

# The SnapNrack Array Skirt

is an enhanced aesthetic option with a sleek black finish providing a flush clean line homeowners love. When installed the Array Skirt provides a clean finish to the front of arrays covering any screws, bolts, wires, or mounting hardware. It mounts directly to standard module frames allowing it to attach to almost any array.

# **Skirt Mounts**

- Hook onto the inside of module frame
- Secured in place with ½" fastener from front of module preventing any need for reaching under array





# Skirt

- Snaps into place on the mount easily with no tools required
- Smooth curved profile provides an elegant finished look

# **Splice**

- Attaching separate sections of skirt is easy with the snap-in splice
- Provides a seamless transition between skirt sections





# **End Caps**

- Cover end sections of skirt so no cuts are visible
- Easily snap end caps onto the ends of any skirt section

# Quality. Innovative. Superior.

SnapNrack Solar Mounting Solutions are engineered to optimize material use and labor resources and improve overall installation quality and safety.


877-732-2860

www.snapnrack.com

contact@snapnrack.com



# **Ultra Rail**





# The Ultimate Value in Rooftop Solar



Industry leading Wire Management Solutions



Mounts available for all roof types



**Single Tool Installation** 



All SnapNrack Module Clamps & Accessories are compatible with both rail profiles

# **Start Installing Ultra Rail Today**

RESOURCES
DESIGN
WHERE TO BUY

snapnrack.com/resources snapnrack.com/configurator snapnrack.com/where-to-buy

# **SnapNrack Ultra Rail System**

A sleek, straightforward rail solution for mounting solar modules on all roof types. Ultra Rail features two rail profiles; UR-40 is a lightweight rail profile that is suitable for most geographic regions and maintains all the great features of SnapNrack rail, while UR-60 is a heavier duty rail profile that provides a larger rail channel and increased span capabilities. Both are compatible with all existing mounts, module clamps, and accessories for ease of install.

# The Entire System is a Snap to Install

- New Ultra Rail Mounts include snap-in brackets for attaching rail
- Compatible with all the SnapNrack Mid Clamps and End Clamps customers love
- Universal End Clamps and snap-in End Caps provide a clean look to the array edge





# **Unparalleled Wire Management**

- Open rail channel provides room for running wires resulting in a long-lasting quality install
- Industry best wire management offering includes Junction Boxes, Universal Wire Clamps, MLPE Attachment Kits, and Conduit Clamps
- System is fully bonded and listed to UL 2703 Standard

# Heavy Duty UR-60 Rail

- UR-60 rail profile provides increased span capabilities for high wind speeds and snow loads
- Taller, stronger rail profile includes profilespecific rail splice and end cap
- All existing mounts, module clamps, and accessories are retained for the same great install experience



# Quality. Innovative. Superior.

SnapNrack Solar Mounting Solutions are engineered to optimize material use and labor resources and improve overall installation quality and safety.

# SnapNrack SpeedSeal™ Foot

Patent Pending Lag Driven Sealant Solution for Ultra Rail



# A New Generation of Roof Attachments

- Innovative design incorporates flashing reliability into a single roof attachment
- 100% waterproof solution
- Sealing cavity with compressible barrier secures sealant in place & fills voids

# Maintain the Integrity of the Roof by Eliminating Disruption


- Zero prying of shingles
- Zero removal of nails leaving holes in the roof
- Roof remains installed the way manufacturer meant it to be

# **Lag Driven Sealant Waterproofing**

- Time Tested Roof Sealant provides lasting seal
- Sealant is compressed into cavity and lag hole as attachment is secured to rafter
- Active sealant solidifies bond if ever touched by liquid
- Technology passes UL 2582 Wind Driven Rain Test and ASTM E2140 Water Column Testing standards. Patent Pending.

# Single Tool Installation

• SnapNrack was the first in the industry to develop a complete system that only requires a single tool. That tradition is continued as a ½" socket is still the only tool necessary to secure the mount as well as all other parts of the system.



Note: Sealant shown in white for illustration purposes only.

# SnapNrack SpeedSeal™ Foot

# Fastest Roof Attachment in Solar

- Lag straight to a structural member, no in-between components such as flashings or bases.
- Simply locate rafter, fill sealant cavity & secure to roof. It's that simple!

# Integrated Flashings. No Questions.

- Sealant fills around lag screw keeping roof and structure sealed and intact
- No added holes from ripping up nails, staples and screws holding shingles on roof



# Less Time. Less Parts. Less Tools.

- No more need for a pry bar to rip up shingles
- No more proprietary lag screws
- Single Tool installation with ½" socket

# Total System Solution One Tool. One Warranty.

- SnapNrack Ultra Rail is a straightforward intuitive install experience on the roof without
  - compromising quality, aesthetics & safety, all supported by a 25 year warranty.
- Built-in Wire Management & Aesthetically pleasing features designed for Ultra Rail result in a long-lasting quality install that installers and homeowners love.



SnapNrack Ultra Rail System has been evaluated by Underwriters Laboratories (UL) and Listed to UL/ANSI Standard 2703 for Mechanical Loading and Fire. Additionally it is listed to UL 2582 for wind-driven rain and ASTM 2140.



