

January 25, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Shahzaib Khan
1600 Heritage Commerce Ct Suite 104
Wake Forest, NC 27587

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2201-0011

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic Encroachment - Proposed solar array and electrical route encroaches on existing septic area and septic repair area. Unable to approve large array in back yard on lot. Array only approvable in sides or front yard. Advised to contact soil scientist for septic proposal prior to any additional proceeding.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at (910) 893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting