

Harnett County 420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone: Fax:

2/11/2022

SUBJECT: **ERES2201-0015**

ELECTRICAL RESIDENTIAL

To: K.B. Electrical Services LLC

Here are the results of all Inspections located at 6540 NC 27 W:

Inspection Type: RECONNECT W/O FINAL

Scheduled Date/Time: 2/1/2022 Completed Date/Time: 2/1/2022

Inspector: Slade Burton Lawson III

Result: APPROVED

Remarks:

Notes: would like afternoon if possible

Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: GAS PIPING Scheduled Date/Time: 2/1/2022 Completed Date/Time: 2/1/2022

Inspector: Slade Burton Lawson III

Result: APPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to SBL

Inspection Type: FINAL**
Scheduled Date/Time: 2/4/2022
Completed Date/Time: 2/4/2022
Inspector: Scott Guy
Result: DISAPPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to TSG

Load calculation sheet required. Label breakers in panel

Inspection Type: FINAL**
Scheduled Date/Time: 2/10/2022
Completed Date/Time: 2/10/2022

Inspector: Justin Ryan McLeod

Result: APPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to JRM