

76 North Meadowbrook Drive Alpine, UT 84004 office (201) 874-3483 swyssling@wysslingconsulting.com

January 10, 2022

Sunpro Solar 22171 MCH Road Mandeville, LA 70471

> Re: Engineering Services Inman Residence 41 Williamsburg Way, Cameron NC 10.500 kW System

To Whom It May Concern:

We have received information regarding solar panel installation on the roof of the above referenced structure. Our evaluation of the structure is to verify the existing capacity of the roof system and its ability to support the additional loads imposed by the proposed solar system.

#### A. Site Assessment Information

- 1. Site visit documentation identifying attic information including size and spacing of rafters for the existing roof structure.
- Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information will be utilized for approval and construction of the proposed system.

#### B. Description of Structure:

Roof Framing: Prefabricated wood trusses at 24" on center. All truss members are

constructed of 2x2 dimensional lumber.

Roof Material: Metal Roofing Roof Slope: 15 degrees Inaccessible

Lumber type: Assumed Douglas Fir

Foundation: Permanent

#### C. Loading Criteria Used

Dead Load

- Existing Roofing and framing = 7 psf
   New Solar Panels and Racking = 3 psf
- TOTAL = 10 PSF
- Live Load = 20 psf (reducible) 0 psf at locations of solar panels
- Ground Snow Load = 15 psf
- Wind Load based on ASCE 7-10
  - Ultimate Wind Speed = 115 mph (based on Risk Category II)
  - Exposure Category C

Analysis performed of the existing roof structure utilizing the above loading criteria is in accordance with the North Carolina Residential Code (2015 IRC), including provisions allowing existing structures to not require strengthening if the new loads do not exceed existing design loads by 105% for gravity elements and 110% for seismic elements. This analysis indicates that the existing rafters will support the additional panel loading without damage, if installed correctly.

#### D. Solar Panel Anchorage

- 1. The solar panels shall be mounted in accordance with the most recent RT Mini installation manual. If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
- 2. Connection on the roof is utilizing (5) 4 screws into the existing decking to resist uplift forces. Contractor to verify installation to be performed in accordance with the A-Roof Tech recommendations. Pull out values per screw are based on National Design Specification values for CDX plywood and are identified as 208 lbs/inch. Based on ½" sheathing the value per screw would be 104 lbs providing 520 lbs uplift resistance per attachment.
- 3. The maximum allowable withdrawal force for a <sup>5</sup>/<sub>16</sub>" lag screw is 235 lbs per inch of penetration as identified in the National Design Standards (NDS) of timber construction specifications. Based on a minimum penetration depth of 2½", the allowable capacity per connection is greater than the design withdrawal force (demand). Considering the variable factors for the existing roof framing and installation tolerances, the connection using one <sup>5</sup>/<sub>16</sub>" diameter lag screw with a minimum of 2½" embedment will be adequate and will include a sufficient factor of safety.
- 4. Considering the wind speed, roof slopes, size and spacing of rafters, and condition of the roof, the panel supports shall be placed no greater than 36" on centers.
- 5. Panel supports connections shall be staggered to distribute load to adjacent rafters.

Based on the above evaluation, this office certifies that with the racking and mounting specified, the existing roof system will adequately support the additional loading imposed by the solar system. This evaluation is in conformance with the North Carolina Residential Code, current industry standards, and is based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Scott E. Wyssling, PE

North Carolina License 46546

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 COA # P-2308

инининини

Date Signed 01-10-22



# NEW PHOTOVOLTAIC SYSTEM 10.50 KW DC 41 WILLIAMSBURG WAY, CAMERON, NC 28326

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

#### SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC



Wyssling Consulting, PLLC
76 N Meadowbrook Drive Alpine UT 84004
North Carolina COA # P-2308

Date Signed 01-10-22

## **VICINITY MAP**



## SATELLITE VIEW



## SHEET INDEX

G-001	COVER PAGE
G-002	NOTES
A-101	SITE PLAN
A-102	ELECTRICAL PLAN
A-103	ATTACHMENT PLAN
A-104	STRUCTURAL PLAN
E-601	LINE DIAGRAM
E-602	ELECTRICAL CALCULATIONS
E-603	PLACARD
R-001	RESOURCE DOCUMENT
R-002	RESOURCE DOCUMENT
R-003	RESOURCE DOCUMENT
R-004	RESOURCE DOCUMENT
R-005	RESOURCE DOCUMENT
R-006	RESOURCE DOCUMENT
R-007	RESOURCE DOCUMENT
R-008	RESOURCE DOCUMENT
R-009	RESOURCE DOCUMENT
R-010	RESOURCE DOCUMENT

### **GENERAL NOTES**

#### 1.1.1 PROJECT NOTES:

1.1.2 THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURERS'S LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION'S (AHJ) APPLICABLE CODES.

1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND

1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AN PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION

1.1.4 GROUND FAULT DETECTION AND INTERRUPTION (GFDI) DEVICE IS INTEGRATED WITH THE MICRO-INVERTER IN ACCORDANCE WITH NEC 690.41(B) 1.1.5 ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4: PV MODULES: UL1703, IEC61730, AND IEC61215, AND NFPA 70 CLASS C FIRE INVERTERS: UL 1741 CERTIFIED, IEEE 1547, 929, 519 COMBINER BOX(ES): UL 1703 OR UL 1741 ACCESSORY

1.1.6 MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.

1.1.7 ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER

690.4. SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3].

1.1.8 ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.

#### 1.2.1 SCOPE OF WORK:

1.2.2 PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN, SPECIFY, AND INSTALL THE EXTERIOR ROOF-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS DOCUMENT

#### 1.3.1 WORK INCLUDES:

1.3.2 PV RACKING SYSTEM INSTALLATION - UNIRAC SOLAR

1.3.3 PV MODULE AND INVERTER INSTALLATION - LG ELECTRONICS LG375N1C-A6 / ENPHASE IQ7PLUS-72-2-US INVERTER

1.3.4 PV EQUIPMENT ROOF MOUNT

1.3.5 PV SYSTEM WIRING TO A ROOF-MOUNTED JUNCTION BOX

1.3.6 PV LOAD CENTERS (IF INCLUDED)

1.3.7 PV METERING/MONITORING (IF INCLUDED)

1.3.8 PV DISCONNECTS

1.3.9 PV GROUNDING ELECTRODE & BONDING TO (E) GEC

1.3.10 PV FINAL COMMISSIONING

1.3.11 (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV

1.3.12 SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

### PROJECT INFORMATION

**OWNER** 

NAME: ORLANDO INMAN

PROJECT MANAGER

NAME: SHAHIN HAYNES PHONE: 8665071461

**CONTRACTOR NAME** 

MARC JONES CONSTRUCTION, LLC DBA SUNPRO SOLAR

PHONE: 5052180838

#### SCOPE OF WORK

SYSTEM SIZE: STC:28 X 375W= 10.50 kW DC

PTC: 28 x 347.3W = 9.72 kW DC (28) LG ELECTRONICS LG375N1C-A6 (28) ENPHASE IQ7PLUS-72-2-US

ATTACHMENT TYPE: ROOF MOUNT MSP UPGRADE: NO UTILITY METER UPGRADE: NO

METER NO: 166426881

#### **AUTHORITIES HAVING JURISDICTION**

BUILDING: HARNETT COUNTY ZONING: HARNETT COUNTY UTILITY: CENTRAL EMC



#### DESIGN SPECIFICATION

OCCUPANCY:

CONSTRUCTION: SINGLE-FAMILY ZONING: RESIDENTIAL

GROUND SNOW LOAD: REFER STRUCTURAL LETTER WIND EXPOSURE: REFER STRUCTURAL LETTER WIND SPEED: REFER STRUCTURAL LETTER

### APPLICABLE CODES & STANDARDS

BUILDING: NCBC 2018, NCRC 2018

ELECTRICAL: NEC 2017 FIRE: NCFC 2018 SHEET TITLE

## **COVER PAGE**

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

G-001

#### 2.1.1 SITE NOTES:

- 2.1.2 A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- 2.1.3 THE PV MODULESARECONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH NO STORAGE BATTERIES.
- 2.1.4 THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING. MECHANICAL. OR BUILDING ROOF VENTS.
- 2.1.5 PROPERACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PERSECTION NEC 110.26.
- 2.1.6 ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.
- 2.2.1 EQUIPMENT LOCATIONS:
- 2.2.2 ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY 2.5.5 EQUIPMENT GROUNDING CONDUCTORS SHALLBE SIZED NEC 110.26.
- 2.2.3 WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED MANUFACTORERS' INSTRUCTIONS. FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 2.5.6 EACH MODULE WILL BE GROUNDED USING WEEB (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C).
- 2.2.4 JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.
- 2.2.5 ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT. 2.2.6 ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.
- 2.2.7 ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

#### 2.3.1 STRUCTURAL NOTES:

- 2.3.2 RACKING SYSTEM & PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES, AND RAILS MUSTALSO EXTEND A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAI MANUFACTURER'S INSTRUCTIONS.
- 2.3.3 JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED & SEALED PER LOCAL REQUIREMENTS.
- 2.3.4 ROOFTOP PENETRATIONS FOR PV RACEWAY WILLBE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.
- 2.3.5 ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.
- 2.3.6 WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.

#### 2.4.1 WIRING & CONDUIT NOTES:

- 2.4.2 ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE, CONDUIT AND WIRE SPECIFICATIONS AREBASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.
- 2.4.3 CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7.
- 2.4.4 VOLTAGE DROP LIMITED TO 1.5%.
- 2.4.5 DC WIRING LIMITED TO MODULE FOOTPRINT. MICROINVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.

2.4.6 AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK PHASE B OR L2- RED, OR OTHER CONVENTION IF THREE PHASE PHASE C OR L3-BLUE, YELLOW, ORANGE\*\*, OR OTHER CONVENTION NEUTRAL-WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH HIGHER VOLTAGE TO BE MARKED ORANGE INEC 110.15].

#### 2.5.1 GROUNDING NOTES:

2.5.2 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVISES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.

2.5.3 PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.

2.5.4 METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURES CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).

ACCORDING TO NEC 690.45 AND MICROINVERTER

GROUNDING CLIPS AS SHOWN IN

MANUFACTURERDOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS.

2.5.7 THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OFA MODULE DOES NOT INTERRUPT A GROUNDING CONDUCTOR TO ANOTHER MODULE. 2.5.8 GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER [NEC 250.119]

2.5.9 THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS INACCESSIBLE, OR INADEQUATE, A GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250, NEC 690,47 AND

2.5.10 GROUND-FAULT DETECTION SHALL COMPLY WITH NEC 690.41(B)(1) AND (2) TO REDUCE FIRE HAZARDS

#### 2.6.1 DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:

2.6.2 DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHENTHE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARECONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS). 2.6.3 DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH 2.6.4 PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS IN ACCORDANCE WITH 690.12(A) THROUGH (D). 2.6.5 ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.

2.6.6 MICROINVERTER BRANCHES CONNECTED TO A SINGLE BREAKER OR GROUPED FUSES IN ACCORDANCE WITH NEC 110.3(B).

2.6.7 IF REQUIRED BY AHJ, SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL1699B.

#### 2.7.1 INTERCONNECTION NOTES:

2.7.2 LOAD-SIDE INTERCONNECTION SHALL BE IN ACCORDANCE WITH [NEC 705.12 (B)] 2.7.3 THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF BUSBAR RATING [NEC 705.12(B)(2)(3)(b)]. 2.7.4 THE SUM OF 125 PERCENT OF THE POWER SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR. PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD [NEC 705.12(B)(2)(3)]. 2.7.5 AT MULTIPLE ELECTRIC POWER SOURCES OUTPUT

COMBINER PANEL, TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED AMPACITY OF BUSBAR. HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED ACCORDING TO NEC 705.12 (B)(2)(3)(C). 2.7.6 FEEDER TAP INTERCONECTION (LOADSIDE) ACCORDING TO NEC 705.12 (B)(2)(1) 2.7.7 SUPPLY SIDE TAP INTERCONNECTION ACCORDING TO NEC 705.12 (A) WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH NEC 230.42 2.7.8BACKFEEDING BREAKER FOR ELECTRIC POWER SOURCES OUTPUT IS EXEMPT FROM ADDITIONAL FASTENING [NEC 705.12 (B)(5)].

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND

SEALED BY SCOTT WYSSLING, PE USING A DIGITAL

SIGNATURE AND DATE. PRINTED COPIES OF THIS

DOCUMENT ARE NOT CONSIDERED SIGNED AND

SEALED AND THE SIGNATURE MUST BE VERIFIED

ON ANY ELECTRONIC COPIES

22171 MCH RD MANDEVILLE, LA 70471 PHONE: 9152011490 **PROJECT NAME & ADDRESS** 

CONTRACTOR

**ORLANDO INMAN** 

**41 WILLIAMSBURG** WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

#### SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308

Date Signed 01-10-22

SHEET TITLE

**NOTES** 

DRAWN DATE 1/7/2022 **DRAWN BY** РТ

SHEET NUMBER

G-002

(28) LG ELECTRONICS LG375N1C-A6 (28) ENPHASE IQ7PLUS-72-2-US

ADDRESS: 41 WILLIAMSBURG WAY CITY ZIP: CAMERON, NC 28326

METER NO: 166426881

TOTAL HOME SQUARE FOOTAGE IS: 2205.06 FT<sup>2</sup> TOTAL ARRAY SQUARE FOOTAGE IS: 546.28 FT<sup>2</sup> % COVERED BY SOLAR IS: 24.77%

DC SIZE 28 X 375W = 10.500 kW DC-STC AC SIZE 28X 290W = 8.120 kW AC

28 LG ELECTRONICS LG375N1C-A6 MODULES WITH -ENPHASE IQ7PLUS-72-2-US MICROINVERTERS UNDER EACH MODULE (240V) (N) VISIBLE LOCKABLE LABELED AND FUSIBLE AC DISCONNECT (UTILITY DISCONNECT) (E) MAIN SERVICE PANEL (ON RACK) DRIVENAY NON HABITABLE GROUP U STRUCTURE 700: WITH ENVOY-IQ METER (E) UTILITY METER (ON RACK) NON HABITABLE GROUP U

**STRUCTURE** 

(N) ENPHASE COMBINER PANEL WITH ENVOY-IQ METER

(E) UTILITY METER (ON RACK)

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

### **LEGEND**



- FIRE SETBACK

- PROPERTY LINE

JB

- JUNCTION BOX

 $\boxtimes$ 

NAVI IOLIT (DOOF ODOTDUOTI

 $\bowtie$ 

- SKYLIGHT (ROOF OBSTRUCTION)

- CHIMNEY (ROOF OBSTRUCTION)

0 [

- VENT, ATTIC FAN (ROOF OBSTRUCTION)

## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308

Date Signed 01-10-22

SHEET TITLE


**SITE PLAN** 

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET NUMBER

A-101





## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

#### SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE

### **ELECTRICAL PLAN**

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

A-102

TOTAL MOUNT COUNT - 91

- CLAMP
- ROOF TECH MINI
- RAIL
- TRAPEZOIDAL METAL SEAM @ 12" O.C.



22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

#### SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308

Date Signed 01-10-22


SHEET TITLE

### ATTACHMENT PLAN

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET NUMBER

A-103



ARRAY 1 TILT- 12 DEG AZIMUTH - 233 DEG

1 ATTACHMENT PLAN


**SCALE:**1/8"=1'-0"

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

### ROOF SECTION(S)

ROOF 1

ROOF MATERIAL -TRAPEZOIDAL METAL SEAM TRUSS SIZE - 2"X2" O.C. SPACING - 24"



1 STRUCTURAL PLAN

**SCALE:**1/2"=1'-0"

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

## CONTRACTOR SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308

Date Signed 01-10-22

SHEET TITLE

### STRUCTURAL PLAN

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

A-104

SOLAR MODULE SPECIFICATIONS		
MANUFACTURER / MODEL #	LG ELECTRONICS LG375N1C-A6	
VMP	35.3V	
IMP	10.63A	
VOC	41.8V	
ISC	11.35A	
TEMP. COEFF. VOC	-0.26%/°C	
MODULE DIMENSION	68.50"L x 41"W x 1.57"D (In Inch)	

INVERTER SPECIFICATIONS		
MANUFACTURER / MODEL #	ENPHASE IQ7PLUS-72-2-US MICROINVERTER	
MIN/MAX DC VOLT RATING	22V MIN/ 60V MAX	
MAX INPUT POWER	235W-440W	
NOMINAL AC VOLTAGE RATING	240V/ 211-264V	
MAX AC CURRENT	1.21A	
MAX MODULES PER STRING	13 (SINGLE PHASE)	
MAX OUTPUT POWER	290 VA	

	WIRE /CONDUIT SCHEDULE		
TAG	DESCRIPTION		
1	#12/2 ROMEX IN ATTIC/ #12 THWN-2 ON EXTERIOR & (1)#6 THWN-2 GROUND / (GN)		
2	#6 THWN-2 & (1)#6 THWN-2 GROUND /(GN)		
3	#6 THWN-2 / (GN)		
4	(1)#6 BARE GROUND		

DC SIZE 28 X 375W = 10.500 kW DC-STC AC SIZE 28X 290W = 8.120 kW AC

ENPHASE IQ7PLUS-72-2-US

EACH PANEL(240V)

MICROINVERTERS ONE UNDER

(GN) GENERAL CONDUIT NOTE:
CONDUIT TO BE UL LISTED FOR WET LOCATIONS AND UV
PROTECTED (EX. -EMT,SCH 80 PVC OR RMC)\*FMC MAYBE
USED IN INDOOR APPLICATIONS WHERE PERMITTED BY
NEC ART .348

TO UTILITY GRID L1 L2 N LG ELECTRONICS LG375N1C-A6 LINE ENPHASE COMBINER PANEL WITH (E) BI-DIRECTIONAL UTILITY METER (ON RACK) ENVOY IQ METER, (3) 20A / 240VAC CIRCUIT BREAKERS, 10 MICROINVERTERS IN BRANCH CIRCUIT 1 M NEMA 3R, UL LISTED,125A RATED 1-PHASE, 3-W, LOAD 120V/240V, 200A AC DISCONNECT: (3) ENPHASE Q CABLES (REVENUE GRADE METER) VISIBLE, LOCKABLE, LABELED 60A FUSED, (2) 60A FUSES, 240V NEMA 3R, UL LISTED SUPPLY SIDE TAP JUNCTION BOX 600 V, NEMA 3 (E) MAIN BREAKER TO LINE HOUSE 240 V, 200A/2P 09 MICROINVERTERS IN BRANCH CIRCUIT 2 (TOP FED) 20A/2P (E) MAIN SERVICE PANEL 200A RATED, 240V (ON RACK) PER MANUFACTURER LINE SIDE SPECIFICATIONS, INTERCONNECTION 20A/2P EITHER 10A OR 15A AT MAIN PANEL BREAKER IS SUITABLE PER ART. 705.12(A) FOR USE LOAD 20A/2P 09 MICROINVERTERS IN BRANCH CIRCUIT 3 BONDED **EXISTING GROUNDING** BONDED ELECTRODE SYSTEM TO EARTH REF. NEC 250.52, 250.53(A)

SHEET TITLE

CONTRACTOR

22171 MCH RD
MANDEVILLE, LA 70471
PHONE: 9152011490
PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

**41 WILLIAMSBURG** 

WAY, CAMERON,

NC 28326

COUNTY:-HARNETT COUNTY

### **LINE DIAGRAM**

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

E-601

AMBIENT TEMPERATURE SPECS	
RECORD LOW TEMP	-10°
AMBIENT TEMP (HIGH TEMP 2%)	36°
CONDUIT HEIGHT	0.5"
CONDUCTOR TEMPERATURE RATE	90°

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS
.80	4-6
.70	7-9
.50	10-20

### **CALCULATIONS:**

- 1. CURRENT CARRYING CONDUCTOR
- (A) <u>BEFORE IQ COMBINER PANEL</u>
  AMBIENT TEMPERATURE (36)°C ...NEC 310.15(B)(3)(c)
  TEMPERATURE DERATE FACTOR 0.91 ...NEC
  310.15(B)(2)(a)
  GROUPING FACTOR 0.8...NEC 310.15(B)(3)(a)

### **CONDUCTOR AMPACITY**

- $= (INV O/P CURRENT) \times 1.25 / A.T.F / G.F ...NEC 690.8(B)$
- $= [(10 \times 1.21) \times 1.25] / [0.91 \times 0.8]$
- = 20.78A

**SELECTED CONDUCTOR - #12 THWN-2 ...NEC 310.15(B)(16)** 

(B) AFTER IQ COMBINER PANEL
TEMPERATURE DERATE FACTOR - 0.91
GROUPING FACTOR - 1

### **CONDUCTOR AMPACITY**

- = (TOTAL INV O/P CURRENT) x 1.25 / 0.91/1 ...NEC 690.8(B)
- $= [(28 \times 1.21) \times 1.25] / [0.91 \times 1]$
- = 46.54 A

**SELECTED CONDUCTOR - #6 THWN-2 ...NEC 310.15(B)(16)** 

2. PV OVER CURRENT PROTECTION ...NEC 690.9(B)

= TOTAL INVERTER O/P CURRENT x 1.25

 $= (28 \times 1.21) \times 1.25 = 42.35 \text{ A}$ 

SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
ELECTRICAL
CALCULATIONS

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET NUMBER

E-602



LABEL 1
ON ALL CONDUITS SPACED AT MAX 10FT

# ! WARNING! ELECTRIC SHOCK HAZARD DO NOT TOUCH TERMINALS. TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL 5
AT EACH AC DISCONNECT

**PHOTOVOLTAIC** 

**AC DISCONNECT** 

AT EACH AC DISCONNECT



THE SERVICE METER IS ALSO SERVED


BY A PHOTOVOLTAIC SYSTEM

! WARNING!

LABEL 10 AT UTILITY METER



LABEL 2 AT INVERTER



LABEL 3 AT INVERTER



! WARNING!

DUAL POWER SOURCES

SECOND SOURCE IS PV SYSTEM


LABEL 7 AT MEP

LABEL 6



## **CAUTION**

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM THE FOLLOWING SOURCES WITH DISCONNECTS LOCATED AS SHOWN:



SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC)
AC SIZE: 8.120 KW AC

SHEET TITLE

**PLACARD** 

DRAWN DATE 1/7/2022
DRAWN BY PT


SHEET NUMBER

E-603

## LG NeON®2

LG370N1C-A6 | LG375N1C-A6

| LG380N1C-A6 Preliminary



370W | 375W | 380W

The LG NeON® 2 is LG's best selling solar module and one of the most powerful and versatile modules on the market today. The cells are designed to appear all-black at a distance, and the performance warranty guarantees 90.6% of labeled power output at 25 years.









#### Features



#### Enhanced Performance Warranty

LG NeON® 2 has an enhanced performance warranty. After 25 years, LG NeON® 2 is guaranteed at least 90.6% of initial performance.



#### 25-Year Limited Product Warranty

The NeON® 2 is covered by a 25-year limited product warranty. In addition, up to \$450 of labor costs will be covered in the rare case that a module needs to be repaired or replaced.



#### Solid Performance on Hot Days

LG NeON® 2 performs well on hot days due to its low temperature coefficient.



#### Roof Aesthetics

LG NeON® 2 has been designed with aesthetics in mind using thinner wires that appear all black at a distance.

#### When you go solar, ask for the brand you can trust: LG Solar

#### About LG Electronics USA, Inc.

LG Electronics is a global leader in electronic products in the clean energy markets by offering solar PV panels and energy storage systems. The company first embarked on a solar energy source research program in 1985, supported by LG Group's vast expenience in the semt-conductor, LCD, chemistry and materials industries. In 2010, LG Solar successfully released its first MonoX<sup>®</sup> series to the market, which is now available in 32 countries. The NeON® (previous MonoX<sup>®</sup> NeON), NeON®2, NeON®2, ReON®2 BiFacial won the "Intersolar AWARD" in 2013, 2015 and 2016, which demonstrates LG's leadership and innovation in the solar industry.





#### General Data

Cell Properties (Material/Type)	Monocrystalline/N-type
Cell Maker	LG
Cell Configuration	60 Cels (6 x 10)
Module Dimensions (L x W x H)	1,740mm x 1,042mm x 40mm
Weight	18.6 kg
Glass (Material)	Tempered Glass with AR Coating
Backsheet (Color)	White
Frame (Material)	Anodized Aluminium
Junction Box (Protection Degree)	IP 68 with 3 Bypass Diodes
Cables (Length)	1,100mm x 2EA
Connector (Type/Maker)	MC 4/MC

LG370N1C-A6 | LG375N1C-A6 | LG380N1C-A6

#### Certifications and Warranty

Certifications**	IEC 61215-1/-1-1/2 : 2016, IEC 61730-1/2 : 2016 UL 61730-1 : 2017, UL 61730-2 : 2017
	ISO 9001, ISO 14001, ISO 50001
	OHSAS 18001
Salt Mist Corrosion Test	IEC 61701:2012 Severity 6
Ammonia Corrosion Test	IEC 62716 : 2013
Module Fire Performance	Type 1 (UL 61730)
Fire Rating	Class C (UL 790, ULC/ORD C 1703)
Solar Module Product Warranty	25 Year Limited
Solar Module Output Warranty	Linear Warranty*

<sup>\*</sup>Improved: 1\* year 98.5%, from 2-24th year: 0.33%/year down, 90.6% at year 25
\*\*In Progress


#### Temperature Characteristics

NMOT*	[°C]	42 ± 3	
Pmax	[%/°C]	-0.34	
Voc	[%/°C]	-0.26	
lsc	[%/°C]	0.03	

\*NMOT (Nominal Module Operating Temperature): Irradiance 800 W/m², Ambient temperature 20°C,

Model		LG370N1C-A6	LG375N1C-A6	LG380N1C-A6
Maximum Power (Pmax)	[W]	277	281	285
MPP Voltage (Vmpp)	[V]	32.8	33.2	33.5
MPP Current (Impp)	[A]	8.46	8.48	8.49
Open Circuit Voltage (Voc)	[V]	39.3	39,4	39,4
Short Circuit Current (Isc)	[A]	9.09	9.13	9.16

#### I-V Curves



LG370-380N1C-A6 AUS.pdf

© 2020 LG Electronics USA, Inc. All rights reserved.

### LG NeON<sup>®</sup>2



#### Preliminary

Model		LG370N1C-A6	LG375N1C-A6	LG380N1C-A6
Maximum Power (Pmax)	[W]	370	375	380
MPP Voltage (Vmpp)	[V]	34.9	35.3	35.7
MPP Current (Impp)	[A]	10.61	10.63	10.65
Open Circuit Voltage (Voc, ± 5%)	[V]	41.7	41.8	41.9
Short Circuit Current (Isc, ± 5%)	[A]	11.31	11.35	11.39
Module Efficiency	[%]	20.4	20.7	21.0
Bifaciality Coefficient of Power	[%]		10	
Power Tolerance	1961		0-+3	

\*STC (Standard Test Condition): Irradiance 1000 W/m2 cell temperature 25°C AM 1.5

#### Operating Conditions

Electrical Properties (STC\*)


Operating Temperature	[°C]	-40 ~+85	
Maximum System Voltage	[V]	1,000	
Maximum Series Fuse Rating	[A]	20	
Mechanical Test Load" (Front)	[Pa/psf]	5,400	
Mechanical Test Load' (Rear)	[Pa/psf]	4,000	

\*Based on IEC 61215-2: 2016 (Test Load – Design Load x Safety Factor (1.5)) Mechanical Test Loads 6,000Pa / 5,400Pa based on IEC 61215: 2005

#### Packaging Configuration

Number of Modules per Pallet	[EA]	25	
Number of Modules per 40' Container	[EA]	650	
Number of Modules per 53' Container	[EA]	850	
Packaging Box Dimensions (L x W x H)	[mm]	1,790 x 1,120 x 1,213	
Packaging Box Dimensions (Lx Wx H)	[in]	70.5 x 44.1 x 47.8	
Packaging Box Gross Weight	[kg]	500	
Packaging Box Gross Weight	[16]	1,102	

#### Dimensions (mm/inch)



CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**41 WILLIAMSBURG** 

WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

**ORLANDO INMAN** 

### SHEET TITLE **RESOURCE DOCUMENT**

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

Data Sheet Enphase Microinverters Region: AMERICAS

## **Enphase** IQ 7 and IQ 7+ Microinverters

The high-powered smart grid-ready Enphase IQ 7 Micro™ and Enphase IQ 7+ Micro™ dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy™, Enphase IQ Battery™, and the Enphase Enlighten™ monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.



- · Lightweight and simple
- · Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

#### Productive and Reliable

- · Optimized for high powered 60-cell and 72-cell\* modules
- · More than a million hours of testing
- · Class II double-insulated enclosure
- UL listed

#### Smart Grid Ready

- · Complies with advanced grid support, voltage and frequency ride-through requirements
- · Remotely updates to respond to changing
- · Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)
- \* The IQ 7+ Micro is required to support 72-cell modules.





#### Enphase IQ 7 and IQ 7+ Microinverters

로마마 14명 이 경기의 P. C.		-			
INPUT DATA (DC)	1Q7-60-2-US		IQ7PLUS-72-2	-US	
Commonly used module pairings!	235 W - 350 W +		235 W - 440 W +		
Module compatibility	60-cell PV mod	ules only	60-cell and 72-cell PV modules		
Maximum input DC voltage	48 V		60 V		
Peak power tracking voltage	27 V - 37 V		27 V - 45 V		
Operating range	16 V - 48 V		16 V - 60 V		
Min/Max start voltage	22 V / 48 V		22 V / 60 V		
Max DC short circuit current (module Isc)	15 A		15 A		
Overvoltage class DC port	11		11		
DC port backfeed current	0 A		0 A		
PV array configuration	1 x 1 ungrounded array; No addition AC side protection requires max 20				
OUTPUT DATA (AC)	IQ 7 Microinverter		IQ 7+ Microin	verter	
Peak output power	250 VA	250 VA			
Maximum continuous output power	240 VA		290 VA		
Nominal (L-L) voltage/range <sup>2</sup>	240 V / 211-264 V	208 V / 183-229 V	240 V / 211-264 V	208 V / 183-229 V	
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V)	1.39 A (208 V)	
Nominal frequency	60 Hz		60 Hz		
Extended frequency range	47 - 68 Hz		47 - 68 Hz		
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms		
Maximum units per 20 A (L-L) branch circuit*	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)	11 (208 VAC)	
Overvoltage class AC port	III		111		
AC port backfeed current	0 A		0 A		
Power factor setting	1.0		1.0		
Power factor (adjustable)	0.85 leading 0.85 lagging		0.85 leading	0.85 lagging	
EFFICIENCY	@240 V	@208 V	@240 V	@208 V	
Peak efficiency	97,6 %	97.6 %	97.5 %	97.3 %	
CEC weighted efficiency	97.0 %	97.0 %	97.0 %	97.0 %	
MECHANICAL DATA					
Ambient temperature range	-40°C to +65°C	_			
Relative humidity range	4% to 100% (cor	4% to 100% (condensing)			

MECHANICAL DATA		
Ambient temperature range	-40°C to +65°C	
Relative humidity range	4% to 100% (condensing)	
Connector type (IQ7-60-2-US & IQ7PLUS-72-2-US)	MC4 (or Amphenol H4 UTX with additional Q-DCC-5 adapter)	
Dimensions (WxHxD)	212 mm x 175 mm x 30.2 mm (without bracket)	
Weight	1.08 kg (2.38 lbs)	
Cooling	Natural convection - No fans	
Approved for wet locations	Yes	
Pollution degree	PD3	
Enclosure	Class II double-insulated, corrosion resistant polymeric enclosure	
Environmental category / UV exposure rating	NEMA Type 6 / outdoor	

Communication	Power Line Communication (PLC)
Monitoring	Enlighten Manager and MyEnlighten monitoring options, Both options require installation of an Enphase IQ Envoy.
Disconnecting means	The AC and DC connectors have been evaluated and approved by UL for use as the load-break disconnect required by NEC 690.
Compliance	CA Rule 21 (UL 1741-SA)  UL 62109-1, UL1741/IEEE1547, FCC Part 15 Class B, ICES-0003 Class B,  CAN/CSA-C22.2 NO. 107.1-01  This product is UL listed as PV Rapid Shut Down Equipment and conforms with NEC-2014 and

NEC-2017 section 690.12 and C22.1-2015 Rule 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according manufacturer's instructions.

1. No enforced DC/A/C ratio. See the compatibility calculator at https://enphase.com/en-us/support/module-compatibility.

FEATURES

Nominal voltage range can be extended beyond nominal if required by the utility.
 Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

#### To learn more about Enphase offerings, visit enphase.com

© 2019 Enphase Energy. All rights reserved. All trademarks or brands used are the property of Enphase Energy, Inc.



## CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

**41 WILLIAMSBURG** WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

> SHEET TITLE **RESOURCE DOCUMENT**

DRAWN DATE 1/7/2022 **DRAWN BY** 

SHEET NUMBER

R-002





To learn more about Enphase offerings, visit enphase.com

Data Sheet Enphase Networking

## **Enphase** IQ Combiner 3

(X-IQ-AM1-240-3)

The Enphase IQ Combiner 3™ with Enphase IQ Envoy™ consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.



#### Smart

- · Includes IQ Envoy for communication and control
- · Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- · Provides production metering and optional consumption
- Supports Ensemble Communications Kit for communication with Enphase Encharge" storage and Enphase Enpower™ smart switch

#### Simple

- · Reduced size from previous combiner
- · Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- . Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- · 80 A total PV or storage branch circuits

#### Reliable

- . Durable NRTL-certified NEMA type 3R enclosure
- · Five-year limited warranty
- UL listed



MODEL NUMBER	
IQ Combiner 3 X-IQ-AM1-240-3	IQ Combiner 3 with Enphase IQ Envoy" printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and optional* consumption monitoring (+/- 2.5%).
ACCESSORIES and REPLACEMENT PARTS (no	t included, order separately).
Enphase Mobile Connect*  CELLMODEM-03 (4G/12-year data plan) CELLMODEM-01 (3G/5-year data plan) CELLMODEM-M1 (4G based LTE-M/5-year data plan) Consumption Monitoring* CT CT-200-SPLIT  *Consumption monitoring is required for Enghase Storage Systems	Plug and play industrial grade cellular modern with data plan for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area.)  Split core current transformers enable whole home consumption metering (+/- 2.5%).
Ensemble Communications Kit COMMS-KIT-01	Installed at the IQ Envoy. For communications with Enphase Encharge" storage and Enphase Enpower" smart switch. Includes USB cable for connection to IQ Envoy or Enphase IQ Combiner" and allows wireless communication with Encharge and Enpower.

BRK-20A-2P-240	Circuit breaker, 2 pole, 20A, Eaton BR220		
EPLC-01	Power line-carrier (communication bridge pair), quantity - one pair		
XA-SOLARSHIELD-ES	Replace the default solar shield with this Ensemble Combiner Solar Shield to match the look and feel of the Enphase Enpower" smart switch and the Enphase Encharge" storage system		
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 3 (required for EPLC-01)		
XA-ENV-PCBA-3	Replacement IQ Envoy printed circuit board (PCB) for Combiner 3		
ELECTRICAL SPECIFICATIONS			
Rating	Continuous duty		
System voltage 120/240 VAC, 60 Hz			

125 A

Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole 15A Faton 8R215

Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers.

Max. continuous current rating (output to gnd)	65 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. continuous current rating (input from PV)	64A
Max. total branch circuit breaker rating (in put)	80 A of distributed generation / 95 A with IQ Envoy breaker included
Envoy breaker	10A or 15A rating GE Q-line/Siemens Type QP /Eaton BR series included
Production Metering CT	200 A solid core pre-installed and wired to IQ Envoy
MECHANICAL DATA	
Dimensions (WxHxD)	49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). Height is 21.06" (53.5 cm with mounting brackets)
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors     60 A breaker branch input: 4 to 1/0 AWG copper conductors     Main lug combined output: 10 to 2/0 AWG copper conductors     Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing.
Altitude	To 2000 meters (6,560 feet)

#### INTERNET CONNECTION OPTIONS Integrated Wi-Fi Ethernet Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included)

CELLMODEM-M1 4G based LTE-M cellular modern (not included). Note that an Enphase Mobile Connect cellular modern is required for all Ensemble installations. Cellular

UL 60601-1/CANCSA 22.2 No. 61010-1

#### COMPLIANCE Compliance, Combiner UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Part 15, Class B, ICES 003 Production metering: ANSI C12.20 accuracy class 0.5 (PV production)

#### To learn more about Enphase offerings, visit enphase.com

Circuit Breakers

BRK-10A-2-240 BRK-15A-2-240

Eaton BR series busbar rating

Compliance, IQ Envoy

May continuous current rating (output to grid)

© 2021 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 3, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2021-05-20.



## CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

**41 WILLIAMSBURG** WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

> SHEET TITLE **RESOURCE DOCUMENT**

DRAWN DATE 1/7/2022 **DRAWN BY** 


SHEET NUMBER


R-003





To learn more about Enphase offerings, visit enphase.com





## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE


DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE RESOURCE

**DOCUMENT** 

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET NUMBER



## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY


#### SYSTEM SIZE


DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET NUMBER





BAR

REVISION DATE:

9/27/2017

ALBUQUERQUE, NM 87102 USA | DESCRIPTION:

PHONE: 505.242.6411

WWW.UNIRAC.COM

PRODUCT PROTECTED BY

ONE OR MORE US PATENTS

LEGAL NOTICE

SHEET

## CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

**41 WILLIAMSBURG** WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 


SYSTEM SIZE


DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

> SHEET TITLE **RESOURCE DOCUMENT**

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER





1411 BROADWAY BLVD. NE

ALBUQUERQUE, NM 87102 USA

PHONE: 505,242,6411 WWW.UNIRAC.COM PRODUCT LINE: SOLARMOUNT
DRAWING TYPE: PART DETAIL
DESCRIPTION: STANDARD RAIL
REVISION DATE: 9/11/2017

DRAWING NOT TO SCALE
ALL DIMENSIONS ARE
NOMINAL
PRODUCT PROTECTED BY
ONE OR MORE US PATENTS
LEGAL NOTICE
SHEET

# CONTRACTOR SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY


SYSTEM SIZE


DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

SHEET TITLE
RESOURCE
DOCUMENT

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER







1411 BROADWAY BLVD. NE ALBUQUERQUE, NM 87102 USA PHONE: 505.242.6411 WWW.UNIRAC.COM

PRODUCT LINE: SOLARMOUNT

DRAWING TYPE: PART DETAIL

DESCRIPTION: END CLAMPS - TOP MOUNTING

REVISION DATE: 9/27/2017

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY
ONE OR MORE US PATENTS
LEGAL NOTICE

SHEET

RESOURCE DOCUMENT

DRAWN DATE 1/7/2022
DRAWN BY PT

SHEET TITLE

CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

**PROJECT NAME & ADDRESS** 

**41 WILLIAMSBURG** 

WAY, CAMERON,

NC 28326

**COUNTY:-HARNETT COUNTY** 


SYSTEM SIZE


DC SIZE: 10.500 KW DC-(STC)

AC SIZE: 8.120 KW AC

**ORLANDO INMAN** 

SHEET NUMBER





## SUNPR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

41 WILLIAMSBURG WAY,CAMERON, NC 28326

COUNTY:-HARNETT COUNTY

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

## SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE	1/7/2022
DRAWN BY	PT

SHEET NUMBER

## RT-MINI

Self-flashing base for asphalt & metal roof-top PV mounting systems

RT-MINI is suitable for mounting any rail system with a conventional L-Foot.



Dual bolt design: M8 or 5/16" for L-Foot & 1/4" for EMC



Installation Manual





**ICC ESR 3575** 

Easy tapping

screw guide

Flat lip for

PV Cable

# RT-MINI

Flexible Flashing certified by the International Code Council (ICC)

Engineered to ASTM D 1761 (Standard Test Methods for Mechanical Fasteners in Wood)

### Components

RT2-00-MINIBK





Extra RT-Butyl: 10 ea.

5 x 60mm Mounting screw (RT2-04-SD5-60): 100 ea./Bag 5/16" Hex bolt, washer & nut set (RT-04-BN30SL-US): 100 ea./Bag RT-Butyl (RT2-04-BUTYLT): 10 ea./Box

RT-Butyl is Roof Tech's flexible flashing used in one million residential PV systems for the last 26 years. It is the first PV mounting system with Flexible Flashing certified by the ICC. Engineered to withstand wind speeds up to 180 mph and ground snow up to 90 psf.

#### Metal Flashing Retrofit Flexible Flashing







ICC ESR-3575 ASTM2140 testing UV testing (7500 hrs.)



1/4" Hex Bolt

upper channel


M8 or 5/16"

bottom channel

Hex Bolt




### Dimensions in (mm)




3 1/2 (90) 2 (50)

### Rafter installation



#### Deck installation



P.E. Stamped Letters available at www.roof-tech.us/support TAS 100 A on metal and asphalt roof.

Roof Tech Inc. www.roof-tech.us info@roof-tech.us 10620 Treena Street, Suite 230, San Diego, CA 92131 858.935.6064

March 2020

# CONTRACTOR

22171 MCH RD MANDEVILLE, LA 70471

PHONE: 9152011490

PROJECT NAME & ADDRESS

**ORLANDO INMAN** 

**41 WILLIAMSBURG** WAY, CAMERON, NC 28326

**COUNTY:-HARNETT COUNTY** 

SYSTEM SIZE

DC SIZE: 10.500 KW DC-(STC) AC SIZE: 8.120 KW AC

> SHEET TITLE **RESOURCE DOCUMENT**

DRAWN DATE 1/7/2022 **DRAWN BY** 

SHEET NUMBER