



May 4, 2022

Re: Samantha and James Grimes  
213 McLamb Road  
Coats, NC 27521

EMPWR Solar has made a site visit to observe and inspect the solar panel installation on May 3, 2022 at the above noted site address. A Professional Engineer from EMPWR Solar provided a structural letter dated March 30, 2022, providing installation requirements to meet the design loading requirements in accordance with the 2018 North Carolina Residential Code.

The solar (PV) system equipment structural installation meets the required design and installation requirements. The loads imposed (dead, snow, wind) from the new equipment will not have a negative impact on the building's structural integrity and design. The installation and loading comply with the 2018 North Carolina Residential Code.

Sincerely,

Peter J. Hazel, PE

