

September 13, 2022

Brooklyn Moose
2101 Westinghouse Blvd
Suite 107
Raleigh, NC 27604

RE: Existing Tank Application #ERES2208-0064

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal on lid. (\$25.00 fee incurred)**
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting