

2/13/2023

PURE ENERGY GROUP, LLC 3661 SUNSET AVE #617 ROCKY MOUNT, NC 27804

Subject: Post Installation Approval Letter

Job Code: Gill, Kathryn and Joseph Address: 325 Silver Maple Dr, Fuquay Varina, NC 27526

Attn: To Whom It May Concern

The purpose of the review was to verify the installation is in conformance with what was specified in the published plan set and that any potential modifications from those plans are adequate under the existing structural calculations.

After reviewing the installation, the footings and flashings of the PV panels were installed in conformance with the above plan set and specifications for this project. The installations comply with the provisions listed below. Design Criteria:

- 2018 NORTH CAROLINA BUILDING CODE (ASCE 7-10)
- Basic Wind Speed Vult = 115 mph
- Ground Snow Load = 15 psf

After reviewing the installation, I certify that:

- i. The PV equipment's structural installation has been designed and inspected,
- ii. The equipment will not create a negative impact on the bulking's structural design, including any additional loads imposed (dead, snow, wind), and
- iii. The installation is in compliance with the North Carolina Residential Code.

If you have any further questions, please do not hesitate to call.

Sincerely, Arash Zandieh, Ph.D., P.E. a.zandieh@ahzengineers.com | 901-692-0431 AHZ Consulting Engineers, Inc

