



Scott E. Wyssling, PE  
Coleman D. Larsen, SE, PE  
Gregory T. Elvestad, PE

76 North Meadowbrook Drive  
Alpine, UT 84004  
office (201) 874-3483  
swyssling@wysslingconsulting.com

March 14, 2023

Legacy Solar  
3333 Digital Drive #600  
Lehi, UT 84043

Re: Engineering Services (Post Installation)  
Calvacamp Residence  
1005 Clarendon Street, Durham NC

To Whom It May Concern:

Pursuant to your request, a representative from this office, under my supervision, has inspected the installation of the above-referenced solar panel system. As you are aware, this office initially prepared a structural assessment, dated July 27, 2022, of the solar panel installation. This installation was inspected and found to be in compliance with the North Carolina Residential Code, the layout plan as specified in our report, and the product installation criteria. We have determined that the equipment will not create a negative impact on the building's structural design, including any additional loads imposed (dead, snow, wind).

This letter pertains only to the panel support attachments to the roof framing and not the engineered photovoltaic panel products, components, or electrical-related installations/connections.

Should you have any questions regarding the above or if you require additional information do not hesitate to contact me.

Very truly yours,

Scott E. Wyssling, PE  
North Carolina License No. 46546  
North Carolina COA# P-2308



Wyssling Consulting, PLLC  
76 N Meadowbrook Drive  
Alpine UT 84004 COA # P-2308

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES