



Harnett County
420 Mckinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

3/1/2023

SUBJECT: ERES2302-0038
ELECTRICAL RESIDENTIAL

To: FOUR HORSEMEN LLC

Here are the results of all Inspections located at **1335 GREGORY CIR:**

Inspection Type: FINAL**
Scheduled Date/Time: 2/22/2023
Completed Date/Time: 2/22/2023
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes:

Inspector DT changed the inspection assignment from DT to TSG
1/ service from home to building covered could not inspect. 2/ seal conduit from panel to inside of structure. 3/ exterior lighting required at man door. Note: 210.70.A.2 .2 Additional lighting outlets shall be installed in accordance with the following: For dwelling units, attached garages, and detached garages with electric power, at least one wall switch-controlled lighting outlet shall be installed to provide illumination on the exterior side of outdoor entrances or exits with grade-level access. A vehicle door in a garage shall not be considered as an outdoor entrance or exit.

Inspection Type: FINAL**
Scheduled Date/Time: 2/28/2023
Completed Date/Time: 2/28/2023
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

