GENERAL NOTES

CODE AND STANDARDS

1. ALL WORK SHALL COMPLY WITH 2017 NATIONAL ELECTRIC CODE (NEC), 2018 NORTH CAROLINA BUILDING CODE (NCBC), 2018 NORTH CAROLINA RESIDENTIAL CODE (NCRC), PLUMBING CODE (NCPC), AND ALL STATE AND LOCAL BUILDING, ELECTRICAL, AND PLUMBING CODES.

2. DRAWINGS HAVE BEEN DETAILED ACCORDING TO UL LISTING REQUIREMENTS.

SITE NOTES / OSHA REGULATION

1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS

2. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM.

3. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS. 4. ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND

THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SHALL SERVE TO PROTECT THE BUILDING OR STRUCTURE.

SOLAR CONTRACTOR

1. MODULE CERTIFICATIONS WILL INCLUDE UL1703, IEC61646, IEC61730.

2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER

3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ.

4. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS.

5. CONDUIT POINT OF PENETRATION FROM EXTERIOR TO INTERIOR TO BE INSTALLED AND SEALED WITH A SUITABLE SEALING COMPOUND

6. DC WIRING LIMITED TO MODULE FOOTPRINT W/ ENPHASE AC SYSTEM.

8. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT

9 ALL INVERTERS MOTOR GENERATORS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AC PHOTOVOLTAIC MODULES, DC COMBINERS, DC-TO-DC CONVERTERS, SOURCE CIRCUIT COMBINERS, AND CHARGE CONTROLLERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER NEC 690.4(B)

10. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

11. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.

EQUIPMENT LOCATIONS

1. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.

2. EQUIPMENT INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690 31(A) AND NEC TABLE 310 15(B)

3. ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES

4. ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

PROJECT INFORMATION:

NUMBER OF STORIES: 2 CONDUIT RUN: Interior ECOBEE QTY: 1

LIGHT BULB QTY: 0 **PV METER:** Not Required

ROOF TYPE (1) INFORMATION:

ROOF TYPE: Comp Shingle

FRAMING TYPE: Manufactured Truss

SHEATHING TYPE: OSB

ATTACHMENT: SFM Infinity Flashkit

RACKING: Unirac SFM Infinity @ 48" OC Portrait / 72" OC Landscape

NUMBER OF ATTACHMENTS: 34

ROOF TYPE (2) INFORMATION (IF APPLICABLE):

*SEE PV4.2

SYSTEM TO BE INSTALLED INFORMATION:

DC SYSTEM SIZE: 8.505 kW DC AC SYSTEM SIZE: 6.09 kW AC

MODULE TYPE: (21) Seraphim SEG-405-BMD-TB INVERTER TYPE: Enphase IQ8PLUS-72-2-US MONITORING: Enphase IQ Combiner 4 X-IQ-AM1-240-4 **AERIAL VIEW**



WIND SPEED: 118 mph GROUND SNOW LOAD: 15 lb/ft2 **WIND EXPOSURE FACTOR: C**

SEISMIC DESIGN CATEGORY: B

CONSTRUCTION - V-B ZONING: RESIDENTIAL

SCOPE OF WORK

INSTALLATION OF UTILITY INTERACTIVE PHOTOVOLTAIC SOLAR SYSTEM AND ANY NECESSARY ADDITIONAL WORK NEEDED FOR INSTALLATION.

PV1 - COVER SHEET PV2 - SITE PLAN

PV3 - ROOF PLAN **PV4** - STRUCTURAL

PV5 - ELECTRICAL 3-LINE DIAGRAM

PV6 - ELECTRICAL CALCULATIONS

PV7 - WARNING LABELS AND LOCATIONS
(ALL OTHER SHEETS AS REQUIRED) Digitally signed by SS - PRODUCT SPEC. SHEETS

John A. Calvert

Date: 2023.03.10

Firm No.: D-0449

3/10/2023

UTILITY COMPANY:

South River Electric Coop 13:53:24 -07'00'

PERMIT ISSUER:

Harnett County

800.377.4480 WWW.BLUERAVENSOLAR.COM CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE

EXCEPT BLUE RAVEN SOLAR NOR

1403 N. Research Way

Orem, UT 84097

SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 800-377-4480

6.09 kW AC 8.505 kW DC Carolina 28390

CUSTOMER INFORMATION: Lake North SIZI Spring 48

DRAWING BY:

PremiumCAD

March 10, 2023

PROJECT NUMBER:

725142


SHEET NAME:

COVER SHEET

REVISION:

0

PV1



PV SYSTEM SPECIFICATIONS

TOTAL NUMBER OF MODULES: 21

MODULE MAKE AND MODEL: Seraphim SEG-405-BMD-TB

MODULE WATTAGE: 405W DC

INVERTER MAKE AND MODEL: Enphase IQ8PLUS-72-2-US **INVERTER TYPE:** Microinverter (1 Inverter per PV Module)

INVERTER CURRENT OUTPUT: 1.21A AC INVERTER NOMINAL VOLTAGE: 240V **INVERTER WATTAGE: 290W AC**

FRONT OF HOME

AC

AC

DÇ AC

DÇ AC

DC/ AC


DC/ AC

DÇ AC

DS/ Ad

DO AC

DS/ Ad



TSRF: 100%

AREA: 1061 ft.2

LEGEND

JUNCTION BOX

UTILITY METER

MSP MAIN SERVICE PANEL

AC AC DISCONNECT

СВ **COMBINER BOX**

LOAD CENTER

SUB SUBPANEL

LC

PV **PV METER**

TS TRANSFER SWITCH

ESS SUNPOWER ESS

HUB SUNPOWER HUB+

RPO REMOTE POWER OFF

FIRE SETBACK

TRENCHING

PROPERTY LINE

SCALE: 1/8" = 1'-0"



Firm No. : D-0449 3/10/2023



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION



OF BLUE RAVEN SOLAR LLC.

PV INSTALLATION **PROFESSIONAL** Scott Gurney

#PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 800-377-4480

: 6.09 kW AC : 8.505 kW DC SIZE: SYSTEM SYSTEM S

CUSTOMER INFORMATION:
William Copes
18 Kirby Smith Cir
Spring Lake North Carolina 28390

DRAWING BY:

PremiumCAD

PLOT DATE:

March 10, 2023

PROJECT NUMBER:

725142

SHEET NAME:

ROOF PLAN

REVISION:

0

PV3

STRUCTURAL INFORMATION: ROOF TYPE (1):

ROOF TYPE: Comp Shingle SHEATHING TYPE: OSB

FRAMING TYPE: Manufactured Truss FRAMING SIZE: 2x4 @ 24" OC CEILING JOIST SIZE: 2x4 @ 24" OC

ATTACHMENT: SFM Infinity Flashkit **RACKING:** Unirac SFM Infinity

@ 48" OC Portrait / 72" OC Landscape

NUMBER OF ATTACHMENTS: 34

PV MODULE COUNT: 21 Modules

TOTAL ARRAY AREA: 428.4 ft² (20.4ft²/panel)

UNIRAC SFM INFINITY

(1) 5/16" STAINLESS STEEL LAG BOLT

WITH 2-1/2" MIN. EMBEDMENT

AND FLAT WASHER

MIDDLE/TOP STANDOFF DETAIL

SERAPHIM SEG-405-BMD-TB

PV MODULE

FLASHING -

TOTAL ROOF AREA: 2428 ft² ARRAY/ROOF AREA: 17.6%

ARRAY WEIGHT: 1,050 lbs (50 lbs/panel)
DISTRIBUTED LOAD: 2.45 lbs/ft²
POINT LOAD: 30.88 lbs/attachment


STRUCTURAL NOTES:

None


*NOTE: LISTED NUMBER OF ATTACHMENT POINTS ARE AN ESTIMATE ONLY AND MAY VARY BASED ON FIELD CONDITIONS. MAXIMUM ATTACHMENT SPACING TO BE FOLLOWED PER ENGINEER OF RECORD SPECIFICATIONS.


2½" MIN. EMBED.

(E) BUILDING STRUCTURE



UNIRAC SFM MICRORAIL/ SPLICE UNIRAC SFM SLIDER (E) ROOF SHEATHING





Sealed For Existing Roof & Attachment Only



Firm No. D-0449

3/10/2023



1403 N. Research Way Orem, UT 84097

800.377.4480
WWW.BLUERAVENSOLAR.COM
CONFIDENTIAL- THE INFORMATION

HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 800-377-4480

es ith Cir North Carolina 28390 A SIZE: 6.09 kW AC

William Copes
18 Kirby Smith Cir
Spring Lake North
AC SYSTEM SIZE
DC SYSTEM SIZE

DRAWING BY:

CUSTOMER INFORMATION:

PremiumCAD

PLOT DATE:

March 10, 2023

PROJECT NUMBER:

725142

SHEET NAME:

STRUCTURAL

REVISION:

0

PV4

(1) 12-2 TC-ER, THHN/THWN-2, CU. 6 AWG BARE, CU (EGC)

240 V A

EXTERIOR

1403 N. Research Way Orem, UT 84097

WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION

OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL** Scott Gurney

#PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 800-377-4480

3.09 kW AC 3.505 kW DC Carolina 28390

Lake North Kirby Spring SY SY

PremiumCAD

8

March 10, 2023

PROJECT NUMBER:

725142

ELECTRICAL


REVISION:

UTILITY COMPANY: South River Electric Coop PERMIT ISSUER: Harnett County

DESIGNER NOTES:

3/4 INCH EMT

INTERCONNECT USING A LOAD SIDE BREAKER IN MSP, INTERIOR POI





INTERCONNECTION NOTES 705.12(B)(3) THE FOLLOWING METHOD(S) SHALL BE USED TO DETERMINE THE RATINGS OF BUSBARS: (2) WHERE TWO SOURCES, ONE A PRIMARY POWER SOURCE AND THE OTHER ANOTHER POWER

(E) GROUNDING

ELECTRODE(S)

IF REQUIRED, VERIFICATION WILL BE DONE TO

ENSURE THE GROUNDING ELECTRODE SYSTEM IS

250 PART III) IF NOT, A NEW GROUND ROD WILL BE

CONGRUENT WITH CURRENT REQUIREMENTS. (NEC

(N) %" COPPER GROUND ROD,

8' LONG, MIN. 6' FROM (E) **GROUNDING CONDUCTOR**

GEC INSTALLED PER NEC

250.64: 6 OR 4 AWG SOLID

3/4 INCH EMT

GRID

SOURCE, ARE LOCATED AT OPPOSITE ENDS OF A BUSBAR THAT CONTAINS LOADS, THE SUM OF 125 PERCENT OF THE POWER-SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUS BAR SHALL NOT

EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR.

(21) Seraphim SEG-405-BMD-TB
UL 1703 COMPLIANT

ELECTRICAL NOTES:

CUSTOMER INFORMATION: Θ. Θ. SIZI STEM STEM

DRAWING BY:

PV5

MODULE SPECIFICATIONS	Seraphim SEG-405-BMD-TB
RATED POWER (STC)	405 W
MODULE VOC	37.22 V DC
MODULE VMP	30.93 V DC
MODULE IMP	13.1 A DC
MODULE ISC	13.7 A DC
VOC CORRECTION	-0.26 %/°C
VMP CORRECTION	-0.34 %/°C
SERIES FUSE RATING	25 A DC
ADJ. MODULE VOC @ ASHRAE LOW TEMP	40.6 V DC
ADJ. MODULE VMP @ ASHRAE 2% AVG. HIGH TEN	1P 26.2 V DC

MICROINVERTER SPECIFICATIONS	Enphase	IQ8+Mid	roinverte
POWER POINT TRACKING (MPPT) MIN/MAX	30 -	58	V DC
MAXIMUM INPUT VOLTAGE			60 V DC
MAXIMUM DC SHORT CIRCUIT CURRENT			15 A DC
MAXIMUM USABLE DC INPUT POWER		4	40 W
MAXIMUM OUTPUT CURRENT		1.	21 A AC
AC OVERCURRENT PROTECTION			20 A
MAXIMUM OUTPUT POWER		2	90 W
CEC WEIGHTED EFFICIENCY		8	97 %

AC PHOTOVOLATIC MODULE MARKING (1	NEC 690.52)
-----------------------------------	-------------

NOMINAL OPERATING AC VOLTAGE	240 V AC
NOMINAL OPERATING AC FREQUENCY	47 - 68 HZ AC
MAXIMUM AC POWER	240 VA AC
MAXIMUM AC CURRENT	1.0 A AC
MAXIMUM OCPD RATING FOR AC MODULE	20 A AC

DESIGN LOCATION AND TEMPERATURES	
TEMPERATURE DATA SOURCE	ASHRAE 2% AVG. HIGH TEMP
STATE	North Carolina
CITY	Spring Lake
WEATHER STATION	SEYMOUR-JOHNSON AFB
ASHRAE EXTREME LOW TEMP (°C)	-10
ASHRAE 2% AVG. HIGH TEMP (°C)	38

SYSTEM ELECTRICAL SPECIFICATIONS	CIR 1	CIR 2	CIR 3	CIR 4	CIR 5	CIR 6
NUMBER OF MODULES PER MPPT	11	10				
DC POWER RATING PER CIRCUIT (STC)	4455	4050				,
TOTAL MODULE NUMBER	21					
STC RATING OF ARRAY	8505					
AC CURRENT @ MAX POWER POINT (IMP)	13.3 12.1					
MAX. CURRENT (IMP X 1.25)	16.6375	15.125				
OCPD CURRENT RATING PER CIRCUIT	20	20				
MAX. COMB. ARRAY AC CURRENT (IMP)	25.4					
MAX. ARRAY AC POWER	6090W AC					

AC VOLTAGE RISE CALCULATIONS	DIST (FT)	COND.	/RISE(V)	VEND(V)	%VRISE
VRISE SEC. 1 (MICRO TO JBOX)	39.6	12 Cu.	1.76	241.76	0.73%
VRISE SEC. 2 (JBOX TO COMBINER BOX)	50	10 Cu.	1.69	241.69	0.70%
VRISE SEC. 3 (COMBINER BOX TO POI)	5	8 Cu.	0.20	240.20	0.08%
TOTAL VRISE	11111		3.65	243.65	1.52%

PHOTOVOLTAIC AC DISCONNECT OUTPUT LABEL (NEC 690.54)		
AC OUTPUT CURRENT	25.4 A AC	
NOMINAL AC VOLTAGE	240 V AC	

MICROINVERTER TO	MAX. SHORT CIRCUIT CURRRENT (ISC) =	13.3	AAC	
JUNCTION BOX (1)	MAX. CURRENT (ISC X1.25) =			
JONE HOW BOX (1)	CONDUCTOR (TC-ER, COPPER (90°C)) =			
	CONDUCTOR RATING =			
	AMB. TEMP. AMP. CORRECTION =			
	ADJUSTED AMP. =		>	16.6
JUNCTION BOX TO	MAX. SHORT CIRCUIT CURRENT (ISC) =		-	20.0
JUNCTION BOX (2)	MAX. CURRENT (ISC X1.25) =			
	CONDUCTOR (UF-B, COPPER (60°C)) =			
	CONDUCTOR RATING =			
	CONDUIT FILL DERATE =	1		
	AMB. TEMP. AMP. CORRECTION =	0.91		
	ADJUSTED AMP. =	27.3	>	16.6
JUNCTION BOX TO	MAX. SHORT CIRCUIT CURRRENT (ISC) =	13.3	AAC	
COMBINER BOX (3)	MAX. CURRENT (ISC X1.25) =	16.6	AAC	
	CONDUCTOR (UF-B, COPPER (60°C)) =	10	AWG	
	CONDUCTOR RATING =	30	A	
	CONDUIT FILL DERATE =	0.8		
	AMB. TEMP. AMP. CORRECTION =	0.91		
	ADJUSTED AMP. =	21.84	>	16.6
COMBINER BOX TO	INVERTER RATED AMPS =	25.4	A AC	
MAIN PV OCPD (15)	MAX. CURRENT (RATED AMPS X1.25) =	31.76	AAC	
	CONDUCTOR (THWN-2, COPPER (75°C TERM.)) =	8	AWG	
	CONDUCTOR RATING =	50	A	
	CONDUIT FILL DERATE =	1		
	AMB. TEMP. AMP. CORRECTION =	0.91		
	ADJUSTED AMP. =	45.5	>	31.8

BLUE RAVEN

1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION



OF BLUE RAVEN SOLAR LLC

PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 800-377-4480

Carolina 28390

North

3.09 kW AC 3.505 kW DC

Θ. Θ.

ш ш

SIZI

ĒM

STI

SY SY

GROUNDING NOTES

- 1. A GROUNDING ELECTRODE SYSTEM IN ACCORDANCE WITH [NEC 690.47] AND [NEC 250.50-60] SHALL BE PROVIDED. PER [NEC 690.47], THE GROUNDING ELECTRODE SYSTEM OF AN EXISTING BUILDING MAY BE USED AND BE BONDED AT THE SERVICE ENTRANCE. IF EXISTING SYSTEM IS INACCESSIBLE, OR INADEQUATE, OR IS ONLY METALLIC WATER PIPING, A SUPPLEMENTAL GROUNDING ELECTRODE WILL BE USED AT THE INVERTER LOCATION CONSISTING OF A UL LISTED 8 FT GROUND ROD WITH ACORN CLAMP.
- 2. THE GROUNDING ELECTRODE CONDUCTOR SHALL BE PROTECTED FROM PHYSICAL DAMAGE BETWEEN THE GROUNDING ELECTRODE AND THE PANEL (OR INVERTER) IF SMALLER THAN #6 AWG COPPER WIRE PER [NEC 250.64(B)]. THE GROUNDING ELECTRODE CONDUCTOR WILL BE CONTINUOUS, EXCEPT FOR SPLICES OR JOINTS AT BUSBARS WITHIN LISTED EQUIPMENT PER [NEC 250.64(C)].
- 3. GROUNDING ELECTRODE CONDUCTORS SHALL BE NO LESS THÂN 8 AWG AND NO GREATER THAN 6 AWG COPPER AND BONDED TO THE EXISTING GROUNDING ELECTRODE TO PROVIDE FOR A COMPLETE SYSTEM.

 4. PV SYSTEM SHALL BE GROUNDED IN ACCORDANCE TO [NEC 250.21], [NEC TABLE 250.122], AND ALL METAL PARTS OR MODULE FRAMES ACCORDING TO [NEC 690.46].
- 5. MODULE SOURCE CIRCUITS SHALL BE GROUNDED IN ACCORDANCE TO [NEC 690.42].
- 6. THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OF A
- MODULE DOES NOT INTERRUPT A GROUNDED CONDUCTOR TO ANOTHER MODULE.
 7. EACH MODULE WILL BE GROUNDED USING THE SUPPLIED CONNECTION POINTS IDENTIFIED IN THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
- 8. ENCLOSURES SHALL BE PROPERLY PREPARED WITH REMOVAL OF PAINT/FINISH AS APPROPRIATE WHEN GROUNDING EQUIPMENT WITH TERMINATION GROUNDING LUGS.
- GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVISES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR DIRECT BURIAL.
 GROUNDING AND BONDING CONDUCTORS SHALL BE COPPER, SOLID OR STRANDED, AND BARE WHEN
- EXPOSED.

 11. EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO [NEC 690.45] AND BE A MINIMUM OF 10 AWG WHEN NOT EXPOSED TO DAMAGE (6 AWG SHALL BE USED WHEN EXPOSED TO
- MINIMUM OF 10 AWG WHEN NOT EXPOSED TO DAMAGE (6 AWG SHALL BE USED WHEN EXPOSED TO DAMAGE).
- 12. GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLOR CODED GREEN (OR MARKED GREEN IF 4 AWG OR LARGER).
- 13. ALL CONDUIT BETWEEN THE UTILITY AC DISCONNECT AND THE POINT OF CONNECTION SHALL HAVE GROUNDED BUSHINGS AT BOTH BODS.
- 14. SYSTEM GEC SIZED ACCORDING TO [NEC 690.47], [NEC TABLE 250.66], DC SYSTEM GEC SIZED ACCORDING TO [NEC 250.166], MINIMUM 8 AWG WHEN INSULATED, 6 AWG WHEN EXPOSED TO DAMAGE.

 15. EXPOSED NON-CURRENT CARRYING METAL PARTS OF MODULE FRAMES, EQUIPMENTS, AND
- 15. EXPOSED NON-CURRENT CARRYING METAL PARTS OF MODULE FRAMES, EQUIPMENTS, AND CONDUCTOR ENCLOSURES SHALL BE GROUNDED IN ACCORDANCE WITH [NEC 250.134] OR [NEC 250.136(A)] REGARDLESS OF VOLTAGE.

WIRING & CONDUIT NOTES

- 1. ALL CONDUIT SIZES AND TYPES, SHALL BE LISTED FOR ITS PURPOSE AND APPROVED FOR THE SITE APPLICATIONS.
- 2. BOLTED CONNECTION REQUIRED IN DC DISCONNECTS ON THE WHITE GROUNDED CONDUCTOR (USE POLARIS BLOCK OR NEUTRAL BAR).
- 3. ANY CONNECTION ABOVE LIVE PARTS MUST BE WATERTIGHT. REDUCING WASHERS DISALLOWED ABOVE LIVE PARTS, MEYERS HUBS RECOMMENDED
- 4. UV RESISTANT CABLE TIES (NOT ZIP TIES) USED FOR PERMANENT WIRE MANAGEMENT OFF THE ROOF SURFACE IN ACCORDANCE WITH [NEC 110.2,110.3(A-B)].
- SURFACE IN ACCORDANCE WITH [NEC 110.2,110.3(A-B)].
 5. SOLADECK JUNCTION BOXES MOUNTED FLUSH WITH ROOF SURFACE TO BE USED FOR WIRE
- MANAGEMENT AND AS FLASHED ROOF PENETRATIONS FOR INTERIOR CONDUIT RUNS.
 6. ALL PV CABLES AND HOMERUN WIRES BE TYPE USE-2, AND SINGLE-CONDUCTOR CABLE LISTED AND IDENTIFIED AS PV WIRE, TYPE TC-ER, OR EQUIVALENT; ROUTED TO SOURCE CIRCUIT COMBINER BOXES AS
- REQUIRED.
 7. ALL CONDUCTORS AND OCPD SIZES AND TYPES SPECIFIED ACCORDING TO [NEC 690.8] FOR MULTIPLE CONDUCTORS.
- 8. ALL PV DC CONDUCTORS IN CONDUIT EXPOSED TO SUNLIGHT SHALL BE INSTALLED AT LEAST 7/8" ABOVE THE ROOF SURFACE AND DERATED ACCORDING TO [NEC TABLE 310.15 (B)(2)(A)], [NEC TABLE 310.15/(B)(3)(A)]& [NEC 310.15(B)(3)(C)].
- 9. EXPOSED ROOF PV DC CONDUCTORS SHALL BE USE-2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED RATED FOR 600V, UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHARP
- 10. PHASE AND NEUTRAL CONDUCTORS SHALL BE DUAL RATED THHN/THWN-2 INSULATED, 90°C RATED, WET AND UV RESISTANT, RATED FOR 600V
- 11. 4-WIRE DELTA CONNECTED SYSTEMS HAVE THE PHASE WITH THE HIGHER VOLTAGE TO GROUND MARKED ORANGE OR IDENTIFIED BY OTHER EFFECTIVE MEANS.
- 12. ALL SOURCE CIRCUITS SHALL HAVE INDIVIDUAL SOURCE CIRCUIT PROTECTION
- 13. VOLTAGE DROP LIMITED TO 2% FOR DC CIRCUITS AND 3% FOR AC CIRCUITS
- 14. NEGATIVE GROUNDED SYSTEMS DC CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS: DC POSITIVE- RED (OR MARKED RED), DC NEGATIVE- GREY (OR MARKED GREY)
- 15. POSITIVE GROUNDED SYSTEMS DC CONDUCTORS COLOR CODED:
- DC POSITIVE- GREY (OR MARKED GREY), DC NEGATIVE- BLACK (OR MARKED BLACK)
- 16. AC CONDUCTORS >4AWG COLOR CODED OR MARKED: PHASE A OR L1- BLACK, PHASE B OR L2- RED, PHASE C OR L3- BLUE. NEUTRAL- WHITE/GRAY
- * USE-2 IS NOT INDOOR RATED BUT PV CABLE IS RATED THWN/THWN-2 AND MAY BE USED INSIDE
- ** USE-2 IS AVAILABLE AS UV WHITE
- 17. RIGID CONDUIT, IF INSTALLED, (AND/OR NIPPLES) MUST HAVE A PULL BUSHING TO PROTECT WIRES.
- 18. IF CONDUIT DETERMINED TO BE RAN THROUGH ATTIC IN FIELD THEN CONDUIT WILL BE EITHER EMT, FMC, OR MC CABLE IF <u>DC</u> CURRENT COMPLYING WITH [NEC 690.31], [NEC 250.118(10)]. DISCONNECTING MEANS SHALL COMPLY WITH [NEC 690.13] AND [NEC 690.15].
- 19. CONDUIT RAN THROUGH ATTIC WILL BE AT LEAST 18" BELOW ROOF SURFACE COMPLYING WITH [NEC 230.6(4)] AND SECURED NO GREATER THAN 6' APART PER [NEC 330.30(B)].

CUSTOMER INFORMATION: William Copes

William Cope 18 Kirby Smi Spring Lake

DRAWING BY:

PremiumCAD

PLOT DATE:

March 10, 2023

PROJECT NUMBER:

725142

SHEET NAME:

ELEC CALCS

REVISION:

PAGE NUMBER:

PV6

STANDARD LABELS

WARNING

ELECTRIC SHOCK HAZARD

TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

PHOTOVOLTAIC SYSTEM

AC DISCONNECT

LABEL 2

LABEL 3

LABEL 4

LABEL 5

[2017 NEC 690.54]

[2020 NEC 690.54]

AND SUBPANELS.

[2017 NEC 705.12(B)(3)]

[2020 NEC 705.12(B)(3)]

[2017 NEC 705.12(B)(2)(3)(b)

APPLY TO THE PV COMBINER BOX [2017 NEC 705.12(B)(2)(3)(c)]

[2020 NEC 705.12(B)(3)(2)]

[2020 NEC 705.12(B)(3)(3)]

OPEN POSITION

[2017 NEC 690.13(B)]

[2020 NEC 690.13(B)]

SHALL BE MARKED AT AN ACCESSIBLE LOCATION AT

THE DISCONNECTING MEANS AS A POWER SOURCE

NOMINAL OPERATING AC VOLTAGE

AND WITH THE RATED AC OUTPUT CURRENT AND THE

IF INTERCONNECTING LOAD SIDE, INSTALL THIS LABEL

ANYWHERE THAT IS POWERED BY BOTH THE UTILITY AND THE SOLAR PV SYSTEM, IE. MAIN SERVICE PANEL

APPLY TO THE DISTRIBUTION EQUIPMENT ADJACENT

TO THE BACK-FED BREAKER FROM THE POWER

RATED AC OUTPUT CURRENT 25.41 A NOMINAL OPERATING AC VOLTAGE 240~
m V

↑ WARNING

DUAL POWER SUPPLY

SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

⚠ WARNING

POWER SOURCE OUTPUT CONNECTION

DO NOT RELOCATE THIS OVERCURRENT **DEVICE**

↑ WARNING

THIS EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR.

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOW SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM



RAPID SHUTDOWN **SWITCH FOR** SOLAR PV SYSTEM

LABEL 7

SWITCH

[2020 NEC 690.56(C)(2)]

LABELING NOTES

4) LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED AND SHALL NOT BE

LABEL 1 **↑ WARNING** FOR PV SYSTEM DISCONNECTING MEANS WHERE THE LINE AND LOAD TERMINALS MAY BE ENERGIZED IN THE

MAIN DISTRIBUTION UTILITY DISCONNECT(S)

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM A ROOF MOUNTED SOLAR ARRAY WITH A RAPID SHUTDOWN DISCONNECTING MEANS GROUPED AND LABELED WITHIN LINE OF SITE
AND 10 FT OF THIS LOCATION

WARNING

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM MAIN DISTRIBUTION UTILITY DISCONNECT LOCATED

WARNING

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM A ROOF MOUNTED SOLAR ARRAY, SOLAR ARRAY RAPID SHUTDOWN DISCONNECT IS LOCATED OUTSIDE NEXT TO THE UTILITY METER.

WARNING

PHOTOVOLTAIC SYSTEM **COMBINER PANEL**

DO NOT ADD LOADS

MAIN

SERVICE PANEL

1

2

4

6

3

IF BREAKER

IS USED

8) OR (10)

OR PLACARD

UTILITY

METER

3

LABEL 8

PERMANENT PLAQUE OR DIRECTORY DENOTING THE LOCATION OF ALL ELECTRIC POWER SOURCE DISCONNECTING MEANS ON OR IN THE PREMISES SHALL BE INSTALLED AT EACH SERVICE EQUIPMENT LOCATION AND AT THE LOCATION(S) OF THE SYSTEM DISCONNECT(S) FOR ALL ELECTRIC POWER PRODUCTION SOURCES CAPABLE OF BEING INTERCONNECTED [2017 NEC 705.10] [2020 NEC 705.10]

LABEL 9

PERMANENT PLAQUE OR DIRECTORY DENOTING THE LOCATION OF ALL ELECTRIC POWER SOURCE DISCONNECTING MEANS ON OR IN THE PREMISES SHALL BE INSTALLED AT EACH SERVICE EQUIPMENT LOCATION AND AT THE LOCATION(S) OF THE SYSTEM DISCONNECT(S) FOR ALL ELECTRIC POWER PRODUCTION SOURCES CAPABLE OF BEING INTERCONNECTED. [2017 NEC 705.10] [2020 NEC 705.10]

LABEL 10

PERMANENT PLAQUE OR DIRECTORY TO BE LOCATED AT MAIN SERVICE EQUIPMENT DENOTING THE LOCATION OF THE RAPID SHUTDOWN SYSTEM DISCONNECTING MEANS IF SOLAR ARRAY RAPID SHUTDOWN DISCONNECTING SWITCH IS NOT GROUPED AND WITHIN LINE OF SITE OF MAIN SERVICE DISCONNECTING MEANS. [2017 NEC 705.10 AND 690.56(C)(1)(a)] [2020 NEC 705.10 AND 690.56(C)]

SUBPANEL

(IF INTERCONNECTION

IS MADE HERE)

6

3

9

1

2

4

PERMANENT PLAQUE OR DIRECTORY TO BE LOCATED AT AC COMBINER PANEL [2017 NEC 110.21(B)] [2020 NFC 110 21(B)

AC

DISCONNECT

1

7

9

2

OR PLACARD

WARNING

ADDITIONAL LABELS

DUAL POWER SUPPLY

SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

PV

METER

PV COMBINER

BOX

1

5

11

2

8

*ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL

REPRESENTATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED

MAY VARY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ON 3 LINE

DIAGRAM. 3 LINE DIAGRAM ON PV5 TO REFLECT ACTUAL REPRESENTATION OF PROPOSED SCOPE OF WORK

LABEL 3

IF INTERCONNECTING LOAD SIDE, INSTALL THIS LABEL ANYWHERE THAT IS POWERED BY BOTH THE UTILITY AND THE SOLAR PV SYSTEM, IE. MAIN SERVICE PANEL AND SUBPANELS. [NEC 705.12(B)(3)]



1403 N. Research Wav Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 800-377-4480

3.09 kW AC 3.505 kW DC Carolina 28390 6. % 证证 SIZI

Ç Lake North Smith STEM William (Kirby Spring SYS

DRAWING BY:

CUSTOMER INFORMATION:

PremiumCAD

 ∞

PLOT DATE:

March 10, 2023

PROJECT NUMBER:

725142

SHEET NAME

LABELS

REVISION:

AGE NUMBER:

0

LABEL 6

PERMANENT LABEL LOCATED AT EACH SERVICE EQUIPMENT LOCATION TO WHICH THE PV SYSTEMS ARE CONNECTED OR AT AN APPROVED READILY VISIBLE LOCATION AND SHALL INDICATE THE LOCATION OF RAPID SHUTDOWN INITIATION DEVICES. [2017 NEC 690.56(C)(1)(a)] [2020 NEC 690 56(C)]

BUILDINGS WITH PV SYSTEMS SHALL HAVE A

SIGN LOCATED AT RAPID SHUT DOWN DISCONNECT [2017 NEC 690.56(C)(3)]

1) LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS. 2) LABELING REQUIREMENTS BASED ON THE 2017 & 2020 NEC CODE, OSHA STANDARD 19010.145, ANSIZ535. 3) MATERIAL BASED ON THE REQUIREMENTS OF THE AHJ.

HANDWRITTEN [NEC 110.21]



SEG SOLAR INC. (SEG)

www.segsolar.com



SEG SOLAR INC. (SEG)

Technical Drawing

www.segsolar.com



SIV SERIES

SEG Solar INC. (SEG) redefined the high-efficiency module series by integrating 182mm silicon wafers with multi-busbar and half-cut cell technologies. SEG panel combined creative technology effectively and extremely improved the module efficiency and power output.

KEY FEATURES

The transmittance of 400~1100nm band in the transparent

Using POE or EVA package, there is no need to worry about component power attenuation caused by PID

A transparent backsheet reduces module weight by 30%, resulting in reduced shipping and installation costs

Through ultraviolet 500kWh/m2 strict test, fully meet the requirements of 25 years of use of the modules

Timely release of packaging material decomposition of acetic acid, effectively reduce the concentration of aceticacid modules

Consistent with conventional component production process, no need to modify production equipment

PRODUCT CERTIFICATION

IEC61215:2016;	IEC 61730:2016;	UL1703;	UL61730/CSA/CEC
IEC62804		PID	
IEC61701		Salt Mist	
IEC62716		Ammonia	Resistance
IEC60068		Dust and	Sand
IEC61215		Hailstone	(25mm)
Fire Type (UL617:	30):1/29 (Type1-	HV Type2	29-BG)
ISO14001:2015;	ISO9001:2015; I	SO45001:	2018












INSURANCE

PKC

WARRANTY



Mechanical Specifications

External Dimension	1722 x 1134 x 30 mm		
Weight	21.5 kg		
Solar Cells	PERC Mono crystalline(108 pcs)		
Front Glass	3.2 / mm AR coating semi-tempered glass / low iron		
Backsheet	Transparent backsheet		
Frame	Black anodized aluminium alloy		
Junction Box	IP68 / 3 diodes		
Connector Type	MC4		
Cable Type / Length	12 AWG PV Wire (UL/IEC) / 1200 mm		
Mechanical Load(Front)	5400 Pa / 113 psf*		
Mechanical Load(Rear)	3600 Pa / 75 psf*		
*Refer to SEG installation Manual for details			

Packing Configuration

Container	20'GP	40'HQ
Pieces per Pallet	40	36
Pallets per Container	6	26
Pieces per Container	240	936
For details, places assembly CF(•	

For details, please consult SEG.

Electrical Characteristics

Module Type	SE	G-405-BM	ID-TB	SEC	G-410-BMI	D-TB	SEG	-415-BMD)-TB	SEC	G-420-BM	D-TB
	Front	Front	Back STC	Front STC	Front NOCT	Back STC	Front	Front	Back STC	Front	Front NOCT	Back STC
Maximum Power -P _{mp} (W)	405	304	284	410	308	287	415	311	291	420	314	294
Open Circuit Voltage -V _{oc} (V)	37.22	34.73	37.20	37.32	34.81	37.30	37.42	34.90	37.40	37.52	34.99	37.50
Short Circuit Current -I _{sc} (A)	13.70	11.07	9.66	13.80	11.15	9.73	13.90	11.23	9.80	14.00	11.31	9.87
Maximum Power Voltage -V _{mp} (V)	30.93	28.91	30.98	31.05	29.05	31.03	31.16	29.19	31.17	31.28	29.33	31.29
Maximum Power Current -I _{mp} (A)	13.10	10.51	9.17	13.21	10.59	9.25	13.32	10.66	9.34	13.43	10.73	9.42
Module Efficiency STC-η _m (%)		20.74			21.00			21.25			21.51	
Power Tolerance (W)					(0, +4.99)							
Pmax Temperature Coefficient						-0.34	%/°C					
Voc Temperature Coefficient		-0.26 %/°C										
Isc Temperature Coefficient						+0.05	%/°C					

STC: Irradiance 1000 W/m² module temperature 25°C AM=1.5

NOCT: Irradiance 800W/m² ambient temperature 20°C module temperature 45°C wind speed: 1m/s Power measurement tolerance: +/-3%


Rear Side Power Gain(SEG-410-BMD-TB)

Power Gain	10%	15%	20%	25%	30%
Maximum Power -P _{mp} (W)	451	472	492	513	533
Open Circuit Voltage -V _{oc} (V)	37.22	37.22	37.22	37.22	37.22
Short Circuit Current -I _{sc} (A)	15.18	15.87	16.56	17.25	17.94
Maximum Power Voltage -V _{mp} (V)	31.05	31.05	31.05	31.05	31.05
Maximum Power Current -I _{mp} (A)	14.53	15.19	15.85	16.51	17.17

Application Conditions

Maximum System Voltage	1500V DC
Maximum Series Fuse Rating	25 A
Operating Temperature	-40~+85 °C
Nominal Operating Cell Temperature	45±2 °C
Bifaciality	70%±10%

I-V Curve



Specifications are subject to change without further notification SEG-DS-EN-2022V1.0 © Copyright 2022 SEG

SEG SOLAR INC. (SEG)

SEG Headquarter California office: 6200 Stoneridge Mall Rd., Ste 300 Pleasanton, CA 94588 SEG San Antonio, Texas office: 973 Isom Road San Antonio, TX 78216 Tel: 925-468-4198 Web: www.segsolar.com



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

AGE NUMBER:

SS



SEG SOLAR INC.(SEG)

SEG Headquarter California office: 6200 Stoneridge Mall Rd., Ste 300 Pleasanton, CA 94588 SEG San Antonio, Texas office: 973 Isom Road San Antonio, TX 78216 Tel: 925-468-4198 Web: www.segsolar.com









IQ8 and IQ8+ Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-n-play MC4 connectors.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



IQ8 Series Microinverters are UL Listed as PV Rapid Shut Down Equipment and conform with various regulations, when installed according to manufacturer's instructions.

© 2022 Enphase Energy, All rights reserved. Enphase, the Enphase logo, IQ8 Microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8SP-DS-0002-01-EN-US-2022-03-17

Easy to install

- Lightweight and compact with plug-n-play connectors
- Power Line Communication (PLC) between components
- Faster installation with simple two-wire cabling

High productivity and reliability

- Produce power even when the grid is down*
- More than one million cumulative hours of testing
- Class II double-insulated enclosure
- Optimized for the latest highpowered PV modules

Microgrid-forming

- Complies with the latest advanced grid support**
- Remote automatic updates for the latest grid requirements
- Configurable to support a wide range of grid profiles
- Meets CA Rule 21 (UL 1741-SA) requirements
- * Only when installed with IQ System Controller 2,
- ** IQ8 and IQ8Plus supports split phase, 240V installations only.

IQ8 and IQ8+ Microinverters

INPUT DATA (DC)		108-60-2-US	IQ8PLUS-72-2-US
Commonly used module pairings ¹	W	235 - 350	235 - 440
Module compatibility		60-cell/120 half-cell	60-cell/120 half-cell, 66-cell/132 half-cell and 72-cell/14 half-cell
MPPT voltage range	V	27 - 37	29 – 45
Operating range	V	25 – 48	25 – 58
Min/max start voltage	V	30 / 48	30 / 58
Max input DC voltage	V	50	60
Max DC current ² [module lsc]	Α	1	5
Overvoltage class DC port		1	II
DC port backfeed current	mA		0
PV array configuration		1x1 Ungrounded array; No additional DC side protection requ	ired; AC side protection requires max 20A per branch circuit
DUTPUT DATA (AC)		108-60-2-US	IQ8PLUS-72-2-US
Peak output power	VA	245	300
Max continuous output power	VA	240	290
Nominal (L-L) voltage/range ³	V	240 / 2	11 – 264
Max continuous output current	Α	1.0	1.21
Nominal frequency	Hz	6	0
Extended frequency range	Hz	50	- 68
AC short circuit fault current over 3 cycles	Arms	2	2
Max units per 20 A (L-L) branch circuit ⁴		16	13
Total harmonic distortion		<5	5%
Overvoltage class AC port		I	II
AC port backfeed current	mA	3	0
Power factor setting		1.	0
Grid-tied power factor (adjustable)		0.85 leading	- 0.85 lagging
Peak efficiency	%	97.5	97.6
CEC weighted efficiency	%	97	97
Night-time power consumption	mW	6	0
MECHANICAL DATA			
Ambient temperature range		-40°C to +60°C	(-40°F to +140°F)
Relative humidity range		4% to 100%	(condensing)
DC Connector type		Mo	C4
Dimensions (HxWxD)		212 mm (8.3") x 175 mm	n (6.9") x 30.2 mm (1.2")
Weight		1.08 kg (2.38 lbs)
Cooling		Natural conve	ction – no fans
Approved for wet locations		Ye	es
Pollution degree		PI	03
Enclosure		Class II double-insulated, corrosi	ion resistant polymeric enclosure
Environ. category / UV exposure rating		NEMA Туре	6 / outdoor
COMPLIANCE		CA Rule 21 (UL 1741-SA), UL 62109-1, UL1741/IEEE1547, FCC Part	15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-0
Certifications		This product is UL Listed as PV Rapid Shut Down Equipment and 690.12 and C22.1-2018 Rule 64-218 Rapid Shutdown of PV Systemanufacturer's instructions.	conforms with NEC 2014, NEC 2017, and NEC 2020 section

by the utility. (4) Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BILLE RAVEN SOLAR ILC



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

IQ8SP-DS-0002-01-EN-US-2022-03-17

| |

SS SAGE NUMBER:

Data Sheet Enphase Networking

IQ Combiner 4/4C



Smart · Includes IQ Gateway for communication and control Includes Mobile Connect cellular modem (CELLMODEM-M1-06-SP-05), included only with 1Q Combiner 4C

· Includes solar shield to match Enphase IQ Battery

The IQ Combiner 4/4C with IQ Gateway and

integrated LTE-M1 cell modem (included

only with IQ Combiner 4C) consolidates

interconnection equipment into a single

enclosure. It streamlines IQ Microinverters and

storage installations by providing a consistent, pre-wired solution for residential applications.

It offers up to four 2-pole input circuits and

Eaton BR series busbar assembly.

- aesthetics and deflect heat
- · Supports Wi-Fi, Ethernet, or cellular connectivity
- · Optional AC receptacle available for PLC bridge
- · Provides production metering and consumption monitoring


Simple

- · Mounts on single stud with centered brackets
- · Supports bottom, back and side conduit entry
- · Allows up to four 2-pole branch circuits for 240VAC plug-in breakers (not included)
- · 80A total PV or storage branch circuits

Reliable

- · Durable NRTL-certified NEMA type 3R enclosure
- · Five-year limited warranty
- · Two years labor reimbursement program coverage included for both the IQ Combiner SKU's
- UL listed
- X2-IQ-AM1-240-4 and X2-IQ-AM1-240-4C comply with IEEE 1547:2018 (UL 1741-SB, 314 Ed.)





X2-IQ-AM1-240-4 (IEEE 1547:2018)



MODEL NUMBER	
IQ Combiner 4 X-IQ-AM1-240-4 X2-IQ-AM1-240-4 (IEEE 1547:2018)	IQ Combiner 4 with IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 ± 0.5%) and consumption monitoring (± 2.5%). Includes a silver solar shield to match the IQ Battery and IQ System Controller 2 and to deflect heat.
IQ Combiner 4C X-IQ-AM1-240-4C X2-IQ-AM1-240-4C (IEEE 1547:2018)	IQ Combiner 4C with IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 ± 0.5% and consumption monitoring (± 2.5%). Includes Mobile Connect cellular modem (CELLMODEM-MT-06-SP-05), a plug-and-play industrial-grade cell modem for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is a dequate cellular service in the installation area.) Includes a tilver solar shield to match the IQ Battery and IQ System Controller: and to deflect heat.
ACCESSORIES AND REPLACEMENT PARTS	(not included, order separately)
Supported microinverters	IQ6, IQ7, and IQ8. (Do not mix IQ6/7 Microinverters with IQ8)
Communications Kit COMMS-CELLMODEM-M1-06 CELLMODEM-M1-06-SP-05 CELLMODEM-M1-06-AT-05	- Includes COMMS-KIT-01 and CELLMODEM-M1-06-SP-05 with 5-year Sprint data plan - 4G based LTE-M1 cellular modern with 5-year Sprint data plan - 4G based LTE-M1 cellular modern with 5-year AT&T data plan
Circuit Breakers BRK-10A-2-240V BRK-15A-2-240V BRK-20A-2P-240V BRK-15A-2P-240V-B BRK-20A-2P-240V-B	Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220 Circuit breaker, 2 pole, 15A, Eaton BR215B with hold down kit support Circuit breaker, 2 pole, 20A, Eaton BR220B with hold down kit support
XA-SOLARSHIELD-ES	Replacement solar shield for IQ Combiner 4/4C
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPLC-01)
X-IQ-NA-HD-125A	Hold-down kit for Eaton circuit breaker with screws
Consumption monitoring CT (CT-200-SPLIT/CT-200-CLAMP)	A pair of 200A split core current transformers
ELECTRICAL SPECIFICATIONS	
Rating	Continuous dufy
System voltage	120/240VAC, 60 Hz
Eaton BR series busbar rating	125A
Max, continuous current rating	65A
Max. continuous current rating (input from PV/storage)	64A
Max. fuse/circuit rating (output)	90A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)

Production	meteri	ng CT
MECHAN	IICAL	DATA

Integrated Wi-Fi

Cellular

IQ Gateway breaker

MECHANICAL DATA	
Dimensions (WxHxD)	37.5 cm x 49.5 cm x 16.8 cm (14.75 in x 19.5 in x 6.63 in). Height is 53.5 cm (21.06 in) with mounting brackets.
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40°C to +46°C (-40°F to 115°F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	20A to 50A breaker inputs: 14 to 4 AWG copper conductors 60A breaker branch input: 4 to 1/0 AWG copper conductors Main lug combined output: 10 to 2/0 AWG copper conductors Neutral and ground; 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing.
Altitude	Up to 3,000 meters (9,842 feet)

10A or 15A rating GE/Siemens/Eaton included

200A solid core pre-installed and wired to IQ Gateway

INTERNET CONNECTION OPTIONS

Ethernet	Optional, IEEE 802.3, Cat5E (or Cat6) UTP Ethernet cable (not included)	
COMPLIANCE		
Compliance, IQ Combiner	CA Rule 21 (UL 1741-SA) SEEF 1547-2018 - UL 1741-SB, 3° Ed. (X2-IQ-AM1-240-4 and X2-IQ-AM1-240-4C) CAN/CSA C22.2 No. 1071, Title 47 CFR, Part 15, Class 8, ICES 003 Production metering: ANSI C12.20 accuracy class 0.5 (PV production) Consumption metering: accuracy class 2.5	
Compliance, IQ Gateway	UL 606D1-1/CANCSA 22.2 No. 61010-1	

cellular modern is required for all Enphase Energy System installations.

CELLMODEM-M1-06-SP-05, CELLMODEM-M1-06-AT-05 (4G based LTE-M1 cellular modern). Note that an Mobile Connect

IEEE 802.11b/g/n

IQ-C-4-4C-DS-0103-EN-US-12-29-2022



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION

OF BLUE RAVEN SOLAR LLC



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

SHEET NAME:


0


SPEC SHEETS


REVISION: PAGE NUMBER:

SS

^{© 2022} Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 4/4C, and other names are trademarks of Enphase Energy, Inc. Data subject to change.







NEMA TYPE 3R

	TERMINAL LUGS ‡					
AMPERES	MAX. WIRE	MIN. WIRE	TYPE			
60	# 2 AWG # 2 AWG	#10 AWG #14 AWG	AL CU			

	KNC	CKOUTS		
SYMBOL	А	В	С	D
CONDUIT SIZE	.50	.75	1	1.25

DUAL DIMENSIONS: INCHES MILLIMETERS

			HORSEPOWE	ER RATINGS
CATALOG	VOLTAGE DATINGO	WIRING	240	VAC
NUMBER	VOLTAGE RATINGS	DIAG.	M/	AX.
			1 Ø	30
DU222RB DU322RB	240VAC 240VAC	A B	10 10	_ 15

FINISH - GRAY BAKED ENAMEL

UL LISTED - FILE E-2875
SUITABLE FOR USE AS SERVICE EQUIPMENT
TOP OF NEMA TYPE 3R SWITCHES HAVE PROVISIONS FOR MAXIMUM 2 1/2" BOLT-ON HUB.
SHORT CIRCUIT CURRENT RATINGS:
10,000 AMPERES WHEN USED WITH OR PROTECTED BY CLASS H OR K FUSES
100,000 AMPERES WHEN USED WITH OR PROTECTED BY CLASS R FUSES.

‡ LUGS SUITABLE FOR 60°C OR 75°C COPPER OR ALUMINUM CONDUCTORS.

DECEMBER 2004

GENERAL DUTY SAFETY SWITCHES
VISIBLE BLADE TYPE
60 AMPERE
ENCLOSURE - NEMA TYPE 3R RAINPROOF

Sci

Schneider Electric

DWG# 1861

REF DWG #1861

BLUE RAVEN

1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

PAGE NUMBER:

VISION.

PV Junction Box for Composition/Asphalt Shingle Roofs

JB-1.2 EZ#SOLAR Specification Sheet

PHONE: 385-202-4150 WWW.EZSOLARPRODUCTS.COM

SIZE

SCALE: 1:2

TORQUE SPECIFICATION:

CERTIFICATION:

WEIGHT:

DWG. NO.

JB-1.2

WEIGHT: 1.45 LBS

REV

SHEET 1 OF 3

15-20 LBS

UL STANDARD 1741

NEMA 3R

1.45 LBS



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION

OF BLUE RAVEN SOLAR LLC

NABCEP CERTIFIED

PV INSTALLATION **PROFESSIONAL** Scott Gurney


#PV-011719-015866


CONTRACTOR: **BRS FIELD OPS** 385-498-6700

ITEM NO. PART NUMBER DESCRIPTION QTY DOLVOADDONATE

2	JB-1.2 LID	POLYCARBONATE WITH UV INHIBITORS	1
3	#10 X 1-1/4" PHILLIPS PAN HEAD SCREW		6
4	#8 X 3/4" PHILLIPS PAN HEAD SCREW		6
4	PAN HEAD SCREW		0
1			

	3	#10 X 1-1/4" PHILLIPS PAN HEAD SCREW	
	4	#8 X 3/4" PHILLIPS PAN HEAD SCREW	
rrosion tely.			





	1	-	_	-	
	Ł	-		-	
					1
					l
	l				l
					1
	L	<u> </u>			2

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

SS

AGE NUMBER:

A. System Specifications and Ratings

Maximum Voltage: 1,000 Volts Maximum Current: 80 Amps

Allowable Wire: 14 AWG - 6 AWG

Spacing: Please maintain a spacing of at least ½" between uninsulated live parts and fittings for conduit, armored cable, and uninsulated live parts of opposite polarity.

Enclosure Rating: Type 3R Roof Slope Range: 2.5 – 12:12 Max Side Wall Fitting Size: 1'

Max Floor Pass-Through Fitting Size: 1"

Ambient Operating Conditions: (-35°C) - (+75°C)

Compliance:

- JB-1.2: UL1741

- Approved wire connectors: must conform to UL1741

System Marking: Interek Symbol and File #5019942

Periodic Re-inspections: If re-inspections yield loose components, loose fasteners, or any corr between components, components that are found to be affected are to be replaced immediate

Table 1: Typical Wire Size, Torque Loads and Ratings

					Torque		
	1 Conductor	2 Conductor	Type	NM	Inch Lbs	Voltage	Current
ABB ZS6 terminal block	10-24 awg	15-24 awg	Sol/Str	0.5-0.7	6.2-8.85	600V	30 amp
ABB ZS10 terminal block	6-24 awg	12-20 awg	Sol/Str	1.0-1.6	8.85-14.16	600V	40 amp
ABB ZS16 terminal bock	4-24 awg	10-20 awg	Sol/Str	1.6-2.4	14.6-21.24	600V	60 amp
ABB M6/8 terminal block	8-22 awg		Sol/Str	.08-1	8.85	600V	50 amp
Ideal 452 Red WING-NUT Wire Connector	8-18 awg		Sol/Str	Self Torque	Self Torque	600V	
Ideal 451 Yellow WING-NUT Wire Connector	10-18 awg		Sol/Str	Self Torque	Self Torque	600V	
Ideal, In-Sure Push-In Connector Part #39	10-14 awg		Sol/Str	Self Torque	Self Torque	600V	
WAGO, 2204-1201	10-20 awg	16-24 awg	Sol/Str	SelfTorque	Self Torque	600V	30 amp
WAGO, 221-612	10-20 awg	10-24 awg	Sol/Str	Self Torque	Self Torque	600V	30 amp
Dottie DRC75	6-12 awg		Sol/Str	Snap-In	Snap-In		
ESP NG-53	4-6 awg		Sol/Str		45	2000V	
ESP NG-93	10-14 awg		Sol/Str		35		
ESP NG-717	4-6 awg	-	Sol/Str		45	201	00V
LSF HG-717	10-14 awg		Sol/Str	U v	35	201	,
Brumall 4-5,3	4-6 awg		Sol/Str		45	20/	00V
bruman 4-5,5	10-14 awg		Sol/Str		35	201	JUN.

Table 2: Minimum wire-bending space for conductors through a wall opposite terminals in mm (inches)

Wire size	, AWG or		Wires per terminal (pole)						
		1		2		3		4 or More	
kcmil	(mm2)	mm	(inch)	mm	(inch)	mm	(inch)	mm	(inch)
14-10	(2.1-5.3)	Not specified			-		-		-
8	(8.4)	38.1	(1-1/2)		-		-		-
6	(13.3)	50.8	(2)		-		-		-

183.06mm 7.21in

265.18mm 10.44in

Rigid Nonmetallic Conduit – Junction Boxes

Molded Nonmetallic Junction Boxes 6P Rated







It's another first from Carlon® - the first nonmetallic junction boxes UL Listed with a NEMA 6P rating per Section 314.29, Exception of the National Electrical Code. Manufactured from PVC or PPO thermoplastic molding compound and featuring foam-in-place gasketed lids attached with stainless steel screws, these rugged enclosures offer all the corrosion resistance and physical properties you need for direct burial applications.

Type 6P enclosures are intended for indoor or outdoor use, primarily to provide a degree of protection against contact with enclosed equipment, falling dirt, hose-directed water, entry of water during prolonged submersion at a limited depth, and external ice formation.








- All Carlon Junction Boxes are UL Listed and maintain a minimum of a NEMA Type 4/4x Rating.
- Parts numbers with an asterisk (*) are UL Listed and maintain a NEMA Type 6P Rating and Type 4/4X Rating.

	Size in	Std.		[1	I		1	Mat	erial	Std.
Part No.	Inches H x W x D	Ctn. Qty.	Min At	Min. AB	Min. B	Min. C	Та Тур	Tc pical	PVC	Thermo- plastic	Ctn. Wt. (Lbs.)
E989NNJ-CAR*	4 x 4 x 2	5	311/16	35/8	N/A	2	.160	.155	Х		3
E987N-CAR*	4 x 4 x 4	5	311/16	31/2	N/A	4	.160	.155	Х		4
† E989NNR-CAR*	4 x 4 x 6	4	311/16	33/8	N/A	6	.160	.200	Х		5
E989PPJ-CAR*	5 x 5 x 2	4	411/16	41/2	N/A	2	.110	.150		Х	3
E987R-CAR*	6 x 6 x 4	2	6	55/8	N/A	4	.190	.190		Х	3
E989RRR-UPC*	6 x 6 x 6	8	55/8	53/8	N/A	6	.160	.150		Х	14
E989N-CAR	8 x 8 x 4	1	8	8	N/A	4	.185	.190		Х	2
E989SSX-UPC	8 x 8 x 7	2	721/32	7 ⁵ /16	N/A	7	.160	.150		Х	6
E989UUN	12 x 12 x 4	3	115/8	111/2	111/8	4	.160	.150		Х	12
E989R-UPC	12 x 12 x 6	2	11 ¹⁵ /16	11 ⁷ /8	11 ⁷ /16	6	.265	.185		Х	10



BLUE RAVEN

1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

PAGE NUMBER

- SS

www.carlon.com







2 INSTALLS PER DAY


Make two installs per day your new standard. **SFM** INFINITY has fewer roof attachments, one tool installation, and pre-assembled components to get you off the roof 40% faster.

BETTER AESTHETICS

Install the system with the aesthetics preferred by homeowners, with integrated front trim, trim end caps, dark components, and recessed hardware.

MAXIMUM POWER DENSITY

Easily mix module orientations to achieve optimal power density without incurring the increased bill of materials, labor, and attachments required by rail.



SYSTEM OVERVIEW


PART NAME	DESCRIPTION
1 TRIMRAIL	Structural front trim provides aesthetic and aligns modules.
TRIMRAIL SPLICE	Connects and electrically bonds sections of TRIM RAIL.
TRIMRAIL FLASHKIT	Attaches TRIM RAIL to roof. Available for comp shingle or tile.
MODULE CLIPS	Secure modules to TRIM RAIL.
5 MICRORAIL	Connects modules to SLIDERS. Provides post-install array leveling.
SPLICE	Connects and supports modules. Provides east-west bonding. ATTACHED SPLICE also available.
SLIDER FLASHKIT	Roof attachment and flashing. Available for comp shingle and tile.

BONDING AND ACCESSORIES

PART NAME	DESCRIPTION
TRIMRAIL ENDCAPS	Covers ends of TRIM RAIL for refined aesthetic.
TRIMRAIL BONDING CLAMP	Electrically bonds TRIM RAIL and modules
N/S BONDING CLAMP	Electrically bonds rows of modules

20% FEWER ATTACHMENTS

Save time and money on every project: **SFM** INFINITY requires fewer attachments than rail systems.



SFM INFINITY 15 Attachments



RAIL 20 Attachments

30% LOGISTICS SAVINGS

With fewer SKUs and compact components, **SFM** INFINITY is easier to stock, easier to transport, and easier to lift to the roof. Plus, make more efficient use of your vehicle fleet.





SFM INFINITY REVOLUTIONIZES ROOFTOP SOLAR WITH BENEFITS ACROSS YOUR BUSINESS, FROM DESIGN AND LOGISTICS, THROUGH ARRAY INSTALLATION AND SERVICE.



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND

USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET


REVISION:

AGE NUMBER:

SS



SYSTEM BONDING & GROUNDING PAGE INSTALLATION GUIDE PAGE



Single Use Only

TERMINAL TORQUE, **Install Conductor and** torque to the following:

4-6 AWG: 35in-lbs 8 AWG: 25 in-lbs 10-14 AWG: 20 in-lbs

LUG DETAIL & TORQUE INFO

Ilsco Lay-In Lug (GBL-4DBT)

- 10-32 mounting hardware
- Torque = 5 ft-lb
- AWG 4-14 Solid or Stranded



TERMINAL TORQUE, **Install Conductor and** torque to the following: 4-14 AWG: 35in-lbs

LUG DETAIL & TORQUE INFO

Ilsco Flange Lug (SGB-4)

- 1/4" mounting hardware
- Torque = 75 in-lb
- AWG 4-14 Solid or Stranded

WEEBLUG Single Use Only



TERMINAL TORQUE Install Conductor and torque to the following: 6-14 AWG: 7ft-lbs


LUG DETAIL & TORQUE INFO

Wiley WEEBLug (6.7)

- 1/4" mounting hardware
- Torque = 10 ft-lb
- AWG 6-14 Solid or Stranded


NOTE: ISOLATE COPPER FROM ALUMINUM CONTACT TO PREVENT CORROSION


System bonding is accomplished through modules. System grounding accomplished by attaching a ground lug to any module at a location on the module specified by the module manufacturer.



E-W BONDING PATH:


E-W module to module bonding is accomplished with 2 pre-installed bonding pins which engage on the secure side of the MicrorailTM and splice.





N-S BONDING PATH:

N-S module to module bonding is accomplished with bonding clamp with 2 integral bonding pins. (refer also to alternate method)





TRIMRAIL BONDING PATH:

Trimrail to module bonding is accomplished with bonding clamp with integral bonding pin and bonding T-bolt. (refer also to alternate method)



1403 N. Research Way Orem, UT 84097

HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYON EXCEPT BLUE RAVEN SOLAR NOR USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSIO OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER

SHEET NAME:

SPEC SHEET

REVISION:

SS





SYSTEM LEVEL FIRE CLASSIFICATION

The system fire class rating requires installation in the manner specified in the SUNFRAME MICRORAIL (SFM) Installation Guide. SFM has been classified to the system level fire portion of UL 1703. This UL 1703 classification has been incorporated into the UL 2703 product certification. SFM has achieved Class A, B & C system level performance for low slope & steep sloped roofs when used in conjunction with type 1 and type 2 modules. Class A, B & C system level fire

performance is inherent in the SFM design, and no additional mitigation measures are required. The fire classification rating is valid for any roof pitch. There is no required minimum or maximum height limitation above the roof deck to maintain the Class A, B & C fire rating for SFM. SUNFRAME MICRORAIL™ components shall be mounted over a fire resistant roof covering rated for the application.

Module Type	Roof Slope	System Level Fire Rating	Microrail Direction	Module Orientation	Mitigation Required
Type 1 and Type 2	Steep Slope & Low Slope	Class A, B & C	East-West	Landscape OR Portrait	None Required

UL2703 TEST MODULES

See pages 22 and 23 for a list of modules that were electrically and mechanically tested or qualified with the SUNFRAME MICRORAIL (SFM) components outlined within this Installation Guide.

- Maximum Area of Module = 27.76 sqft
- UL2703 Design Load Ratings:
 - Downward Pressure 113 PSF / 5400 Pa a)
 - b) Upward Pressure – 50 PSF / 2400 Pa
 - Down-Slope Load 21.6 PSF / 1034 Pa c)
- Tested Loads:
 - Downward Pressure 170 PSF / 8000 Pa a)
 - b) Upward Pressure – 75 PSF / 3500 Pa
 - Down-Slope Load 32.4 PSF / 1550 Pa c)
- Maximum Span = 6ft
- Use with a maximum over current protection device OCPD of 30A
- System conforms to UL Std 2703, certified to LTR AE-001-2012
- Rated for a design load of 2400 Pa / 5400 Pa with 24 inch span
- PV modules may have a reduced load rating, independent of the SFM load rating. Please consult the PV module manufacturer's installation guide for more information
- Down-Slope design load rating of 30 PSF/ 1400 Pa for module areas of 22.3 sq ft or less



1403 N. Research Way Orem, UT 84097

HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE O IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEP IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY

PLOT DATE:

PROJECT NUMBER

SPEC SHEET

REVISION:

SS



TESTED / CERTIFIED MODULE LIST | 22 INSTALLATION GUIDE | PAGE

Manufacture	Module Model / Series
Aleo	P-Series
Aptos	DNA-120-(BF/MF)26 DNA-144-(BF/MF)26
Astronergy	CHSM6612P, CHSM6612P/HV, CHSM6612M, CHSM6612M/HV, CHSM6610M (BL)(BF)/(HF), CHSM72M-HC
Auxin	AXN6M610T, AXN6P610T, AXN6M612T & AXN6P612T
Axitec	AXIblackpremium 60 (35mm), AXIpower 60 (35mm), AXIpower 72 (40mm), AXIpremium 60 (35mm), AXIpremium 72 (40mm).
Boviet	BVM6610, BVM6612
BYD	P6K & MHK-36 Series
Canadian Solar	CS1(H/K/U/Y)-MS CS3(K/L/U), CS3K-MB-AG, CS3K-(MS/P) CS3N-MS, CS3U-MB-AG, CS3U-(MS/P), CS3W CS5A-M, CS6(K/U), CS6K-(M/P), CS6K-MS CS6P-(M/P), CS6U-(M/P), CS6V-M, CS6X-P
Centrosolar America	C-Series & E-Series
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04
Dehui	DH-60M

Manufacture	Module Model / Series			
Eco Solargy	Orion 1000 & Apollo 1000			
ET Solar	ET-M672BHxxxTW			
Freedom Forever	FF-MP-BBB-370			
FreeVolt	Mono PERC			
GCL	GCL-P6 & GCL-M6 Series			
Hansol	TD-AN3, TD-AN4, UB-AN1, UD-AN1			
Heliene	36M, 60M, 60P, 72M & 72P Series, 144HC M6 Monofacial/ Bifacial Series, 144HC M10 SL Bifacial			
HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)			
Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series HiA-SxxxHG			
ITEK	iT, iT-HE & iT-SE Series			
Japan Solar	JPS-60 & JPS-72 Series			
JA Solar	JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/xxx, JAP6(k)-72-xxx/4BB, JAP72SYY-xxx/ZZ, JAP6(k)-60-xxx/4BB, JAP60SYY-xxx/ZZ, JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HiT, IB, MW, MR			
Jinko	JKM & JKMS Series Eagle JKMxxxM JKMxxxM-72HL-V			
Kyocera	KU Series			

Manufacture	Module Model / Series
	LGxxxN2T-A4
	LGxxx(A1C/E1C/E1K/N1C/N1K/N2T/N2W/
	Q1C/Q1K/S1C/S2W)-A5
	LGxxxN2T-B5
	LGxxxN1K-B6
	LGxxx(A1C/M1C/M1K/N1C/N1K/Q1C/Q1K/
LG Electronics	QAC/QAK)-A6
	LGxxx(N1C/N1K/N2T/N2W)-E6
	LGxxx(N1C/N1K/N2W/S1C/S2W)-G4
	LGxxxN2T-J5
	LGxxx(N1K/N1W/N2T/N2W)-L5
	LGxxx(N1C/Q1C/Q1K)-N5
	LGxxx (N1C/N1K/N2W/Q1C/Q1K)-V5
	LR4-60(HIB/HIH/HPB/HPH)-xxxM
	LR4-72(HIH/HPH)-xxxM
	LR6-60(BP/HBD/HIBD)-xxxM (30mm)
	LR6-60(BK)(PE)(HPB)(HPH)-xxxM (35mm)
LONGi	LR6-60(BK)(PE)(PB)(PH)-xxxM (40mm)
	LR6-72(BP)(HBD)(HIBD)-xxxM (30mm)
	LR6-72(HV)(BK)(PE)(PH)(PB)(HPH)-xxxM
	(35mm)
	LR6-72(BK)(HV)(PE)(PB)(PH)-xxxM (40mm)
Mission Solar Energy	MSE Series
Mitsubishi	MJE & MLE Series
Neo Solar Power Co.	D6M & D6P Series

- Unless otherwise noted, all modules listed above include all wattages and specific models within that series. Variable wattages are represented as "xxx"
- Items in parenthesis are those that may or may not be present in a compatible module's model ID
- Slashes "/" between one or more items indicates that either of those items may be the one that is present in a module's model ID
- Please see the SFM UL2703 Construction Data Report at Unirac.com to ensure the exact solar module selected is approved for use with SFM
- SFM Infinity is not compatible with module frame height of less than 30mm and more than 40mm. See Module Mounting section, page 12 for further information



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:



TESTED / CERTIFIED MODULE LIST | 23 INSTALLATION GUIDE | PAGE

Manufacture	Module Model / Series
	EVPVxxx (H/K/PK),
	VBHNxxxSA15 & SA16,
	VBHNxxxSA17 & SA18,
Panasonic	VBHNxxxSA17(E/G) & SA18E,
	VBHNxxxKA01 & KA03 & KA04,
	VBHNxxxZA01, VBHNxxxZA02,
	VBHNxxxZA03, VBHNxxxZA04
Peimar	SGxxxM (FB/BF)
Phono Solar	PS-60, PS-72
Prism Solar	P72 Series
	Plus, Pro, Peak, G3, G4, G5, G6(+), G7, G8(+)
	Pro, Peak L-G2, L-G4, L-G5, L-G6, L-G7
	Q.PEAK DUO BLK-G6+
	Q.PEAK DUO BLK-G6+/TS
Q.Cells	Q.PEAK DUO (BLK)-G8(+)
Q.Cetts	Q.PEAK DUO L-G8.3/BFF
	Q.PEAK DUO (BLK) ML-G9(+)
	Q.PEAK DUO XL-G9/G9.2/G9.3
	Q.PEAK DUO (BLK) ML-G10(+)
	Q.PEAK DUO XL-G(10/10.2/10.3/10.c/10.d)
	Alpha (72) (Black) (Pure)
	N-Peak (Black)
REC	N-Peak 2 (Black)
NLC	PEAK Energy Series
	PEAK Energy BLK2 Series
	PEAK Energy 72 Series

Manufacture	Module Model / Series	
	TwinPeak Series	
REC (cont.)	TwinPeak 2 Series	
	TwinPeak 2 BLK2 Series	
	TwinPeak 2S(M)72(XV)	
	TwinPeak 3 Series (38mm)	
	TP4 (Black)	
Renesola	Vitrus2 Series & 156 Series	
Risen	RSM72-6 (MDG) (M), RSM60-6	
SEG Solar	SEG-xxx-BMD-HV	
S-Energy	SN72 & SN60 Series (40mm)	
Seraphim	SEG-6 & SRP-6 Series	
Sharp	NU-SA & NU-SC Series	
Cilfab	SLA, SLG, BC Series & SILxxx(BL/NL/NT/HL	
Silfab	ML/BK/NX/NU/HC)	
Solarever USA	SE-166*83-xxxM-120N	
	PowerXT-xxxR-(AC/PD/BD)	
Solaria	PowerXT-xxxC-PD	
	PowerXT-xxxR-PM (AC)	
SolarWorld	Sunmodule Protect,	
Solai World	Sunmodule Plus	
	SS-M-360 to 390 Series,	
	SS-M-390 to 400 Series,	
Sonali	SS-M-440 to 460 Series,	
	SS-M-430 to 460 BiFacial Series,	
	SS 230 - 265	
SunEdison	F-Series, R-Series & FLEX FXS Series	
Suniva	MV Series & Optimus Series	

Manufacture	Module Model / Series
SunPower	A-Series A400-BLK , SPR-MAX3-XXX-R,
	X-Series, E-Series & P-Series
Suntech	STP, STPXXXS - B60/Wnhb
T-1	TP572, TP596, TP654, TP660,
Talesun	TP672, Hipor M, Smart
Toolo	SC, SC B, SC B1, SC B2
Tesla	TxxxH, TxxxS
	PA05, PD05, DD05, DE06, DD06, PE06,
Trina	PD14, PE14, DD14, DE09.05, DE14, DE15,
	PE15H
Uncolor	UP-MxxxP(-B),
Upsolar	UP-MxxxM(-B)
	D7MxxxH7A, D7(M/K)xxxH8A
URE	FAKxxx(C8G/E8G), FAMxxxE7G-BB
	FAMxxxE8G(-BB)
	Eldora,
Vikram	Solivo,
	Somera
Waaree	AC & Adiya Series
Winaico	WST & WSP Series
Yingli	YGE & YLM Series
ZN Shine	ZXM6-72, ZXM6-NH144-166 2094

- Unless otherwise noted, all modules listed above include all wattages and specific models within that series. Variable wattages are represented as "xxx"
- Items in parenthesis are those that may or may not be present in a compatible module's model ID
- Slashes "/" between one or more items indicates that either of those items may be the one that is present in a module's model ID
- Please see the SFM UL2703 Construction Data Report at Unirac.com to ensure the exact solar module selected is approved for use with SFM
- SFM Infinity is not compatible with module frame height of less than 30mm and more than 40mm. See Module Mounting section, page 12 for further information



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

PAGE NUMBER:

SS



AUTHORIZATION TO MARK

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Unirac, Inc Manufacturer: Redacted information

1411 Broadway Blvd NE Address: Albuquerque, NM 87102

USA Country:

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Intertek Testing Services NA, Inc., Lake Forest, CA

Control Number: *5003705* Authorized by: for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015 Ed.1+R:24Mar2021] Standard(s):

PV Module and Panel Racking Mounting System and Accessories [CSA TIL No. A-40:2020]

Page 1 of 4

Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2022SEP28 Product:

Brand Name: Unirac Unirac SFM Models:

ATM for Report 102393982LAX-002

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Unirac, Inc Manufacturer: Redacted information

1411 Broadway Blvd NE Address: Albuquerque, NM 87102

USA Country:

Party Authorized To Apply Mark: Same as Manufacturer

Intertek Testing Services NA, Inc., Lake Forest, CA Report Issuing Office:

Control Number: *5014989* Authorized by: for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must list be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015 Ed.1+R:24Mar2021]

Standard(s):

PV Module and Panel Racking Mounting System and Accessories [CSA TIL No. A-40:2020]

Page 2 of 4

Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2022SEP28 Product:

Brand Name: Unirac Models: Unirac SFM 1403 N. Research Way

Orem. UT 84097 800.377.4480

WWW BLUERAVENSOLAR COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

ATM Issued: 27-Oct-2022

ED 16.3.15 (1-Jul-2022) Mandatory

SPEC SHEET

REVISION:

SS

AGE NUMBER:

ATM Issued: 27-Oct-2022 ED 16.3.15 (1-Jul-2022) Mandatory



AUTHORIZATION TO MARK

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Unirac, Inc Manufacturer: Redacted information

1411 Broadway Blvd NE Address: Albuquerque, NM 87102

USA Country:

Party Authorized To Apply Mark: Same as Manufacturer

Intertek Testing Services NA, Inc., Lake Forest, CA Report Issuing Office:

Control Number: *5019851* Authorized by: for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

PV Module and Panel Racking Mounting System and Accessories [CSA TIL No. A-40:2020]

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015 Ed.1+R:24Mar2021] Standard(s):

Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2022SEP28 Product:

Brand Name: Unirac Models:

Unirac SFM

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Unirac, Inc Manufacturer: Redacted information

1411 Broadway Blvd NE Address: Albuquerque, NM 87102

USA Country:

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Intertek Testing Services NA, Inc., Lake Forest, CA

Control Number: *5021866* Authorized by: for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number. This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned

by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must list be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015 Ed.1+R:24Mar2021]

Standard(s):

PV Module and Panel Racking Mounting System and Accessories [CSA TIL No. A-40:2020]

Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2022SEP28 Product:

Brand Name: Unirac Models: Unirac SFM 1403 N. Research Way

Orem. UT 84097

800.377.4480 WWW BLUERAVENSOLAR COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OF IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

AGE NUMBER: SS


ATM Issued: 27-Oct-2022 ATM for Report 102393982LAX-002 Page 3 of 4

ATM Issued: 27-Oct-2022



1.0 Reference and Address

Listing Constructional Data Report (CDR)



Report Number	102393982LAX-002	Original	11-Apr-2016
Standard(s)	Mounting Systems, Mounting Systems, Mowith Flat-Plate Photovo	oltaic Modules an	d Panels [UL 2703
Applicant	Unirac, Inc		Manufacturer 2
Address	1411 Broadway Blvd N Albuquerque, NM 8710		Address
Country	USA		Country
Contact	Klaus Nicolaedis Todd Ganshaw		Contact
Phone	505-462-2190 505-843-1418		Phone
FAX	NA		FAX
Email	klaus.nicolaedis@uniratoddg@unirac.com	ac.com	Email
Manufacturer 3			Manufacturer 4
Address			Address
Country			Country
Contact			Contact
Phone			Phone
FAX	[FAX
Email			Email

Address

Country

Contact

Phone

Page 1 of 138

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Listing Constructional Data Report (CDR)

1.0 Reference a	nd Address			
Report Number	102393982LAX-002	Original 11-Apr-20)16	Revised: 5-Oct-2022
Email				



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

Page 2 of 13

SPEC SHEET

AGE NUMBER:

SS

REVISION:

SHEET NAME:

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

.___ |

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Description

Page 3 of 138 Issued: 11-

Issued: 11-Apr-2016 Revised: 5-Oct-2022 Page 4 of 138

Report No. 102393982LAX-002

Unirac, Inc

Other Ratings NA

Issued: 11-Apr-2016 Revised: 5-Oct-2022

> 1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

2.0 Product Des	_ '
Models	Unirac SFM
Model Similarity	NA
	Fuse Rating: 30A Module Orientation: Portrait or Landscape Maximum Module Size: 17.98 ft²
	UL2703 Design Load Rating: 33 PSF Downward, 33 PSF Upward, 10 PSF Down-Slope Tested Loads - 50 psf/2400Pa Downward, 50psf/2400Pa Uplift, 15psf/720Pa Down Slope Trina TSM-255PD05.08 and Sunpower SPR-E20-327 used for Mechanical Loading
	Increased size ML test: Maximum Module Size: 22.3 ft² UL2703 Design Load Rating: 113 PSF Downward, 50 PSF Upward, 30 PSF Down-Slope LG355S2W-A5
	used for Mechanical Loading test. Mounting configuration: Four mountings on each long side of panel with the longest span of 24" UL2703 Design Load Rating: 46.9 PSF Downward, 40 PSF Upward, 10 PSF Down-Slope LG395N2W-A5,
	LG360S2W-A5 and LG355S2W-A5 used for used for Mechanical Loading test. Mounting configuration: Six mountings for two modules used with the maximum span of 74.5" IEC 61646 Test Loads - 112.78 psf/5400Pa Downward, 50psf/2400Pa Uplift
Ratings	Mechanical Load test to add FlashLoc Slider and Trim Assemblies to UL2703 and IEC 61646 Certifications, & Increase SFM System UL2703 Module Size: Maximum Module Size: 27.76 ft²
	UL2703 Design Load Rating: 113 PSF Downward, 50 PSF Upward, 21.6 PSF Down-Slope Jinko Eagle 72HM G5 used for Mechanical Loading test.
	Mounting configuration: Four mountings on each long side of panel with the longest span of 24" Mamzimum module size: 21.86 ft2 IEC 61646 Test Loads - 112.78 psf/5400Pa Downward, 75psf/3600Pa Uplift
	SunPower model SPR-A430-COM-MLSD used for Mechanical Loading
	Fire Class Resistance Rating: - Class A for Steep Slope Applications when using Type 1 Modules. Can be installed at any interstitial gap. Installations must include Trim Rail Class A for Steep Slope Applications when using Type 2 Modules. Can be installed at any
	interstitial gap. Installations must include Trim Rail. - Class A Fire Rated for Low Slope applications with Type 1 or 2 listed photovoltaic modules. This system was evaluated with a 5" gap between the bottom of the module and the roof's surface
	See section 7.0 illustractions # 1, 1a and 1b for a complete list of PV modules evaluated with these racking systems

Product Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2022SEP28

Brand name Unirac

The product covered by this report is the Sun Frame Micro Rail roof mounted Photovoltaic Rack Mounting System. This system is designed to provide bonding and grounding to photovoltaic modules. The mounting system employs anodized or mill finish aluminum brackets that are roof mounted using the slider, outlined in section 4 of this report. There are no rails within this product, whereas the 3" Micro Rail, Floating Splice, and 9" Attached Splice electrically bond the modules together forming the path to ground.

The Micro Rails are installed onto the module frame by using a stainless steel bolt anodized with black oxide with a stainless type 300 bonding pin, torqued to 20 ft-lbs, retaining the modules to the bracket. The bonding pin of the Micro Rail when bolted and torqued, penetrate the anodized coating of the photovoltaic module frame (at bottom flange) to contact the metal, creating a bonded connection from module to module.

The grounding of the entire system is intended to be in accordance with the latest edition of the National Electrical Code, including NEC 250: Grounding and Bonding, and NEC 690: Solar Photovoltaic Systems or the Canadian Electrical Code, CSA C22.1 Part 1 in accordance to the revision in effect in the jurisdiction in which the project resides. Any local electrical codes must be adhered in addition to the national electrical codes. The Grounding Lug is secured to the photovoltaic module, torqued in accordance with the installation manual provided in this document.

Other optional grounding includes the use of the Enphase UL2703 certified grounding system, which requires a minimum of 2 micro-inverters mounted to the same rail, and using the same engage cable.

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

PAGE NUMBER:

ED 16.3.15 (1-Jul-2022) Mandatory ED 16.3.15 (1-Jul-2022) Mandatory

Page 42 of 138 Issue

Issued: 11-Apr-2016 Report No. 102393982LAX-002 Unirac, Inc

Page 43 of 138

Issued: 11-Apr-2016 Revised: 5-Oct-2022 BLUE RAVEN

1403 N. Research Way Orem, UT 84097 800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

7.0 Illustrations

Illustration 1a - Approved PV Modules Continue

Manufacture	Module Model / Series	Manufacture	Module Model / Series
LGxxxxN2T-A4 LGxxx(A1C/E1C/E1K/N1C/N1K/N2T/N2W/Q1C/Q1K/S1C/S2W)-A5 LGxxxX1Z-B5 LGxxxX1K-B6 LGxxx(A1C/M1C/M1K/N1C/N1K/Q1C/Q1K/Q1C/Q1K/QAC/QAK)-A6	Panasonic	EVPVxxx (H/K/PK), VBHNxxxSA15 & SA16, VBHNxxxSA17 & SA18, VBHNxxxSA17(E/G) & SA18E, VBHNxxxKA01 & KA03 & KA04, VBHNxxxZA01, VBHNxxxZA02, VBHNxxxZA03, VBHNxxxZA04	
	LGxxx(N1C/N1K/N2T/N2W)-E6	Peimar	SGxxxM (FB/BF)
	LGxxx(N1C/N1K/N2W/S1C/S2W)-G4 LGxxxN2T-J5	Phono Solar	PS-60, PS-72
	LGxxx(N1K/N1W/N2T/N2W)-L5	Prism Solar	P72 Series
	LGxxx(N1C/Q1C/Q1K)-N5 LGxxx (N1C/N1K/N2W/Q1C/Q1K)-V5 LR4-60(HIB/HIH/HPB/HPH)-xxxM		Plus, Pro, Peak, G3, G4, G5, G6(+), G7, G8(+) Pro, Peak L-G2, L-G4, L-G5, L-G6, L-G7 Q.PEAK DUO BLK-G6+
LONGI	LR4-72(HIH/HPH)-xxxM LR6-60(BP/HBD/HIBD)-xxxM (30mm) LR6-60(BK)(PE)(HPB)(HPH)-xxxM (35mm) LR6-60(BK)(PE)(PB)(PH)-xxxM (40mm) LR6-72(BP)(HBD)(HIBD)-xxxM (30mm) LR6-72(HV)(BK)(PE)(PH)(PB)(HPH)-xxxM (35mm)	Q.Ceits	Q.PEAK DUO BLK:-G6+/TS Q.PEAK DUO (BLK)-G8(+) Q.PEAK DUO L-G8.3/BFF Q.PEAK DUO (BLK) ML-G9(+) Q.PEAK DUO XL-G9/G9.2/G9.3 Q.PEAK DUO (BLK) ML-G10(+) Q.PEAK DUO XL-G(10/10.2/10.3/10.c/10.d)
	LR6-72(BK)(HV)(PE)(PB)(PH)-xxxM (40mm)		Alpha (72) (Black) (Pure) N-Peak (Black)
Mission Solar Energy	MSE Series		N-Peak 2 (Black)
Mitsubishi	MJE & MLE Series	REC	PEAK Energy Series
Neo Solar Power Co.	D6M & D6P Series		PEAK Energy BLK2 Series PEAK Energy 72 Series

7.0 Illustrations

Illustration 1 - Approved PV Modules

Manufacture	Module Model / Series	
Aleo	P-Series	
Aptos	DNA-120-(BF/MF)26 DNA-144-(BF/MF)26	
Astronergy	CHSM6612P, CHSM6612P/HV, CHSM6612M CHSM6612M/HV, CHSM6610M (BL)(BF)/(HF CHSM72M-HC	
Auxin	AXN6M610T, AXN6P610T, AXN6M612T & AXN6P612T	
Axitec	AXIblackpremium 60 (35mm), AXIpower 60 (35mm), AXIpower 72 (40mm), AXIpremium 60 (35mm), AXIpremium 72 (40mm).	
Boviet	BVM6610, BVM6612	
BYD	P6K & MHK-36 Series	
Canadian Solar	C51(H/K/U/Y)-MS C53(K/L/U), C53K-MB-AG, C53K-(MS/P) C53N-MS, C53U-MB-AG, C53U-(MS/P), C53W C55A-M, C56(K/U), C56K-(M/P), C56K-MS C56P-(M/P), C56I-(M/P), C56V-M, C56X-P	
Centrosolar America	C-Series & E-Series	
CertainTeed	CT2xxMxx-01, CT2xxPxx-01, CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04	
Dehul	DH-60M	

Manufacture	Module Model / Series		
Eco Solargy	Orion 1000 & Apollo 1000		
ET Solar	ET-M6728HxxxTW		
Freedom Forever	FF-MP-BBB-370		
FreeVolt	Mono PERC		
GCL	GCL-P6 & GCL-M6 Series		
Hansol	TD-AN3, TD-AN4, UB-AN1, UD-AN1		
Heliene	36M, 60M, 60P, 72M & 72P Series, 144HC M6 Monofacial/ Bifacial Series, 144HC M10 SL Bifacial		
HT Solar	HT60-156(M) (NDV) (-F), HT 72-156(M/P)		
Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series HiA-SxxxHG		
ITEK	IT, IT-HE & IT-SE Series		
Japan Solar	JPS-60 & JPS-72 Series		
JA Solar	IAP6 60-xxx, IAM6-60-xxx/SI, IAM6(K)-60/ xxx, IAP6(k)-72-xxx/4BB, IAP72SYY-xxx/ZZ IAP6(k)-60-xxx/4BB, IAP60SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, IAM72SYY-xxx/ZZ, IAM6(k)-60-xxx/ZZ, IAM60SYY-xxx/ZZ. i, YY: 01, 02, 03, 09, 10 ii, ZZ: SC, PR, BP, HiT, IB, MW, MR		
linko	JKM & JKMS Series Eagle JKMooxM JKMxxxM-72HL-V		
Kyocera	KU Series		

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

Page 44 of 138

Issued: 11-Apr-2016 Revised: 5-Oct-2022

7.0 Illustrations

Illustration 1b - Approved PV Modules Continue

Manufacture	Module Model / Series
	TwinPeak Series
	TwinPeak 2 Series
	TwinPeak 2 BLK2 Series
REC (cont.)	TwinPeak 2S(M)72(XV)
	TwinPeak 3 Series (58mm)
	TP4 (Black)
Renesola	Vitrus2 Series & 156 Series
Risen	RSM72-6 (MDG) (M), RSM60-6
SEG Solar	SEG-xxx-BMD-HV
S-Energy	SN72 & SN60 Series (40mm)
Seraphim	SEG-6 & SRP-6 Series
Sharp	NU-SA & NU-SC Series
	SLA, SLG, BC Series & SILxxx(BL/NL/NT/HL,
Silfab	ML/BK/NX/NU/HC)
Solarever USA	SE-166*83-xxxM-120N
	PowerXT-xxxR-(AC/PD/BD)
Solaria	PowerXT-xxxC-PD
	PowerXT-xxxR-PM (AC)
SolarWorld	Sunmodule Protect,
Solar World	Sunmodule Plus
	SS-M-360 to 390 Series,
	SS-M-390 to 400 Series,
Sonati	SS-M-440 to 460 Series,
	SS-M-430 to 460 BiFacial Series,
	SS 230 - 265
SunEdison	F-Series, R-Series & FLEX FXS Series
Suniva	MV Series & Optimus Series

Manufacture	Module Model / Series	
SunPower	A-Series A400-BLK , SPR-MAX3-XXX-R, X-Series, E-Series & P-Series	
Suntech	STP, STPXXXS - 860/Winhb	
Talesun	TP572, TP596, TP654, TP660, TP672, Hipor M, Smart	
Testa	SC, SC B, SC B1, SC B2 TxxxH, TxxxS	
Trina	PAOS, PDOS, DDOS, DCO6, DDOG, PEO6, PD14, PE14, DD14, DE09.05, DE14, DE15 PE15H	
Upsolar	UP-MxxxP(-B), UP-MxxxM(-B) D7MxxxH7A, D7(M/K)xxxH8A FAKxxx(C8G/E8G), FAMxxxE7G-BB FAMxxxE8G(-BB)	
URE		
Vikram	Eldora, Solivo, Somera	
Waaree	AC & Adiya Series	
Winaico	WST & WSP Series	
Yingti	YGE & YLM Series	
ZN Shine	ZXM6-72, ZXM6-NH144-166 2094	



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: BRS FIELD OPS 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:


SPEC SHEET

REVISION:

Temperature range

RECORD LOW RECORD HIGH

-27 34






















IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC

1403 N. Research Way Orem, UT 84097 800.377.4480 WWW.BLUERAVENSOLAR.COM


CONFIDENTIAL- THE INFORMATION



PV INSTALLATION **PROFESSIONAL**


Scott Gurney #PV-011719-015866


CONTRACTOR: **BRS FIELD OPS** 385-498-6700























SEG-400-BMD-HV





* IQ8H-208 support split phase, 208V only.





















Compatible \times Not compatible

Notice

Modules paired with Enphase microinverters with Integrated Ground must use PV Wire or PV Cable that is compliant with NEC 690.35(D) for Ungrounded PV Power Systems. When using this solar panel calculator, do not connect an Enphase microinverter to a module that the calculator indicates is incompatible. Doing so may void the warranty. This calculator only shows the compatibility of the modules with Enphase microinverters and doesn't provide any information on clipping that may occur due to sizing and other DC parameters of the PV module. Enphase IQ Series microinverters are compatible with bi-facial PV modules if the temperature adjusted electrical parameters (maximum power, voltage and current) of the modules, considering the electrical parameters including the Bifacial gain, are within the allowable microinverter input parameters range. In evaluating the amount of Bifaciality gain, follow the recommendations of the module manufacturers.

V2-NA-EN-08-18

Copyright © 2022 Enphase Energy. All rights reserved.

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

SS



UNIRAC, INC. **PROGRESS LETTER REPORT**

SCOPE OF WORK

SUN Update for three existing reports of 102675852LAX-001(Bonding Clip), 102393982LAX-002 (SFM) and 102675852LAX-002 (MLPE Mount) and addition of PV modules to SFM report

REPORT NUMBER:

105140118LAX-001b

ISSUE DATE

09/27/22

PAGES

DOCUMENT CONTROL NUMBER

GFT-OP-10a (21-June-2019) © 2019 INTERTEK





PROGRESS LETTER REPORT

25800 Commercentre Drive Lake Forest, CA 92630 USA

Telephone: (949) 448-4100 Facsimile: (949) 448-4111 www.intertek.com

Report No. 105140118LAX-001b Intertek Project No. G105140118

Klaus Nicolaedis Unirac Inc. 1411 Broadway Blvd NE Albuquerque, NM 87102-1545

Subject:

9/27/22

SUN Update for three existing reports of 102675852LAX-001 (Bonding Clip), 102393982LAX-002 (SFM) and 102675852LAX-002 (MLPE Mount) and addition of PV module to SFM report

Dear Klaus,

This letter report represents the result of the construction evaluation of the SUN letter and PV module addition to the requirements contained in the following standards:

Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703:2015] Ed.1+R:24Mar202111

SECTION 1

SUMMARY

The scope of this project was to perform an evaluation for SUN update that is standard update from May 2019 revision to 2021 and 7 PV module addition. 3 additional module manufacturers were requested and evaluated at the same time. This project, G1051408118 was authorized by quote Qu-01275837-3 dated July 15, 2022.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification

GFT-OP-10a Version: 21-June-2019 Page 2 of 4



1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION **PROFESSIONAL**

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION:

SS



PROGRESS LETTER REPORT

Unirac, Inc. Intertek Report No: 105140118LAX-001b

SECTION 2

S.U.N. CONSTRUCTION EVALUATION to UL 2703

UL2703 REVISION MARCH 24 TH , 2021 EVALUATION							
CLAUSE	VERDICT	COMMENT	EVALUATION				
9	INFO	BONDING					
9.2	New Manual needed	Routine maintenance of a PV module or mounting system, e. g. inspection or cleaning, shall not involve breaking or disturbing the bonding path of the system. If the removal of a module may break or disrupt the bonding path of the system, the installation manual shall comply with 26.10.	Update the instructions, it either: 1. Needs to be clear removing 1 module cannot break bonding path to grounding lug for multiple modules 2. Needs to comply with 26.10 below				
26.10	New Manual needed	For a system where the removal of a module may break or disrupt the bonding path of the system (see 9.2), the installation manual shall comply with all of the following: a) Module removal is not presented as a frequently expected occurrence and will not be required as part of routine maintenance. b) Include the following statement, or equivalent "CAUTION: Module removal may disrupt the bonding path and could introduce the risk of electric shock. Additional steps may be required to maintain the bonding path. Modules should only be removed by qualified persons in compliance with the instructions in this manual." c) Scenarios that could result in a disruption of the bonding path are described, for example irregularly-shaped arrays, arrays consisting of individual rows, and any other scenario where module removal could disrupt the bonding path. d) Instructions for maintaining a complete bonding path when modules are removed.	 b) Please add b) compliance "CAUTION:" quote c) Please comply with C, the methods and actions are left to you. d) Please provide item d on the user manual 				



Unirac, Inc. Intertek Report No: 105140118LAX-001b

PROGRESS LETTER REPORT

The following PV Modules can be added to the system:

Model Name	Verdict	Comment (full added models)	
Freedom Forever	Pass	FF-MP-BBB-370	
Heliene	Pass	144HC M6 Monofacial and Bifacial, 144HC M10 SL Bifacial	
Panasonic	Pass	EVPV 350 PK, EVPVxxx 360, 370, EVPVxxx 370, 380, EVPVxxxH 400, 410, EVPVxxxK 350, 360, EVPVxxxK 360, 370, EVPVxxxK 360, 370	
SEG	Pass	SEG-XXX-BMD-HV	
SolarEver	Pass	SE-166_83-xxxM-120N	
Sonali	Pass SS-M Bi Facial 144 Cell, SS-M-360 to 390 Series, SS-M-390 to 400 Series, SS-M-440 to 460 Series		
(Wuxi) Suntech	Pass	STPXXXS - B60/Wnhb	
Sunpower (Maxeon)	Pass	A-Series A400-BLK, SPR-MAX3-XXX-R	
Tesla	Pass	TxxxH	
ZN Shine	Pass	ZXM6-NH144-166_2094	

SECTION 3

PROJECT STATUS & ACTION

Issuance of this letter report provides status of construction evaluation covered by Intertek Project G105140118. To complete the update INTERTEK needs a new instruction manual. No more information or details are needed to complete the addition of PV models to the listings. Please provide an updated manual.

If there are any questions regarding the results contained in this report, or any of the other services offered by Intertek, please do not hesitate to contact your dedicated Intertek Project Manager.

Completed by: Title:	Andrew Gunnoe Project Engineer	Reviewed by: Title:	Abhinav Prakash Reviewer			
Signature:	Ordraw Murmoe	Signature	All			
Date	09/27/22	Date:	09/27/22			
Diagram and a third attending to the diagram of an attending to the contract of an attending to the contract of the contract o						

Please note: this Letter Report does not represent authorization for the use of any Intertek certification marks.

1403 N. Research Way Orem, UT 84097

800.377.4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL- THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE
RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT WITHOUT THE WRITTEN PERMISSION
OF BLUE RAVEN SOLAR LLC.



PV INSTALLATION PROFESSIONAL

Scott Gurney #PV-011719-015866

CONTRACTOR: **BRS FIELD OPS** 385-498-6700

DRAWING BY:

PLOT DATE:

PROJECT NUMBER:

SHEET NAME:

SPEC SHEET

REVISION: