



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

7/5/2023

**SUBJECT: ERES2304-0069**  
**ELECTRICAL RESIDENTIAL**

To: BARRETO RICHARD

Here are the results of all Inspections located at **89 CALDWELL ST:**

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 5/16/2023  
Completed Date/Time: 5/16/2023  
Inspector: John B Kokoszka  
Result: DISAPPROVED  
Remarks:  
Notes: Need to up load all the pictures of the install only got a few. Max overcurrent device doesn't match the plans

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 6/22/2023  
Completed Date/Time: 6/22/2023  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: see uploaded pic

