



Scott E. Wyssling, PE
Coleman D. Larsen, SE, PE
Gregory T. Elvestad, PE

76 North Meadowbrook Drive
Alpine, UT 84004
office (201) 874-3483
swysling@wysslingconsulting.com

February 14, 2023
Revised July 13, 2023

Titan Solar Power
210 North Sunway Drive
Gilbert, AZ 85233

Scott
Wyssling, PE

Digitally signed by Scott Wyssling, PE
DN: C=US, S=Utah, L=Alpine, O=Wyssling
Consulting, OU=Engineering, CN="Scott
Wyssling, PE",
E=swysling@wysslingconsulting.com
Reason: I am the author of this document
Location: your signing location here
Date: 2023.07.13 09:55:57-06'00'
Foxit PDF Editor Version: 11.1.0

Re: Engineering Services
Spivey Residence
131 Edna John Court, Dunn, NC
10.400 kW System

To Whom It May Concern:

We have received information regarding solar panel installation on the roof of the above referenced structure. Our evaluation of the structure is to verify the existing capacity of the roof system and its ability to support the additional loads imposed by the proposed solar system.

A. Site Assessment Information

1. Site visit documentation identifying attic information including size and spacing of framing for the existing roof structure.
2. Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information will be utilized for approval and construction of the proposed system.
3. During installation, please avoid stacking multiple panels/equipment on roof at any single location. If absolutely necessary, do not exceed a maximum of (2) panels at any single location.

B. Description of Structure:

Roof Framing: Assumed prefabricated wood trusses at 24" on center. All truss members are constructed of 2x2 dimensional lumber.

Roof Material: Composite Asphalt Shingles

Roof Slope: 14 & 22 degrees

Attic Access: Inaccessible

Foundation: Permanent

C. Loading Criteria Used

- **Dead Load**
 - Existing Roofing and framing = 7 psf
 - New Solar Panels and Racking = 3 psf
 - TOTAL = 10 PSF
- **Live Load** = 20 psf (reducible) – 0 psf at locations of solar panels
- **Ground Snow Load** = 15 psf
- **Wind Load** based on ASCE 7-10
 - Ultimate Wind Speed = 119 mph (based on Risk Category II)
 - Exposure Category C

Analysis performed of the existing roof structure utilizing the above loading criteria is in accordance with the 2018 NCRC, including provisions allowing existing structures to not require strengthening if the new loads do not exceed existing design loads by 105% for gravity elements and 110% for seismic elements. This analysis indicates that the existing framing will support the additional panel loading without damage, if installed correctly.


D. Solar Panel Anchorage

1. The solar panels shall be mounted in accordance with the most recent K2 Systems installation manual. If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
2. The maximum allowable withdrawal force for a M5 x 60mm lag screw is 213 lbs per inch of penetration as identified in the National Design Standards (NDS) of timber construction specifications. Based on a minimum penetration depth of 1-5/8", the allowable capacity per connection is greater than the design withdrawal force (demand). Considering the variable factors for the existing roof framing and installation tolerances, the connection using two (2) M5 x 60mm lag screw with a minimum of 1-5/8" embedment will be adequate and will include a sufficient factor of safety.
3. Considering the wind speed, roof slopes, size and spacing of framing members, and condition of the roof, the panel supports shall be placed no greater than 48" on center.

Based on the above evaluation, this office certifies that with the racking and mounting specified, the existing roof system will adequately support the additional loading imposed by the solar system. This evaluation is in conformance with the 2018 NCRC, current industry standards, and is based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Very truly yours,



Scott E. Wyssling, PE
North Carolina License No. 46546
COA # P-2308



Wyssling Consulting, PLLC
76 N Meadowbrook Drive Alpine UT 84004
North Carolina COA # P-2308

Signed 7/13/2023

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

**SPIVEY, STEPHEN PV SYSTEM
131 EDNA JOHN COURT .
DUNN, NC, 28334
APN: 021537 0110 09
JURISDICTION: HARNETT COUNTY (NC)
GENERAL INFORMATION**

SYSTEM SIZE: 10.400 kW-DC-STC
10.000 kW-AC

ROOF PITCHED: 14 DEGREES

INVERTER: (1) SOLAREEDGE ENERGYHUB SE10000H-US W/ S440 OPTIMIZERS
(1) SE ENERGYBANK 10K

MODULES: (26) HY-DH108P8-400B

STRINGS: (1) x 14 (1) x 12 MODULE SERIES STRINGS

ELECTRICAL SERVICE RATING: 200A

PV SYSTEM OVERCURRENT RATING: 100A

PV SYSTEM DISCONNECT SWITCH: EATON DG223NRB (100A / 2P)

ROOF TYPE: COMP SHINGLE

ROOF FRAMING: ENGINEERED TRUSS

RACKING/RAILING: K2 SYSTEMS / K2RAIL

ATTACHMENT METHOD: SPLICE FOOT


ROOF ATTACHMENT : M5 x 60 S.S LAG SCREWS

TABLE OF CONTENTS

| REQUIRED INFORMATION | SHEET NAME | SHEET NUMBER |
|--|-----------------------|--------------|
| SITE INFORMATION | COVER PAGE | PV 1 |
| MODULE AND EQUIPMENT LAYOUT | SITE PLAN | PV 2 |
| LOCATION & QUANTITY OF PACKING & STANDOFFS | PV LAYOUT | PV 3 |
| RACKING LOAD & UPLIFT CALCULATIONS | PV LAYOUT | PV 3 |
| ROOF ATTACHMENT DETAILS | DETAILS | PV 4 |
| ELECTRICAL 1 LINE DIAGRAM | ONE LINE | PV 5 |
| ELECTRICAL 3 LINE DIAGRAM | THREE LINE | PV 6 |
| OCP & WIRE SIZING CALCULATIONS | 1 & 3 LINE | PV 5 & 6 |
| ARRAY & INVERTER ELECTRICAL SPECIFICATIONS | 1 & 3 LINE | PV 5 & 6 |
| EQUIPMENT SPECIFICATIONS | 1 & 3 LINE | PV 5 & 6 |
| LABEL NOTES | LABELS | PV 7 |
| PV EQUIPMENT LABELING DETAIL | LABELS | PV 7 |
| DIRECTORY LABEL | PLACARD | PV 8 |
| JOB SAFETY PLAN | SAFETY PLAN | PV 9 |
| PV EQUIPMENT SPECIFICATIONS | EQUIPMENT SPEC. | PV 10 - 17 |
| DATA SHEETS & ADDITIONAL INFORMATION | SUPPLEMENTAL MATERIAL | |

VICINITY MAP

SCALE: NTS



AERIAL MAP

SCALE: NTS



Wyssling Consulting, PLLC
76 N Meadowbrook Drive Alpine UT 84004
North Carolina COA # P-2308
Signed 7/13/2023

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

NOTES

EQUIPMENT LOCATION


- ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY NEC 110.26.
- WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC690.31(A),(C) AND NEC TABLES 310.15(B)(2)(A) AND 310.15(B)(3)(C).
- JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.
- ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT.
- ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.
- ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

WIRING & CONDUIT NOTES

- ALL CONDUITS AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.
- CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7.
- DC WIRING LIMITED TO MODULE FOOTPRINT. MICRO INVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY WITH SUITABLE WIRING CLIPS.
- AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK, PHASE B OR L-2 RED, OR OTHER CONVENTION IF THREE PHASE, PHASE C OR L3-BLUE, YELLOW, ORANGE, OR OTHER CONVENTION NEUTRAL- WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH THE HIGHER VOLTAGE TO BE MARKED ORANGE NEC 110.15.

GENERAL NOTES

- MODULES ARE LISTED UNDER UL 1703 AND CONFORM TO THE STANDARDS.
- INVERTERS ARE LISTED UNDER UL 1741 AND CONFORM TO THE STANDARDS.
- DRAWINGS ARE DIAGRAMMATIC, INDICATING GENERAL ARRANGEMENT OF THE PV SYSTEM AND THE ACTUAL SITE CONDITION MIGHT VARY.
- WORKING CLEARANCES AROUND THE NEW PV ELECTRICAL EQUIPMENT WILL BE MAINTAINED IN ACCORDANCE WITH NEC 110.26.
- ALL GROUND WIRING CONNECTED TO THE MAIN SERVICE GROUNDING IN MAIN SERVICE PANEL/SERVICE COMPONENT.
- ALL CONDUCTORS SHALL BE 600V, 75° C STANDARD COPPER UNLESS OTHERWISE NOTED.
- WHEN REQUIRED, A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- THE SYSTEM WILL NOT BE INTERCONNECTED BY THE CONTRACTOR UNTIL APPROVAL FROM THE LOCAL JURISDICTION AND/OR THE UTILITY.
- ROOF ACCESS POINT SHALL BE LOCATED IN AREAS THAT DO NOT REQUIRE THE PLACEMENT OF GROUND LADDERS OVER OPENINGS SUCH AS WINDOWS WHERE THE ACCESS POINT DOES NOT CONFLICT WITH OVERHEAD OBSTRUCTIONS SUCH AS TREES, WIRES OR SIGNS.
- PV ARRAY COMBINER/JUNCTION BOX PROVIDES TRANSITION FROM ARRAY WIRING TO CONDUIT WIRING.



PROJECT NOTES

1. UTILITY SHALL HAVE 24HR UNRESTRICTED ACCESS TO ALL PHOTOVOLTAIC COMPONENTS LOCATED AT SES EQUIPMENT
2. NO LOCKED GATES, DOGS, ETC SHALL IMPEDE ACCESS TO SES EQUIPMENT
3. WORKSPACE IN FRONT OF AC ELECTRICAL SYSTEM COMPONENTS SHALL BE IN ACCORDANCE WITH DUKE ENERGY PROGRESS (NC) AND NEC REQUIREMENTS.



Wysling Consulting, PLLC
 76 N Meadowbrook Drive Alpine UT 84004
 North Carolina COA # P-2308
 Signed 7/13/2023

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



TITAN
 SOLAR POWER
 525 W BASELINE RD., MESA AZ, 85210
 CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
 131 EDNA JOHN COURT , DUNN, NC, 28334
 LAT:35.339800, LON:-78.652052
 TSP152526

(26) HY-DH108P8-400B
 (1) SOLAREEDGE ENERGYHUB SE10000H-US
 (1) SE ENERGYBANK 10K
 10.400 kW DC SYSTEM SIZE
 10.000 kW AC SYSTEM SIZE

SCALE: 9/256" = 1'-0"
 DATE: 7/13/2023
 REV: A
 DRAWN BY: JS

SEAL:

SITE PLAN
 PV 2

ARRAY INFORMATION

AR-01

QUANTITY: 8
 MOUNTING TYPE: FLUSH
 ARRAY TILT: 14°
 AZIMUTH: 129°
 ATTACHMENT SPACING: 4' STAGGERED
 ROOF TYPE: COMP SHINGLE

AR-02

QUANTITY: 7
 MOUNTING TYPE: FLUSH
 ARRAY TILT: 14°
 AZIMUTH: 129°
 ATTACHMENT SPACING: 4' STAGGERED
 ROOF TYPE: COMP SHINGLE

AR-03


QUANTITY: 2
 MOUNTING TYPE: FLUSH
 ARRAY TILT: 22°
 AZIMUTH: 219°
 ATTACHMENT SPACING: 4' STAGGERED
 ROOF TYPE: COMP SHINGLE

AR-04

QUANTITY: 2
 MOUNTING TYPE: FLUSH
 ARRAY TILT: 22°
 AZIMUTH: 39°
 ATTACHMENT SPACING: 4' STAGGERED
 ROOF TYPE: COMP SHINGLE

AR-05

QUANTITY: 7
 MOUNTING TYPE: FLUSH
 ARRAY TILT: 14°
 AZIMUTH: 309°
 ATTACHMENT SPACING: 4' STAGGERED
 ROOF TYPE: COMP SHINGLE



NOTES

- ROOF VENTS, SKYLIGHTS, WILL NOT BE COVERED UPON PV INSTALLATION
- TOTAL ROOF AREA = 1467 SQ-FT
- TOTAL ARRAY AREA = 546.59 SQ-FT
- ARRAY COVERAGE = 37.26%
-
-



Wyssling Consulting, PLLC
 76 N Meadowbrook Drive Alpine UT 84004
 North Carolina COA # P-2308
 Signed 7/13/2023

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



SPIVEY, STEPHEN RESIDENCE
 131 EDNA JOHN COURT, DUNN, NC, 28334
 LAT:35.339800, LON:-78.652052
 TSP152526

(26) HY-DH108P8-400B
 (1) SOLAREEDGE ENERGYHUB SE10000H-US
 (1) SE ENERGYBANK 10K
 10.400 kW DC SYSTEM SIZE
 10.000 kW AC SYSTEM SIZE

SCALE: 1/8" = 1'-0"
 DATE: 7/13/2023
 REV:A
 DRAWN BY: JS

SEAL:

PV LAYOUT
PV 3

MODULE & RACKING INFORMATION

MODULE: HY-DH108P8-400B
MODULE WEIGHT: 49.80 LBS
MODULE DIMENSIONS: 67.8" x 44.65" x 1.5"
RACKING/RAIL: K2 SYSTEMS / K2RAIL
ROOF ATTACHMENT : M5 x 60 S.S LAG SCREWS

ROOF & FRAMING INFORMATION

MATERIAL: COMP SHINGLE
RAFTER/TRUSS SIZE: 2" x 2"
RAFTER/TRUSS SPACING: 2'

ARRAY 01: 8 MODULES

UPLIFT = 5045.45 LBS.
POINT LOAD = 19.38 LBS. PER MOUNTING POINT
PULLOUT STRENGTH = 6930.00 LBS.
DISTRIBUTED LOAD = 2.54 PSF
MODULE & RACKING WEIGHT = 426.40 LBS

ARRAY 04: 2 MODULES

UPLIFT = 1261.36 LBS.
POINT LOAD = 17.77 LBS. PER MOUNTING POINT
PULLOUT STRENGTH = 1890.00 LBS.
DISTRIBUTED LOAD = 2.54 PSF
MODULE & RACKING WEIGHT = 106.60 LBS

ARRAY 02: 7 MODULES


UPLIFT = 4414.77 LBS.
POINT LOAD = 20.73 LBS. PER MOUNTING POINT
PULLOUT STRENGTH = 5670.00 LBS.
DISTRIBUTED LOAD = 2.54 PSF
MODULE & RACKING WEIGHT = 373.10 LBS

ARRAY 05: 7 MODULES

UPLIFT = 4414.77 LBS.
POINT LOAD = 20.73 LBS. PER MOUNTING POINT
PULLOUT STRENGTH = 5670.00 LBS.
DISTRIBUTED LOAD = 2.54 PSF
MODULE & RACKING WEIGHT = 373.10 LBS


ARRAY 03: 2 MODULES

UPLIFT = 1261.36 LBS.
POINT LOAD = 17.77 LBS. PER MOUNTING POINT
PULLOUT STRENGTH = 1890.00 LBS.
DISTRIBUTED LOAD = 2.54 PSF
MODULE & RACKING WEIGHT = 106.60 LBS



Wyssling Consulting, PLLC
76 N Meadowbrook Drive Alpine UT 84004
North Carolina COA # P-2308
Signed 7/13/2023

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT , DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREEDGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV:A
DRAWN BY: JS

SEAL:

DETAILS
PV 4

PV MODULE

HY-DH108P8-400B
 W = 400 W
 ISC = 13.79 ADC
 VOC = 37.07 VDC
 IMP = 12.90 ADC
 VMP = 31.21 VDC
 TVOC = -0.304% / °C

WIRE SCHEDULE


A - (4) #10 AWG-CU PV WIRE (HR)
 (1) #10 AWG-CU BARE COPPER WIRE (GND)
 IN FREE AIR
 B - (4) #10 AWG-CU THWN-2 WIRE (HR)
 (1) #10 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT

C - (3) #6 AWG-CU THWN-2 WIRE (HR)
 (1) #8 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT
 D - (3) 3/0 AWG-CU THWN-2 WIRE (HR)
 (1) #6 AWG-CU THWN-2 WIRE (GND)
 1" EMT
 E - (3) #6 AWG-CU THWN-2 WIRE (HR)
 (1) #8 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT

MAIN SERVICE PANEL

BUS RATING = 200A
 MAX. CURRENT RATING = 240A (200A X 1.2)
 SOLAR BACKFEED = 53A
 MAIN BREAKER = 200A
 TOTAL = 253A

7/13/2023




WIRE SIZE CALCULATIONS

TEMP CORRECTION FACTOR: 0.87 (43° AMBIENT)
 ROOFTOP TEMP CORRECTION FACTOR: 1.00 (43° ADJUSTED)
 (2" ABOVE ROOFTOP / 0° TEMP ADDERS - AS OCCURS)
 (TEMP DATA TAKEN FROM ASHRAE 2% AVG HIGH TEMP)

DC WIRING
 CONDUIT FILL FACTOR = 0.80
 OPTIMIZER MAX. CURRENT = 18.75A DC (15.00A X 1 X 1.25)
 #10- AWG CU. AMPACITY = 47.85A (55A X 0.87)
 FREE AIR
 #10 - AWG CU. AMPACITY = 27.84A (40A X 0.87 X 0.80)
 ROOFTOP CONDUIT

AC WIRING
 CONDUIT FILL FACTOR = 1 (3) CONDUCTORS
 MAX. INVERTER CURRENT = 42A (PER INVERTER SPECS)
 MIN. INVERTER OCP = 52.5A (42A X 1.25)
 INVERTER OCP = 60A
 #6 - AWG CU AMPACITY = 65.25A (75A X 1 X 0.87)



SPIVEY, STEPHEN RESIDENCE
 131 EDNA JOHN COURT, DUNN, NC, 28334
 LAT:35.339800, LON:-78.652052
 TSP152526

(26) HY-DH108P8-400B
 (1) SOLAREDBGE ENERGYHUB SE10000H-US
 (1) SE ENERGYBANK 10K
 10.400 kW DC SYSTEM SIZE
 10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
 REV:A
 DRAWN BY: JS

SEAL:

ONE LINE
 PV 5

PV MODULE

HY-DH108P8-400B
 W = 400 W
 ISC = 13.79 ADC
 VOC = 37.07 VDC
 IMP = 12.90 ADC
 VMP = 31.21 VDC
 TVOC = -0.304% / °C


WIRE SCHEDULE

A - (4) #10 AWG-CU PV WIRE (HR)
 (1) #10 AWG-CU BARE COPPER WIRE (GND)
 IN FREE AIR
 B - (4) #10 AWG-CU THWN-2 WIRE (HR)
 (1) #10 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT

C - (3) #6 AWG-CU THWN-2 WIRE (HR)
 (1) #8 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT
 D - (3) 3/0 AWG-CU THWN-2 WIRE (HR)
 (1) #6 AWG-CU THWN-2 WIRE (GND)
 1" EMT
 E - (3) #6 AWG-CU THWN-2 WIRE (HR)
 (1) #8 AWG-CU THWN-2 WIRE (GND)
 3/4" EMT

MAIN SERVICE PANEL

BUS RATING = 200A
 MAX. CURRENT RATING = 240A (200A X 1.2)
 SOLAR BACKFEED = 53A
 MAIN BREAKER = 200A
 TOTAL = 253A



WIRE SIZE CALCULATIONS


TEMP CORRECTION FACTOR: 0.87 (43° AMBIENT)
 ROOFTOP TEMP CORRECTION FACTOR: 1.00 (43° ADJUSTED)
 (2" ABOVE ROOFTOP / 0° TEMP ADDERS - AS OCCURS)
 (TEMP DATA TAKEN FROM ASHRAE 2% AVG HIGH TEMP)

DC WIRING

CONDUIT FILL FACTOR = 0.80
 OPTIMIZER MAX. CURRENT = 18.75A DC (15.00A X 1 X 1.25)
 #10- AWG CU. AMPACITY = 47.85A (55A X 0.87)
 FREE AIR
 #10 - AWG CU. AMPACITY = 27.84A (40A X 0.87 X 0.80)
 ROOFTOP CONDUIT

AC WIRING

CONDUIT FILL FACTOR = 1 (3) CONDUCTORS
 MAX. INVERTER CURRENT = 42A (PER INVERTER SPECS)
 MIN. INVERTER OCP = 52.5A (42A X 1.25)
 INVERTER OCP = 60A
 #6 - AWG CU AMPACITY = 65.25A (75A X 1 X 0.87)



SPIVEY, STEPHEN RESIDENCE
 131 EDNA JOHN COURT, DUNN, NC, 28334
 LAT:35.339800, LON:-78.652052
 TSP152526

(26) HY-DH108P8-400B
 (1) SOLAREDEGE ENERGYHUB SE10000H-US
 (1) SE ENERGYBANK 10K
 10.400 kW DC SYSTEM SIZE
 10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
 REV:A
 DRAWN BY: JS

SEAL:

THREE LINE
 PV 6

1

CAUTION
PHOTOVOLTAIC SYSTEM CIRCUIT IS BACKFED

LOCATION: BACKFED BREAKER
CODE REF: NEC 705.12(4)

2

WARNING
INVERTER OUTPUT CONNECTION:
DO NOT RELOCATE THIS
OVERCURRENT DEVICE

LOCATION: BACKFED BREAKER
CODE REF: 2017 NEC 705.12(2)(3)(b)

3

WARNING
A GENERATION SOURCE IS CONNECTED TO THE SUPPLY
(UTILITY) SIDE OF THE MAIN SERVICE DISCONNECT. FOLLOW
THE PROPER LOCK-OUT/TAG-OUT PROCEDURES TO ENSURE
THE PHOTOVOLTAIC SYSTEM UTILITY DISCONNECT SWITCH IS
OPENED PRIOR TO PERFORMING WORK ON THIS DEVICE

LOCATION: (IF APPLICABLE)
SUPPLY SIDE TAP
LOAD PANEL
CODE REF: UTILITY

4

PHOTOVOLTAIC AC DISCONNECT
RATED AC OPERATING CURRENT: 42A AC
NOMINAL OPERATING AC VOLTAGE: 240VAC

LOCATION: MAIN PANEL
AC DISCONNECT(S)
CODE REF: NEC 690.54

5

**RAPID SHUTDOWN
SWITCH FOR
SOLAR PV SYSTEM**

LOCATION: MAIN PANEL (EXTERIOR)
PV BREAKER (INTERIOR)
CODE REF: NEC 690.56(C)(3)

6

WARNING
ELECTRICAL SHOCK HAZARD
TERMINALS ON BOTH LINE AND
LOAD SIDES MAY BE ENERGIZED
IN THE OPEN POSITION

LOCATION: COMBINER PANEL
AC DISCONNECT
JUNCTION BOX
INVERTER(S)
CODE REF: NEC 690.13(B)

7

**PHOTOVOLTAIC
SYSTEM METER**

LOCATION: DEDICATED KWH METER
CODE REF: NEC 690.4(B) UTILITY

8

WARNING
PHOTOVOLTAIC SYSTEM
COMBINER PANEL
DO NOT ADD LOADS

LOCATION: AC COMBINER PANEL
CODE REF: NEC 690.13(B)

9

PHOTOVOLTAIC SYSTEM DC DISCONNECT
MAXIMUM VOLTAGE: 480VDC
MAXIMUM CIRCUIT CURRENT: 15.0ADC
MAX. RATED OUTPUT CURRENT OF
THE CHARGE CONTROLLER OR DC-
TO-DC- CONVERTER (IF INSTALLED) 15.0ADC

LOCATION: DC DISCONNECT
INVERTER
CODE REF: UTILITY


10

WARNING
ELECTRICAL SHOCK HAZARD
TERMINALS ON BOTH LINE AND
LOAD SIDES MAY BE ENERGIZED
IN THE OPEN POSITION
DC VOLTAGE IS ALWAYS PRESENT
WHEN SOLAR MODULES ARE
EXPOSED TO SUNLIGHT

LOCATION: DC DISCONNECT, COMBINE BOX
CODE REF: NEC 690.13(B)

11

**SOLAR PV SYSTEM EQUIPPED
WITH RAPID SHUTDOWN**
TURN RAPID SHUTDOWN
SWITCH TO THE "OFF"
POSITION TO SHUT DOWN
PV SYSTEM AND REDUCE
SHOCK HAZARD IN THE
ARRAY.



LOCATION: MAIN SERVICE (OUTSIDE COVER)
CODE REF: NEC 690.12
NEC 690.56(C)(1)(a)
YELLOW STICKER

12

WARNING PHOTOVOLTAIC POWER SOURCE

LOCATION: DC CONDUIT
JUNCTION BOX
NO MORE THAN 10FT
CODE REF: NEC 690.31(G)(3)
NEC 690.31(G)(4)
REFLECTIVE AND WEATHER RESISTANT

13

CAUTION
DUAL POWER SOURCE
SECOND SOURCE IS
PHOTOVOLTAIC

LOCATION: SERVICE METER
MAIN PANEL

14

WARNING
INVERTER OUTPUT CONNECTION
DO NOT RELOCATE THIS
OVERCURRENT DEVICE

LOCATION: (IF APPLICABLE)
SERVICE PANEL
CODE REF: NEC 705.12(7)

15

**PHOTOVOLTAIC SYSTEM
UTILITY DISCONNECT SYSTEM**

LOCATION: AC DISCONNECT
CODE REF: UTILITY

16

PV SOLAR BREAKER
DO NOT RELOCATE THIS
OVERCURRENT DEVICE

LOCATION: MAIN PANEL (EXTERIOR)
PV BREAKER: (INTERIOR)
CODE REF: NEC 705.12(B)(2)(3)(B)

LABEL REQUIRES CAPITALIZED LETTERS WITH A MINIMUM HEIGHT OF 3/8 INCH, WHITE LETTERS ON RED BACKGROUND
LABELS SHALL BE PLACED ON INTERIOR AND EXTERIOR DC CONDUIT, RACEWAYS, ENCLOSURES, AND CABLE ASSEMBLIES
EVERY 10 FEET, WITHIN 1 FOOT OF TURNS OR BENDS AND WITHIN 1 FOOT ABOVE AND BELOW PENETRATIONS OF
ROOF/CEILING ASSEMBLIES, WALLS OR BARRIERS.



SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT, DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREEDGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE


DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

LABELS
PV 7


CAUTION

POWER TO THIS BUILDING IS
SUPPLIED FROM THE FOLLOWING
SOURCES WITH DISCONNECTS AS
SHOWN:



DIRECTORY PLAQUE IN
ACCORDANCE WITH
NEC690.56(A)(B), 705.10



 **TITAN**
SOLAR POWER
525 W BASELINE RD., MESA AZ, 85210
CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT , DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526


(26) HY-DH108P8-400B
(1) SOLAREEDGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

PLACARD
PV 8

JOB SAFETY PLAN



LOCATION OF NEAREST URGENT CARE FACILITY

NAME:

ADDRESS:

PHONE NUMBER:

NOTES:

- INSTALLER SHALL DRAW IN DESIGNATED SAFETY AREA AROUND HOME
- INSTALLER SHALL UPDATE NAME, ADDRESS, AND PHONE NUMBER OF NEAREST URGENT CARE FACILITY RELATIVE TO THE JOB SITE BEFORE STARTING WORK.

| PRINT NAME | INITIAL | YES | NO |
|------------|---------|-----|----|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Single Phase Energy Hub Inverter with Prism Technology For North America

SE3000H-US / SE3800H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US⁽¹⁾



12-25 YEAR WARRANTY

HOME BACKUP

Optimized battery storage with HD-Wave technology

Record-breaking 99% weighted efficiency with 200% DC oversizing

Small, lightweight, and easy to install

Modular design, future ready with optional upgrades to:

- DC-coupled storage for full or partial home backup
- Built-in consumption monitoring
- Direct connection to the SolarEdge smart EV charger

Multi-inverter, scalable storage solution With enhanced battery power up to 10kW

Integrated arc fault protection and rapid shutdown for NEC 2014, NEC 2017 and NEC 2020, per article 690.11 and 690.12

Embedded revenue grade production data, ANSI C12.20 Class 0.5

Single Phase Energy Hub Inverter with Prism Technology For North America

SE3000H-US / SE3800H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US⁽¹⁾

| | SE3000H-US | SE3800H-US | SE6000H-US | SE7600H-US | SE10000H-US | SE11400H-US | UNITS | |
|---|---------------------------------|---------------------------|---------------------------|----------------|-------------|-----------------------------|-------------------------|---|
| OUTPUT - AC ON GRID | | | | | | | | |
| Rated AC Power | 3000 | 3800 @ 240V / 3300 @ 208V | 6000 @ 240V / 5000 @ 208V | 7600 | 10000 | 11400 @ 240V / 10000 @ 208V | W | |
| Maximum AC Power Output | 3000 | 3800 @ 240V / 3300 @ 208V | 6000 @ 240V / 5000 @ 208V | 7600 | 10000 | 11400 @ 240V / 10000 @ 208V | W | |
| AC Frequency Range (min - nom - max) | 59.3 - 60 - 60.5 ⁽²⁾ | | | | | | | |
| Maximum Continuous Output Current @ 240V | 12.5 | 16 | 25 | 32 | 42 | 47.5 | A | |
| Maximum Continuous Output Current @ 208V | - | 16 | 24 | - | - | 48.5 | A | |
| GFDI Threshold | 1 | | | | | | | |
| Total Harmonic Distortion (THD) | <3 | | | | | | | |
| Power Factor | 1, adjustable -0.85 to 0.85 | | | | | | | |
| Utility Monitoring, Islanding Protection, Country Configurable Thresholds | Yes | | | | | | | |
| Charge Battery from AC (if allowed) | Yes | | | | | | | |
| Typical Nighttime Power Consumption | <2.5 | | | | | | | |
| OUTPUT - AC BACKUP⁽³⁾ | | | | | | | | |
| Rated AC Power in Backup Operation ⁽⁴⁾ | 3000 | 3800 / 7600* | 6000 | 7600 / 10300* | 10000 | 10300 | W | |
| AC L-L Output Voltage Range in Backup | 211 - 264 | | | | | | | |
| AC L-N Output Voltage Range in Backup | 105 - 132 | | | | | | | |
| AC Frequency Range in Backup (min - nom - max) | 55 - 60 - 65 | | | | | | | |
| Maximum Continuous Output Current in Backup Operation | 12.5 | 16 / 32* | 25 | 32 / 43* | 42 | 43 | A | |
| GFDI | 1 | | | | | | | |
| THD | <5 | | | | | | | |
| OUTPUT - SMART EV CHARGER AC | | | | | | | | |
| Rated AC Power | 9600 | | | | | | | |
| AC Output Voltage Range | 211 - 264 | | | | | | | |
| On-Grid AC Frequency Range (min - nom - max) | 59.3 - 60 - 60.5 | | | | | | | |
| Maximum Continuous Output Current @240V (grid, PV and battery) | 40 | | | | | | | |
| INPUT - DC (PV AND BATTERY) | | | | | | | | |
| Transformer-less, Ungrounded | Yes | | | | | | | |
| Max Input Voltage | 480 | | | | | | | |
| Nom DC Input Voltage | 380 | | | | | | | |
| Reverse-Polarity Protection | Yes | | | | | | | |
| Ground-Fault Isolation Detection | 600kΩ Sensitivity | | | | | | | |
| INPUT - DC (PV) | | | | | | | | |
| Maximum DC Power @ 240V | 6000 | 7600 / 15200* | 12000 | 15200 / 22800* | 22000 | 22800 | W | |
| Maximum DC Power @ 208V | - | 6600 | 10000 | - | - | 20000 | W | |
| Maximum Input Current ⁽⁵⁾ @ 240V | 8.5 | 10.5 / 20* | 16.5 | 20 / 31* | 27 | 31 | Adc | |
| Maximum Input Current ⁽⁵⁾ @ 208V | - | 9 | 13.5 | - | - | 27 | Adc | |
| Max. Input Short Circuit Current | 45 | | | | | | | |
| Maximum Inverter Efficiency | 99 | 99.2 | | | | | | % |
| CEC Weighted Efficiency | 99 | | | | | | 99 @ 240V / 98.5 @ 208V | % |
| 2-pole Disconnection | Yes | | | | | | | |

* Supported with PN SExxxxH-USMxxxxx or SExxxxH-USMxxxxx
 (1) These specifications apply to inverters with part numbers SExxxxH-USMxxxxx or SExxxxH-USNxxxxx and connection unit model number DCD-1PH-US-PH-F-x
 (2) For other regional settings please contact SolarEdge support
 (3) Not designed for stand-alone applications and requires AC for commissioning. Backup functionality is only supported for 240V grid
 (4) Rated AC power in Backup Operation are valid for installations with multiple inverters. For a single backup inverter operation, rated AC power in Backup is 90% of the value stated
 (5) A higher current source may be used; the inverter will limit its input current to the values stated

Single Phase Energy Hub Inverter with Prism Technology For North America

SE3000H-US / SE3800H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US⁽¹⁾

| | SE3000H-US | SE3800H-US | SE6000H-US | SE7600H-US | SE10000H-US | SE11400H-US | UNITS |
|---|---|--------------|-------------------------------------|------------|-------------------------------------|-------------|---------|
| INPUT - DC (BATTERY) | | | | | | | |
| Supported Battery Types | SolarEdge Energy Bank, LG RESU Prime ⁽⁶⁾ | | | | | | |
| Number of Batteries per Inverter | Up to 3 SolarEdge Energy Bank, up to 2 LG RESU Prime | | | | | | |
| Continuous Power ⁽⁷⁾ | 6000 | 7600 | 10000 | | | | W |
| Peak Power ⁽⁸⁾ | 6000 | 7600 | 10000 | | | | W |
| Max Input Current | 16 | 20 | 26.5 | | | | Adc |
| 2-pole Disconnection | Yes | | | | | | |
| SMART ENERGY CAPABILITIES | | | | | | | |
| Consumption Metering | Built-in ⁽⁹⁾ | | | | | | |
| Backup & Battery Storage | With Backup interface (purchased separately) for service up to 200A; Up to 3 inverters | | | | | | |
| EV Charging | Direct connection to Smart EV charger | | | | | | |
| ADDITIONAL FEATURES | | | | | | | |
| Supported Communication Interfaces | RS485, Ethernet, Cellular ⁽¹⁰⁾ , Wi-Fi (optional), SolarEdge Energy Net (optional) | | | | | | |
| Revenue Grade Metering, ANSI C12.20 | Built-in ⁽⁹⁾ | | | | | | |
| Integrated AC, DC and Communication Connection Unit | Yes | | | | | | |
| Inverter Commissioning | With the SetApp mobile application using built-in Wi-Fi Access Point for local connection | | | | | | |
| DC Voltage Rapid Shutdown (PV and Battery) | Yes, according to NEC 2014, NEC 2017 and NEC 2020 690.12 | | | | | | |
| STANDARD COMPLIANCE | | | | | | | |
| Safety | UL1741, UL1741 SA, UL1741 PCS, UL1699B, UL1998, UL9540, CSA 22.2 | | | | | | |
| Grid Connection Standards | IEEE1547, Rule 21, Rule 14H | | | | | | |
| Emissions | FCC part 15 class B | | | | | | |
| INSTALLATION SPECIFICATIONS | | | | | | | |
| AC Output and EV AC Output Conduit Size / AWG Range | 1" maximum / 14-4 AWG | | | | | | |
| DC Input (PV and Battery) Conduit Size / AWG Range | 1" maximum / 14-6 AWG | | | | | | |
| Dimensions with Connection Unit (H x W x D) | 17.7 x 14.6 x 6.8 / 450 x 370 x 174 | | 17.7 x 14.6 x 6.8 / 450 x 370 x 174 | | 17.7 x 14.6 x 6.8 / 450 x 370 x 174 | | in / mm |
| Weight with Connection Unit | 26 / 11.8 | | 26 / 11.8 | | 30.2 / 13.7* | | lb / kg |
| Noise | < 25 | < 25 / < 50* | < 25 | < 50 | | | dBa |
| Cooling | Natural Convection | | | | | | |
| Operating Temperature Range | -40 to +140 / -40 to +60 ⁽¹⁰⁾ | | | | | | |
| Protection Rating | NEMA 4 | | | | | | |

(6) The part numbers SExxxxH-USMxxxxx only support the SolarEdge Energy Bank. The part numbers SExxxxH-USNxxxxx support both SolarEdge Energy Bank and LG RESU Prime batteries
 (7) Requires supporting inverter firmware
 (8) Discharge power is limited up to the inverter rated AC power for on-grid and backup applications
 (9) For consumption metering, current transformers should be ordered separately. SECT-SPR-225A-T-20 or SEACT10750-400NA-20 units per box. Revenue grade metering is only for production metering
 (10) Information concerning the Data Plan's terms & conditions is available in the following link: <https://www.solaredge.com/sites/default/files/se-communication-plan-terms-and-conditions-eng.pdf>
 (10) Full power up to at least 50°C / 122°F; for power de-rating information refer to: <https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf>

solaredge.com



© SolarEdge Technologies, Inc. All rights reserved. SOLAREGE, the SolarEdge logo, OPTIMIZED BY SOLAREGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: 06/2021 DS-00031-15-NAM. Subject to change without notice.

RoHS

TITAN
SOLAR POWER
525 W BASELINE RD., MESA AZ, 85210
CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT, DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

EQUIPMENT SPECIFICATIONS
PV 10

Backup Interface for North America

BI-EUSGN-01 / BI-NUSGN-01

12 YEAR WARRANTY



STOREDGE®

Backup Interface for Flexible Backup

- Automatically provides backup power to home loads in the event of grid interruption
- Full flexibility in which loads to backup - the entire home or selected loads
- Scalable solution to support higher power & higher capacity^(*)
- Built-in Auto Transformer and Energy Meter for easier and faster installation
- Seamless integration with the Energy Hub Inverter with Prism Technology to manage and monitor both PV generation and energy storage
- Generator connection support^(†)

^(*) Requires supporting inverter firmware

solaredge.com



Backup Interface for North America

BI-EUSGN-01 / BI-NUSGN-01

| | BI-EUSGN-01 | BI-NUSGN-01 | |
|---|---------------------------------------|-------------------|---------|
| INPUT FROM GRID | | | |
| AC Current Input | 200 | | A |
| AC Output Voltage (Nominal) | 240 | | Vac |
| AC Output Voltage Range | 211 - 264 | | Vac |
| AC Frequency (Nominal) | 60 | | Hz |
| AC Frequency Range | 59.3 - 60.5 | | Hz |
| Microgrid Interconnection Device Rated Current | 200 | | A |
| Service Side AC Main Circuit Breaker Rated Current | 200 | N/A | A |
| Service Side AC Main Circuit Breaker Interrupt Current | 10k | N/A | A |
| Grid Disconnection Switchover Time | <100 | | ms |
| OUTPUT TO MAIN DISTRIBUTION PANEL | | | |
| Maximum AC Current Output | 200 | | A |
| AC L-L Output Voltage (Nominal) | 240 | | Vac |
| AC L-L Output Voltage Range | 211 - 264 | | Vac |
| AC Frequency (Nominal) | 60 | | Hz |
| AC Frequency Range | 59.3 - 60.5 | | Hz |
| Maximum Inverters AC Current Output in Backup Operation | 78 | | A |
| Imbalance Compensation in Backup Operation | 5000 | | W |
| AC L-N Output Voltage in Backup (Nominal) | 120 | | V |
| AC L-N Output Voltage Range in Backup | 105 - 132 | | V |
| AC Frequency Range in Backup | 55 - 65 | | Hz |
| INPUT FROM INVERTER | | | |
| Number of Inverter Inputs | 3 | | # |
| Rated AC Power | 7,600 | | W |
| Maximum Continuous Input Current @ 240V | 32 | | A |
| Rated AC Power in Continuous Backup Operation | 6,100 | | W |
| Maximum Continuous Input Current in Backup Operation | 26 | | A |
| Peak AC Power (<10 sec) in Backup Operation | 7,000 | | W |
| Peak AC Current (<10 sec) in Backup Operation | 30 | | A |
| Inverter Input AC Circuit Breaker | 40 | | A |
| Upgradability | Up to 3 X 63A CB ^(†) | | |
| GENERATOR^(†) | | | |
| Maximum Rated AC Power | 15,000 | | W |
| Maximum Continuous Input Current | 63 | | Adc |
| Dry Contact Switch Voltage Rating | 250/30 | | Vac/Vdc |
| Dry Contact Switch Current Rating | 5 | | A |
| 2-wire Start Switch | Yes | | |
| ADDITIONAL FEATURES | | | |
| Installation Type | Suitable for use as service equipment | For main lug only | |
| Number of Communication Inputs | 2 | | |
| Communication | RS485 | | |
| Energy Meter (for Import/Export) | 1% accuracy | | |
| Manual Control Over Microgrid Interconnection Device | Yes | | |


^(†) Each 40A CB supports up to one 7.6kW inverter, with each 63A CB supporting one 10kW and one 11.4kW inverter. The CB upgrade kit is available with the following part numbers: for 40A CB, CB-UPG-40-01; for 63A, CB-UPG-63-01

⁽²⁾ Requires supporting inverter firmware

Backup Interface for North America

BI-EUSGN-01 / BI-NUSGN-01

| | BI-EUSGN-01 | BI-NUSGN-01 | |
|---|---|-------------|---------|
| STANDARD COMPLIANCE | | | |
| Safety | UL1741, CSA 22.2 NO. 107 | | |
| Emissions | UL869A | N/A | |
| | FCC part 15 class B | | |
| INSTALLATION SPECIFICATIONS | | | |
| Supported Inverters | SolarEdge single phase inverter Single phase Energy Hub inverter with Prism technology | | |
| AC From Grid Conduit Size / AWG Range | 2" conduits / #0 - 4/0 AWG | | |
| AC Inverter Conduit Size / AWG Range | 1" conduit / 14 - 4 AWG | | |
| AC Generator Input Conduit Size / AWG Range | 1" conduit / 8 - 3 AWG | | |
| Communication Conduit Size / AWG Range | 3/4" / 24 - 10 AWG | | |
| Weight | 73 / 33 | | lb / Kg |
| Cooling | Fan (user replaceable) | | |
| Noise | < 50 | | dBA |
| Operating Temperature Range | -40 to +122 / -40 to +50 | | °F / °C |
| Protection Rating | NEMA 3R, IP44 | | |
| Dimensions (HxWxD) | 20.59 x 13.88 x 8.62 / 523.5 x 352.5 x 219 | | in / mm |



© SolarEdge Technologies, Ltd. All rights reserved. SOLAREEDGE, the SolarEdge logo, OPTIMIZED BY SOLAREEDGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. 10/2020/01/ENG NA. Subject to change without notice.

CE FC

TITAN
SOLAR POWER
525 W BASELINE RD., MESA AZ, 85210
CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT, DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREEDGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

EQUIPMENT SPECIFICATIONS
PV 11

Power Optimizer For Residential Installations

S440 / S500 / S500B



POWER OPTIMIZER

Enabling PV power optimization at the module level

- Specifically designed to work with SolarEdge residential inverters
- Detects abnormal PV connector behavior, preventing potential safety issues*
- Module-level voltage shutdown for installer and firefighter safety
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch loss, from manufacturing tolerance to partial shading
- Faster installations with simplified cable management and easy assembly using a single bolt
- Flexible system design for maximum space utilization
- Compatible with bifacial PV modules

*Functionality subject to inverter model and firmware version

solaredge.com

solaredge

/ Power Optimizer For Residential Installations S440 / S500 / S500B

| | S440 | S500 | S500B | UNIT |
|---|--|--------------------|----------------|------|
| INPUT | | | | |
| Rated Input DC Power ⁽¹⁾ | 440 | | 500 | W |
| Absolute Maximum Input Voltage (Voc) | | 60 | 125 | Vdc |
| MPPT Operating Range | | 8 – 60 | 12.5 – 105 | Vdc |
| Maximum Short Circuit Current (Isc) of Connected PV Module | 14.5 | | 15 | Adc |
| Maximum Efficiency | | 99.5 | | % |
| Weighted Efficiency | | 98.6 | | % |
| Overvoltage Category | | II | | |
| OUTPUT DURING OPERATION | | | | |
| Maximum Output Current | | 15 | | Adc |
| Maximum Output Voltage | | 60 | 80 | Vdc |
| OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM INVERTER OR INVERTER OFF) | | | | |
| Safety Output Voltage per Power Optimizer | | 1 ± 0.1 | | Vdc |
| STANDARD COMPLIANCE⁽²⁾ | | | | |
| EMC | FCC Part 15 Class B, IEC61000-6-2, IEC61000-6-3, CISPR11, EN-55011 | | | |
| Safety | IEC62109-1 (class II safety), UL1741 | | | |
| Material | UL94 V-0, UV Resistant | | | |
| RoHS | Yes | | | |
| Fire Safety | VDE-AR-E 2100-712:2018-12 | | | |
| INSTALLATION SPECIFICATIONS | | | | |
| Maximum Allowed System Voltage | | 1000 | | Vdc |
| Dimensions (W x L x H) | | 129 x 155 x 30 | 129 x 155 x 45 | mm |
| Weight (including cables) | | 655 | | gf |
| Input Connector | | MC4 ⁽³⁾ | | |
| Input Wire Length | | 0.1 | | m |
| Output Connector | | MC4 | | |
| Output Wire Length | | (+) 2.3, (-) 0.10 | | m |
| Operating Temperature Range ⁽⁴⁾ | | -40 to +85 | | °C |
| Protection Rating | | IP68 | | |
| Relative Humidity | | 0 – 100 | | % |

(1) Rated power of the module at STC will not exceed the Power Optimizer Rated Input DC Power. Modules with up to +5% power tolerance are allowed.

(2) For details about CE compliance, see [Declaration of Conformity – CE](#).

(3) For other connector types please contact SolarEdge.


(4) For ambient temperatures above +70°C power de-rating is applied. Refer to [Power Optimizers Temperature De-Rating Technical Note](#) for details.

| PV System Design Using a SolarEdge Inverter ⁽⁵⁾ | SolarEdge Home Wave Inverter Single Phase | SolarEdge Home Short String Inverter Three Phase | Three Phase for 230/400V Grid | Three Phase for 277/480V Grid | |
|---|---|--|-------------------------------|-------------------------------|---|
| Minimum String Length (Power Optimizers) | S440, S500: 8 S500B: 6 | 9 | 16 | 18 | |
| Maximum String Length (Power Optimizers) | 25 | 20 | 50 | | |
| Maximum Continuous Power per String | 5700 | 5625 | 11250 | 12750 | W |
| Maximum Allowed Connected Power per String (Permitted only when the power difference between strings is less than 2,000W) | See ⁽⁶⁾ | See ⁽⁶⁾ | 13500 | 15000 | W |
| Parallel Strings of Different Lengths or Orientations | | | Yes | | |

(5) It is not allowed to mix S-series and P-series Power Optimizers in new installations.

(6) If the inverter's rated AC power < maximum nominal power per string, then the maximum power per string will be able to reach up to the inverters maximum input DC power.

Refer to [Application Note: Single String Design Guidelines](#).



*45mm for S500B

© SolarEdge Technologies, Ltd. All rights reserved. SOLAREGE, the SolarEdge logo, OPTIMIZED BY SOLAREGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: November 8, 2022 DS-000091-ENG. Subject to change without notice.

CE RoHS

TITAN
SOLAR POWER
525 W BASELINE RD., MESA AZ, 85210
CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT, DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

EQUIPMENT
SPECIFICATIONS
PV 12



TITAN SOLAR POWER
 525 W BASELINE RD
 MESA, AZ 85210
 TEL 855 SAY-SOLAR
 INFO@TITANSOLARPOWER
 TITANSOLARPOWER.COM

390-410W

HIGH CONVERSION EFFICIENCY
 Module efficiency up to 21.0% through advanced cell technology and manufacturing process


EXCELLENT WEAK LIGHT PERFORMANCE
 More power output in weak light condition, such as cloudy days, morning and sunset

EXTENDED MECHANICAL PERFORMANCE
 Module certified to withstand extreme wind (2400 Pa) and snow loading (5400 Pa)

QUALITY GUARANTEE
 High module quality ensures long-term reliability

INFO@HYPERION-USA.COM
 7/559 MOO.6, MAPYANGPHON SUBDISTRICT,
 PLUAK DAENG DISTRICT, RAYONG PROVINCE,
 21140, THAILAND

HY-DH108P8
 108 HALF-CELL BIFACIAL MODULE



■ Conventional Module ■ Hyperion Performance
 25 Years warranty for materials and workmanship
 30 Years warranty for extra linear power output



IEC61215 / IEC61730 / UL61730
 IEC61701 / IEC62716
 ISO9001: Quality Management System

12/22

BLACK DH108P8

Mechanical Parameters


| | |
|---------------|--|
| Solar Cell | Mono PERC 182mm |
| No. of Cells | 108 (6 × 18) |
| Dimensions | 1722 × 1134 × 30mm (67.08 × 44.65 × 1.18in.) |
| Weight | 25.2kg (55.55lbs) |
| Junction Box | IP68 rated (3 bypass diodes) |
| Output Cables | 4mm ² (IEC), 12 AWG (UL) (-/+1200mm (47.24in.) or customized) |
| Connector | EVO2 or customized |
| Front Cover | 2.0mm (0.079in.) semi-tempered AR glass |
| Back Cover | 2.0mm (0.079in.) semi-tempered glass |
| Container | 36 pcs/Pallet, 792 pcs/40' HC |

Operating Parameters

| | |
|------------------------|---------------------------------|
| Max. System Voltage | DC 1500V (IEC/UL) |
| Operating Temperature | -40°C ~ +85°C (-40°F ~ +185°F) |
| Max. Fuse Rating | 30A |
| Frontside Max. Loading | 5400Pa (112lb/ft ²) |
| Backside Max. Loading | 2400Pa (50lb/ft ²) |
| Bifaciality | 70%±10% |
| Fire Resistance | IEC Class A, UL Type 29 |

HY-DH108P8-390/410B

Engineering Drawing



Electrical Characteristics - STC

| | Irradiance 1000 W/m ² , ambient temperature 25 °C, AM1.5 | | | | |
|-----------------------------------|---|-------|-------|-------|-------|
| Maximum Power at STC (Pmax/W) | 410 | 405 | 400 | 395 | 390 |
| Power Tolerance (W) | 0 ~ +5 | | | | |
| Optimum Operating Voltage (Vmp/V) | 31.45 | 31.21 | 31.01 | 30.84 | 30.64 |
| Optimum Operating Current (Imp/A) | 13.04 | 12.98 | 12.90 | 12.81 | 12.73 |
| Open Circuit Voltage (Voc/V) | 37.32 | 37.23 | 37.07 | 36.98 | 36.85 |
| Short Circuit Current (Isc/A) | 13.95 | 13.87 | 13.79 | 13.70 | 13.61 |
| Module Efficiency | 21.0% | 20.7% | 20.5% | 20.2% | 20.0% |

Electrical Characteristics - NMOT


| | Irradiance 800 W/m ² , ambient temperature 20 °C, AM1.5, wind speed 1 m/s. | | | | |
|-----------------------------------|---|-------|-------|-------|-------|
| Maximum Power at NMOT (Pmax/W) | 310.2 | 306.4 | 302.5 | 298.8 | 295.0 |
| Optimum Operating Voltage (Vmp/V) | 29.82 | 29.60 | 29.41 | 29.25 | 29.15 |
| Optimum Operating Current (Imp/A) | 10.40 | 10.35 | 10.29 | 10.22 | 10.15 |
| Open Circuit Voltage (Voc/V) | 35.39 | 35.31 | 35.15 | 35.07 | 34.95 |
| Short Circuit Current (Isc/A) | 11.25 | 11.19 | 11.13 | 11.05 | 10.98 |

Rearside Power Gain (Reference to 410W Front)


| | 5% | 15% | 25% |
|-----------------------------------|-------|-------|-------|
| Rearside Power Gain | 5% | 15% | 25% |
| Maximum Power (Pmax/W) | 431.4 | 472.3 | 514.8 |
| Optimum Operating Voltage (Vmp/V) | 31.57 | 31.57 | 31.65 |
| Optimum Operating Current (Imp/A) | 13.66 | 14.96 | 16.27 |
| Open Circuit Voltage (Voc/V) | 37.46 | 37.46 | 37.46 |
| Short Circuit Current (Isc/A) | 14.57 | 15.96 | 17.35 |
| Module Efficiency | 22.1% | 24.2% | 26.4% |

Temperature Characteristics

| | |
|--------------------------------------|-----------|
| Nominal Module Operating Temperature | 42 ± 2 °C |
| Nominal Cell Operating Temperature | 45 ± 2 °C |
| Temperature Coefficient of Pmax | -0.35%/°C |
| Temperature Coefficient of Voc | -0.27%/°C |
| Temperature Coefficient of Isc | 0.05%/°C |



©Copyright 2022 HYPERION
 HY-DH108P8-EN-V1.4 US
 www.hyperion-usa.com



SPIVEY, STEPHEN RESIDENCE
 131 EDNA JOHN COURT, DUNN, NC, 28334
 LAT:35.339800, LON:-78.652052
 TSP152526


(26) HY-DH108P8-400B
 (1) SOLAREEDGE ENERGYHUB SE10000H-US
 (1) SE ENERGYBANK 10K
 10.400 kW DC SYSTEM SIZE
 10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
 REV: A
 DRAWN BY: JS

SEAL:

EQUIPMENT SPECIFICATIONS
PV 13

We support PV systems
Formerly Everest Solar Systems



Splice Foot X

Patent Pending

TECHNICAL SHEET

| Item Number | Description | Part Number |
|-------------|----------------------|-----------------------------------|
| 1 | Splice Foot X | 4000113 Splice Foot X Kit, Mill |
| 2 | K2 FlexFlash Butyl | |
| 3 | M5 x 60 lag screws | |
| 4 | T-Bolt & Hex Nut Set | |

Technical Data





| Splice Foot X | |
|-----------------|--|
| Roof Type | Composition shingle |
| Material | Aluminum with stainless steel hardware |
| Finish | Mill |
| Roof Connection | M5 x 60 lag screws |
| Code Compliance | UL 2703 |
| Compatibility | CrossRail 44-X, 48-X, 48-XL, 80 |

k2-systems.com

We support PV systems
Formerly Everest Solar Systems




Units: [in] mm



k2-systems.com



NEW!



NEW PRODUCT

CrossRail 44-X

- ▶ Optimized rail profile
- ▶ One rail for all markets
- ▶ Built-in wire management
- ▶ Maintains same structural integrity as 48-X
- ▶ Tested up to 200 mph winds
- ▶ Tested up to 100 PSF snow loads

| Part Number | Description |
|-------------|-----------------------------|
| 4000019 | CrossRail 44-X 166", Mill |
| 4000020 | CrossRail 44-X 166", Dark |
| 4000021 | CrossRail 44-X 180", Mill |
| 4000022 | CrossRail 44-X 180", Dark |
| 4000051 | RailConn Set, CR 44-X, Mill |
| 4000052 | RailConn Set, CR 44-X, Dark |
| 4000067 | End Cap, Black, CR 44-X |



www.everest-solarsystems.com
 CrossRail 44-X Product Sheet US01 | 0520 · Subject to change · Product illustrations are exemplary and may differ from the original.

Recommended OCPD Size per Grid

| Inverter | Maximum Output Current (A) | Minimum Fuse Rating (A) | Maximum Fuse Rating (A) |
|-------------|----------------------------|-------------------------|-------------------------|
| SE3000H-US | 12.5 | 20 | 50 |
| SE3800H-US | 16 | 20 | 50 |
| SE5000H-US | 24 @ 208V 21 @ 240V | 30 | 50 |
| SE6000H-US | 24 @ 208V 25 @ 240V | 30 @ 208V 35 @ 240V | 50 |
| SE7600H-US | 32 | 40 | 50 |
| SE10000H-US | 42 | 60 | 80 |
| SE11400H-US | 48.5 @ 208V 47.5 @ 240V | 70 @ 208V 60 @ 240V | 80 |

SolarEdge Single Phase Inverter with HD-Wave Technology Installation MAN-01-00541-1.1

SolarEdge Energy Bank 10kWh Battery

STORAGE



10
YEAR
WARRANTY

Optimized for SolarEdge Energy Hub inverters**

- Maximized system performance, gaining more energy to store and use for on-grid and backup power applications
- Integrates with the complete SolarEdge residential offering, providing a single point of contact for warranty, support, training, and simplified logistics & operations
- DC coupled Li-ion battery featuring industry-leading 93.3% overall system efficiency, from PV to battery to grid
- Scalable solution for increased power and capacity with multiple SolarEdge inverters and batteries
- Solar, storage, EV charging, and smart devices all monitored and managed by a single app to optimize solar production, consumption and backup power
- Wireless communication to the inverter, reducing wiring, labor and risk of installation faults
- Simple plug and play installation, with automatic SetApp-based configuration using predefined profiles
- Includes multiple safety features for battery protection at all times

solaredge.com

solaredge

/ SolarEdge Energy Bank

| BATTERY SPECIFICATION | | BAT-10K1PS0B-01 | |
|---------------------------|--|---|---------|
| Usable Energy | | 9800 (100% depth of discharge) | Wh |
| Continuous Output Power | | 5000 | W |
| Peak Output Power | | 7500 (for 10 seconds) | W |
| Peak Roundtrip Efficiency | | >94.5 | % |
| Warranty ⁽¹⁾ | | 10 | Years |
| Voltage Range | | 350-450 | Vdc |
| Communication Interfaces | | Wireless / RS485 | |
| Batteries per inverter | | Up to 3 | |
| STANDARD COMPLIANCE | | | |
| Certificate | | UL1642, UL1973, UL9540, UL9540A, UN38.3 | |
| Emissions | | FCC Part 15 Class B | |
| MECHANICAL SPECIFICATIONS | | | |
| Dimensions (W x H x D) | | 31.1 x 46.4 x 9.84 / 790 x 1179 x 250 | in / mm |
| Weight | | 238 / 108 | lb / kg |
| Mounting | | Wall mount or floor mount ⁽²⁾ | |
| Operating Temperature | | +14 to +122 / -10 to +50 | °F / °C |
| Storage Temperature | | -22 to +140 / -30 to +60 | °F / °C |
| Altitude | | 9842 / 3000 | ft / m |
| Enclosure Protection | | IP65 / NEMA 3R - indoor and outdoor (water and dust protection) | |
| Cooling | | Natural convection | |
| Noise | | <25 | dBA |

(1) For warranty details please refer to the warranty letter
 (2) Floor mount stand is purchased separately
 * The specifications included in this document are preliminary and subject to change
 ** Please refer to SolarEdge battery compatible inverters app note

© SolarEdge Technologies Ltd. All rights reserved. SOLAREEDGE, the SolarEdge logo, OPTIMIZED BY SOLAREEDGE are trademarks or registered trademarks of SolarEdge Technologies, Ltd. All other trademarks mentioned herein are trademarks of their respective owners. Date: 03/2021 DS-000026-3.0-NA. Subject to change without notice.

CE RoHS

TITAN
SOLAR POWER
525 W BASELINE RD., MESA AZ, 85210
CONTRACTOR LIC# U.34445

SPIVEY, STEPHEN RESIDENCE
131 EDNA JOHN COURT, DUNN, NC, 28334
LAT:35.339800, LON:-78.652052
TSP152526

(26) HY-DH108P8-400B
(1) SOLAREEDGE ENERGYHUB SE10000H-US
(1) SE ENERGYBANK 10K
10.400 kW DC SYSTEM SIZE
10.000 kW AC SYSTEM SIZE

DATE: 7/13/2023
REV: A
DRAWN BY: JS

SEAL:

EQUIPMENT
SPECIFICATIONS
PV 17