



5112 Departure Dr, Raleigh, NC  
27616

December 04, 2023

Inspections Department,

Harnett County,

To Whom It May Concern:

The solar PV installation performed at **742 River Rd Fuquay Varina NC 27526** was supervised by NABCEP certified engineer Ali Buttar (Certification No. 031310-32) and all components were verified and approved for the installations.

A post-install site inspection was performed by Usman Noor (PE) which verified the following:

- i. The PV equipment's structural installation has been designed and inspected
- ii. The equipment will not create a negative impact on the building's structural design including the PV dead load imposed i.e. 2.60 psf
- iii. The installation is in compliance with the North Carolina 2018 Residential Code

Sincerely,



12.04.2023

Usman Noor