

Lucent Engineering, P.C.

814 E 1475 N Lehi, UT 84043 m: (309) 645-0999 admin@lucenteng.co

November 10, 2023

Encōr Solar, LLC 2392 N Orchard Way Saratoga Springs, UT 84045

RE: Engineering Services
Benton Residence
886 Juno Dr, Broadway, NC
5.51 kW System
Solo Job #4128556

To Whom It May Concern,

We have reviewed the following information regarding the solar panel installation for this project. Alterations to these documents or plans shall not be made without direct written consent of the Engineer of Record.

A. Assumptions from Field Observation provided by Encor Solar, LLC

The following structural design regarding the proposed alterations have been prepared from these assumptions. The verification of the field observations is the responsibility of the contractor. **Prior to** commencement of work, the contractor shall verify the framing sizes, spacings, and spans noted in the sealed plans, calculations, and/or certification letter and notify the Engineer of Record of any discrepancies.

Roof A Roof B

Roof Finish: Asphalt Shingle Asphalt Shingle

Roof Underlayment: OSB OSB
Roof Profile: Gable Monoslope
Roof Structural System: Metal Plate Trusses Rafter

Truss Top Chord/Setup: 2 x 4 / Fink 2 x 4 / Rafter

Chord/Rafter Wood Grade: Southern Pine #2 or better Southern Pine #2 or better

Truss/Rafter Spacing: 24" o.c. 24" o.c.
Roof Slope: 30 deg 10 deg

Max Top Chord/Rafter Span: 7.24 ft 5.08 ft
Bearing Wall Type: Convl Lt-Frame Constr CLFC

Foundation : Permanent Concrete Permanent Concrete

Stories: Two Single

B. Building Design Criteria

Code: 2018 NCRC (ASCE 7-10) Risk Category: II

Roof Live Load: 20 psf (0 psf at panels) Occupancy Class: R-3

Ground Snow Load: 10 psf Roof Dead Load: 6.5 psf

Ult Wind Speed: 120 mph PV Dead Load: 3 psf

Exposure Category: C Total Dead Load: 9.5 psf

C. Summary of Existing Structure Results

Roof A & B

After review of the field observations and based on our calculations and in accordance with the applicable building codes and current industry standards, the existing roof structure supporting the proposed alterations consisting of the solar array has been determined to be:

- Adaquate to support the additional imposed loads. No structural upgrades are required.

D. Solar Panel Support Bracket Anchorage

- 1. Solar panels shall be designed, mounted, and installed in accordance with the most recent "SnapNrack Manual", which can be found on the SnapNrack website (http://snapnrack.com/).
- 2. Manufacturer's Panel Bracket Connection to Roof Chord/Rafter Member:

Fastener: (1) 5/16" Lag Screw per Bracket

NDS Withdrawl Value: 307 lbs/inch


Min. Thread Length and Pentration Depth: 2.5"

- 3. Considering the existing roof's slope, size, spacing, condition, and calculated loads, the panel bracket supports shall be placed no greater than 48 in. o/c.
- 4. Panel supports connections shall be staggered to distribute load to adjacent trusses.

E. Overall Summary

Based on the information supplied to us at the time of this report, on the evaluation of the existing structure, and solar array panel bracket connection, it is our opinion that the roof system will adequately support the additional loads imposed by the solar array. This evaluation conforms to 2018 NCRC and current industry standards.

Should you have any questions regarding this letter or if you require further information, do not hesitate to contact me.




Nicholas J. Bowens, PE License No. 55156

Limits of Scope of Work and Liablity

The existing structure is assumed to have been designed and constructed following appropriate codes at the time of erection and assumed to have appropriated permits. The calculations performed are only for the roof framing supporting the solar array installation referenced in the stamped plans and were completed according to generally recognized structural analysis standards and procedures, professional engineering, and design experience opinions and judgements. Existing deficiencies which are unknown or were not observed during the time the site observation are not included in this scope of work. All solar panel modules, racking, and mounting equipment shall be designed and installed per the manufacturer's approved installation specifications. The Engineer of Record and the engineering consulting firm assume no responsibility for misuse or improper installation. This analysis is not stamped for water leakage. Framing was determined on information in provided plans and/or photos, along with engineering judgement. Prior to commencement of work, the contractor shall verify the framing sizes, spacings, and spans noted in the stamped plans, calculations, and/or certification letter and notify the Engineer of Record of any discrepancies prior to starting construction. If during solar panel installation, the roof framing members appear unstable or deflect nonuniformly, our office should be notified before proceeding with the installation. The contactor shall also verify that there are no damage/deficiencies (i.e., dry rot, water damage, termite damage, framing member/connection damage, etc.) to framing that was not addressed in the stamped plans, calculations, and/or certification letter and notify the Engineer of Record of any concerns prior to starting construction.

AERIAL VIEW



GENERAL NOTES

- 1. INSTALLATION OF SOLAR PHOTOVOLTAIC SYSTEM SHALL BE IN ACCORDANCE WITH NEC ARTICLE 690, AND ALL OTHER APPLICABLE NEC CODES WHERE NOTED OR EXISTING
- 2. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL COMPLY WITH NEC ARTICLE 110
- 3. ALL WIRES, INCLUDING THE GROUNDING ELECTRODE CONDUCTOR SHALL BE PROTECTED FROM PHYSICAL DAMAGE IN ACCORDANCE WITH NEC ARTICLE 250
- 4. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE; THIS SYSTEM IS UTILITY INTERACTIVE PER UL 1741 AND DOES NOT INCLUDE STORAGE BATTERIES OR OTHER ALTERNATIVE STORAGE SOURCES
- 5. ALL DC WIRES SHALL BE SIZED ACCORDING TO [NEC 690.8]
- 6. DC CONDUCTORS SHALL BE WITHIN PROTECTED RACEWAYS IN ACCORDANCE WITH [NEC 690.31]
- 7. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL JURISDICTIONAL BUILDING CODE

STREET VIEW



PHOTOVOLTAIC (PV) SYSTEM SPECIFICATIONS

ELECTRICAL EQUIPMENT

PV MODULES:

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

DC SYSTEM SIZE: 7.6 KW DC

INVERTER(S):

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

AC SYSTEM SIZE: 5.51 KW AC

RACKING

RACKING: SNAPNRACK SNAPNRACK - ULTRA RAIL - UR-40

ATTACHMENT: SPEEDSEAL FOOT

2018 NORTH CAROLINA STATE BUILDING CODE: RESIDENTIAL 2018 NORTH CAROLINA STATE BUILDING CODE: BUILDING

SHEET INDEX

PV01 COVER

PV02 SITE PLAN

PV03 ROOF PLAN

PV04 MOUNTING DETAIL

PV05 LINE DIAGRAM

PV06 ELECTRICAL CALCS

PV07 LABELS

PV08 PLACARD

PV09 SITE PHOTOS

APPLICABLE GOVERNING CODES

2020 NATIONAL ELECTRICAL CODE

2018 NORTH CAROLINA STATE BUILDING CODE: FIRE

SITE SPECIFICATIONS


OCCUPANCY: R-3 **ZONING: RESIDENTIAL**





CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743



SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

PV MODULES


(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC


DRAWN BY: SoloCAD

11/10/2023

COVER - PV01








EQUIPME	NT INFORMATION:	ROC	OF INFO:	PHOTOVOLTAIC ARRAY STRUCTURAL CRITERIA:		
RACKING MANUFACTURER:	RACKING MANUFACTURER: SNAPNRACK		ROOF TYPE: ASPHALT SHINGLE		19	
RACKING PART NUMBER:	SNAPNRACK - ULTRA RAIL - UR-40	ROOF FRAMING:	MANUFACTURED TRUSS	ARRAY AREA:	MODULE COUNT * 21.14 FT ² = 401.66	
ATTACHMENTS	SPEEDSEAL FOOT	RAFTER/TOP CHORD SIZE:	2x4	ROOF AREA:	1829 FT²	
ATTACHMENT QTY:	32	RAFTER/TOP CHORD SPACING:	24"	PERCENT OF ROOF COVERED:	22%	
SPLICE QTY:	2	ATTACHMENT SPACING:	48''	ARRAY WEIGHT:	MODULE COUNT * 49 LBS = 931 LBS	
MIDCLAMP QTY:	26			POINT LOAD:	ARRAY LBS/ATTACHMENTS = 29.09	
ENDCLAMP QTY:	24			DISTRIBUTED LOAD: (lbs/ft²)	ARRAY WEIGHT/AREA = 2.32 LBS/FT ²	



CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743



SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

PV MODULES


(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

ROOF PLAN - PV03



EQUIPME	NT INFORMATION:	ROC	OF INFO:	PHOTOVOLTAIC ARRAY STRUCTURAL CRITERIA:		
RACKING MANUFACTURER: SNAPNRACK		ROOF TYPE: ASPHALT SHINGLE		PV MODULE COUNT:	19	
RACKING PART NUMBER:	SNAPNRACK - ULTRA RAIL - UR-40	ROOF FRAMING:	MANUFACTURED TRUSS	ARRAY AREA:	MODULE COUNT * 21.14 FT ² = 401.66	
ATTACHMENTS	SPEEDSEAL FOOT	RAFTER/TOP CHORD SIZE:	2x4	ROOF AREA:	1829 FT²	
ATTACHMENT QTY:	32	RAFTER/TOP CHORD SPACING:	24"	PERCENT OF ROOF COVERED:	22%	
SPLICE QTY:	2	ATTACHMENT SPACING:	48"	ARRAY WEIGHT:	MODULE COUNT * 49 LBS = 931 LBS	
MIDCLAMP QTY:	26			POINT LOAD:	ARRAY LBS/ATTACHMENTS = 29.09	
ENDCLAMP QTY: 24				DISTRIBUTED LOAD: (lbs/ft²)	ARRAY WEIGHT/AREA = 2.32 LBS/FT ²	



CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743



SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

MOUNTING DETAIL - PV04

HANWHA Q.PEAK DUO BLK ML-G10-	- 400 SPECS
POWER MAX (PMAX):	400 W
OPEN CIRCUIT VOLTAGE (VOC):	45.3 V
MAX POWER-POINT CURRENT (IMP):	10.77 A
MAX POWER-POINT VOLTAGE (VMP):	37.13 V
SHORT CIRCUIT CURRENT (ISC):	11.14 A
SERIES FUSE RATING:	20 A

ENPHASE IQ8PLUS-72-2-US SPE	ECS
MAX INPUT VOLTAGE:	60 V
MAX DC SHORT CIRCUIT CURRENT:	15 A
MAXIMUM OUTPUT POWER:	290 W
MAXIMUM OUTPUT CURRENT:	1.21 A
NOM. OUTPUT VOLTAGE:	240 V
MAX UNITS PER 20A CIRCUIT:	13
1-PHASE, 60 HZ, UL 1741 LISTI	ED .


		EQUIPMENT SCHEDULE	
TYPE	QTY	DESCRIPTION	RATING
MODULES:	(19)	HANWHA Q.PEAK DUO BLK ML-G10+ 400	400 W
INVERTERS:	(19)	ENPHASE IQ8PLUS-72-2-US	290 W
AC DISCONNECT(S):	(1)	PV AC DISCONNECT, 240V, 2-POLE	30 A
AC COMBINER:	(1)	ENPHASE (X2-IQ-AM1-240-4)	125 A

		CONDUIT & CONDUCTOR SCHEDULE								
1	TAG	QTY	WIRE GAUGE	DESCRIPTION	CONDUIT SIZE					
	1	(2)	12-2	ENPHASE Q-CABLE COPPER - (L1, L2)	N/A - FREE AIR					
1	1	(1)	6 AWG	BARE COPPER - (GROUND)	IN/A - FREE AIR					
┪	2	(4)	10 AWG	THHN/THWN-2 COPPER - (L1, L2)	3/4" EMT					
┪	2	(1) 10 AWG		THWN-2 COPPER - (GROUND)	3/4 EIVI I					
\dashv	3	(3)	10 AWG	THHN/THWN-2 COPPER - (L1, L2, NEUTRAL)	3/4" EMT					
4	3	(1)	10 AWG	THWN-2 COPPER -(GROUND)	3/4 EIVII					
- 1										



CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743



SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400 PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

VISIBLE, LOCKABLE, LABELED AC DISCONNECT

LOCATED WITHIN 10' OF UTILITY METER

LINE DIAGRAM - PV05

	STRING CALCULATIONS					
	STRING #1	STRING #2				
MAX AC CURRENT:	12.10A	10.89A				
MICRO INVERTERS IN CIRCUIT	10	9				
NOMINAL STRING VOLTAGE:	240V	240V				
MAX AC OUTPUT POWER	2900W	2610W				
ARRAY DC POWER:	7600W					
TOTAL MAX AC CURRENT:	22.99A					

PERCENT OF VALUES
.80
.70
.50

	SYSTEM OCPD CALCULATIONS				
INVERTER MODEL(S):	ENPHASE IQ8PLUS-72-2-US				
# OF INVERTERS:	19				
MAX OUTPUT CURRENT:	1.21A				
(# OF IN	VERTERS) X (MAX OUTPUT CURRENT) X 125% <= OCPD RATING				
(19 X 1.21A X 1.25) = 29A <= 30A, OK					
	BUSBAR CALCULATIONS - 120% RULE				
MAIN BUSBAR RATING:	200A				
MAIN DISCONNECT RATING:	200A				
PV OCPD RATING: 30A					
(MAIN BUS RATING X 120%) - MAIN DISCONNECT RATING >= OCPD RATING					
	(200A X 1.2) - 200A = 40A, >= 30A, OK				

ENCŌR

CONTRACTOR INFORMATION: ENCŌR SOLAR, LLC

> 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743

CONDUIT & CONDUCTOR SCHEDULE

	CONDOTT & CONDOCTOR SCREEN										
TAG	QTY	WIRE GAUGE	DESCRIPTION	CONDUIT SIZE	CONDUCTOR RATING	CONDUCTOR TEMP. RATE	AMBIENT TEMP	TEMP. DERATE	# OF CONDUCTORS DERATE	CONDUCTOR RATING W/DERATES	CONDUIT FILL
1	(2)	12-2	ENPHASE Q-CABLE COPPER - (L1, L2)	N/A - FREE AIR	30A	90°C	34°C	0.96	N/A - FREE AIR	28.8A	N/A - FREE AIR
1	(1)	6 AWG	BARE COPPER - (GROUND)	N/A - FREE AIR	SUA	90 C	34 C	0.50	N/A - I NEL AIN	20.0A	N/A - I KLL AIK
,	(4)	10 AWG	THHN/THWN-2 COPPER - (L1, L2)	3/4" EMT	40A	90°C	34°C	0.96	0.8	30.72A	19.8%
2	(1)	10 AWG	THWN-2 COPPER - (GROUND)	3/4 EIVIT	40A	90 C	34 C	0.96	0.8	50.72A	19.6%
2	(3)	10 AWG	THHN/THWN-2 COPPER - (L1, L2, NEUTRAL)	3/4" EMT	254	75°C	34°C	0.94	1	32.9A	15.9%
3	(1)	10 AWG	THWN-2 COPPER -(GROUND)	3/4 EIVIT	MT 35A	75 C	34 C	0.94	1	52.9A	15.9%

GROUNDING & GENERAL NOTES:

- 1. PV INVERTER IS UNGROUNDED, TRANSFORMER-LESS TYPE.
- 2. DC GEC AND AC EGC TO BE SPLICED TO EXISTING ELECTRODE
- 3. ANY EXISTING WIRING INVOLVED WITH PV SYSTEM CONNECTION THAT IS FOUND TO BE INADEQUATE PER CODE SHALL BE CORRECTED PRIOR TO FINAL INSPECTION.
- 4. JUNCTION BOX QUANTITIES, AND PLACEMENT SUBJECT TO CHANGE IN THE FIELD JUNCTION BOXES DEPICTED ON ELECTRICAL DIAGRAM REPRESENT WIRE TYPE TRANSITIONS.
- 5. AC DISCONNECT NOTED IN EQUIPMENT SCHEDULE OPTIONAL IF OTHER AC DISCONNECTING MEANS IS LOCATED WITHIN 10' OF SERVICE DISCONNECT.

INTERCONNECTION NOTES:

- 1. INTERCONNECTION SIZING, LIMITATIONS AND COMPLIANCE DETERMINED IN ACCORDANCE WITH [NEC 705.12].
- 2. GROUND FAULT PROTECTION IN ACCORDANCE WITH [NEC 215.9], [NEC 230.95] AND [NEC 690.41]
- 3. ALL EQUIPMENT TO BE RATED FOR BACKFEEDING.
- 4. PV BREAKER TO BE POSITIONED AT THE OPPOSITE END OF THE BUSBAR RELATIVE TO THE MAIN BREAKER.

DISCONNECT NOTES:

- 1. DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING LIVE ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS)
- 2. AC DISCONNECT MUST BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH

SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

ELECTRICAL CALCS - PV06

MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

WARNING

ELECTRIC SHOCK HAZARD TERMINALS ON THE LINE AND **LOAD SIDES MAY BE ENERGIZED** IN THE OPEN POSITION

WARNING

POWER SOURCE OUTPUT CONNECTION. DO NOT RELOCATE THIS OVERCURRENT DEVICE.

A CAUTION

MULTIPLE SOURCES OF POWER

WARNING

THIS EQUIPMENT IS FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL **OVERCURRENT DEVICES, EXCLUDING** MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR.

LABEL 1

PLACED ON THE MAIN DISCONNECTING MEANS FOR THE PV SYSTEM. [NEC 690.13(B)]

FOR PV DISCONNECTING MEANS WHERE THE LINE AND LOAD TERMINALS MAY BE ENERGIZED IN THE OPEN POSITION [NEC 690.13(B)]

PLACED ADJACENT TO THE BACK-FED BREAKER FROM THE INVERTER IF TIE IN CONSISTS OF LOAD SIDE CONNECTION TO BUSBAR. [NEC 705.12(B)(3)(2)]

PLACED ON EQUIPMENT CONTAINING OVERCURRENT DEVICES IN CIRCUITS SUPPLYING POWER TO A BUSBAR OR CONDUCTOR SUPPLIED FROM MULTIPLE [NEC 705.10]

EQUIPMENT CONTAINING OVERCURRENT DEVICES IN CIRCUITS SUPPLYING POWER TO A BUSBAR OR CONDUCTOR SUPPLIED FROM MULTIPLE SOURCES SHALL BE MARKED TO INDICATE THE PRESENCE OF ALL SOURCES.[NEC 705.12(B)(3)(3)]

PHOTOVOLTAIC AC DISCONNECT


23 RATED AC OUTPUT CURRENT: NOMINAL OPERATING AC VOLTAGE: 240

MARKED AT AC DISCONNECTING MEANS. [NEC 690.54]

PHOTOVOLTAIC POWER SOURCE

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWICH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY



RAPID SHUTDOWN **SWITCH FOR SOLAR PV SYSTEM**

AT DIRECT-CURRENT EXPOSED RACEWAYS, CABLE TRAYS, COVERS AND ENCLOSURES OF JUNCTION BOXES. AND OTHER WIRING METHODS: SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY ENCLOSURES. WALLS. PARTITIONS, CEILINGS, OR FLOORS, [NEC 690.31(D)(2)]

LABEL 8

FOR PV SYSTEMS THAT SHUT DOWN THE ARRAY AND CONDUCTORS I FAVING THE ARRAY: SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT AWAY FROM

SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATION OF ALL IDENTIFIED RAPID SHUTDOWN SWITCHES IF NOT AT THE SAME LOCATION. [NEC 690.56(C)(1)]

SIGN LOCATED ON OR NO MORE THAN 3FT FROM INITIATION DEVICE [NEC 690.56(C)(2)].

MAIN SERVICE PANEL

""

(1)

SIDE BREAKER)

LABELING DIAGRAM: PV COMBINER **EXISTING SUB PANEL** SUBPANEL - IF USED TO (ONLY IF WHERE POINT

2 COMBINE PV OUTPUT OF INTERCONNECTION (3) (4) CIRCUITS OR INVERTER AC DISCONNECT IS MADE) (6) (1)JUNCTION BOX (1) 4 (3) (8) 3 (7) $\overline{7}$ (9) (5) (ONLY IF PV (ONLY IF PV CONSISTS OF LOAD CONSISTS OF LOAD

ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VERY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ELECTRICAL DIAGRAM PAGE. **

SIDE BREAKER)

ENCŌR

CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743

SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400

PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD


11/10/2023

LABELS - PV07

- 1. LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS.
- LABELING REQUIREMENTS BASED ON THE 2020 NATIONAL ELECTRIC CODE, OSHA STANDARD 19010.145, ANSI Z535.
- MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED [NEC
- 5. LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8", WHITE ON RED BACKGROUND; REFLECTIVE, AND PERMANENTLY AFFIXED [NEC 690 31(D)(2)]



POWER TO THIS BUILDING IS ALSO SUPPLIED FROM ROOF MOUNTED SOLAR ARRAYS WITH SAFETY DISCONNECTS AS SHOWN:



DIRECTORY:

PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM. (ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS OUTLINED WITHIN: NEC 690.56(B)&(C), [NEC 705.10]



CONTRACTOR INFORMATION:

ENCŌR SOLAR, LLC 3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743

SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400 PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)


DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

PLACARD - PV08

SITE PHOTOS:





$\frac{\texttt{CONTRACTOR} \ \, \texttt{INFORMATION:}}{\texttt{ENC\bar{O}R} \ \, \texttt{SOLAR, LLC}}$

3049 Executive Parkway Suite 300 Lehi, UT 84043 License # U.35743



SITE INFORMATION

CHARLES BENTON

886 JUNO DR

BROADWAY, NC 27505

AC SYSTEM SIZE: 5.51 KW AC

DC SYSTEM SIZE: 7.6 KW DC

LAT, 35.3260124 LONG, -79.0240457

(19) HANWHA Q.PEAK DUO BLK ML-G10+ 400 PV MODULES

(19) ENPHASE IQ8PLUS-72-2-US INVERTER(S)

DUKE ENERGY PROGRESS NC

DRAWN BY: SoloCAD

11/10/2023

SITE PHOTOS - PV09



Q.PEAK DUO BLK ML-G10+ 385-410

ENDURING HIGH PERFORMANCE









BREAKING THE 20% EFFICIENCY BARRIER

Q.ANTUM DUO Z Technology with zero gap cell layout boosts module efficiency up to 21.1%.



THE MOST THOROUGH TESTING PROGRAMME IN THE INDUSTRY

Q CELLS is the first solar module manufacturer to pass the most comprehensive quality programme in the industry: The new "Quality Controlled PV" of the independent certification institute TÜV Rheinland.



INNOVATIVE ALL-WEATHER TECHNOLOGY

Optimal yields, whatever the weather with excellent low-light and temperature behaviour.



ENDURING HIGH PERFORMANCE

Long-term yield security with Anti LID Technology, Hot-Spot Protect and Traceable Quality Tra.Q™.



EXTREME WEATHER RATING

High-tech aluminium alloy frame, certified for high snow (5400 Pa) and wind loads (4000 Pa).



A RELIABLE INVESTMENT

Inclusive 25-year product warranty and 25-year linear performance warranty¹.

¹ See data sheet on rear for further information.






Engineered in Germany



MECHANICAL SPECIFICATION

Format	1879 mm × 1045 mm × 32 mm (including frame)
Weight	22.0 kg
Front Cover	3.2mm thermally pre-stressed glass with anti-reflection technology
Back Cover	Composite film
Frame	Black anodised aluminium
Cell	6 × 22 monocrystalline Q.ANTUM solar half cells
lunction box	53-101 mm × 32-60 mm × 15-18 mm Protection class IP67, with bypass diodes
Cable	4 mm² Solar cable; (+) ≥1250 mm, (-) ≥1250 mm
Connector	Stäubli MC4; IP68




ELECTRICAL CHARACTERISTICS

PO	VER CLASS			385	390	395	400	405	410
MIN	IIMUM PERFORMANCE AT STANDARE	TEST CONDITIO	NS, STC ¹ (P	OWER TOLERAI	VCE +5 W / -0 V	V)			
	Power at MPP ¹	P _{MPP}	[W]	385	390	395	400	405	410
_	Short Circuit Current ¹	I _{sc}	[A]	11.04	11.07	11.10	11.14	11.17	11.20
unu	Open Circuit Voltage ¹	V _{oc}	[V]	45.19	45.23	45.27	45.30	45.34	45.37
Minir	Current at MPP	I _{MPP}	[A]	10.59	10.65	10.71	10.77	10.83	10.89
	Voltage at MPP	V _{MPP}	[V]	36.36	36.62	36.88	37.13	37.39	37.64
	Efficiency ¹	η	[%]	≥19.6	≥19.9	≥20.1	≥20.4	≥20.6	20.9
MIN	IIMUM PERFORMANCE AT NORMAL C	PERATING CON	DITIONS, N	MOT ²					
	Power at MPP	P _{MPP}	[W]	288.8	292.6	296.3	300.1	303.8	307.6
Ę	Short Circuit Current	I _{sc}	[A]	8.90	8.92	8.95	8.97	9.00	9.03
Minim	Open Circuit Voltage	V _{oc}	[V]	42.62	42.65	42.69	42.72	42.76	42.79
	Current at MPP	L _{MPP}	[A]	8.35	8.41	8.46	8.51	8.57	8.62
	Voltage at MPP	V _{MPP}	[V]	34.59	34.81	35.03	35.25	35.46	35.68


 $^{1}\text{Measurement tolerances P}_{MPP}\pm3\%; I_{SC}; V_{OC}\pm5\% \text{ at STC}: 1000 \text{ W/m}^{2}, 25\pm2\text{ °C}, AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 • $^{2}800 \text{ W/m}^{2}, NMOT, spectrum AM 1.5 according to IEC 6$

Q CELLS PERFORMANCE WARRANTY



At least 98% of nominal power during first year. Thereafter max. 0.5% degradation per year. At least 93.5% of nominal power up to 10 years. At least 86% of nominal power up to

All data within measurement toler-ances. Full warranties in accordance with the warranty terms of the Q CELLS sales organisation of your respective country.



Typical module performance under low irradiance conditions in comparison to STC conditions (25°C, 1000 W/m²).

TEMPERATURE COEFFICIENTS							
Temperature Coefficient of I _{sc}	α	[%/K]	+0.04	Temperature Coefficient of Voc	β	[%/K]	-0.27
Temperature Coefficient of P		IN /V1	0.24	Naminal Madula Operating Temperature	TOMA	[00]	12+2

PROPERTIES FOR SYSTEM DESIGN

Maximum System Voltage	V_{sys}	[V]	1000	PV module classification	Class II
Maximum Reverse Current	I _R	[A]	20	Fire Rating based on ANSI/UL 61730	C/TYPE 2
Max. Design Load, Push/Pull		[Pa]	3600/2660	Permitted Module Temperature	-40°C - +85°C
Max. Test Load, Push / Pull		[Pa]	5400/4000	on Continuous Duty	

QUALIFICATIONS AND CERTIFICATES

PACKAGING INFORMATION

JEC 61215:2016: JEC 61730:2016 This data sheet complies with DIN EN 50380. QCPV Certification ongoing













Note: Installation instructions must be followed. See the installation and operating manual or contact our technical service department for further information on approved installation and

Made in Korea

Suite 1, Level 1, 15 Blue Street, North Sydney, NSW 2060, Australia | TEL +61 (0)2 9016 3033 | FAX +61 (0)2 9016 3032 | EMAIL q-cells-australia@q-cells.com | WEB www.q-cells.com/au

QCELLS

Engineered in Germany





Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC), which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built using advanced 55-nm technology with high-speed digital logic and has superfast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the IQ Battery, IQ Gateway, and the Enphase App monitoring and analysis software.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-and-play MC4 connectors.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



IQ8 Series Microinverters are UL Listed as PV rapid shutdown equipment and conform with various regulations, when installed according to the manufacturer's instructions.

Easy to install

- Lightweight and compact with plugand-play connectors
- Power line communication (PLC) between components
- Faster installation with simple two-wire cabling

High productivity and reliability

- Produce power even when the grid is down*
- More than one million cumulative hours of testing
- · Class II double-insulated enclosure
- Optimized for the latest high-powered PV modules

Microgrid-forming

- Compliant with the latest advanced grid support**
- Remote automatic updates for the latest grid requirements
- Configurable to support a wide range of grid profiles
- Meet CA Rule 21 (UL 1741-SA) and IEEE® 1547:2018 (UL 1741-SB 3rd Ed.)

NOTE:

- IQ8 Microinverters cannot be mixed with previous generations of Enphase microinverters (IQ7 Series, IQ6 Series, and so on) in the same system.
- IQ Gateway is required to change the default grid profile at the time of installation to meet local Authority Having Jurisdiction (AHJ) requirements.

^{*}Meets UL 1741 only when installed with IQ System Controller 2.

^{**}IQ8 and IQ8+ support split-phase, 240 V installations only.

INPUT DATA (DC)	UNITS	IQ8-60-2-US	108PLUS-72-2-US	
Commonly used module pairings ¹	W	235-350	235-440	
Module compatibility	_	To meet compatibility, PV modules must be within maximur Module compatibility can be checked at https://er		
MPPT voltage range	V	27–37	27–45	
Operating range	V	16-48	16-58	
Minimum/Maximum start voltage	V	22/48	22/58	
Maximum input DC voltage	٧	50	60	
Maximum continuous input DC current	Α	10	12	
Maximum input DC short-circuit current	А	25	5	
Maximum module I _{sc}	Α	20		
Overvoltage class DC port	_	П		
OC port backfeed current	mA	0		
PV array configuration	-	1×1 ungrounded array; no additional DC side protection required	; AC side protection requires maximum 20 A per branch ci	
DUTPUT DATA (AC)	UNITS	108-60-2-US	108PLUS-72-2-US	
Peak output power	VA	245	300	
Maximum continuous output power	VA	240	290	
Nominal grid voltage (L-L)	V	240, split-pha	se (L-L), 180°	
Minimum and Maximum grid voltage ²	V	211-2	264	
Maximum continuous output current	А	1.0	1.21	
Nominal frequency	Hz	60		
Extended frequency range	Hz	47-	68	
AC short-circuit fault current over three cycles	Arms	2		
Maximum units per 20 A (L-L) branch circuit ³	-	16	13	
Total harmonic distortion	%	<5	5	
Overvoltage class AC port	_	III		
AC port backfeed current	mA	30)	
Power factor setting	_	1.C		
Grid-tied power factor (adjustable)	-	0.85 leading	0.85 lagging	
Peak efficiency	%	97.	7	
CEC weighted efficiency	%	97	,	
Nighttime power consumption	mW	23	25	
MECHANICAL DATA				
Ambient temperature range		-40°C to 60°C (-	-40°F to 140°F)	
Relative humidity range		4% to 100% (condensing)		
OC connector type		MC4		
Dimensions (H × W × D)		212 mm (8.3 in) × 175 mm (6.9 in) × 30.2 mm (1.2 in)		
Weight		1.08 kg (2.38 lbs)		
Cooling		Natural convection-no fans		
Approved for wet locations		Ye:	s	
Pollution degree		PD3		
Enclosure		Class II double-insulated, corrosion-resistant polymeric enclosure		
Environmental category/UV exposure ratin	a	NEMA Type 6	S/Outdoor	

COMPLIANCE

Certifications

CA Rule 21 (UL 1741-SA), UL 62109-1, IEEE® 1547:2018 (UL 1741-SB 3'd Ed.), FCC Part 15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-01 This product is UL Listed as PV rapid shutdown equipment and conforms with NEC 2014, NEC 2017, NEC 2020, and NEC 2023 section 690.12 and C22.1-2018 Rule 64-218 rapid shutdown of PV Systems, for AC and DC conductors, when installed according to the manufacturer's instructions.

Revision history

REVISION	DATE	DESCRIPTION
DSH-00207-2.0	October 2023	Included NEC 2023 specification in the Compliance section
DSH-00207-1.0	September 2023	Updated module compatibility specification



UR-40 UR-60

Ultra Rail






The Ultimate Value in Rooftop Solar



Industry leading Wire Management Solutions





Mounts available for all roof types



All SnapNrack Module Clamps & Accessories are compatible with both rail profiles

Start Installing Ultra Rail Today

RESOURCES
DESIGN
WHERE TO BUY

snapnrack.com/resources snapnrack.com/configurator snapnrack.com/where-to-buy

SnapNrack Ultra Rail System

A sleek, straightforward rail solution for mounting solar modules on all roof types. Ultra Rail features two rail profiles; UR-40 is a lightweight rail profile that is suitable for most geographic regions and maintains all the great features of SnapNrack rail, while UR-60 is a heavier duty rail profile that provides a larger rail channel and increased span capabilities. Both are compatible with all existing mounts, module clamps, and accessories for ease of install.

The Entire System is a Snap to Install

- New Ultra Rail Mounts include snap-in brackets for attaching rail
- Compatible with all the SnapNrack Mid Clamps and End Clamps customers love
- Universal End Clamps and snap-in End Caps provide a clean look to the array edge





Unparalleled Wire Management

- Open rail channel provides room for running wires resulting in a long-lasting quality install
- Industry best wire management offering includes Junction Boxes, Universal Wire Clamps, MLPE Attachment Kits, and Conduit Clamps
- System is fully bonded and listed to UL 2703 Standard

Heavy Duty UR-60 Rail

- UR-60 rail profile provides increased span capabilities for high wind speeds and snow loads
- Taller, stronger rail profile includes profilespecific rail splice and end cap
- All existing mounts, module clamps, and accessories are retained for the same great install experience



Quality. Innovative. Superior.

SnapNrack Solar Mounting Solutions are engineered to optimize material use and labor resources and improve overall installation quality and safety.

877-732-2860

www.snapnrack.com

contact@snapnrack.com

© 2019 by SnapNrack Solar Mounting Solutions. All rights reserved

DESCRIPTION:

SNAPNRACK, ULTRA RAIL SPEEDSEAL™ FOOT

PART NUMBER(S):

242-02163, 242-02167

DRAWN BY:

mwatkins


REVISION:

Α

Solar Mounting Solutions

595 MARKET STREET, 29TH FLOOR ● SAN FRANCISCO, CA 94105 USA PHONE (415) 580-6900 ● FAX (415) 580-6902

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF SUNRUN SOUTH LLC.



PARTS LIST						
ITEM	QTY	DESCRIPTION				
1	1	SNAPNRACK, SPEEDSEAL FOOT, BASE, SEALING, SILVER / BLACK				
2	1	BOLT, FLANGE, SERRATED, 5/16IN-18 X 2IN, SS				
3	1	SNAPNRACK, RL UNIVERSAL, MOUNT SPRING, SS				
4	1	SNAPNRACK, ULTRA RAIL MOUNT THRU PRC, CLEAR / BLACK				
5	1	SNAPNRACK, ULTRA RAIL MOUNT TAPPED PRC, CLEAR / BLACK				

MATERIALS:	DIE CAST A380 ALUMINUM, 6000 SERIES ALUMINUM, STAINLESS STEEL		
DESIGN LOAD (LBS):	802 UP, 1333 DOWN, 357 SIDE	OPTIONS:	
ULTIMATE LOAD (LBS):	2118 UP, 4006 DOWN, 1331 SIDE	CLEAR / BLACK	
TORQUE SPECIFICATION:	12 LB-FT		
CERTIFICATION:	UL 2703, FILE E359313; WIND-DRIVEN RAIN TEST FROM SUBJECT UL 2582		
WEIGHT (LBS):	0.45		

DESCRIPTION:

PART NUMBER(S):

SNAPNRACK, ULTRA RAIL SPEEDSEAL™ FOOT

242-02163, 242-02167

Mwatkins

REVISION:


Α


DRAWN BY:




595 MARKET STREET, 29TH FLOOR ◆ SAN FRANCISCO, CA 94105 USA PHONE (415) 580-6900 ◆ FAX (415) 580-6902

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. AN REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT TH







ALL DIMENSIONS IN INCHES

SnapNrack SpeedSeal™ Foot

Patent Pending Lag Driven Sealant Solution for Ultra Rail



A New Generation of Roof Attachments

- Innovative design incorporates flashing reliability into a single roof attachment
- 100% waterproof solution
- Sealing cavity with compressible barrier secures sealant in place & fills voids

Maintain the Integrity of the Roof by Eliminating Disruption

- Zero prying of shingles
- Zero removal of nails leaving holes in the roof
- Roof remains installed the way manufacturer meant it to be


Lag Driven Sealant Waterproofing

Time Tested Roof Sealant provides lasting seal

- Sealant is compressed into cavity and lag hole as attachment is secured to rafter
- Active sealant solidifies bond if ever touched by liquid
- Technology passes UL 2582 Wind Driven Rain Test and ASTM E2140 Water Column Testing standards. Patent Pending.

Single Tool Installation

• SnapNrack was the first in the industry to develop a complete system that only requires a single tool. That tradition is continued as a $\frac{1}{2}$ " socket is still the only tool necessary to secure the mount as well as all other parts of the system.



Note: Sealant shown in white for illustration purposes only.

SnapNrack SpeedSeal™ Foot

Fastest Roof Attachment in Solar

- Lag straight to a structural member, no in-between components such as flashings or bases.
- Simply locate rafter, fill sealant cavity & secure to roof. *It's that simple!*

Integrated Flashings. No Questions.

- Sealant fills around lag screw keeping roof and structure sealed and intact
- No added holes from ripping up nails, staples and screws holding shingles on roof

Less Time. Less Parts. Less Tools.

- No more need for a pry bar to rip up shingles
- No more proprietary lag screws
- Single Tool installation with ½" socket

Total System Solution One Tool. One Warranty.

- SnapNrack Ultra Rail is a straightforward intuitive install experience on the roof without
- compromising quality, aesthetics & safety, all supported by a 25 year warranty.
- Built-in Wire Management & Aesthetically pleasing features designed for Ultra Rail result in a long-lasting quality install that installers and homeowners love.

Certifications

SnapNrack Ultra Rail System has been evaluated by Underwriters Laboratories (UL) and Listed to UL/ANSI Standard 2703 for Mechanical Loading and Fire. Additionally it is listed to UL 2582 for wind-driven rain and ASTM 2140.



877-732-2860 www.snapnrack.com

contact@snapnrack.com