

CAROLINA GAS SALES AND SERVICE, INC.

INSTALLATION, SALES & SERVICE OF GAS APPLIANCES

Dillon Tart, Owner License # 20968

I Dillon Tart with Carolina Gas Sales and Service Inc. Performed an air pressure test on gasline held 30PSI, for 30 minutes ok. no leaks. Ready for inspection

Job Name Charlene Edwards
802 Leslie Campbell Ave.
Lillington, N.C. 27546
910-890-4232

Thanks
Dillon Tart / Carolina Gas
910-237-5320