

76 North Meadowbrook Drive Alpine, UT 84004 office (201) 874-3483 swyssling@wysslingconsulting.com

November 27, 2023 Revised January 4, 2024

Current Insight 2852 W. Amini Way South Jordan, UT 84095

> Re: Engineering Services Stocks Residence 57 Simmons Drive, Erwin NC 6.400 kW System

To Whom It May Concern:

We have received information regarding solar panel installation on the roof of the above referenced structure. Our evaluation of the structure is to verify the existing capacity of the roof system and its ability to support the additional loads imposed by the proposed solar system.

A. Site Assessment Information

- 1. Site visit documentation identifying attic information including size and spacing of framing for the existing roof structure.
- Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information will be utilized for approval and construction of the proposed system.

B. Description of Structure:

Roof Framing: 2x6 dimensional lumber at 24" on center.

Roof Material: Composite Asphalt Shingles

Roof Slope: 22 degrees
Attic Access: Accessible
Foundation: Permanent

C. Loading Criteria Used

- Dead Load
 - Existing Roofing and framing = 7 psf
 - New Solar Panels and Racking = 3 psf
 - o TOTAL = 10 PSF
- Live Load = 20 psf (reducible) 0 psf at locations of solar panels
- Ground Snow Load = 15 psf
- Wind Load based on ASCE 7-10
 - Ultimate Wind Speed = 119 mph (based on Risk Category II)
 - Exposure Category C

Analysis performed of the existing roof structure utilizing the above loading criteria is in accordance with the 2018 North Carolina Residential Code, including provisions allowing existing structures to not require strengthening if the new loads do not exceed existing design loads by 105% for gravity elements and 110% for seismic elements. This analysis indicates that the existing framing will support the additional panel loading without damage, if installed correctly.

D. Solar Panel Anchorage

- 1. The solar panels shall be mounted in accordance with the most recent Ironridge installation manual. If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
- 2. The maximum allowable withdrawal force for a 5/16" lag screw is 229 lbs per inch of penetration as identified in the National Design Standards (NDS) of timber construction specifications. Based on a minimum penetration depth of 2½", the allowable capacity per connection is greater than the design withdrawal force (demand). Considering the variable factors for the existing roof framing and installation tolerances, the connection using one 5/16" diameter lag screw with a minimum of 2½" embedment will be adequate and will include a sufficient factor of safety.
- Considering the wind speed, roof slopes, size and spacing of framing members, and condition of the roof, the panel supports shall be placed no greater than 48" on center.

Based on the above evaluation, this office certifies that with the racking and mounting specified, the existing roof system will adequately support the additional loading imposed by the solar system. This evaluation is in conformance with the 2018 North Carolina Residential Code, current industry standards, and is based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

July D. Logge

Scott E. Wyssling, PE North Carolina License 1. 46546 North Carolina COA P-2308



Wyssling Consulting, PLLC 76 N Meadowbrook Brive Alpine UT 84004 North Carolina COA # P-2308 Signed 1/04/2024

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



ALICE STOCKS 57 RESIDENCE

NEW PHOTOVOLTAIC ROOF MOUNT SYSTEM PROJECT - 6.400 KW DC / 4.640 KW AC

| SHEET# | SHEET NAME |
|--------|--------------------|
| T-1 | COVER SHEET |
| T-2 | PLAN NOTES |
| PV-1 | SITE PLAN LAYOUT |
| PV-2 | ATTACHMENT DETAILS |
| PV-3 | MOUNTING DETAILS |
| E-1 | ELECTRICAL DIAGRAM |
| E-2 | WARNING LABELS |
| S-1 | SPEC SHEET |
| S-2 | SPEC SHEET |
| S-3 | SPEC SHEET |
| S-4 | SPEC SHEET |

BYLD BETTER

CONTRACTOR

DESIGN SPECIFICATIONS

PROPERTY OWNER

CONTRACTOR

NAME:

NAME:

OCCUPANCY:

CONSTRUCTION TYPE: SINGLE FAMILY RESIDENCE

BYLD

ALICE STOCKS 57

ZONING: RESIDENTIAL

PROJECT INFORMATION

WIND EXPOSURE:

AHJ: HARNETT COUNTY UTILITY: SOUTH RIVER EMC

APPLICABLE CODES & STANDARDS

NORTH CAROLINA RESIDENTIAL CODE 2018 (NCRC 2018) NORTH CAROLINA BUILDING CODE 2018 (NCBC 2018) NORTH CAROLINA FIRE CODE 2018 (NCFC 2018)

NATIONAL ELECTRICAL CODE, NEC 2020 CODE BOOK, NFPA 70

TYPE OF

INTERCONNECTION: BACKFEED BREAKER IN THE SSP

SCOPE OF WORK

TYPE OF SYSTEM: **ROOF MOUNT**

SYSTEM SIZE: STC: 16 X 400W = 6.400kW

PTC: 16 X 383W = 6.128kW

(16) REC SOLAR REC ALPHA REC400AA PURE-R (400W) [BLK] MODULES

(1) 30A KNIFE AC DISCONNECT (1) 100A PV LOAD CENTER



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carelina COA # P-2308 Signed 1/04/2024

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SIGNATURE AND DATE, PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

(8) NORTHERN ELECTRIC BDM-600X(BDM-300X2X) MICROINVERTERS

MSP UPGRADE: NO

RACKING & MOUNTING

MAIN BREAKER DERATE:

PV ATTACHMENT TYPE: IRONRIDGE FLASHVUE FOR COMP SHINGLE ROOF

RACKING TYPE:

IRONRIDGE XR10 RAIL ROOF MOUNT RACKING HARDWARE



AERIAL VIEW



BYLD

ADDRESS:1213W MOOREHEAD ST. STE500 CHARLOTTE. NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR. **ERWIN**, NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY



A Brighter Way.

SHEET

T-1 **COVER SHEET**

1.1. PROJECT NOTES:

- 1.2. THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRICAL CODE (NEC) ARTICLE 690, ALL MANUFACTURER'S LISTING AND
- INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION'S (AHJ) APPLICABLE CODES.
- 1.3. THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION
- 1.4. GROUND FAULT DETECTION AND INTERRUPTION (GFDI) DEVICE IS INTEGRATED WITH THE MICROINVERTER IN ACCORDANCE WITH NEC 690.5(A)
- 1.5. ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4 & NEC 690.60: PV MODULES: UL1703, IEC61730, AND IEC61215, AND NFPA 70 CLASS C FIRE INVERTERS: UL 1741 CERTIFIED, IEEE 1547, 929, 519 COMBINER BOX(ES): UL 1703 OR UL 1741 ACCESSORY
- 1.6. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.
- 1.7. ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4 (D). SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3].
- 1.8. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.

1.9. SCOPE OF WORK:

1.10. PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN, SPECIFY, AND INSTALL THE EXTERIOR ROOF-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS DOCUMENT.

1.11. WORK INCLUDES:

- 1.12. PV ROOF ATTACHMENTS IRONRIDGE FLASHVUE FOR COMP SHINGLE ROOF
- 1.13. PV RACKING SYSTEM INSTALLATION IRONRIDGE XR10 RAIL ROOF MOUNT RACKING HARDWARE
- 1.14. PV MODULE AND INVERTER INSTALLATION REC SOLAR REC ALPHA REC400AA PURE-R (400W) [BLK] MODULES/ NORTHERN ELECTRIC BDM-600X(BDM-300X2X) MICROINVERTER
- 1.15. PV EQUIPMENT GROUNDING
- 1.16. PV SYSTEM WIRING TO A ROOF-MOUNTED JUNCTION BOX
- 1.17. PV LOAD CENTERS (IF INCLUDED)
- 1.18. PV METERING/MONITORING (IF INCLUDED)
- 1.19. PV DISCONNECTS
- 1.20. PV GROUNDING ELECTRODE & BONDING TO (E) GEC
- 1.21. PV FINAL COMMISSIONING
- 1.22. (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV
- 1.23. SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE
- 1.24. SITE NOTES:
- 1.25. A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- 1.26. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH NO STORAGE BATTERIES.
- 1.27. THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.
- 1.28. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.
- 1.29. ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.

1.30. EQUIPMENT LOCATIONS:

- 1.31. ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY NEC
- 1.32. WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C)
- 1.33. JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.
- 1.34. ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT.
- 1.35. ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.
- 1.36. ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

1.37. STRUCTURAL NOTES:

- 1.38. RACKING SYSTEM
- 1.39. PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES, AND RAILS MUST ALSO EXTEND
- 1.40. A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAI MANUFACTURER'S INSTRUCTIONS.
- 1.41. JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED SEALED PER LOCAL REQUIREMENTS.
- 1.42. ROOFTOP PENETRATIONS FOR PV RACEWAY WILL BE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.
- 1.43. ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.
- 1.44. WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.

1.45. WIRING & CONDUIT NOTES:

- 1.46. ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.
- 1.47. CONDUCTORS SIZED ACCORDING TO NEC 690.8. NEC 690.7.
- 1.48. VOLTAGE DROP LIMITED TO 2%.
- 1.49. DC WIRING LIMITED TO MODULE FOOTPRINT. MICROINVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.
- 1.50. AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1-BLACK PHASE B OR L2-RED, OR OTHER CONVENTION IF THREE PHASE PHASE C OR L3-BLUE, YELLOW, ORANGE**, OR OTHER CONVENTION NEUTRAL- WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH HIGHER VOLTAGE TO BE MARKED ORANGE [NEC 110.15

1.51. **GROUNDING NOTES**:

- 1.52. GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVISES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.
- 1.53. PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.
- 1.54. METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURES CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).
- 1.55. EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO NEC 690.45 AND MICROINVERTER MANUFACTURER'S INSTRUCTIONS.

- 1.56. EACH MODULE WILL BE GROUNDED USING WEEB GROUNDING CLIPS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURER'S INSTALLATION REQUIREMENTS.
- 1.57. THE GROUNDING CONNECTION TO

 A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OF
 A MODULE DOES NOT INTERRUPT
 A GROUNDING CONDUCTOR TO ANOTHER MODULE.
- 1.58. GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER INEC 250.1191
- 1.59. THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS INACCESSIBLE, OR INADEQUATE, A GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250.
- NEC 690.47 AND AHJ.

 1.60. GROUND-FAULT DETECTION SHALL COMPLY WITH NEC 690.5 IN GENERAL AND NEC 690.5 (A)(1) SPECIFICALLY.

1.61. DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:

- 1.62. DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS).
- 1.63. DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH
- 1.64. RAPID SHUTDOWN OF ENERGIZED CONDUCTORS BEYOND 10 FT OF PV ARRAY OR 5 FT INSIDE A BUILDING WITHIN 10 SECONDS. CONTROLLED CONDUCTORS ≤30V AND ≤240VA [NEC 690.12]. LOCATION OF LABEL ACCORDING TO AHJ
- 1.65. ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.
- 1.66. MICROINVERTER BRANCHES CONNECTED TO
 A SINGLE BREAKER OR GROUPED FUSES IN ACCORDANCE WITH NEC
 110.3(B).
- 1.67. IF REQUIRED BY AHJ, SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL1699B.

1.68. ELECTRICAL INTERCONNECTION NOTES:

- 1.68. THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF THE BUSBAR RATING.
- 1.69. WHEN THE SUM OF THE PV SOURCES EQUALS >100% OF THE BUSBAR RATING, PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD.
- AT MULTIPLE PV OUTPUT COMBINER PANEL, THE TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED THE AMPACITY OF THE BUSBAR. HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED.

 SUPPLY-SIDE TAP INTERCONNECTION SHOULD BE WITH SERVICE ENTRANCE.
- CONDUCTORS.

 1.72. BACKFEEDING BREAKER FOR UTILITY-INTERACTIVE INVERTER OUTPUT
- EXEMPT FROM ADDITIONAL FASTENING.

 1.73. BACKFEEDING BREAKER FOR UTILITY-INTERACTIVE INVERTER AU PUT IS



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308

Signed 1/04/2024

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57
RESIDENCE

57 SIMMONS DR, ERWIN , NC 28339

APN: 0588713857000


DATE:1/4/2024


DESIGN BY



A Brighter Way

SHEET T-2 PLAN NOTES





Roof Section 1
Roof Azimuth: 131°
Roof Tilt: 22°

EXISTING 2"X6" ROOF RAFTERS @ 24"O.C

PROPOSED IRONRIDGE

XR10 RAIL RACKING

EXISTING COMP SHINGLE ROOF

IRONRIDGE FLASHVUE FOR COMP

SHINGLE ROOF@ 48" O.C. MAX

TH CAROL WYSSIMMING OF THE WY

Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308 Signed 1/04/2024

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

PROPOSED REC SOLAR REC ALPHA REC400AA PURE-R (400W) [BLK] PV SOLAR MODULES BYLD BETTER

CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR, ERWIN , NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY


CompleteSolar


A Brighter Way.


SHEET
PV-2
ATTACHMENT DETAILS


PV SYSTEM MOUNTING DETAILS

SCALE: 1/8" = 1'-0"










RACKING DETAIL (LONGITUDINAL)



Wyssling Consulting, PLLC 76 N Meadowbrook Drive Alpine UT 84004 North Carolina COA # P-2308 Signed 1/04/2024

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



- ROOF MATERIAL: COMP SHINGLE ROOF
- **ROOF STRUCTURE: RAFTERS**
- ATTACHMENT TYPE: IRONRIDGE FLASHVUE
- MODULE MANUFACTURER: REC SOLAR
- MODULE MODEL: REC ALPHA REC400AA PURE-R (400W) [BLK]
- MODULE LENGTH: 68.11"
- MODULE WIDTH: 44.01"
- MODULE WEIGHT: 47.39 LBS.
- SEE SHEET S-1 FOR DIMENSION(S)
- MIN. FIRE OFFSET
- RAFTERS SPACING: 24" O.C.
- RAFTERS SIZE: 2"X6" NOMINAL
- LAG BOLT DIAMETER: 5/16 IN.
- LAG BOLT EMBEDMENT: 2.5 IN.
- TOTAL # OF ATTACHMENTS: 34
- TOTAL AREA: 333.06 SQ. FT.
- TOTAL WEIGHT: 758.24LBS.
- WEIGHT PER ATTACHMENT: 22.30 LBS.
- DISTRIBUTED LOAD: 2.28 PSF
- MAX. HORIZONTAL STANDOFF: 48 IN.
- MAX. VERTICAL STANDOFF: LANDSCAPE: 26 IN., PORTRAIT: 44 IN.
- 22. STANDOFF STAGGERING: YES
- RAIL MANUFACTURER AND MODEL (OR EQUIV.):IRONRIDGE XR10 RAIL
- RAIL WEIGHT: 0.436 PLF.
- MAX. RAFTERS SPAN: 12 FT.
- MODULE CLEARANCE: 3 IN. MIN., 6 IN. MAX.



CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

> 57 SIMMONS DR, **ERWIN**, NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY


Complete Solar

A Brighter Way

SHEET PV-3 MOUNTING DETAILS

D5

NOT TO SCALE



!WARNING

ELECTRICAL SHOCK HAZARD

TERMINALS ON LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL LOCATION:

INVERTER(S), AC DISCONNECT(S), AC COMBINER PANEL (IF APPLICABLE). PER CODE(S): NEC: 690.13(B), NEC: 690.17(E), NEC: 690.17(4)

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

LABEL LOCATION:

UTILITY SERVICE ENTRANCE/METER, INVERTER/DC DISCONNECT IF REQUIRED BY LOCAL AHJ, OR OTHER LOCATIONS AS REQUIRED BY LOCAL AHJ. PER CODE(S): NEC: 690.56(C)(3), NEC: 690.12, NEC 690.56, IFC: 605.11.1, IFC: 1204.5.3



POWER SOURCE OUTPUT CONNECTION

DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL LOCATION:

ADJACENT TO PV BREAKER (IF APPLICABLE). PER CODE(S): NEC: 705.12(B)(3)(2), NEC: 705.12(B)(2)(3)(b), NEC: 705.12(D)(2)(3)(b)

! WARNING

THIS EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR.

LABEL LOCATION:

AC DISCONNECT(S), PHOTOVOLTAIC SYSTEM POINT OF INTERCONNECTION.

PER CODE(S): NEC: 690.54, NEC: 690.54, NEC: 690.54

MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

<u>LABEL LOCATION:</u> PV SYSTEM DISCONNECT PER CODE(S): NEC 690.13(B)



DUAL POWER SOURCE SECOND SOURCE IS PHOTOVOLTAIC SYSTEM

LABEL LOCATION:

MAIN SERVICE PANEL (IF APPLICABLE).
PER CODE(S): NEC: 705.12(C) & 690.59

PHOTOVOLTAIC AC DISCONNECT

MAXIMUM AC OPERATING CURRENT: 19.36 AMPS NOMINAL OPERATING AC VOLTAGE: 240.0 VAC


LABEL LOCATION:

AC DISCONNECT(S), PHOTOVOLTAIC SYSTEM POINT OF INTERCONNECTION.

PER CODE(S): NEC : 690.54

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY.



LABEL LOCATION:


ON OR NO MORE THAT 3 M (10 FT) FROM THE SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED.

PER CODE(S): NEC: 690.56(C)(1)(a)

CAUTION:

POWER TO THIS BUILDING IS
ALSO SUPPLIED FROM THE
FOLLOWING SOURCES WITH
DISCONNECTS AS SHOWN





CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR, ERWIN, NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY

Complete Solar

A Brighter Way.

SHEET E-2 WARNING LABELS


PERMANENT SIGNAGE NOTES:


- NOT ALL PLACARDS SHOWN MAY BE REQUIRED BY LOCAL AHJ. CONTRACTOR TO VERIFY PLACARD REQUIREMENTS WITH LOCAL AHJ BEFORE INSTALLATION.
- 2. ALL PLAQUES AND SIGNAGE REQUIRED BY THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE
- ALTERNATE POWER SOURCE PLACARD SHALL BE METALLIC OR MACHINE PRINTED LETTERS IN A
 CONTRASTING COLOR TO THE PLAQUE. THIS PLAQUE WILL BE ATTCHED BY POP RIVETS OR SCREWS OR
 OTHER APPROVED METHOD.
- 4. DIRECTORY PLACARD MARKING CONTENT AND FORMAT: RED BACKGROUND, WHITE LETTERING, MINIMUM 3/8" LETTER HIEGHT, ALL CAPITAL LETTERS, ARIAL OR SIMILAR FONT, NON BOLD, REFLECTIVE WEATHER RESISTANT MATERIAL SUITABLE FOR THE ENVIRONMENT.



REC ALPHA PURE-R SERIES PRODUCT SPECIFICATIONS







IEC 61701

IEC 62716

ISO 11925-2

IEC 62782

IFC 62321

IEC 61215:2016, IEC 61730:2016, UL 61730

IEC 61215-2:2016 Hailstone (35mm)

Nominal Module Operating Temperature: Temperature coefficient of P_{MAX}

Temperature coefficient of V_{ov}

Temperature coefficient of I

IEC 61730-2:2016 Fire Class C (as per UL790)

Salt Mist

Ammonia Resistance

Dynamic Mechanical Load

Ignitability (EN 13501-1 Class E)

Lead-free acc. to RoHS EU 863/2015

-0.24 %/°C

0.04 %/°C

924 (28 pallets)

| ELECTRICAL DATA P | | | Product Code*: RI | ECxxxAA Pure-R | | | |
|-------------------|--|-------|-------------------|----------------|-------|--|--|
| | Power Output - P _{MAX} (Wp) | 400 | 410 | 420 | 430 | | |
| | Watt Class Sorting - (W) | 0/+10 | 0/+10 | 0/+10 | 0/+10 | | |
| | Nominal Power Voltage - $V_{MPP}(V)$ | 48.8 | 49.4 | 50.0 | 50.5 | | |
| , | Nominal Power Current - I _{MPP} (A) | 8.20 | 8.30 | 8.40 | 8.52 | | |
|) | Open Circuit Voltage - V _{oc} (V) | 58.9 | 59.2 | 59.4 | 59.7 | | |
| | Short Circuit Current - I _{SC} (A) | 8.80 | 8.84 | 8.88 | 8.91 | | |
| | Power Density (W/m²) | 207 | 212 | 218 | 223 | | |
| | Panel Efficiency (%) | 20.7 | 21.2 | 21.8 | 22.3 | | |
| | Power Output - P _{MAX} (Wp) | 305 | 312 | 320 | 327 | | |
| | Nominal Power Voltage - V _{MPP} (V) | 46.0 | 46.6 | 47.1 | 47.6 | | |
| 2 | Nominal Power Current - I _{MPP} (A) | 6.64 | 6.70 | 6.80 | 6.88 | | |
| | Open Circuit Voltage - V _{oc} (V) | 55.5 | 55.8 | 56.0 | 56.3 | | |
| | Short Circuit Current - I _{SC} (A) | 7.11 | 7.16 | 7.20 | 7.24 | | |

Values at standard test conditions (STC: air mass AM1.5, irradiance 1000 W/m², temperature 25°C), based on a production spread with a tolerance of P_{WAC} , V_{DC} & I_{DC} ±3% within one watt class. Nominal module operating temperature (NMOT: air mass AM1.5, irradiance 800 W/m², temperature 20°C, windspeed 1 m/s).* Where xxx indicates the nominal power class (P_{MAC}) at STC above.

| MAXIMUM RATINGS | |
|--------------------------|----------------------------------|
| Operational temperature: | -40+85°C |
| System voltage: | 1000 V |
| Test load (front): | +7000 Pa (713 kg/m²)° |
| Test load (rear): | -4000 Pa (407 kg/m²)° |
| Series fuse rating: | 25 A |
| Reverse current: | 25 A |
| | nanual for mounting instructions |

| 2 | | Standard | REC | ProTrust | |
|-----|--|----------|--------|-----------|--|
| / | Installed by an REC Certified Solar Professional | No | Yes | Yes | |
|)~ | System Size | All | ≤25 kW | 25-500 kW | |
|)" | Product Warranty (yrs) | 20 | 25 | 25 | |
| 4 | Power Warranty (yrs) | 25 | 25 | 25 | |
| Α . | Labor Warranty (yrs) | 0 | 25 | 10 | |
| ns. | Power in Year 1 | 98% | 98% | 98% | |
| or) | Annual Degradation | 0.25% | 0.25% | 0.25% | |
| | Power in Year 25 | 92% | 92% | 92% | |
| | The REC ProTrust Warranty is only available on panels purchased through an REC Certified Solar Professional installer. Warranty conditions apply. See www.recgroup.com for more details. | | | | |

Panels per 40 ft GP/high cube container: 858 (26 pallets) Panels per 13.6 m truck:

| 25 | |
|--|--|
| 25 | LOW LIGHT BEHAVIOUR |
| 10 | Typical low irradiance performance of module at STC: |
| 8% | % 38 38 38 38 38 38 38 38 38 38 38 38 38 |
| 25% | |
| 12% rchased /arranty details. | Rel. Efficiency |
| | 160 200 300 400 500 400 700 000 500 1000 Irradiance (W/m²) |

Available from:

Founded in 1996, REC Group is an international pioneering solar energy company dedicated to empowering consumers with clean, affordable solar power. As Solar's Most Trusted, REC is committed to high quality, innovation, and a low carbon footprint in the solar materials and solar panels it manufactures. Headquartered in Norway with operational headquarters in Singapore, REC also has regional hubs in North America, Europe, and Asia-Pacific.

REC Solar PTE. LTD. 20 Tuas South Ave. 14 Singapore 637312 post@recgroup.com www.recgroup.com





CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST. STE500 CHARLOTTE. NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR. ERWIN, NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY



A Brighter Way.

SHEET S-1 SPEC SHEET






BDM-600X (BDM-300X2X) **MICROINVERTER**




Features




 High continuos output power up to 580Wac, recommended for dua max 450W solar panel



• Globally certified for UL1741, SAA, TUV, VDE-AR-N 4105, VDE 0126, G83/2, CEL 021, IEC61727, EN50438



• High efficiency with 95.5% CEC



with RDG-256 gateway

Can connect with BDM-300 and BDM-250



Important product information

• NEP is committed to developing Clean, Affordable, Reliable and Efficient (CARE) products for our customers worldwide.

• NEP microinverters have an isolation transformer and basic isolation between the DC input and the AC output network.

| NORTHERN ELECTRIC |
|-----------------------|
| BDM-600X (BDM-300X2X) |
| MICROINVERTER |
| |



* Grid parameters are configurable through a BDG-256 or

Group parameters are cominguration introdgin a BDG-250 BDG-256P3 gateway

* All NEC required adjustment factors have been considered for AC outputs. AC current outputs will not exceed stated values for Rated Output AC Current

COMPLIANCE
*NEC 2014 Section 690.11 DC Arc-Fault Circuit Protection
*NEC 2014 Section 690.12 Rapid Shutdown of PV Systems on

Buildings
*NEC 2014 Section 705.12 Point of Connection (AC Arc-Fault

| | Recommended Max PV Power (Wp) | | 450 x 2 | | |
|-------------------|--|-----------------------------------|-----------------------------------|--|--|
| | Max DC Open Circuit Voltage (Vdc) | | 60 | | |
| | Max DC Input Current (Adc) | | 14 x 2 | | |
| INPUT(DC) | MPPT Tracking Accuracy | | >99.5% | | |
| | MPPT Tracking Range (Vdc) | | 22-55 | | |
| | Isc PV (absolute maximum) (Adc) | | 18 x 2 | | |
| | Maximum Inverter Backfeed Current to the Array (Adc) | | 0 | | |
| | Peak AC Output Power (Wp) | | 580(continuous) | | |
| | Rated AC Output Power (Wp) | | 500 | | |
| | Nominal Power Grid Voltage (Vac) | 240 | 208 | 230 | |
| | Allowable Power Grid Voltage (Vac) | 211-264* | 183-229* | configurable* | |
| | Allowable Power Grid Frequency (Hz) | 59.3 a | 0.5* | configurable | |
| | THD | <3% | at rated pov | | |
| | Power Factor (cos phi, fixed) | | at rated po | | |
| OUTPUT (AC) | Rated Output Current (Aac) | 2.42 | 2.78 | 2.52 | |
| | Current (inrush)(Peak and Duration) | | 24A, 15u | | |
| | Nominal Frequency (Hz) | 6 | 0 | 50 | |
| | Maximum Output Fault Current (Aac) | | 4.4A pea | - | |
| | Maximum Output Overcurrent Protection (Aac) | | 10 | | |
| | Maximum Number of Units Per Branch (20A) (All NEC adjustment factors have been considered) | 7 | 6 | 6 | |
| | Weighted Averaged Efficiency (CEC) | | 95.50% | | |
| SYSTEM EFFICIENCY | Night Time Tare Loss (Wp) | | 0.11 | | |
| | Over/Under Voltage Protection | | Yes | | |
| | Over/Under Frequency Protection | | Yes | | |
| | Anti-Islanding Protection | | Yes | | |
| | Over Current Protection | | Yes | | |
| | Reverse DC Polarity Protection | | Yes | | |
| | Overload Protection | | Yes | | |
| | Protection Degree | NE | NEMA-6 / IP-66 / IP-67 | | |
| | Ambient Temperature | | -40°F to +149°F (-40°C to +65°C) | | |
| | Operating Temperature | | -40°F to +185°F (-40°C to +85°C) | | |
| | Display | | LED LIGHT | | |
| | Comunications | | Power Line | | |
| PROTECTION | Dimension (W-H-D) | | 10.91"x5.20"x1.97"(277x132x50 mm) | | |
| | Weight | | 6.4 lbs. (2.9 kg) | | |
| FUNCTIONS | Environment Category | | Indoor and outdoor | | |
| | Wet Location | | Suitable | | |
| | Pollution Degree | | PD 3 | | |
| | Overvoltage Category | II(P | II(PV), III (AC MAINS) | | |
| | Product Safety Compliance | UL 1741 CSA C22.2 No. 107.1 | IEC/E | N 62109-1 N 62109-2 | |
| | Grid Code Compliance* (Refer to the label for the detailed grid code compliance) | IEEE 1547 | VDE V G83/2 AS 47 | AR-N 4105* 0126-1-1/A1 2, CEI 021 777.2 & AS 3.EN50438 | |

CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR. ERWIN, NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY



A Brighter Way.

SHEET S-2 SPEC SHEET



Their superior spanning capability

requires fewer roof attachments,


reducing the number of roof

penetrations and the amount

of installation time.

XR Rail Family

Solar Is Not Always Sunny Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame. XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure.



Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

Corrosion-Resistant Materials



Compatible with Flat & Pitched Roofs



IronRidge offers a range of tilt leg options for flat roof mounting applications.

All XR Rails are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.

XR Rail Family

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



XR10

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves spans up to 6 feet, while remaining light and economical.

· 6' spanning capability

Rail Selection

None

20

30

40

80

120

- Moderate load capability
- · Clear & black anodized finish
- Internal splices available

Load

Snow (PSF) Wind (MPH)

120

140

160

90 120

140

160

90

160

90

160

160

160

XR10



XR100

XR100 is the ultimate residential mounting rail. It supports a range of maximizing spans up to 10 feet.

- · 10' spanning capability
- Heavy load capability
- Internal splices available



XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications

- 12' spanning capability
- Extreme load capability
- Clear anodized finish
- Internal splices available

XR1000

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR. ERWIN, NC 28339

DESIGN BY



A Brighter Way.

SHEET S-3 SPEC SHEET



wind and snow conditions, while also

Rail Span

XR100

*Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved certification letters for actual design guidance.

- · Clear & black anodized finish

The table below was prepared in compliance with applicable engineering codes and standards.* Values are

based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof

Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed certification letters.



CONTRACTOR

BYLD BETTER

BYLD

ADDRESS:1213W MOOREHEAD ST. STE500 CHARLOTTE. NC 28208 LICENSE #:

DESIGNER: OAV

APN: 0588713857000

DATE: 1/4/2024






Cut Sheet





FlashVue

v1.0




| ITEM NO | DESCRIPTION | QTY IN KIT |
|---------|----------------------------|------------|
| 1 | BOLT, LAG 5/16 X 4.25" | 1 |
| 2 | WASHER, EPDM BACKED | 1 |
| 3 | FM FLASHING, MILL OR BLACK | 1 |
| 4 | GRIP CAP, MILL OR BLACK | 1 |

FLASHVUE


| PART NUMBER | DESCRIPTION |
|-------------|----------------------------|
| FV-01-M1 | FLASHING, FLASHFOOT, MILL |
| FV-01-B1 | FLASHING, FLASHFOOT, BLACK |


1) BOLT, LAG 5/16 x 4.25"



Clear


Finish





| Property | Value |
|----------|------------|
| Material | Aluminum |
| Finish | Mill/Black |

4) FM Flashing





CONTRACTOR

BYLD

ADDRESS:1213W MOOREHEAD ST, STE500 CHARLOTTE, NC 28208 LICENSE #:

DESIGNER: OAV

ALICE STOCKS 57 RESIDENCE

57 SIMMONS DR, ERWIN , NC 28339

APN: 0588713857000

DATE:1/4/2024

DESIGN BY



A Brighter Way.

SHEET S-4 SPEC SHEET