CODE AND STANDARDS

THE INSTALLATION OF SOLAR ARRAYS AND PHOTOVOLTAIC POWER SYSTEMS SHALL COMPLY WITH THE FOLLOWING CODES:

NOTICE TO CONTRACTOR
Al construction must comply with current No Building Codes and its subject to feed in appeal con and referedation.

12/22/2023

PHOTOVOLTAIC ROOF MOUNT SYSTEM

- 2020 NATIONAL ELECTRICAL CODE
- 2018 NORTH CAROLINA RESIDENTIAL CODE
- 2018 NORTH CAROLINA BUILDING CODE
- ALL OTHER ORDINANCE ADOPTED BY THE LOCAL GOVERNING AGENCIES

SITE NOTES / OSHA REGULATION

- 1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- 2. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.
- 3. ROOFTOP MOUNTED PHOTOVOLTAIC PANELS AND MODULES SHALL BE TESTED, LISTED AND IDENTIFIED BY RECOGNIZED ELECTRICAL TESTING LABORATORY.
- 4. MODULES AND SUPPORT STRUCTURES SHALL BE GROUNDED
- 5. SOLAR INVERTER SHALL BE LISTED TO UL1741
- 6. ALL CONDUCTORS SHALL BE COPPER AND SHOULD BE 75 AND 90 DEG RATED
- 7. REMOVAL OF AN INTERACTIVE INVERTER OR OTHER EQUIPMENT SHALL NOT DISCONNECT THE BONDING CONNECTION BETWEEN THE GROUNDING ELECTRODE CONDUCTOR, THE PHOTOVOLTAIC SOURCE AND OUTPUT CIRCUIT GROUNDED CONDUCTORS.
- 8. LIVE PARTS OF PV SOURCE CIRCUITS AND PV OUTPUT CIRCUITS OVER 150V TO GROUND SHALL NOT BE ACCESSIBLE TO OTHER THAN QUALIFIED PERSONS WHILE ENERGIZED.
- 9. ALL PV MODULES AND ASSOCIATED EQUIPMENT AND WIRING SHALL BE PROTECTED FROM PHYSICAL DAMAGE.

SOLAR CONTRACTOR

- 1. MODULE CERTIFICATIONS INCLUDE UL1703, IEC61646, IEC61370.
- 2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER THE MANUFACTURERS INSTALLATION REQUIREMENTS.
- 3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ.
- 4. ALL MICROINVERTERS, PHOTOVOLTAIC MODULES, AC COMBINERS, DC-AC CONVERTERS AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER NEC690.4(B).
- 5. ALL SIGNAGE TO BE INSTALLED IN ACCORDANCE WITH LOCAL BUILDING CODE.
- 6. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.
- 7. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT AVAILABLE.

	SR.#	PF	ROJECT INFORMATION	
	1	PV MODULES	45 x SILFAB ELITE SIL-410 BG	
	2	INVERTER	45 x IQ8PLUS-72-2-US	
	3	ROOF TYPE	METAL ROOF	
	4	RACKING	PSR-B84 RAILS (BLACK)	
	5	MOUNTING TYPE	S5 SOLARFOOT	
	6	DC SIZE	18.45 KW	
	7	AC SIZE	13.05 KVA	Cu
	SR.#	PI	ROJECT INFORMATION	Ge
	1	PV1	DRAWING INDEX	292 Sar
	2	PV2	SITE LAYOUT	

2	PV2	SITE LAYOUT	
3	PV3	STRING MAPPING	
4	PV4	ELECTRICAL ONE LINE DIAGRAM	
5	PV5	DETAILED ELECTRICAL WIRING SCHEMATIC	
6	PV6	PV LABELS	
7	PV7	BILL OF MATERIALS	
8	PV8	ATTACHMENT DETAILS	
Burtreport Mel	Helioboough Durtharm	Wuke Grant	



ustomer Information:	
-	
E: info@8msolar.com	
O: 919.948.6474	
Raleigh NC 27616	
5112 Departure Drive,	

8MSOLAR

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:

Drawing Index

JOB NUMBER:

23-625-GR

Date:	Revision:
12/11/2023	A
Sheet Size:	Sheet Number:
ANSI C 17" X 22"	PV1

DESIGN CRITERIA
WIND SPEED: 110 MPH
GROUND SNOW LOAD: 10 PSF
WIND EXPOSURE FACTOR: B


UTILITY COMPANY:DUKE ENERGY

PERMIT ISSUER (AHJ):
HARNETT COUNTY

SCOPE OF WORK
INSTALLATION OF UTILITY
INTERACTIVE PHOTOVOLTAIC
SOLAR SYSTEM.

VICINITY MAP

TOP VIEW OF THE BUILDING



	MODULE DIMENSIONS			
ROOF	PITCH	AZIMUTH	NO. OF MODULES	40.5 in
А	22°	258°	45	4
				73.4 in.
				—————
			•	

No vents will be covered by


PV modules during the

installation

Note: Roof will be grounded by connecting it to any of array's ground

using a grounding lug.

PV System Dead Load (Panel + Racking weight) / PV System Area (No. of panels x Weight of panel(lbs.) +Length of racking(ft.) x 1.15 lb.ft) / (No. of panels x Height x Width) = Total psf ROOF Α DEAD LOAD 2.63 (PSF)





NUMBER OF PANELS: 45

PANELS MODEL : SILFAB ELITE SIL-410 BG

DC SIZE: 18.45 KW AC SIZE: 13.05 KVA



5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:


Site Layout

JOB NUMBER:

23-625-GR

Date:	Revision:
12/11/2023	А
Sheet Size:	Sheet Number:
ANSI C 17" X 22"	PV2





6in setback from sides of the roof


Vent

N SITE LAYOUT SCALE: 1/8" - 1'

ROOF DESCRIPTION MODUL			LE DIMENSIONS			STRING	LAYOUT				
ROOF	PITCH	AZIMUTH	NO. OF MODULES		√ 40.5 in ←			ENPHASE IQ	COMBINER 4		
A	22°	258°	45			Strings #	No. of Modules	Color	Strings #	No. of Modules	Color
				73.4 in.		String 1	12		String 4	11	
				7		String 2	11				
						String 3	11				

6in setback from

sides of the roof



SYSTEM DETAILS

NUMBER OF PANELS: 45

PANELS MODEL : SILFAB ELITE SIL-410 BG

DC SIZE : 18.45 KW AC SIZE : 13.05 KVA



5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:


Sheet Name:


String Mapping

JOB NUMBER:

Date:	Revision:
12/11/2023	А
Sheet Size:	Sheet Number:
ANSI C 17" X 22"	PV3







STRING CALCULATION							
String # No of Estimated Power Imax Voc Vmpp Vrise (<=							
1	12	4,920 W	18.15 AC	<30	240V AC	1.47+0.38 = 0.85	
2	11	4,510 W	16.63 AC	<30	240V AC	1.35+0.35 = 1.70	
3	11	4,510 W	16.63 AC	<30	240V AC	1.37+0.37 = 1.74	
4	11	4,510 W	16.63 AC	<30	240V AC	1.30+0.34 = 1.64	

NEC Code (2020) and UL Standard Refrences					
Rapid Shut Down	NEC 690.12 (A-D), UL1741	Grounding	NEC Article 250.30(A)		
Disconnecting Means	NEC 690.13	Conduit Fill	NEC Table C.9, 310.15(B)(3)(a)		
Feeder Sizing	NEC Table 310, 15(B)(16, 17)	Interconnection	NEC 705.12		
Over current Protection	NEC 690.9				

FROM UTILITY


Utility Meter



5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474

E: info@8msolar.com

45 X SILFAB ELITE SIL-410 BG 410W ENPHASE IQ8PLUS-72-2-US MICROINVERTERS 290VA RAPID SHUTDOWN EQUIPPED



Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:

Electrical One Line Diagram

JOB NUMBER:


Date:	Revision:
12/11/2023	А
Sheet Size:	Sheet Number:
ANSI C 17" X 22"	PV4

- System Size: 18,450W DC
- (45) SILFAB ELITE SIL-410 BG
- (45) ENPHASE IQ8PLUS-72-2-US MICROINVERTERS
- Inverter Output: 1.21A max @ 240 VAC (each microinverter)
- 290 VA AC output max (each micro inverter)
- 13.05 kVA AC output max

- Grounding will be done via Pegasus grounding lugs and mid-clamps to ensure the rail and panels are continuously grounded.
- Rapid Shutdown is included in the Micro Inverters, refer to Micro Inverter attached datasheets.
- The load center / disconnect will be visible, lockable accessible to utility linesmen and will be properly labelled as per NEC requirements. It will be located on the exterior wall of the building, next to the utility meter.

Sr.No	#Wire	Conduit Size	Ground Wire	Amperage
1	1 x #12 Q Cable		#10 Bare CU	20
2	8 x #10 THHN Cu	3/4" EMT	#10 Green Cu	20
3	3 x #4 THHN Cu	1" EMT	#8 Green Cu	80
4	3 x #4 THHN Cu	1" EMT		80
5	Lead Wire 18AWG, PVC Extruded			







5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

FROM UTILITY

GRID

2923 Highway 87 N Sanford NC 27332


Customer Signature:


Sheet Name:


Detailed Electrical Diagram

JOB NUMBER:

Date:	Revision:
12/11/2023	А
Sheet Size:	Sheet Number:
ANSI C 17" X 22"	PV5







LABELING AND WARNING SIGNS: NEC 2020

A. PURPOSE

PROVIDE EMERGENCY RESPONDERS WITH APPROPRIATE WARNING AND GUIDANCE WITH RESPECT TO ISOLATING THE SOLAR ELECTRIC SYSTEM. THIS CAN FACILITATE IDENTIFYING ENERGIZED ELECTRICAL LINES THAT CONNECT THE SOLAR PANELS TO THE INVERTER, AS SHOULD NOT BE CUT WHEN VENTING FOR SMOKE REMOVAL.

B. MAIN SERVICE DISCONNECT:

- 1. RESIDENTIAL BUILDINGS- THE MARKING MAY BE PLACED WITHIN THE MAIN SERVICE DISCONNECT. THE MARKING SHALL BE PLACED ON THE OUTSIDE COVER IF THE MAIN SERVICE DISCONNECT IS OPERABLE WITH THE SERVICE PANEL CLOSED.
- 2. COMMERCIAL BUILDINGS- THE MARKINGS SHALL BE PLACED ADJACENT TO THE MAIN SERVICE DISCONNECTCLEARLY VISIBLE FROM THE LOCATION WHERE THE LEVER IS OPERATED
- 3. MARKINGS, VERBIAGE, FORMAT AND TYPE OF MATERIAL
 - a. VERBIAGE: CAUTION; SOLAR ELECTRIC SYSTEM CONNECTED b. FORMAT:
 - (1) WHITE LETTERING ON A RED BACKGROUND
 - (2) MINIMUM 3/8 INCH LETTER HEIGHT
 - (3) ALL LETTERS SHALL BE CAPITALIZED
 - (4) ARIAL OR SIMILAR FONT, NON-BOLD


c. MATERIAL:

- (1) REFLECTIVE, WEATHER RESISTANT MATERIAL SUITABLE FOR THE ENVIRONMENT (USE UL-969) AS STANDARD FOR WEATHER RATING): DURABLE ADHESIVE MATERIALS MEET THIS REQUIREMENT.
- C. MARKING REQUIREMENTS ON CONDUIT, RACEWAYS, ENCLOSURES, CABLE ASSEMBLIES, COMBINERS AND JUNCTION BOXES;
 - 1. MARKING: PLACEMENT, VERBIAGE, FORMAT AND TYPE OF MATERIAL.
 - a. PLACEMENT: MARKINGS SHALL BE PLACED EVERY 10 (TEN) FEET ON ALL INTERIOR AND EXTERIOR DC CONDUITS, RACEWAYS, ENCLOSURES AND CABLE ASSEMBLIES, AT TURNS ABOVE AND/OR BELOW PENETRATIONS, ALL COMBINERS AND JUNCTION BOXES. b. VERBIAGE: CAUTION SOLAR CIRCUIT
 - c. THE FORMAT AND TYPE OF MATERIAL SHALL ADHERE TO SECTION B-3.B & C ABOVE
- D. INVERTERS ARE NOT REQUIRED TO HAVE CAUTION MARKINGS



RAPID SHUTDOWN
SWITCH FOR
SOLAR PV SYSTEM





SOLAR AC DISCONNECT
LOCATED AT SOUTH SIDE WALL
OF THE HOUSE BESIDE THE
UTILITY METER

#6
SERVICE DISCONNECT LOCATED
INSIDE THE MAIN LOAD PANEL

#7
PHOTOVOLTAIC SYSTEM
COMBINER PANEL
DO NOT ADD LOADS

WARNING

THIS EQUIPMENT FED BY MULTIPLE
SOURCES.TOTAL RATING OF ALL
OVERCURRENT DEVICES,EXCLUDING
MAIN SUPPLY OVERCURRENT
DEVICE,SHALL NOT EXCEED
AMPACITY OF BUSBAR



DUAL POWER SUPPLY
SOURCES: UTILITY GRID AND
PV SOLAR ELECTRIC SYSTEM

#10 _____ WARNING

TURN OFF PHOTOVOLTAIC AC DISCONNECT PRIOR TO WORKIN INSIDRE PANEL

! WARNING

ELECTRIC SHOCK HAZARD

TERMIONAL OM THE LINE AND LOAD

SIDES MAY BE ENERGIZED IN THE OPEN POSITION

#12 ! WARNING

THIS SERVICE METER
IS ALSO SERVED BY A PHOTOVOLTAIC
SYSTEM

#13 SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN
SWITCH TO THE "OFF"
POSITION TO SHUT DOWN
PV SYSTEM AND REDUCE
SHOCK HAZARD IN THE
ARRAY





5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:

PV Labels

JOB NUMBER:

23-625-GR


Date:
Revision:

12/11/2023
A

Sheet Size:
ANSI C
17" X 22"
PV6



	ROOF DESCRIPTION			MODULE DIMENSIONS	Doile and Calines - DCD DOA (DLACK)	Do of Attack we are the CC Colores of
ROOF	PITCH	AZIMUTH	NO. OF MODULES	→ 40.5 in →	Rails and Splices : PSR-B84 (BLACK)	Roof Attachment : S5 SolarFoot
А	22°	258°	45	73.4 in.	Rafter Spacing : 24 in	There is an exposed fastened 9" AG panel metal roof
					Attachment Span: 4ft	The roof is located in 110mph wind zone





5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:


Bill of Material

JOB NUMBER:

23-625-GR

Date:	Revision:			
12/11/2023	А			
Sheet Size:	Sheet Number:			
Sheet Size: ANSI C 17" X 22"	Sheet Number: PV7			

Note: Roof will be grounded by connecting it to any of array's ground using a grounding lug.



RAILS AND MOUNTING SYSTEM

- 52 x PSR-B84: Pegasus Rail, Black, 84" (7 Feet)
- 32 x PSR-SPL: Pegasus Bonded, Structural Splice
- 70 x PSR-MCB: Pegasus Multiclamp, Mid/End, 30 to 40 mm, Black
- 52 x PSR-HEC: Pegasus Hidden End Clamp
- 45 x PSR-MLP: Pegasus MLPE Mount
- 15 x PSR-LUG: Pegasus Grounding Lug
- 70 x PSR-WMC: Pegasus Wire Management Clip
- 08 x PSR-CBG: Pegasus Cable Grip
- 52 x PSR-CAP: Pegasus End Cap
- 108 x LFT-03-M1 Slotted L-Foot, Mill
- 108 x PSR-DTN: Pegasus, Dovetail 3/8" T-Bolt
- 108 x S-5-Solarfoot
- 432 x 1/4-14 Type 17 AB Milled Point, 2-1/2"Length
- (Metal to Wood Screw) 250/bag
- 90 x Heyco Wire Clips

SOLAR MODULES

• 45 x SILFAB ELITE SIL-410 BG

INVERTER & SUPPORTING ITEMS

- 45 x Enphase IQ8PLUS-72-2-US micro inverter
- 01 x X-IQ-AM1-240-4: IQ Combiner 4

ENPHASE CABLES AND ACCESSORIES

- 45 x Q-12-10-240: Q Cable
- 07 x Q-12-20-200: Q Cable
- 01 x Q-12-RAW-300:Q Cable, 12 AWG (100ft)
- 22 x Q-CONN-10M Male Field-wireable connector
- 22 x Q-CONN-10F Female Field-wireable connector
- 04 x Q-TERM-10: Terminator Cap
- 06 x Q-SEAL-10: Female Sealing Cap
- 01 x Q-CLIP-100: Q Cable rail mount cable management clip (Pack of 100)
- 01 x Q-DISC-10: Disconnect tool

ELECTRICAL ITEMS

- 04 x Eaton BR220B with hold down kit support (Circuit breaker, 2 pole,
- 02 x IPCS 4002: Line/Load Side Hot Taps (#4/0 main #2-10 tap) Medium types
- 01 x D223NRB: 250volt/100amp/2pole fusible disconnect (NEMA 3R)
- 02 x SQUARE D FRNR80: 250volt/80amp fuses

N **BILL OF MATERIAL** SCALE: 1/8" - 1'



PV Installation Professional

Ali Buttar

6in setback from sides of the roof

PV LABELS

Code

03-302

02-316

03-390

03-306

8M-001

8M-002

03-355

05-108

05-211

05-372

05-215

07-359

07-111

Sr No

01

02

03

04

05

06

07

80

09

10

11

12

13

Qty

01

01

01

01

01

01

01

01


02


01


03

01

02







PV System Dead Load (Panel + Racking weight) / PV System Area (45 panels x 48.7 lbs./panel + 334 ft. of racking x 1.17 lb.ft) / (45 panels x 6.11' x 3.37') = 2.63 psf



5112 Departure Drive, Raleigh NC 27616 O: 919.948.6474 E: info@8msolar.com

Customer Information:

Gerald B Rhodes

2923 Highway 87 N Sanford NC 27332

Customer Signature:

Sheet Name:

Attachment Details

JOB NUMBER:

CERTIFIED

PV Installation Professional


Ali Buttar PVIP #031310-32

Revision:
А
Sheet Number:

SILFAB ELITE

SIL - 410 BG





NOT JUST ANOTHER SOLAR PANEL.

Silfab Elite

Back-contact technology with an innovative conductive backsheet and integrated cell design delivers the highest performance, durability and beautiful aesthetics.

Manufactured exclusively in the United States.

SILFABSOLAR.COM
















ELECTRICAL SPECIFICATIONS		410			
Test Conditions		STC	NOCT		
Module Power (Pmax)	Wp	410	305		
Maximum power voltage (Vpmax)	V	38.07	35.35		
Maximum power current (Ipmax)	Α	10.77	8.64		
Open circuit voltage (Voc)	V	45.92	42.14		
Short circuit current (Isc)	Α	11.30	9.16		
Module efficiency	%	21.4%	19.9%		
Maximum system voltage (VDC)	V	1000			
Series fuse rating	А	20			
Power Tolerance	Wp	0 to +10			

 $Measurement\ conditions:\ STC\ 1000\ W/m2\bullet AM\ 1.5\bullet\ Temperature\ 25\ ^{\circ}C\bullet NOCT\ 800\ W/m^2\bullet AM\ 1.5\bullet\ Measurement\ uncertainty\ \le\ 3\%$ $Sun simulator calibration reference modules from Fraunhofer Institute. Electrical characteristics may vary by \pm 5\% and power by 0 to +10W. \\$

MECHANICAL PROPERTIES / CO	MPONENTS	METRIC		IMI	PERIAL		
Module weight				8+0.4 lbs			
Dimensions (H x L x D)				8±0.4 lbs 4 in x 40.5 in x 1.4 in			
, ,		1864 mm x 1029 mm x 35 mm					2 for and 1 and
Maximum surface load (wind/snow)*		5400 Pa rear load / 5400 Pa fro	ont load		.8 lb/ft² rear load	/ 112.8 ιb/π	² front load
Hail impact resistance		ø 25 mm at 83 km/h			in at 51.6 mph		
Cells		66 high-efficiency mono-PER 166 x 166 mm	C MWT c-Si cells		nigh-efficiency mo 3x6.53 in	ono-PERC M	WT c-Si cells
Glass		3.2 mm high transmittance, to DSM anti-reflective coating	empered,		16 in high transmi I anti-reflective co		pered,
Cables and connectors (refer to instal	lation manual)	1200 mm ø 5.7 mm, MC4 from	Staubli	47.2	in, ø 0.22 (12AW	G), MC4 fror	n Staubli
Backsheet		Multilayer, integrated insulation film and electrically conductive backsheet, superior hydrolysis and UV resistance, fluorine-free PV backsheet					
Frame		Anodized Aluminum (Black)					
Bypass diodes		3 diodes-30SQ045T (45V max DC blocking voltage, 30A max forward rectified current)					
Junction Box		UL 3730 Certified, IEC 62790 Certified, IP67 rated					
TEMPERATURE RATINGS			WARRANTIES				
Temperature Coefficient Isc	+0.046 %/°C		Module product workmansh	ship warranty 25 years**		**	
Temperature Coefficient Voc	-0.279 %/°C		Linear power performance guarantee 30 years				
Temperature Coefficient Pmax	-0.377 %/°C						end 1st yr
NOCT (± 2°C)	43.5 °C						end 12th yr end 25th yr
Operating temperature	-40/+85 °C						end 30th yr
CERTIFICATIONS					SHIPPING	SPECS	
CSA C22 2#61730-1·2		.1, UL 61215-2:2017 Ed.1, UL 61730-1:2017 Ed.1, UL 61730-2:2017 Ed.1, 2019 Ed.2, CSA C22.2#61730-2:2019 Ed.2, IEC 61215-1:2016 Ed.1, IEC		Modules Per Pallet: 27		27 or 27 (California)	
Product 61215-2:2016 Ed.1, I		IEC 61730-1:2016 Ed.2, IEC 61730-2	EIC 61730-1:2016 Ed.2, IEC 61730-2:2016 Ed.2, IEC 61701:2020 (Salt Mist L6:2013 (Ammonia Corrosion), CEC Listing***, UL Fire Rating: Type 1		Pallets Per Truck		31 or 30 (California)
Factory	ISO9001:2015				Modules Per T	ruck	837 or 810 (California)

- ▲ Warning. Read the Safety and Installation Manual for mounting specifications and before handling, installing and operating modules.
- ** 12 year extendable to 25 years subject to registration and conditions outlined under "Warranty" at silfabsolar.com
- Certification in progress.

PAN files generated from 3rd party performance data are available for download at: silfabsolar.com/downloads



SILFAB SOLAR INC.

800 Cornwall Ave Bellingham WA 98225 USA T +1 360.569.4733 info@silfabsolar.com

SILFABSOLAR.COM

1770 Port Drive Burlington WA 98233 USA

T +1 360.569.4733

240 Courtneypark Drive East Mississauga ON L5T 2Y3 Canada

T +1 905.255.2501

F +1 905.696.0267

Silfab - SIL-410-BG-20221017
No reproduction of any kind is allowed without permission. Data and information is subject to modifications without notice. © Silfab Solar Inc., 2022. Silfab Solar si a registered trademark of Silfab Solar inc.







IQ8 Series Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-n-play MC4 connectors.



IQ8 Series Microinverters are UL Listed as PV Rapid Shut Down Equipment and conform with various regulations, when installed according to manufacturer's instructions.

Easy to install

- Lightweight and compact with plug-n-play connectors
- Power Line Communication (PLC) between components
- Faster installation with simple two-wire cabling

High productivity and reliability

- Produce power even when the grid is down*
- More than one million cumulative hours of testing
- Class II double-insulated enclosure
- Optimized for the latest highpowered PV modules

Microgrid-forming

- Complies with the latest advanced grid support**
- Remote automatic updates for the latest grid requirements
- Configurable to support a wide range of grid profiles
- Meets CA Rule 21 (UL 1741-SA) requirements

- * Only when installed with IQ System Controller 2, meets UL 1741. IQ8H-208V operates only in grid-tied mode.
- ** IQ8 Series Microinverters supports split phase, 240V. IQ8H-208 supports split phase, 208V only.

^{© 2022} Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ8 Microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8 Series Microinverters

INPUT DATA (DC)		IQ8-60-2-US	IQ8PLUS-72-2-US	IQ8M-72-2-US	108A-72-2-US	IQ8H-240-72-2-US	IQ8H-208-72-2-U	
Commonly used module pairings ²	W	235 - 350	235 - 440	260 - 460	295 - 500	320 - 540+	295 - 500+	
Module compatibility		60-cell/120 half-cell	60-cell/120 half-cell 60-cell/120 half-cell, 66-cell/132 half-cell and 72-cell/144 half-cell					
MPPT voltage range	٧	27 - 37	29 - 45	33 – 45	36 - 45	38 – 45	38 - 45	
Operating range	٧	25 - 48			25 - 58			
Min/max start voltage	٧	30 / 48	30 / 48 30 / 58					
Max input DC voltage	٧	50	50 60					
Max DC current ³ [module lsc]	Α			15	5			
Overvoltage class DC port				I	I			
DC port backfeed current	mA			C)			
PV array configuration		1x1 Ungrounded	array; No additional D	C side protection requ	ired; AC side protecti	on requires max 20A p	er branch circuit	
OUTPUT DATA (AC)		IQ8-60-2-US	IQ8PLUS-72-2-US	IQ8M-72-2-US	IQ8A-72-2-US	IQ8H-240-72-2-US	IQ8H-208-72-2-U	
Peak output power	VA	245	300	330	366	384	366	
Max continuous output power	VA	240	290	325	349	380	360	
Nominal (L-L) voltage/range⁴	٧			240 / 211 - 264			208 / 183 - 250	
Max continuous output current	Α	1.0	1.21	1.35	1.45	1.58	1.73	
Nominal frequency	Hz			6	0			
Extended frequency range	Hz			50 -	- 68			
AC short circuit fault current over 3 cycles	Arms	S		2			4.4	
Max units per 20 A (L-L) branch circuit ⁵		16	13	11	11	10	9	
Total harmonic distortion				<5	5%			
Overvoltage class AC port				II	II			
AC port backfeed current	mA			3	0			
Power factor setting				1.	0			
Grid-tied power factor (adjustable)				0.85 leading -	- 0.85 lagging			
Peak efficiency	%	97.5	97.6	97.6	97.6	97.6	97.4	
CEC weighted efficiency	%	97	97	97	97.5	97	97	
Night-time power consumption	mW			6	0			
MECHANICAL DATA								
Ambient temperature range				-40°C to +60°C	(-40°F to +140°F)			
Relative humidity range				4% to 100% ((condensing)			
DC Connector type				М	C4			
Dimensions (HxWxD)			:	212 mm (8.3") x 175 mm	ı (6.9") x 30.2 mm (1.2	")		
Weight			1.08 kg (2.38 lbs)					
Cooling		Natural convection - no fans						
Approved for wet locations		Yes						
Pollution degree		PD3						
Enclosure			Class II do	uble-insulated, corrosi	on resistant polymeri	ic enclosure		
Environ. category / UV exposure rating				NEMA Type	6 / outdoor			
COMPLIANCE								
		CA Rule 21 (UL 1741-	SA), UL 62109-1, UL17	41/IEEE1547, FCC Part	15 Class B, ICES-000	3 Class B, CAN/CSA-0	C22.2 NO. 107.1-01	
Certifications		•	018 Rule 64-218 Rapid			2014, NEC 2017, and NE anductors, when install		

(1) The IQ8H-208 variant will be operating in grid-tied mode only at 208V AC. (2) No enforced DC/AC ratio. See the compatibility calculator at https://link.enphase.com/module-compatibility (3) Maximum continuous input DC current is 10.6A (4) Nominal voltage range can be extended beyond nominal if required by the utility. (5) Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

Enphase IQ Combiner 4/4C

X-IQ-AM1-240-4 X-IQ-AM1-240-4C



The Enphase IQ Combiner 4/4C with Enphase IQ Gateway and integrated LTE-M1 cell modem (included only with IQ Combiner 4C) consolidates interconnection equipment into a single enclosure and streamlines IQ microinverters and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- · Includes IQ Gateway for communication and control
- Includes Enphase Mobile Connect cellular modem (CELLMODEM-M1-06-SP-05), included only with IQ Combiner 4C
- Includes solar shield to match Enphase IQ Battery aesthetics and deflect heat
- · Flexible networking supports Wi-Fi, Ethernet, or cellular
- · Optional AC receptacle available for PLC bridge
- Provides production metering and consumption monitoring

Simple

- · Centered mounting brackets support single stud mounting
- · Supports bottom, back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- · 80A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- · Two years labor reimbursement program coverage included for both the IQ Combiner SKU's
- UL listed





Enphase IQ Combiner 4/4C

MODEL NUMBER	
IQ Combiner 4 (X-IQ-AM1-240-4)	IQ Combiner 4 with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and consumption monitoring (+/- 2.5%). Includes a silver solar shield to match the IQ Battery system and IQ System Controller 2 and to deflect heat.
IQ Combiner 4C (X-IQ-AM1-240-4C)	IQ Combiner 4C with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and consumption monitoring (+/- 2.5%). Includes Enphase Mobile Connect cellular modem (CELLMODEM-M1-06-SP-05), a plug-and-play industrial-grade cell modem for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area.) Includes a silver solar shield to match the IQ Battery and IQ System Controller and to deflect heat.
ACCESSORIES AND REPLACEMENT PARTS	(not included, order separately)
Ensemble Communications Kit COMMS-CELLMODEM-M1-06 CELLMODEM-M1-06-SP-05 CELLMODEM-M1-06-AT-05	- Includes COMMS-KIT-01 and CELLMODEM-M1-06-SP-05 with 5-year Sprint data plan for Ensemble sites - 4G based LTE-M1 cellular modem with 5-year Sprint data plan - 4G based LTE-M1 cellular modem with 5-year AT&T data plan
Circuit Breakers BRK-10A-2-240V BRK-15A-2-240V BRK-20A-2P-240V BRK-15A-2P-240V-B BRK-20A-2P-240V-B	Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers. Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220 Circuit breaker, 2 pole, 15A, Eaton BR215B with hold down kit support Circuit breaker, 2 pole, 20A, Eaton BR220B with hold down kit support
EPLC-01	Power line carrier (communication bridge pair), quantity - one pair
XA-SOLARSHIELD-ES	Replacement solar shield for IQ Combiner 4/4C
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPLC-01)
XA-ENV-PCBA-3	Replacement IQ Gateway printed circuit board (PCB) for Combiner 4/4C
X-IQ-NA-HD-125A	Hold down kit for Eaton circuit breaker with screws.
ELECTRICAL SPECIFICATIONS	
Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating	65 A
Max. continuous current rating (input from PV/storage)	64 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. total branch circuit breaker rating (input)	80A of distributed generation / 95A with IQ Gateway breaker included
Envoy breaker	10A or 15A rating GE/Siemens/Eaton included
Production metering CT	200 A solid core pre-installed and wired to IQ Gateway
Consumption monitoring CT (CT-200-SPLIT)	A pair of 200 A split core current transformers
MECHANICAL DATA	
Dimensions (WxHxD)	37.5 x 49.5 x 16.8 cm (14.75" x 19.5" x 6.63"). Height is 21.06" (53.5 cm) with mounting brackets.
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	 20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors 60 A breaker branch input: 4 to 1/0 AWG copper conductors Main lug combined output: 10 to 2/0 AWG copper conductors Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing.
Altitude	To 2000 meters (6,560 feet)
INTERNET CONNECTION OPTIONS	
Integrated Wi-Fi	802.11b/g/n
Cellular	CELLMODEM-M1-06-SP-05, CELLMODEM-M1-06-AT-05 (4G based LTE-M1 cellular modem). Note that an Enphase Mobile Connect cellular modem is required for all Ensemble installations.
Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included)
COMPLIANCE	
Compliance, IQ Combiner	UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Part 15, Class B, ICES 003 Production metering: ANSI C12.20 accuracy class 0.5 (PV production) Consumption metering: accuracy class 2.5
Compliance, IQ Gateway	UL 60601-1/CANCSA 22.2 No. 61010-1




Rapid shutdown is built-in

The 2014 edition of the National Electrical Code (NEC 2014) added new rapid shutdown requirements for PV systems installed on buildings. Enphase Microinverters fully meet rapid shutdown requirements in the new code without the need to install any additional electrical equipment.

What's new in NEC 2014?


NEC 2014, Section 690.12 applies to PV conductors over 10 feet from the PV array and requires that the conductors power down to 30 volts and 240 volt-amperes within 10 seconds of rapid shutdown initiation.

String inverters require work arounds for rapid shutdown



Work around.

String inverter installed on roof, a hostile environment that string inverters are not built to live in.



Commercial String Inverter

Enphase comes standard with rapid shutdown capability

All Enphase microinverters, even those that were previously installed, inherently meet rapid shutdown requirements, no additional equipment or workarounds needed



Enphase microinverters can safely shut down automatically, leaving only low-voltage DC electricity isolated to the PV module




Commercial Microinverter





RAIL SYSTEM



Next-Level Solar Mounting

A complete system for hassle-free rooftop installation, from watertight mounts to lifetime wire management.



Simplicity

1/2"socket for everything. One clamp for mid or end. No tool splicing and bonding. Easy wire management.



Code Compliant

UL 2703 listed LTR-AE-001-2012 listed Class A fire rating for any slope ASCE 7-16 PE Certified



Premium Aesthetics

The narrowest panel gap available. Optional Hidden End Clamps and End Caps provide a flush look on the edge of the array.



Watertight for Life

Secured on industry-leading Pegasus Mounts, for composite shingle and tile roofs. Backed by a 25-year warranty.



RAIL SYSTEM









Dovetail T-bolt

Pegasus Rail

Available in 14' and 7' lengths for easy layout and shipping.

Open-channel design holds MC4 connectors, PV wire and trunk cables.

Black and Mill finish



Pegasus Max Rail

Maximum-strength design.

Meets specifications for high
snow-load and hurricane zones.

Black and Mill finish



Splice and Max Splice

Installs by hand.
Works over mounts.

Structurally connects and bonds rails automatically; UL2703 listed as reusable.

Dovetail shape for extra strength.
Uses ½" socket.





Multi-Clamp

Fits 30-40mm PV frames, as mid- or end-clamp.

Twist-locks into position; doesn't pinch wires in rail.

Bonds modules to rail; UL2703 listed as reusable



Offers premium edge appearance. Preinstalled pull-tab grips rail edge, allowing easy, one-hand installation. Tucks away for reuse.

Ground Lug

Holds 6 or 8 AWG wire.

Mounts on top or side of rail.

Assembled on MLPE Mount.

UL2703 listed as reusable.

N-S Bonding Jumper

Installs by hand, eliminates row-to-row copper wire.

UL2703 listed as reusable only with Pegasus Rail.









MLPE Mount

Secures and bonds most micro-inverters and optimizers to rail.

Connectors and wires easily route underneath after installation.

UL2703 listed as reusable.

Cable Grip

Secures four PV wires or two trunk cables. Stainless-steel backing provides durable grip.

Eliminates sagging wires.

Wire Clip

Hand operable.
Holds wires in channel.
Won't slip.

End Cap and Max End Cap

Fits flush to PV module and hides raw or angled cuts.

Hidden drain quickly clears water from rail.

Certifications:

- UL 2703, Edition 1
- LTR-AE-001-2012
- ASCE 7-16 PE certified
- Class A fire rating for any slope roof



Quickly calculate the most efficient layout, spans and materials needed to suit your job. Visit the Pegasus Customer Portal. pegasussolar.com/portal

Patents pending. All rights reserved. ©2021 Pegasus Solar Inc.

LO	AD		SPA	AN	
SNOW (PSF)	WIND (MPH)	32"	4′	6′	8′
	120				
0	160				
	190				
	140				
15	160				
	190				
30	160				
30	190				
45	190				
70	190				
110	190			PEGASUS RAIL	PEGASUS MAX RAIL

For reference only. Spans above are calculated using ASCE 7-16 for a Gable Roof, Exposure Category B, 7-20deg roof angle, 30ft mean roof height with non-exposed modules. For PE certified span tables, visit www.pegasussolar.com/spans.



COMP MOUNT



Simple 3-Piece Design Watertight For Life



Pegasus solar's comp mounts are a cost effective, high-quality option for rail installations on composition shingle roofs. Designed to last decades, the one-piece flashing with elevated cone means there is simply nothing to fail.



25-Year Warranty

Manufactured with advanced materials and coatings to outlast the roof itself



Code Compliant

Fully IBC/CBC Code Compliant Exceeds ASCE 7-16 Standards



Superior Waterproofing

Tested to AC286 without sealant Water seal elevated 0.9" above



All-In-One Kit Packaging

Flashings, L-Feet and SS lags with bonded EPDM washers are included in each 24-pack



COMP MOUNT

1 Drill pilot hole in the center of the rafter.




2Optional: Apply a
"u-shape" of sealant to
the underside of the
flashing and position
under 2nd shingle
course, cone over
pilot hole.



3Place L-Foot over cone and install lag with washer through L-Foot.





4Drive lag to required depth. Attach rail per rail manufacturer's instructions.



1.5" 3.5"









SPECIFICATIONS	COMP MOUNT INSTALL KITS							
SKU	PSCR-CBB0	PSCR-UBB0	SPCR-CBBH	PSCR-CMM0	PSCR-UMM0			
Finish	Blac	k L-Foot And Black Flash	ing	M	lill			
L-Foot Type	Closed Slot	Open Slot	Closed Slot	Closed Slot	Open Slot			
Kit Contents	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer and M10 Hex Bolt	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer			
Roof Type			Composition Shingle					
Certifications		I	BC, ASCE/SEI 7-16, AC28	36				
Install Application	Railed Systems							
Compatible Rail	Most							
Kit Quantity		24						
Boxes per Pallet		72						

Protected under US Patent: 10,998,847. Additional patents pending. All rights reserved. ©2021 Pegasus





Introducing the new SolarFoot[™] for exposed fastener metal roofing with the strength, testing, quality, and time-proven integrity you expect from S-5!. The SolarFoot provides an ideal mounting platform to attach the L-Foot (not included) of a rail-mounted PV system to the roof. This solution is The Right Way to secure rail-mounted solar systems to exposed fastener metal such as AG-Panel or R-Panel.

SolarFoot Features:

Manufactured in the U.S.A. from certified raw material

Fabricated in our own ISO 9001:2015 certified factory

All aluminum and stainless components

25yr limited warranty

Compatible with all commercial L-Foot products on the market


Factory applied 40-year isobutylene/ isoprene crosslink polymer sealant for reliable weathertightness

Sealant reservoir to prevent overcompression of sealant

Load-to-failure tested Normal to Seam by a nationally accredited laboratory on numerous metal roof materials and substrates

Four points of attachment into structure or deck with tested holding strength for engineered applications

Integrated M8-1.25x17mm stud and M8-1.25 stainless steel hex flange nut included






888-825-3432 | www.S-5.com






SolarFoot[™] Mounting for Exposed Fastener Roofing

The SolarFoot is a simple, cost-effective pedestal for L-Foot (not included) attachment of rail-mounted solar PV. The unique design is compatible with all rail producer L-Foot components. The new SolarFoot assembly ensures a durable weathertight solution for the life of the roof. Special factory applied butyl co-polymeric sealant contained in a reservoir is The Right Way, allowing a water-tested seal. Stainless integrated stud and hex flange lock-nut secure the L-Foot into position. A low center of gravity reduces the moment arm commonly associated with L-Foot attachments. Direct attachment of the SolarFoot to the structural member or deck provides unparalleled holding strength.





*Fasteners sold separately. Fastener type varies with substrate. Contact S-5! on how to purchase fasteners and obtain our test results. L-Foot also sold separately.

Fastener Selection





To source fasteners for your projects, contact S-5!
When other brands claim to be "just as good as S-5!", tell them to PROVE IT.

S-5!® Warning! Please use this product responsibly!

 $The independent \ lab \ test \ data \ found \ at \ www. S-5. com \ can \ be \ used \ for \ load-critical \ designs \ and \ applications.$

Products are protected by multiple U.S. and foreign patents. For published data regarding holding strength, fastener torque, patents, and trademarks, visit the S-5! website at www.S-5.com. Copyright 2017, Metal Roof Innovations, Ltd. S-5! products are patent protected.

Copyright 2017, Metal Roof Innovations, Ltd. Version 102017

SolarFoot Advantages:

Exposed fastener mounting platform for solar arrays attached via L-Foot and Rails

Weatherproof attachment to exposed fastener roofing

Butyl sealant reservoir provides long-term waterproof seal

M8-1.25x17mm stud with M8 hex flange nut for attachment of all popular L-Foot/rail combinations

Tool: 13 mm Hex Socket or ½" Hex Socket

Tool Required: Electric screw gun with hex drive socket for self-tapping screws.

Low Center of Gravity reduces moment arm commonly associated with L-Foot/Rail solar mounting scenarios

Attaches directly to structure or deck for optimal holding strength

S-5! Recommended substratespecific (e.g. steel purlin, wood 2x4, OSB, etc.) fasteners provide excellent waterproofing and pullout strength

Fastener through-hole locations comply with NDS (National Design Specification)for Wood Construction

Distributed by:





UL50 Type 3R Enclosure • Stamped 18 gauge gal. steel • Powder coated finish • Weather tight

Enclosure Includes:

- Dual ground lug
- · Universal DIN rail
- 1/2". 3/4" & 1" knockouts
- · Wire strain relief clip
- Complete hardware package



INTRODUCED AT SOLAR POWER 2007





PV Roof-Mount Combiner/Enclosure

Benefits

- •The ability to prep the building is now possible
- Replaces several parts used today
- Provides professional looking install
- · Saves time on install
- Allows for easy access
- Guaranteed seal to roof
- Low profile design

For product information contact us at [866] 367-7782

www.commdeck.com



RSTC Enterprises, Inc 2219 Heimstead Road Eau Claire, WI 54703 1 (866) 367 - 7782





SolaDeck Part # 780

Specifications:

18 Gauge Steel Base (1) and Cover (2)
Pre Punched 7 holes in base (1) for roof deck
Pre Punched 4 holes in base (1) and cover (2) for match
Draw Process both parts
Powder Coated to withstand 1000 hours Salt Spray (Primer Gray)
High UV resistance
15" x 15" flashing dimension
Cavity dimension 8"W x 9" L x 2.5"D
Approx. 162 Cubic inch equipment cavity
Norloked steel base plate (3) to drawn base (2)
Three knockout locations .5", .75" and 1"
3" DIN rail installed
Grounding Lug- Installed (In Equipment Cavity)
Wire Strain Relief Clip –Installed (In Equipment Cavity)
Hardware pack withstands 500 hours Salt Spray

- 7 2" Trusshead Screws
- 4 .5" 8-32 thread cutting screws
- 4 #10 Bonded Seal washers
- 1 Foam closed Cell Seal

ETL Listed UL50 Type 3R

Total Weight 6.9 pounds each

Packaging:

Individually bagged and boxed
Box dimension 15.5"w x 16" L x 3" D
White Carton labeled with Cut out template
Print One Color - Black

Master Cartons of 6 Units each
Master Carton dimension 18.75"x16"x16.375"
Master Carton Weight – 42 pounds
18 Master Cartons per skid Approx 800 pounds with skid





Safety switch, general duty, fusible, 100A, 3 wire, 2 poles, 1 neutral, 30hp, 240VAC, Type 3R, bolt on hub provision

D223NRB

Product availability: Stock - Normally stocked in distribution

facility

Price*: 480.00 USD

Main

Product	Single Throw Safety Switch
Duty Rating	General duty
Device Application	Residential
Disconnect Type	Fusible disconnect switch
Factory Installed Neutral	Neutral (factory installed)
Phase	3 phase
Number of Poles	2
Current Rating	100 A
Voltage Rating	240 V AC
Enclosure Rating NEMA	NEMA 3R
Maximum Horse Power Rating	7.5 hp 240 V at AC 60 Hz for 1 phase conforming to NEC 240.6 15 hp 240 V at AC 60 Hz for 3 phase conforming to NEC 240.6 15 hp 240 V at AC 60 Hz for 1 phase conforming to NEC 430.52 30 hp 240 V at AC 60 Hz for 3 phase conforming to NEC 430.52

Complementary


o o in promontary	
Short Circuit Current Rating	100 kA maximum depending on fuse H, K or R
Fuse type	H, K or R
Mounting Type	Surface
Electrical Connection	Lugs
Wiring configuration	3-wire
Wire Size	AWG 14AWG 1 copper AWG 12AWG 1 aluminium
Tightening torque	35 lbf.in (3.95 N.m) 0.000.01 in² (2.085.26 mm²) (AWG 14AWG 10) 40 lbf.in (4.52 N.m) 0.01 in² (8.37 mm²) (AWG 8) 35 lbf.in (3.95 N.m) (AWG 14AWG 10) 45 lbf.in (5.08 N.m) 0.020.03 in² (12.321.12 mm²) (AWG 6AWG 4) 50 lbf.in (5.65 N.m) (AWG 3AWG 1)
Depth	6.5 in (165.10 mm)
Width	10.56 in (268.22 mm)
Height	17.5 in (444.50 mm)

^{*} Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

	45 40 -(10) (7.1)
Net Weight	15.43 lb(US) (7 kg)
Environment	
Certifications	UL listed file E2875
Ordering and shipping details	
Category	00106-D & DU SW,NEMA3R, 30-200A
Discount Schedule	DE1A
GTIN	785901460701
Nbr. of units in pkg.	1
Package weight(Lbs)	15.60 lb(US) (7.076 kg)
Returnability	Yes
Country of origin	US
Packing Units	
Unit Type of Package 1	PCE
Package 1 Height	7.30 in (18.542 cm)
Package 1 width	10.80 in (27.432 cm)
Package 1 Length	20.00 in (50.8 cm)
Unit Type of Package 2	PAL
Number of Units in Package 2	40
Package 2 Weight	650.00 lb(US) (294.835 kg)
Package 2 Height	41.00 in (104.14 cm)
Package 2 width	41.00 in (104.14 cm)
Package 2 Length	48.00 in (121.92 cm)
Offer Sustainability	
Sustainable offer status	Green Premium product
California proposition 65	WARNING: This product can expose you to chemicals including: Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov
REACh Regulation	REACh Declaration
REACh free of SVHC	Yes
EU RoHS Directive	Compliant EU RoHS Declaration
Mercury free	Yes
RoHS exemption information	Yes
China RoHS Regulation	China RoHS declaration Product out of China RoHS scope. Substance declaration for your information.
Environmental Disclosure	Product Environmental Profile
PVC free	Yes
Contractual warrants	
Contractual warranty Warranty	18 months
Warranty	io monulo

Technical Illustration

Dimensions



WHEN MOUNTING, ALLOW 4.00/[102] MIN. CLEARANCE BETWEEN ENCLOSURES FOR OPENING OF SIDE HINGED DOOR.

TOP OF NEM A TYPE 3R DEVICES H AVE PROVISIONS FOR MAX 2.50/[64] BO LT-ON HUB.


DU323RB REQUIRES FIELD INS TALLATION OF EQUIPMEN T GROUNDING KIT GTK0610 WHEN USED AS SERVICE EQUIPMEN T.

ALL DIMENSIONS ARE APPROXIMATE. REFER TO TECHNICAL DRAWINGS AND DOCUMENTATION FOR COMPLETE DE TAILS.

TI DIM CD10021

Technical Illustration

Wiring Diagram



223NRB CD223NRB