



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/14/2025

SUBJECT: **ERES2401-0010**
ELECTRICAL RESIDENTIAL

To: Cockrell's Electrical Services

Here are the results of all Inspections located at **57 AMBER HORTON LN:**

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 4/12/2024
Completed Date/Time: 4/12/2024
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes: Changed from meterbase on pole to meter on house. And new 200amp service pole in rear yard with just a 20amp gfci outlet.