



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

3/19/2024

**SUBJECT: ERES2401-0014**  
**ELECTRICAL RESIDENTIAL**

To: BYLD LLC

Here are the results of all Inspections located at **66 WILLIAMS CREEK DR:**

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 2/23/2024  
Completed Date/Time: 2/23/2024  
Inspector: John B Kokoszka  
Result: DISAPPROVED  
Remarks:  
Notes: Need to have the picture for inside the panel. Plans call for a 40 amp fuses at the disconnect

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 3/15/2024  
Completed Date/Time: 3/15/2024  
Inspector: James T Hall  
Result: APPROVED  
Remarks:  
Notes: