

76 North Meadowbrook Drive Alpine, UT 84004 office (201) 874-3483 swyssling@wysslingconsulting.com

January 2, 2024

BYLD Better 1213 W Moorehead Street Suite 500 Charlotte, NC 28208

> Re: Engineering Services Caldwell Residence 46 Appomattox Drive Cameron, NC 5.925 kW System

To Whom It May Concern:

We have received information regarding solar panel installation on the roof of the above referenced structure. Our evaluation of the structure is to verify the existing capacity of the roof system and its ability to support the additional loads imposed by the proposed solar system.

A. Site Assessment Information

- 1. Site visit documentation identifying attic information including size and spacing of framing for the existing roof structure.
- Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information will be utilized for approval and construction of the proposed system.

B. Description of Structure:

Roof Framing: Prefabricated wood trusses at 24" on center. All truss members are

constructed of 2x4 dimensional lumber.

Roof Material: Composite Asphalt Shingles

Roof Slope: 22 degrees
Attic Access: Accessible
Foundation: Permanent

C. Loading Criteria Used

Dead Load

- Existing Roofing and framing = 7 psf
- New Solar Panels and Racking = 3 psf
- TOTAL = 10 PSF
- Live Load = 20 psf (reducible) 0 psf at locations of solar panels
- Ground Snow Load = 15 psf
- Wind Load based on ASCE 7-10
 - Ultimate Wind Speed = 119 mph (based on Risk Category II)
 - Exposure Category C

Analysis performed of the existing roof structure utilizing the above loading criteria is in accordance with the 2018 North Carolina Residential Code, including provisions allowing existing structures to not require strengthening if the new loads do not exceed existing design loads by 105% for gravity elements and 110% for seismic elements. This analysis indicates that the existing framing will support the additional panel loading without damage, if installed correctly.

D. Solar Panel Anchorage

- 1. The solar panels shall be mounted in accordance with the most recent Ironridge installation manual. If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
- 2. The maximum allowable withdrawal force for a 5/16" lag screw is 229 lbs per inch of penetration as identified in the National Design Standards (NDS) of timber construction specifications. Based on a minimum penetration depth of 2½", the allowable capacity per connection is greater than the design withdrawal force (demand). Considering the variable factors for the existing roof framing and installation tolerances, the connection using one 5/16" diameter lag screw with a minimum of 2½" embedment will be adequate and will include a sufficient factor of safety.
- 3. Considering the wind speed, roof slopes, size and spacing of framing members, and condition of the roof, the panel supports shall be placed no greater than 48" on center.

Based on the above evaluation, this office certifies that with the racking and mounting specified, the existing roof system will adequately support the additional loading imposed by the solar system. This evaluation is in conformance with the *2018* North Carolina Residential Code, current industry standards, and is based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Scott E. Wyssling, PE North Carolina Licen (27). 46546


North Carolina COA P-2308

Signed 1/02/2024



NEW PV ROOFTOP SYSTEM DESIGN

15 MODULES - 5.925 KW DC & 7.600 KW AC SYSTEM SIZE LOLEATHA CALDWELL RESIDENCE - 46 APPOMATTOX DRIVE, CAMERON, NORTH CAROLINA 28326



SHEET INDEX

SPECS 1-5

PV-1 COVER SHEET
PV-2 SITE PLAN
PV-3 MOUNTING PLAN
S-1 STRUCTURAL DETAILS
E-1 ELECTRICAL DIAGRAM
E-2 EQUIPMENT INFORMATION
E-3 PV LABELS
PV-4 SITE PHOTOS

MANUFACTURER'S SPECS

SCOPE OF WORK

INSTALL 5.925 KW DC ROOF MOUNTED
PV SYSTEM UTILIZING
(15) TRINASOLAR TSM-395DE09.05
(1) TESLA INVERTER 7.6KW
(5) TESLA OPTIMIZERS
IRONRIDGE XR10 RACKING WITH
IRONRIDGE - FLASHVUE MOUNTS
EXISTING 200 A BUSBAR WITH 200 A MAIN BREAKER

TRENCHING: NO
INTERCONNECTION METHOD: LOAD SIDE BREAKER
60A UTILITY AC DISCONNECT
ROOF TYPE: COMP SHINGLE

CONTRACTOR

BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500 CHARLOTTE, NC 28208

CODE REFERENCE

IJ: HARNETT

2018 NORTH CAROLINA ELECTRIC CODE 2018 NORTH CAROLINA BUILDING CODE 2018 NORTH CAROLINA RESIDENTIAL CODE

DESIGN CRITERIA

ASCE 7-10 WIND SPEED: 119 MPH EXPOSURE CATEGORY C GROUND SNOW LOAD: 15 PSF

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

ENGINEERED PLANS COMPLETED BY ENGINEERS IN THE USA



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER
1213 W MOOREHEAD STREET SUITE
500
CHARLOTTE. NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

	REVISIONS						
ı	NO	DATE:	COMMENTS				
	1						
	2						

COVER SHEET



Signed 1/02/2024


SCOTT E. WYSSLING, P.E. NORTH CAROLINA LICENSE NO. 46546

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV

PV-1

GENERAL NOTES

- I. CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND REVIEW ALL MANUFACTURER INSTALLATION DOCUMENTS PRIOR TO INITIATING CONSTRUCTION.
- 2. ALL COMPONENTS SHALL BE NEW AND LISTED BY A RECOGNIZED ELECTRICAL TESTING LABORATORY AND LISTED FOR THEIR SPECIFIC APPLICATION.
- 3. OUTDOOR EQUIPMENT SHALL BE NEMA 3R RATED OR BETTER.
- 4. ACCESS TO ELECTRICAL COMPONENTS OVER 150 VOLTS TO GROUND SHALL BE RESTRICTED TO QUALIFIED PERSONNEL
- 5. CONTRACTOR SHALL OBTAIN ELECTRICAL PERMITS PRIOR TO INSTALLATION AND SHALL COORDINATE ALL INSPECTIONS, TESTING COMMISSIONING, AND ACCEPTANCE WITH THE CLIENT, UTILITY CO. AND CITY INSPECTORS AS NEEDED.
- 6. EACH MODULE TO BE GROUNDED USING THE SUPPLIED CONNECTION POINT PER THE MANUFACTURER'S REQUIREMENTS. ALL PV MODULES, EQUIPMENT, AND METALLIC COMPONENTS ARE TO BE BONDED. IF THE EXISTING GROUNDING ELECTRODE SYSTEM CANNOT BE VERIFIED OR IS ONLY METALLIC WATER PIPING, IT IS THE CONTRACTOR'S RESPONSIBILITY TO INSTALL A SUPPLEMENTAL GROUNDING ELECTRODE.
- 7. DC CONDUCTORS SHALL BE RUN IN EMT AND/OR MC (METAL CLAD CABLE) AND SHALL BE LABELED. ALL DC CONDUCTORS RUN INSIDE OF THE STRUCTURE SHALL BE INSTALLED A MINIMUM OF 18" BELOW THE ROOF DECK.
- 8. EXPOSED NON-CURRENT CARRYING METAL PARTS OF ELECTRICAL EQUIPMENT SHALL BE GROUNDED IN ACCORDANCE WITH APPLICABLE NEC.
- CONFIRM LINE SIDE VOLTAGE AT THE ELECTRIC UTILITY SERVICE PRIOR TO CONNECTING INVERTER. VERIFY SERVICE VOLTAGE IS WITHIN INVERTER VOLTAGE OPERATIONAL RANGE.
- 10. ELECTRICAL CONTRACTOR TO PROVIDE CONDUIT EXPANSION JOINTS AND ANCHOR CONDUIT RUNS AS REQUIRED PER CODE.
- 11. ALL WIRING MUST BE PROPERLY SUPPORTED BY DEVICES OR MECHANICAL MEANS DESIGNED AND LISTED FOR SUCH USE, AND FOR ROOF-MOUNTED SYSTEMS, WIRING MUST BE PERMANENTLY AND COMPLETELY HELD OFF OF THE ROOF SURFACE.
- 12. ALL ROOF PENETRATIONS MUST BE SEALED OR FLASHED.
- 13. EQUIPMENT MAY BE SUBSTITUTED FOR SIMILAR EQUIPMENT BASED ON AVAILABILITY. SUBSTITUTED EQUIPMENT SHALL COMPLY WITH DESIGN CRITERIA.
- 14. REMOVAL OF AN INTERACTIVE INVERTER OR OTHER EQUIPMENT SHALL NOT DISCONNECT THE BONDING CONNECTION BETWEEN THE GROUNDING ELECTRODE CONDUCTOR AND THE PHOTOVOLTAIC SOURCE AND/OR OUTPUT CIRCUIT GROUNDED CONDUCTORS.
- 15. WHENEVER A DISCREPANCY IN THE QUALITY OF EQUIPMENT ARISES ON THE DRAWING OR SPECIFICATIONS, THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING AND INSTALLING ALL MATERIAL AND SERVICES REQUIRED BY THE STRICTEST CONDITIONS NOTED ON THE DRAWINGS OR IN THE SPECIFICATIONS TO ENSURE COMPLETE COMPLIANCE AND LONGEVITY OF THE OPERABLE SYSTEM REQUIRED BY THE ENGINEERS.



BE WITHIN 10' OF THE UTILITY METER

MANUFACTURER/ MODEL **TESLA INVERTER 7.6KW** 32 A AC OUTPUT VOLTAGE 240 V MAX DC INPUT VOLTAGE 600 V MAX INPUT CURRENT 11 A WEIGHTED CEC EFFICIENCY 98.00% 7600 W

76 N. MEADOWBROOK DRIVE

ALPINE, UTAH 84004 swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT

DESIGN ENGINEER



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS						
NO	DATE:	COMMENTS				
1						
2						

SITE PLAN



Signed 1/02/2024

SCOTT E. WYSSLING, P.E. NORTH CAROLINA LICENSE NO.


46546

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV

SCALE: 3/32" = 1'-0"

PV-2

ENGINEERED PLANS COMPLETED BY ENGINEERS IN THE USA



MOUNTING PLAN NOTES:

- VERIFY ALL OBSTRUCTIONS AND DIMENSIONS IN THE FIELD.
- PROVIDE RAIL SPLICES AS REQUIRED BY MANUFACTURER'S GUIDELINES.
- NO SIGNIFICANT SHADING WILL RESULT FROM EXISTING ROOF OBSTRUCTIONS.
- PV MODULES CANNOT BE INSTALLED OVER OR BLOCK ATTIC, PLUMBING, FURNACE OR WATER HEATER VENTS

MOUNT QUANTITY:

1. (32) IRONRIDGE - FLASHVUE ATTACHMENTS DISTRIBUTED LOAD - (ARRAY) WEIGHT/AREA = 2.24 lbs/ft² TOTAL WEIGHT OF SYSTEM - 694.5 lbs

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES

APPOMATTOX DRIVE

CHIMNEY (TYP.) -

0

	TILT	AZIMUTH	# OF MODULES	ROOF FRAMING	FRAMING SPACING	ROOF TYPE	MAX MOUNT SPACING	MOUNT TYPE
ROOF SECTION 1	22°	207°	15	2X4 - TRUSSES	24"	COMP SHINGLE	48"	IRONRIDGE - FLASHVUE

RAIL (TYP.)MOUNT (TYP.)

2X4 ROOF TRUSSES (TYP.)

(N) PV MODULE EQUIPPED W/ 1 TESLA

(RSD) PER 3 MODULE

ROOF SECTION 1

TILT: 22° AZIMUTH: 207°

ROOF FRAMING 24" ON CENTER

48" MAX MOUNT SPACING

FRONT OF HOME



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT

ROOF OBSTRUCTION (TYP.)



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA **46 APPOMATTOX DRIVE** CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS						
NO	DATE:	COMMENTS				
1						
2						

MOUNTING PLAN



Signed 1/02/2024


SCOTT E. WYSSLING, P.E. NORTH CAROLINA LICENSE NO. 46546

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV

PV-3

SCALE: 3/32" = 1'-0" ENGINEERED PLANS COMPLETED BY ENGINEERS IN THE USA

(E) CONCRETE DRIVEWAY



ROOF MOUNT

NTS

(1) \$\frac{5}{16}\$ \times 4\frac{1}{4}\$" LAG SCREW PROVIDED BY MANUFACTURER CONNECTED INTO ROOF FRAMING

FLASHING PROVIDED BY MANUFACTURER

ROOF FRAMING

ROOF FRAMING

ROOF FRAMING

SEE TABLE ON SHEET PV-3

2.5" MIN EMBEDMENT

MOUNT INSTALLATION NOTES

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED

- 1. CONTRACTOR IS TO FOLLOW THE PLAN FOR INSTALLING ROOF MOUNTS.
- IF THE CONTRACTOR IDENTIFIES THE ROOF FRAMING IS DIFFERENT FROM WHAT IS IDENTIFIED ON THIS PLAN, CONTRACTOR SHALL NOTIFY THE ENGINEER BEFORE PROCEEDING WITH INSTALLATION.
- 3. CONTRACTOR IS TO LOCATE THE ROOF FRAMING BY UTILIZING A HAMMER.
- 4. WHEN THE ROOF FRAMING IS LOCATED, CONTRACTOR IS TO DRILL A PILOT HOLE TO CONFIRM CENTER OF ROOF FRAMING. IF THE ROOF FRAMING IS MISSED, AND A NEW PILOT HOLE IS TO BE DRILLED, CONTRACTOR TO UTILIZE SILICON/CAULK TO SEAL THE ORIGINAL PILOT HOLE.
- 5. DIRECT TO DECK MOUNTS ARE ONLY TO BE USED WITH APPROVED DESIGN BY THE ENGINEER. DIRECT TO DECK MOUNT INSTALLATION IS NOT A SUBSTITUTION FOR LAG SCREWS INTO ROOF FRAMING.
- 6. CONTRACTOR TO FOLLOW MANUFACTURERS SPECIFICATIONS FOR INSTALLATION AND REQUIRED SCREWS.

DESIGN ENGINEER



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER
1213 W MOOREHEAD STREET SUITE
500
CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326

5.925 KW DC 7.600 KW AC

REVISIONS

NO DATE: COMMENTS

1

STRUCTURAL DETAILS



Signed 1/02/2024

SCOTT E. WYSSLING, P.E.
NORTH CAROLINA LICENSE NO.

RTH CAROLINA LICENSE NO 46546

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV

S-1

ROOF MOUNT CROSS SECTION DETAIL
NTS

NTS

ENGINEERED PLANS COMPLETED BY ENGINEERS IN THE USA

NTS

CONDUCTOR SCHEDULE								
		CONDUC	TORS			GROUND		
TAG ID	WIRES IN CONDUIT	WIRE AWG	TYPE, MATERIAL	AMPACITY	SIZE	TYPE, MATERIAL		
1	3	#10 AWG	PV CABLE	30	#6 AWG	BARE, CU		
2	3	#10 AWG	THWN-2, CU	30	#10 AWG	THHW, CU	3/4" CONDUIT	
3	4	#8 AWG	THWN-2, CU	50	#10 AWG	THHW, CU	3/4" CONDUIT	
4	4	#8 AWG	THWN-2, CU	50	#10 AWG	THHW, CU	3/4" CONDUIT	

EQUIPMENT LIST:

(15) TRINASOLAR TSM-395DE09.05


(1) TESLA INVERTER 7.6KW

(5) TESLA OPTIMIZERS

TRENCHING: NO INTERCONNECTION METHOD: LOAD SIDE BREAKER

60A UTILITY AC DISCONNECT

IRONRIDGE XR10 RACKING WITH IRONRIDGE - FLASHVUE MOUNTS



DESIGN ENGINEER WYSSLING CONSULTING COMMODATE FAMORENCE WITH SAME BUJONESS WALKE

76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT

(E) UTILITY METER

BYLD BETTER
1213 W MOOREHEAD STREET SUITE
500
CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS

NO DATE: COMMENTS

1

ELECTRICAL DIAGRAM

GENERAL NOTES

 AC DISCONNECT SHALL BE VISIBLE-OPEN TYPE, LOCKABLE AND READILY ACCESSIBLE. TO BE WITHIN 10' OF THE UTILITY METER
 DATE:
 1/2/2024

 DRAWN BY:
 JDM

 REVIEWED BY:
 HEV

(E) 200A MAIN SERVICE PANEL (E) 200A / 2P MAIN BREAKER

SYSTEM SIZE

AC SYSTEM SIZE: 7.600 kW DC SYSTEM SIZE: 5.925 kW

INTERCONNECTION CALCULATIONS

ITEM	UNIT	PANEL
BUS RATING	AMPS	200A
MAIN OCPD	AMPS	200A
ALLOWED PV PER NEC	AMPS	40A

CONDUCTOR CALCULATIONS

TAG 1 (SEE E-1)	TAG 2 (SEE E-1)	TAG 3 (SEE E-1)	TAG 4 (SEE E-1)
UNDER MODULES, NOT IN CONDUIT	#10 AWG MAX CURRENT = 30A	#8 AWG MAX CURRENT = 50A	#8 AWG MAX CURRENT = 50A
#10 AWG MAX CURRENT = 30A			
		TESLA INVERTER 7.6KW MAX OUTPUT = 32 A	TESLA INVERTER 7.6KW MAX OUTPUT = 32 A
TESLA INVERTER 7.6KW MAX CIRCUIT CURRENT	TESLA INVERTER 7.6KW MAX CIRCUIT CURRENT	32 A * 1.25 A = 40	32 A * 1.25 A = 40
15 A FOR CIRCUIT 2	15 A FOR CIRCUIT 2	RECOMMENDED OCPD = 40	RECOMMENDED OCPD = 40

EQUIPMENT INFORMATION

MODULE	
MANUFACTURER/ MODEL	TRINASOLAR TSM-395DE09.05
PMAX	395 W
voc	41 V
VMP	34 V
IMP	11.62 A
ISC	12.21 A
TEMPERATURE COOEFFICIENT OF PMAX	-0.34 %/°C
TEMPERATURE COEFFICIENT OF VOC	-0.25 %/°C

INVERTER	
MANUFACTURER/ MODEL	TESLA INVERTER 7.6KW
MAX AC OUTPUT	32 A
AC OUTPUT VOLTAGE	240 V
MAX DC INPUT VOLTAGE	600 V
MAX INPUT CURRENT	11 A
WEIGHTED CEC EFFICIENCY	98.00%
INVERTER WATTAGE	7600 W



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS		
NO	DATE:	COMMENTS
1		
2		

EQUIPMENT INFORMATION

 DATE:
 1/2/2024

 DRAWN BY:
 JDM

 REVIEWED BY:
 HEV

PHOTOVOLTAIC AC DISCONNECT

MAXIMUM AC OPERATING CURRENT: 32

NOMINAL OPERATING AC VOLTAGE: 240

AT POINT OF INTERCONNECTION, MARKED AT DISCONNECTING MEANS [NEC 690.54]

AWARNING DUAL POWER SOURCE SECOND SOURCE IS PHTOVOLTAIC SYSTEM

AT POINT OF INTERCONNECTION. [NEC 705.12(C), 690.59]

MAIN PHOTOVOLTAIC SYSTEM DISCONNECT

EACH PV SYSTEM DISCONNECTING MEANS SHALL PLAINLY INDICATE WHETHER IN THE OPEN (OFF) OR CLOSED (ON) POSITION AND BE PERMANENTLY MARKED [NEC. 690.13(B)]

PHOTOVOLTAIC

AT EACH DC DISCONNECTING MEANS [NEC 690.13(B)]

DC DISCONNECT

PHOTOVOLTAIC

AT EACH AC DISCONNECTING MEANS [NEC 690.13(B)]

AC DISCONNECT

WARNING: PHOTOVOLTAIC POWER SOURCE

AT EXPOSED RACEWAYS, CABLE TRAYS, AND OTHER WIRING METHODS; SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS [NEC 690.31(D)(2)]

ELECTRICAL SHOCK HAZARD

DO NO TOUCH TERMINALS
TERMINALS ON BOTH LINE AND LOAD SIDES
MAY BE ENERGIZED IN THE OPEN POSITION

AT BUILDING OR STRUCTURE MAIN DISCONNECTING MEANS. [NEC 690.12(E), NEC 690.13(B)]

AWARNING

THE EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES. SCLUDING MAIN SUPPLY OVERCURRENT DEVICE SHALL NOT EXCEED AMPACITY OF BUSBAR

AWARNING
INVERTER OUTPUT CONNECTION. DO NOT RELOCATE THIS OVERCURRENT DEVICE

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUTDOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY



RAPID SHUTDOWN
SWITCH FOR SOLAR PV

PERMANENT WARNING LABELS SHALL BE APPLIED TO DISTRIBUTION EQUIPMENT


A PERMANENT WARNING LABEL SHALL BE APPLIED TO THE DISTRIBUTION EQUIPMENT ADJACENT TO THE BACK-FED BREAKER FROM THE INVERTER. [NEC 705.12(B)(3)(2)]

FOR PV SYSTEMS THAT SHUT DOWN THE ARRAY AND CONDUCTORS LEAVING THE ARRAY: THE TITLE "SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN" SHALL UTILIZE CAPITALIZED CHARACTERS WITH A MINIMUM HEIGHT OF 3/8 IIN. IN BLACK ON YELLOW BACKGROUND, AND THE REMAINING CHARACTERS SHALL BE CAPITALIZED WITH A MINIMUM HEIGHT OF 3/16 IN. IN BLACK ON WHITE BACKGROUND. [NEC 690.56(C)(1)(A)]

A RAPID SHUTDOWN SWITCH SHALL
HAVE A LABEL LOCATED ON OR NO MORE
THAN 3 FT FROM THE SWITCH THAT
INCLUDES THIS WORDING. THE LABEL
SHALL BE REFLECTIVE, WITH ALL
LETTERS CAPITALIZED AND HAVING A
MINIMUM HEIGHT OF 3/8 IN., IN WHITE ON
RED BACKGROUND.[NEC 690.56(C)(2)]

CAUTION

MULTIPLE SOURCES OF POWER



46 APPROMATTOX DRIVE, CAMERON, NORTH CAROLINA 28326

LABEL LOCATION: MSP CODE REF: NEC 2018 - 705.10

DESIGN ENGINEER VISSLING CONSULTING COASULTING COASULTING COASULT EXPERIENCE WITH SAMEL RUPPING MALAY

76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS NO DATE: COMMENTS 1 2


PV LABELS

LABELING NOTES:

- LABELING REQUIREMENTS BASED ON THE 2020 NATIONAL ELECTRIC CODE, OSHA STANDARD 19010.145, ANSI Z535.
- 2. MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- 3. LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED [NEC 110.21]
- 4. LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8", WHITE ON RED BACKGROUND; REFLECTIVE, AND PERMANENTLY AFFIXED [IFC 605 11 1 1]

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV

STRUCTURAL





76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER

1213 W MOOREHEAD STREET SUITE

500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPOMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS		
NO	DATE:	COMMENTS
1		
2		

SITE PHOTOS

DATE:	1/2/2024
DRAWN BY:	JDM
REVIEWED BY:	HEV



PRODUCT: TSM-DE09.05

POWER RANGE: 380-395 W

395 W+ MAXIMUM POWER OUTPUT

0/+5 W

POSITIVE POWER TOLERANCE

MAXIMUM EFFICIENCY

Outstanding Visual Appearance

- Designed with aesthetics in mind
 - Ultra-thin, virtually invisible busbars
 - Excellent cell color control by machine selection



- Generates up to 395 W, 20.5 % module efficiency with high density interconnect technology
- Multi-busbar technology for better light trapping, lower series resistance, improved current collection and enhanced reliability
- Excellent low light performance (IAM) with cell process and module material optimization




Universal solution for residential and C&I rooftops

- Designed for compatibility with existing mainstream inverters, optimizers and mounting systems
- Perfect size and low weight for easy handling. Optimized transportation cost
- Reduces installation cost with higher power bin and efficiency
- Flexible installation solutions for system deployment



High Reliability

- 6,000 Pa snow load (test load)
- 4,000 Pa wind load (test load)



Comprehensive Product and System Certificates








LISTED LI ISO14001: Environmental management System
ISO45041 (Greenhouse Gases Emissions Verification
ISO45001: Occupational Health and Safety Management System



Vertex S



ELECTRICAL DATA (STC)	TSM-380 DE09.05	TSM-385 DE09.05	TSM-390 DE09.05	TSM-395 DE09.05
Peak Power Watts-PMAX (Wp)*	380	385	390	395
Power Tolerance-PMAX (W)	0/+5	0/+5	0/+5	0/+5
Maximum Power Voltage-VMPP (V)	33.4	33.6	33.8	34.0
Maximum Power Current-Impp (A)	11.38	11.46	11.54	11.62
Open Circuit Voltage-Voc (V)	40.4	40.6	40.8	41.0
Short Circuit Current-Isc (A)	12.00	12.07	12.14	12.21
Module Efficiency η m (%)	19.8	20.0	20.3	20.5
STC: Irradiance 1000 W/m², Cell Temperature 25°C, Air Mass AM1.5 *Measuring tolerance: ±3%				
ELECTRICAL DATA (NOCT)	TSM-380 DE09.05	TSM-385 DE09.05	TSM-390 DE09.05	TSM-395 DE09.05
Maximum Power-PMAX (Wp)	286	290	294	298

TSM-380 DE09.05	TSM-385 DE09.05	TSM-390 DE09.05	TSM-395 DE09.05
286	290	294	298
31.4	31.6	31.8	31.9
9.12	9.18	9.24	9.32
38.0	38.2	38.4	38.6
9.67	9.73	9.78	9.84
	286 31.4 9.12 38.0	286 290 31.4 31.6 9.12 9.18 38.0 38.2	DE09.05 DE09.05 DE09.05 286 290 294 31.4 31.6 31.8 9.12 9.18 9.24 38.0 38.2 38.4

Solar Cells	Monocrystalline	
No. of cells	120 cells	
Module Dimensions	1754×1096×30 mm	
Weight	21.0 kg	
Glass	3.2 mm, High Transmission, AR Coated Heat Strengthened Glass	
Encapsulant material	EVA/POE	
Backsheet	Black-White	
Frame	30 mm Anodized Aluminium Alloy	
J-Box	IP 68 rated	
	Photovoltaic Technology Cable 4.0 mm²	
Cables	Landscape: 1100/1100 mm	
	Portrait: 280/280 mm*	
Connector	TS4/MC4 EVO2*	

TEMPERATURE RATINGS MAXIMUM RATINGS Operational Temperature -40 to +85°C

NOCT (Nominal Operating Cell Temperature)	43°C(±2K)
Temperature Coefficient of PMAX	-0.34%/K
Temperature Coefficient of Voc	-0.25%/K
Temperature Coefficient of Isc	0.04%/K

ARRANTY
Year product workmanship warranty
Year power warranty
% First year degradation
55% Annual power degradation

PACKAGING CONFIGURATION

todules per box	36 pieces
fodules per 40' container	936 pieces

Maximum System Voltage 1500 V DC (IEC) Max Series Fuse Rating 20 A



CAUTION: READ SAFETY AND INSTALLATION INSTRUCTIONS BEFORE USING THE PRODUCT. © 2021 Trina Solar Limited, All rights reserved, Specifications included in this datasheet are Version number: TSM EN 2021 B

DESIGN ENGINEER

76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA **46 APPROMATTOX DRIVE** CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REV	ISIONS	
NO	DATE:	COMMENTS
1		
2		

MODULE SPEC SHEET

DATE: 12/29/2023 DRAWN BY: JDM REVIEWED BY:



SOLAR INVERTER

3.8 kW | 7.6 kW

Tesla Solar Inverter completes the Tesla home solar system, converting DC power from solar to AC power for home consumption. Tesla's renowned expertise in power electronics has been combined with robust safety features and a simple installation process to produce an $outstanding\ solar\ inverter\ that\ is\ compatible\ with\ both\ Solar\ Roof\ and\ traditional\ solar\ panels.\ Once\ installed,\ homeowners\ use\ the\ Tesla$ $mobile \ app \ to \ manage \ their \ solar \ system \ and \ monitor \ energy \ consumption, \ resulting \ in \ a \ truly \ unique \ ecosystem \ experience.$

- Built on Powerwall 2 technology for exceptional efficiency and reliability
- Wi-Fi, Ethernet, and cellular connectivity with easy over-the-air updates
- Designed to integrate with Tesla Powerwall and Tesla App
- 3.8 kW and 7.6 kW models available

SOLAR INVERTER

Tesla Solar Inverter provides DC to AC conversion and integrates with the Tesla ecosystem, including Solar Panels, Solar Roof, Powerwall, and vehicle charging, to provide a seamless sustainable energy experience.

KEY FEATURES

- No neutral wire simplifies installation
- Integrated rapid shutdown, arc fault, and ground fault protection 2x the standard number of MPPTs for high production on complex roofs



ELECTRICAL SPECIFICATIONS

OUTPUT (AC)	3.8 kW	7.6 kW
Nominal Power	3,800 W	7,600 W
Maximum Apparent Power	3,328 VA at 208 V	6,656 VA at 208 V
	3,840 VA at 240 V	7,680 VA at 240 V
Maximum Continuous Current	16 A	32 A
Breaker (Overcurrent Protection)	20 A	40 A
Nominal Power Factor	1 - 0.85 (leading / lagging)	
THD (at Nominal Power)	<5%	
INPUT (DC)		
MPPT	2	4
Input Connectors per MPPT	1-2	1-2-1-2
Maximum Input Voltage	600	VDC
DC Input Voltage Range	60 - 550 VDC	
DC MPPT Voltage Range ¹	60 - 480 VDC	
Maximum Current per MPPT (I _{mp})	11 A	
Maximum Short Circuit	15	. A
Current per MPPT (I _{sc})	10	


PERFORMANCE SPECIFICATIONS

Peak Efficiency ²	97.5%	98.0%
CEC Efficiency ²	97.5%	
Allowable DC/AC Ratio	1.4	
Customer Interface	Tesla Mobile App	
Internet Connectivity	Wi-Fi (2.4 GHz, 802.11 Ethernet, Cellular (LTE	
AC Remote Metering Support	Wi-Fi (2.4 GHz, 802.11 RS-485	b/g/n),
Protections	Integrated arc fault circ (AFCI), Rapid Shutdov	
Supported Grid Types	60 Hz, 240 V Split Phase 60 Hz, 208 V Wye	se
Required Number of Tesla Solar Shutdown Devices per Solar Module	See Solar Shutdown De Requirements per Moo	
Warranty	12.5 years	
184		

Expected efficiency pending final CEC listing.
Cellular connectivity subject to network operator service coverage and signal

MECHANICAL SPECIFICATIONS

Dimensions	660 mm x 411 mm x 158 mm (26 in x 16 in x 6 in)
Weight	52 lb ⁴
Mounting options	Wall mount (bracket)



ENVIRONMENTAL SPECIFICATIONS

Operating Temperature ⁵	-30°C to 45°C (-22°F to 113°F)
Operating Humidity (RH)	Up to 100%, condensing
Storage Temperature	-30°C to 70°C (-22°F to 158°F)
Maximum Elevation	3000 m (9843 ft)
Environment	Indoor and outdoor rated
Enclosure Rating	Type 3R
Ingress Rating	IP55 (Wiring compartment)
Pollution Rating	PD2 for power electronics and terminal wiring compartment, PD3 for all other components
Operating Noise @ 1 m	< 40 db(A) nominal, < 50 db(A) maximum
	rter, performance may be de-rated to 6.2 kW at when operating at temperatures greater than

COMPLIANCE INFORMATION

Grid Certifications	UL 1741, UL 1741 SA, IEEE 1547, IEEE 1547.1
Safety Certifications	UL 1699B, UL 1741, UL 1998 (US)
Emissions	EN 61000-6-3 (Residential), FCC 47CFR15.109 (a)

NA 2021-1-14 TESLA.COM/ENERGY



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPROMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

	REVI	SIONS	
ı	NO	DATE:	COMMENTS
ı	1		
	2		

INVERTER SPEC SHEET

DATE: 12/29/2023 DRAWN BY: JDM

SOLAR SHUTDOWN DEVICE

The Tesla Solar Shutdown Device is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with the Tesla Solar Inverter, the PVRSS is initiated by any loss of AC power.



ELECTRICAL SPECIFICATIONS

Nominal Input DC Current Rating (I _{MP})	12 A
Maximum Input Short Circuit Current (I _{sc})	15 A
Maximum System Voltage	600 V DC

RSD MODULE PERFORMANCE

5
Power Line Excitation
Normally open
7 W
25 years

COMPLIANCE INFORMATION

Certifications	UL 1741 PVRSS
	PVRSA (Photovoltaic Rapid
	Shutdown Array)

PVRSS


RSD Initiation Method	Loss of AC power
Compatible Equipment	Tesla Solar Inverter

ENVIRONMENTAL SPECIFICATIONS

Ambient Temperature	-40°C to 50°C (-40°F to 122°F)
Storage Temperature	-30°C to 70°C (-22°F to 158°F)
Enclosure Rating	NEMA 4 / IP65

MECHANICAL SPECIFICATIONS

Electrical Connections	MC4 Connector
Housing	Plastic
Dimensions	125 mm x 150 mm x 22 mm (5 in x 6 in x 1 in)
Weight	350 g (0.77 lb)
Mounting Options	ZEP Home Run Clip M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw



SOLAR SHUTDOWN DEVICE REQUIREMENTS PER MODULE

The following modules have been certified as part of a PV Rapid Shutdown Array (PVRSA) when installed together with the Tesla Solar Inverter and Tesla Solar Shutdown Devices. See the Tesla Solar Inverter Installation Manual for guidance on installing Tesla Solar Inverter and Solar Shutdown Devices with other modules.

Brand	Model	Required Solar Shutdown Devices
Tesla	Solar Roof V3	1 Solar Shutdown Device per 10 modules
Hanwha	anwha Q.PEAK DUO BLK-G5 1 Solar Shutdown Device per 3 modules	
Hanwha	Q.PEAK DUO BLK-G6+	1 Solar Shutdown Device per 3 modules

T = 5 L = NA 2021-1-14 TESLA.COM/ENERGY



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER
1213 W MOOREHEAD STREET SUITE
500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA 46 APPROMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS				
NO	DATE:	COMMENTS		
1				
2				

OPTIMIZER SPEC SHEET

 DATE:
 12/29/2023

 DRAWN BY:
 JDM

 REVIEWED BY:
 HEV



XR Rail® Family

Solar Is Not Always Sunny Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame. XR Rails® are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time. Force-Stabilizing Curve Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails® is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme

Compatible with Flat & Pitched Roofs



a range of tilt leg options for flat roof mounting

Corrosion-Resistant Materials

All XR Rails® are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing



Tech Brief

XR Rail® Family

The XR Rail® Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail® to match.



XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves spans up to 6 feet, while remaining light and economical.

- 6' spanning capability
 Moderate load capability
 Clear & black anodized finish
 Internal splices available



XR100 is a residential and commercial mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 10 feet.

10' spanning capability
 Heavy load capability
 Clear & black anodized finish
 Internal splices available



XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications.

Rail Selection

The table below was prepared in compliance with applicable engineering codes and standards.* Values are based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed certification letters.

Load		Rail Span					
Snow (PSF)	Wind (MPH)		5' 4"	6'	8'		12'
	90						
None	120						
None	140	XR10		XR100		XR1000	
	160						
	90						
20	120						
20	140						
	160						
30	90						
30	160						
40	90						
40	160						
80	160						
120	160						



76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500 CHARLOTTE, NC 28208

> CALDWELL, LOLEATHA 46 APPROMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVI	REVISIONS				
NO	DATE:	COMMENTS			
1					
2					

RAIL SPEC SHEET

DATE: 12/29/2023 DRAWN BY: JDM



Tech Brief



FlashVue®

Moving Flashing Forward

We set out to design a flashing that checked all the boxes: fully waterproof, fast and easy to install correctly, economical, and strong enough to handle every environmental condition. FlashVue® does it

The optimized flashing design features a large viewport, for easy alignment with the pilot hole. And the GripCap® and GripCap+® sit snugly in place, so the lag can be driven single-handedly.



placed in any orientation, and provide a "friction-fit" for easy installs. Push snug into the viewport, without worrying it will roll away or rotate while driving the lag



Triple Certified to Protect the Roof™ UL 2703, 441 (27) TAS 100(A)-95



Three-Tier Water Seal, Reimagined


FlashVue®'s seal architecture utilizes three layers of protection. The viewport is elevated 0.30", and provides a "friction-fit" for the GripCap®. The GripCap® fully covers the viewport while a sealing washer adds another layer of protection. And an EPDM washer and lag bolt "seal the deal" in the

Large Viewport in Flashing

Ø 0.75"

The large viewport makes it easy to align the flashing with the pilot hole, and drive the lag centered into the rafter. The elevated rim not only provides a sturdy dock for the GripCap® or GripCap+®,

See Your Pilot Holes



Solve Roof Undulations



Trusted Strength & Certification

- **Attachment Loading**
 - FlashVue® has been tested and rated to support 1161 (lbs) of uplift and 353 (lbs) of lateral load.
- - Designed and certified for compliance with the International Building Code & ASCE/SEI-7.
- **Water Seal Ratings**
 - Passed both the UL 441 Section 27 "Rain Test" and TAS 100-95 "Wind Driven Rain Test" by Intertek.
- UL 2703 Listed System
 - Conforms to UL 2703 mechanical and bonding requirements. See Flush Mount Manual for more info.





76 N. MEADOWBROOK DRIVE ALPINE, UTAH 84004

swyssling@wysslingconsulting.com (201) 874-3483

NORTH CAROLINA COA NO. P-2308

SOLAR COMPANY/CLIENT



BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500

CHARLOTTE, NC 28208

CALDWELL, LOLEATHA **46 APPROMATTOX DRIVE** CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

REVISIONS				
NO	DATE:	COMMENTS		
1				
2				

MOUNTING SPEC SHEET

DATE: 12/29/2023 DRAWN BY: JDM REVIEWED BY:





CALDWELL, LOLEATHA 46 APPROMATTOX DRIVE CAMERON, NC 28326 5.925 KW DC 7.600 KW AC

BYLD BETTER 1213 W MOOREHEAD STREET SUITE 500 CHARLOTTE, NC 28208

BILL OF MATERIALS

QTY:	EQUIPMENT:	PART NUMBER:
1	INVERTER	TESLA INVERTER 7.6KW
15	PANELS	TRINASOLAR TSM-395DE09.05 (395W) SOLAR MODULES
15	OPTIMIZER MOUNT	
0	RAILS	IRONRIDGE XR10
0	RAILS	IRONRIDGE XR10
4	SPLICE	
32	ATTACHMENT	IRONRIDGE - FLASHVUE
12	ENDCLAMP	
24	MIDCLAMP	
3	GROUND LUG	
1	JUNCTION BOX	
1	DISCONNECT A/C NON-FUSED	60A NON-FUSED DISCONNECT
0	DISCONNECT A/C FUSED	
0		
0		
0		
0	BREAKER-020 AMP 2-POLE CH	BR220 / CUTLER-HAMMER 2 POLE 20 AMP BREAKER
0	BREAKER-030 AMP 2-POLE CH	BR230 / CUTLER HAMMER 2 POLE 30 AMP BREAKER
0	BREAKER-040 AMP 2-POLE CH	BR240 / CUTLER HAMMER 2 POLE 40 AMP BREAKER
0	BREAKER-030 AMP 2-POLE EATON	EATON 2 POLE 30 AMP BREAKER
0	BREAKER-030 AMP 2-POLE GE	GE 2 POLE 30 AMP BREAKER
0	ENPHASE IQ COMBINER 4/4C	IQ COMBINER 4C SUPPORTS IQ8 PV GRID INDEPENDENT SYSTEMS FOR NA. INCLUDES CELLMODEM (CELLMODEM-M1-06)
0	ENPHASE IQ COMBINER 5/5C	IQ COMBINER 5C SUPPORTS IQ8 PV GRID INDEPENDENT SYSTEMS FOR NA. INCLUDES CELLMODEM (CELLMODEM-M1-06)
1	ENPHASE CELL MODEM	ENP CELLMODEM-M1 M ENPHASE MOBILE CONNECT LTE CAT M1 CELL MODEM, 5YR
0	ENPHASE CT'S	ENPHASE CT'S
18	ENPHASE Q CABLE PORTRAIT	ENP Q-12-10-240 IQ8 PLUS CABLE PORTRAIT
0	ENPHASE Q CABLE LANDSCAPE	ENP Q-12-10-240 IQ8 PLUS CABLE LANDSCAPE
0	STRAIN RELIEFS	M3234GBR-SM
0	PV METER OKLAHOMA	COPPER B LINE 011 WITH 125A SOCKET