



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

4/17/2024

SUBJECT: ERES2403-0035
ELECTRICAL RESIDENTIAL

To: ZAMORA KELLY MARIE

Here are the results of all Inspections located at **4247 SPRING HILL CHURCH RD:**

Inspection Type: FINAL**
Scheduled Date/Time: 3/25/2024
Completed Date/Time: 3/25/2024
Inspector: James T Hall
Result: CANCELLED
Remarks:
Notes: Contractor was not ready for inspection hasn't started work

Inspection Type: FINAL**
Scheduled Date/Time: 3/28/2024
Completed Date/Time: 3/28/2024
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: Need ring less meter base per Duke energy

Inspection Type: FINAL**
Scheduled Date/Time: 4/1/2024
Completed Date/Time: 4/1/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: