

**PHOTOVOLTAIC ROOF MOUNT SYSTEM**

**CODE AND STANDARDS**

THE INSTALLATION OF SOLAR ARRAYS AND PHOTOVOLTAIC POWER SYSTEMS SHALL COMPLY WITH THE FOLLOWING CODES:

- 2020 NATIONAL ELECTRICAL CODE
- 2018 NORTH CAROLINA RESIDENTIAL CODE
- 2018 NORTH CAROLINA BUILDING CODE
- ALL OTHER ORDINANCE ADOPTED BY THE LOCAL GOVERNING AGENCIES

**SITE NOTES / OSHA REGULATION**

1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
2. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.
3. ROOFTOP MOUNTED PHOTOVOLTAIC PANELS AND MODULES SHALL BE TESTED, LISTED AND IDENTIFIED BY RECOGNIZED ELECTRICAL TESTING LABORATORY.
4. MODULES AND SUPPORT STRUCTURES SHALL BE GROUNDED
5. SOLAR INVERTER SHALL BE LISTED TO UL1741
6. ALL CONDUCTORS SHALL BE COPPER AND SHOULD BE 75 AND 90 DEG RATED
7. REMOVAL OF AN INTERACTIVE INVERTER OR OTHER EQUIPMENT SHALL NOT DISCONNECT THE BONDING CONNECTION BETWEEN THE GROUNDING ELECTRODE CONDUCTOR, THE PHOTOVOLTAIC SOURCE AND OUTPUT CIRCUIT GROUNDED CONDUCTORS.
8. LIVE PARTS OF PV SOURCE CIRCUITS AND PV OUTPUT CIRCUITS OVER 150V TO GROUND SHALL NOT BE ACCESSIBLE TO OTHER THAN QUALIFIED PERSONS WHILE ENERGIZED.
9. ALL PV MODULES AND ASSOCIATED EQUIPMENT AND WIRING SHALL BE PROTECTED FROM PHYSICAL DAMAGE.
10. NFPA 855 ONLY PERMITS RESIDENTIAL ESS TO BE INSTALLED IN THE FOLLOWING AREAS: ATTACHED GARAGES, DETACHED GARAGES, ON EXTERIOR WALLS AT LEAST 3 FT AWAY FROM DOORS OR WINDOWS, OUTDOORS AT LEAST 3 FT AWAY FROM DOORS OR WINDOWS, UTILITY CLOSETS, STORAGE OR UTILITY SPACES.

**SOLAR CONTRACTOR**

1. MODULE CERTIFICATIONS INCLUDE UL1703, IEC61646, IEC61370.
2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER THE MANUFACTURERS INSTALLATION REQUIREMENTS.
3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ.
4. ALL MICROINVERTERS, PHOTOVOLTAIC MODULES, AC COMBINERS, DC-AC CONVERTERS AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER NEC690.4(B).
5. ALL SIGNAGE TO BE INSTALLED IN ACCORDANCE WITH LOCAL BUILDING CODE.
6. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.
7. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT AVAILABLE.

**DESIGN CRITERIA**

**WIND SPEED:** 110 MPH  
**GROUND SNOW LOAD:** 20 PSF  
**WIND EXPOSURE FACTOR:** B

**UTILITY COMPANY:**  
DUKE ENERGY

**PERMIT ISSUER (AHJ):**  
HARNETT COUNTY

**SCOPE OF WORK**

INSTALLATION OF UTILITY INTERACTIVE PHOTOVOLTAIC SOLAR SYSTEM.

**SR.#**

**PROJECT INFORMATION**

1	PV MODULES	32 x Q.TRON BLK M-G2+ 425W
2	INVERTER	01 x Tesla Powerwall3 01 x Tesla Inverter 7.6 kW
3	ROOF TYPE	ASPHALT SHINGLES
4	RACKING	PSR-B84 RAILS (BLACK) IRONRIDGE
5	MOUNTING TYPE	COMP MOUNT FLASHING (BLACK) GROUND SCREW
6	DC SIZE	13.6 KW
7	AC SIZE	19.1 KVA

**SR.#**

**PROJECT INFORMATION**

1	PV1	DRAWING INDEX
2	PV2	SITE LAYOUT
3	PV3	STRING MAPPING
4	PV4	ELECTRICAL ONE LINE DIAGRAM
5	PV5	DETAILED ELECTRICAL WIRING SCHEMATIC
6	PV6	PV LABELS
7	PV7	BILL OF MATERIALS
8	PV8	ATTACHMENT DETAILS
9	PV9	PLOT PLAN



5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com

**Customer Information:**

**Robert Pietrocola**  
165 Buie Farm Ln  
Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Drawing Index

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**


A

**Sheet Size:**

ANSI C  
17" X 22"

**Sheet Number:**

PV1





**VICINITY MAP**


**TOP VIEW OF THE BUILDING**




PV Installation Professional  
Ali Buttar  
PVIP #031310-32



ROOF DESCRIPTION			
	PITCH/TILT	AZIMUTH	NO. OF MODULES
Array A	30°	180°	18
Roof A	40°	174°	14
Vent		No vents will be covered by PV modules during the installation.	
<b>Trench 40ft.</b>			



PV System Dead Load (Panel + Racking weight) / PV System Area (No. of panels x Weight of panel(lbs.) + Length of racking(ft.) x 1.15 lb.ft) / (No. of panels x Height x Width) = Total psf			
ROOF	A		
DEAD LOAD (PSF)	2.66		



**SYSTEM DETAILS**  
 NUMBER OF PANELS : 32  
 PANELS MODEL : Q.TRON BLK M-G2+ 425W  
 DC SIZE : 13.6 KW  
 AC SIZE : 19.1 KVA



5112 Departure Drive,  
 Raleigh NC 27616  
 O: 919.948.6474  
 E: info@8msolar.com

**Customer Information:**

**Robert Pietrocola**  
 165 Buie Farm Ln  
 Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Site Layout

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**




A

**Sheet Size:**

ANSI C  
 17" X 22"

**Sheet Number:**


PV2




**SITE LAYOUT**  
 SCALE: 1/8" - 1'



ROOF DESCRIPTION			
	PITCH/TILT	AZIMUTH	NO. OF MODULES
Array A	30°	180°	18
Roof A	40°	174°	14



STRING LAYOUT					
TESLA POWERWALL 3			TESLA 7.6KW		
Strings #	No. of Modules	Color	Strings #	No. of Modules	Color
String 1	09	Blue	String 3	07	Green
String 2	09	Orange	String 4	07	Purple
		Brown			Light Blue



5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com

Tesla MCI (Mid Circuit Interrupter)	<input type="checkbox"/>
-------------------------------------	--------------------------

**SYSTEM DETAILS**  
 NUMBER OF PANELS : 32  
 PANELS MODEL : Q.TRON BLK M-G2+ 425W  
 DC SIZE : 13.6 KW  
 AC SIZE : 19.1 KVA

**Customer Information:**

**Robert Pietrocola**  
 165 Buie Farm Ln  
 Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

String Mapping

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**

A


**Sheet Size:**

ANSI C  
17" X 22"


**Sheet Number:**

PV3


**Array A**  
18 Modules



**Roof A**  
14 Modules



STRING MAPPING  
SCALE: 1/8" - 1'



**STRING CALCULATION**

String #	No of Modules	Estimated Power	Imax	Impp	Voc	Vmpp
1,2	09	3,825 W	20.24 Adc	12.98 Adc	351.27Vdc	550 Vdc
3,4	07	2,975 W	20.24 Adc	12.98 Adc	273.21Vdc	550 Vdc

**NEC Code (2020) and UL Standard References**

Rapid Shut Down	NEC 690.12 (A-D), UL1741	Grounding	NEC Article 250.30(A)
Disconnecting Means	NEC 690.13	Conduit Fill	NEC Table C.9, 310.15(B)(3)(a)
Feeder Sizing	NEC Table 310, 15(B)(16, 17)	Interconnection	NEC 705.12
Over current Protection	NEC 690.9		




5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com

**Note: Service Side Work: Power Drop Required**

32 X Q.TRON BLK M-G2+ 425W  
425W

TESLA MCI-2 (Mid Circuit Interrupter)  
RAPID SHUTDOWN EQUIPPED



- Voltage Drop Calculation:**
- Voltage Drop: 2.41V
  - Voltage Drop Percentage: 0.44%
  - Voltage at End: 547.59V
  - Trench Path: 40' approximately
  - Total wire length: 55' approx

- System Size: 13,600W DC
- Battery Total Energy: 13.5 KWh
- (32) Q.TRON BLK M-G2+ 425W
- (12) 1879359-00-X: Tesla MCI-2
- (01) Tesla Powerwall3 (1707000-00-J)
- Inverter Output: 48A max @ 240 VAC (each)
- (01) 1538000-45-y: Tesla Solar Inverter 7.6kW
- Inverter Output: 32A max @ 240 VAC
- 19.1 kVA AC output max

- Grounding will be done via Pegasus grounding lugs and mid-clamps to ensure the rail and panels are continuously grounded.
- Rapid Shutdown is included in the Mid Circuit Interrupter, refer to Mid Circuit Interrupter and Inverter attached datasheets.
- The load center / disconnect will be visible, lockable accessible to utility linesmen and will be properly labelled as per NEC requirements. It will be located on the exterior wall of the building, next to the utility meter.

Sr.No	#Wire	Conduit Size	Ground Wire	Amperage
1	2 x #10 PV		#10 Bare Cu	20.24
2	4 x #10 PV Wire	Direct Burial	#10 Bare Cu	20.24
3	4 x #10 THHN Cu	3/4" EMT	#10 Green Cu	20.24
4	2 x #10 MC Cable			20.24
5	3 x #6 THHN Cu	3/4" EMT	#8 Green Cu	60
6	3 x #8 THHN Cu	3/4" EMT	#10 Green Cu	40
7	3 x #3 THHN Cu	1.25" EMT	#6 Green Cu	100
8	3 x #3/0 THHN Cu	2" PVC		200
9	3 x #3/0 THHN Cu	2" PVC	#6 Green Cu	200
10	4-conductor shielded (1 twisted pair) 16 AWG	3/4" EMT		
11	2 x #12 THHN Cu	3/4" EMT		

**Customer Information:**

**Robert Pietrocola**  
165 Buie Farm Ln  
Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Electrical One Line Diagram

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**

A


**Sheet Size:**

ANSI C  
17" X 22"

**Sheet Number:**

PV4





5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com

**Customer Information:**

**Robert Pietrocola**  
165 Buie Farm Ln  
Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Detailed Electrical Diagram

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**

A


**Sheet Size:**

ANSI C  
17" X 22"

**Sheet Number:**

PV5





**8MSOLAR**  
ADVANCING ENERGY INDEPENDENCE

5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com

## LABELING AND WARNING SIGNS: NEC 2020

**A. PURPOSE**  
PROVIDE EMERGENCY RESPONDERS WITH APPROPRIATE WARNING AND GUIDANCE WITH RESPECT TO ISOLATING THE SOLAR ELECTRIC SYSTEM. THIS CAN FACILITATE IDENTIFYING ENERGIZED ELECTRICAL LINES THAT CONNECT THE SOLAR PANELS TO THE INVERTER, AS SHOULD NOT BE CUT WHEN VENTING FOR SMOKE REMOVAL.

**B. MAIN SERVICE DISCONNECT:**  
1. RESIDENTIAL BUILDINGS- THE MARKING MAY BE PLACED WITHIN THE MAIN SERVICE DISCONNECT. THE MARKING SHALL BE PLACED ON THE OUTSIDE COVER IF THE MAIN SERVICE DISCONNECT IS OPERABLE WITH THE SERVICE PANEL CLOSED.

2. COMMERCIAL BUILDINGS- THE MARKINGS SHALL BE PLACED ADJACENT TO THE MAIN SERVICE DISCONNECT CLEARLY VISIBLE FROM THE LOCATION WHERE THE LEVER IS OPERATED

3. MARKINGS, VERBIAGE, FORMAT AND TYPE OF MATERIAL
- a. VERBIAGE: CAUTION; SOLAR ELECTRIC SYSTEM CONNECTED
  - b. FORMAT:
    - (1) WHITE LETTERING ON A RED BACKGROUND
    - (2) MINIMUM 3/8 INCH LETTER HEIGHT
    - (3) ALL LETTERS SHALL BE CAPITALIZED
    - (4) ARIAL OR SIMILAR FONT, NON-BOLD

- c. MATERIAL:
  - (1) REFLECTIVE, WEATHER RESISTANT MATERIAL SUITABLE FOR THE ENVIRONMENT (USE UL-969) AS STANDARD FOR WEATHER RATING); DURABLE ADHESIVE MATERIALS MEET THIS REQUIREMENT.

**C. MARKING REQUIREMENTS ON DC CONDUIT, RACEWAYS, ENCLOSURES, CABLE ASSEMBLIES, DC COMBINERS AND JUNCTION BOXES;**

1. MARKING: PLACEMENT, VERBIAGE, FORMAT AND TYPE OF MATERIAL.

a. PLACEMENT: MARKINGS SHALL BE PLACED EVERY 10 (TEN) FEET ON ALL INTERIOR AND EXTERIOR DC CONDUITS, RACEWAYS, ENCLOSURES AND CABLE ASSEMBLIES, AT TURNS ABOVE AND/OR BELOW PENETRATIONS, ALL DC COMBINERS AND JUNCTION

- BOXES.
- b. VERBIAGE: CAUTION SOLAR CIRCUIT
- c. THE FORMAT AND TYPE OF MATERIAL SHALL ADHERE TO SECTION B-3.B & C ABOVE

**D. INVERTERS ARE NOT REQUIRED TO HAVE CAUTION MARKINGS**

#1 **WARNING: PHOTOVOLTAIC POWER SOURCE**

#2 **PHOTOVOLTAIC DC DISCONNECT**

#3 **PHOTOVOLTAIC AC DISCONNECT**

#4 **RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM**

#5 **MAXIMUM VOLTAGE 550Vdc**  
**MAX. RATED CIRCUIT CURRENT 12.98Adc**  
**OF THE CHARGE CONTROLLER OR DC-TO-DC CONVERTER (IF INSTALLED)**

#6 **PHOTOVOLTAIC POWER SOURCE**  
**OPERATING AC VOLTAGE 240 V**  
**MAXIMUM OPERATING AC OUTPUT CURRENT 48 A**

#7 **AC DISCONNECT PHOTOVOLTAIC SYSTEM POWER SOURCE**  
**RATED AC OUTPUT CURRENT 48 AMPS**  
**NOMINAL OPERATING AC VOLTAGE 240 VOLTS**

#8 **WARNING**  
**ELECTRIC SHOCK HAZARD**  
**TERMINAL ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION**

#9 **WARNING**  
**DUAL POWER SUPPLY**  
**SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM**

#10 **WARNING**  
**THREE POWER SOURCES**  
**SOURCES: UTILITY GRID, BATTERY AND PV SOLAR ELECTRIC SYSTEM**

#11 **WARNING**  
**TURN OFF PHOTOVOLTAIC AC DISCONNECT PRIOR TO WORKING INSIDE PANEL**

#12 **WARNING**  
**BIPOLAR PHOTOVOLTAIC ARRAY DISCONNECT OF NEUTRAL GROUNDED CONDUCTORS MAY RESULT IN OVERVOLTAGE ON ARRAY OR INVERTER**

#13 **WARNING**  
**POWER SOURCE OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE**

#14 **WARNING**  
**SOLAR ELECTRIC CIRCUIT BREAKER IS BACKFEED**

#15 **SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN**  
TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY

#16 **SOLAR AC DISCONNECT LOCATED AT SOUTH SIDE WALL OF THE HOUSE BESIDE THE UTILITY METER**

#17 **SERVICE DISCONNECT LOCATED IN THE BACKUP GATEWAY2 PANEL**

#18 **BATTERY**

#19 **MAIN BATTERY SYSTEM DISCONNECT**

#20 **BATTERY DISCONNECT LOCATED IN THE BACKUP GATEWAY 2 PANEL**

#21 **CAUTION**  
**POWER TO THIS BUILDING IS SUPPLIED FROM THE FOLLOWING SOURCES**  
UTILITY GRID  
ELECTRICAL GENERATOR  
PV SOLAR ELECTRICAL SYSTEM

#22 **GENERATOR WILL BE MANAGED BY ATS**

#23 **WARNING**  
**THIS EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR**

**Customer Information:**  
**Robert Pietrocola**  
165 Buie Farm Ln  
Lillington NC 27546

**Customer Signature:**

**Sheet Name:**  
PV Labels


**JOB NUMBER:**  
24-49-RP

**Date:** 03/13/2024  
**Revision:** A

**Sheet Size:** ANSI C 17" X 22"  
**Sheet Number:** PV6



ROOF DESCRIPTION			
	PITCH/TILT	AZIMUTH	NO. OF MODULES
Array A	30°	180°	18
Roof A	40°	174°	14



Rails and Splices : PSR-B84 (BLACK)  
 Rails (Ground mount) : XR100


Rafter Spacing : 16 in

Attachment Span: 4ft

Roof Attachment : Pegasus Comp Mount  
 Roof Attachment: Krinner Screws

There is one layer of shingles  
 Roofing material is asphalt shingles

The roof is located in 110mph wind zone



5112 Departure Drive,  
 Raleigh NC 27616  
 O: 919.948.6474  
 E: info@8msolar.com

Trench 40ft.

PV LABELS			
Sr No	Code	Qty	
01	02-314	12	
02	03-301	02	
03	03-302	01	
04	02-316	02	
05	03-308	02	
06	03-390	01	
07	03-306	01	
08	05-215	02	
09	05-211	03	
10	03-230	01	
11	05-372	01	
12	05-103	02	
13	05-216	01	
14	05-342	02	
15	07-111	01	
16	8M-001	03	
17	8M-002	03	
18	03-395	01	
19	04-304	01	
20	8M-004	03	
21	8M-005	01	
22	8M-003	02	
23	05-108	01	

**RAILS**

- 12 x XR-100-168A: XR100, Rail 168" Clear

**CLAMPS & GROUNDING**

- 24 x UFO-CL-01-B1: Universal Module Clamp, Black
- 24 x CAMO-01-M1: Hidden End Cam (universal clamp)
- 01 x XR-LUG-03-A1: Grounding Lug, Low Profile

**SUBSTRUCTURE**

- 16 x 70-0200-SGA: SGA Top Cap at 2"
- 24 x GM-BRC2-01-M1: Ground Mount Bonded Rail Connector - 2"
- 64 x GM-HSHW-01-M1: Hex Head Set Screw

**ACCESSORIES**

- 02 x XR-100-CAP: Kit, End Cap XR100 (10 sets per bag)

**GROUNDING SCREWS AND PIPES**

- 16 x KRINN 25529 : 2" GROUND SCREW 1600MM
- 19 x CONDR RACKGALV2-3/8X144: 2" IRON GM STR PIPE 12' (37) 2-3/8" OD 12GAUGE GALV PIPE 144" (2.0" IRIDG)
- 02 x CONDR RACKGALV2X96: 2" IRON GM COUPLER 8' (37) 2" OD 9GAUGE GALV PIPE 96" (COUPLING)

**RAILS AND MOUNTING SYSTEM**

- 16 x PSR-B84: Pegasus Rail, Black, 84" (7 Feet)
- 12 x PSR-SPL: Pegasus - Bonded, Structural Splice
- 24 x PSR-MCB: Pegasus - Multicomp, Mid/End, 30 to 40 mm, Black
- 08 x PSR-HEC: Pegasus - Hidden End Clamp
- 08 x PSR-LUG: Pegasus - Grounding Lug
- 21 x PSR-WMC: Pegasus - Wire Management Clip
- 03 x PSR-CBG: Pegasus - Cable Grip
- 08 x PSR-CAP: Pegasus - End Cap
- 28 x PSCR-UBBDT: Pegasus Comp Mount - Open Slot, Black L Foot, Black Flashing, Dovetail 3/8" T-Bolt
- 64 x Heyco Wire Clips

**SOLAR MODULES**

- 32 x Q.TRON BLK M-G2+ 425W

**INVERTER & SUPPORTING ITEMS**

- 01 x 1707000-00-J :Tesla Powerwall3
- 01 x 1538000-45-y: Tesla Solar Inverter 7.6kW
- 12 x 1879359-00-X: Tesla MCI-2
- 01 x 1232100-00-X: Backup GateWay 2
- 01 x 1529623-00-X: Internal Panelboard Kit
- 01 x 1549184-00-X: 02" Conduit Hub Kit

**Wire**

- 500 ft x #10 PV WIRE BLK (Cu)

**ELECTRICAL ITEMS**

- 01 x BW2200: Gateway Main Breaker-Eaton BW2200
- 01 x BR2100: Eaton BR 100/2
- 01 x HOM816L125PRB: Combiner Sub Panel (Sq D HOMELINE) 125A MLO/4-8 space minimum (NEMA 3R)
- 01 x HOM260: SQ D HOM 60/2
- 01 x HOM240: SQ D HOM 40/2
- 01 x EATON M22-PV-K01: EMG STOP W/ CONTACTOR
- 01 x Eaton M22-11-PG: Emergency Stop Enclosure
- 01 x DG223URB: 250volt/100amp/2pole non fusible disconnect (NEMA 3R)
- 01 x EZSLR JB-1.2: SolaDeck Boxes

**Customer Information:**

**Robert Pietrocola**  
 165 Buie Farm Ln  
 Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Bill of Material

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**

A


**Sheet Size:**

ANSI C  
 17" X 22"


**Sheet Number:**



PV7

6in setback from sides of the roof



**BILL OF MATERIAL**  
 SCALE: 1/8" - 1'





**Customer Information:**

**Robert Pietrocola**  
165 Buie Farm Ln  
Lillington NC 27546

**Customer Signature:**

**Sheet Name:**

Attachment Details

**JOB NUMBER:**

24-49-RP

**Date:**

03/13/2024

**Revision:**







A


**Sheet Size:**

ANSI C  
17" X 22"

**Sheet Number:**

PV8


					
Multi-Clamp	Hidden End Clamp	MLPE Mount	Dovetail T-Bolt	Ground Lug	Cable Grip
Torque Value 100 in-lbs.	Torque Value 135 in-lbs.	Torque Value 135 in-lbs.	Torque Value 300 in-lbs.	Torque Value 135 in-lbs.	Torque Value 135 in-lbs.




PV Dead Load	
<b>Roof A</b>	<p><b>PV System Dead Load</b> <b>(Panel + Racking weight) / PV System Area</b> (14 panels x 47.2 lbs./panel + 105 ft. of racking x 1.17 lb.ft) / (14 panels x 5.65' x 3.71') = 2.66 psf</p>




ROOF DESCRIPTION			
	PITCH	AZIMUTH	NO. OF MODULES
Array A	30°	180°	18
Roof A	40°	174°	14



Trench 40ft.



5112 Departure Drive,  
Raleigh NC 27616  
O: 919.948.6474  
E: info@8msolar.com



**SYSTEM DETAILS**

NUMBER OF PANELS : 32  
 PANELS MODEL : Q.TRON BLK M-G2+ 425W  
 DC SIZE : 13.6 KW  
 AC SIZE : 19.1 KVA

Solar Panel on Ground Array (A)	
Solar Panel on Roof Roof (A)	
Trench Path	
Electrical Lines	
Gas Line	
Septic Tank	

**Customer Information:**

**Robert Pietrocola**  
 165 Buie Farm Ln  
 Lillington NC 27546

**Customer Signature:**

**Sheet Name:**


Plot Plan

**JOB NUMBER:**

24-49-RP

<b>Date:</b>	<b>Revision:</b>
03/13/2024	A

<b>Sheet Size:</b>	<b>Sheet Number:</b>
ANSI C 17" X 22"	PV9



# Q.TRON BLK M-G2+ SERIES



405-430 Wp | 108 Cells  
22.0% Maximum Module Efficiency

MODEL Q.TRON BLK M-G2+



## High performance Qcells N-type solar cells

Q.ANTUM NEO Technology with optimized module layout boosts module efficiency up to 22.0%.



## A reliable investment

Inclusive 25-year product warranty and 25-year linear performance warranty<sup>1</sup>.



## Enduring high performance

Long-term yield security with Anti LeTID Technology, Anti PID Technology<sup>2</sup>, Hot-Spot Protect.



## Extreme weather rating

High-tech aluminium alloy frame, certified for high snow (8100 Pa) and wind loads (3600 Pa).



## Innovative all-weather technology

Optimal yields, whatever the weather with excellent low-light and temperature behaviour.



## The most thorough testing programme in the industry

Qcells is the first solar module manufacturer to pass the most comprehensive quality programme in the industry: The new "Quality Controlled PV" of the independent certification institute TÜV Rheinland.

<sup>1</sup> See data sheet on rear for further information.

<sup>2</sup> APT test conditions according to IEC/TS 62804-1:2015, method A (-1500 V, 96 h)

### The ideal solution for:




Rooftop arrays on residential buildings



# Q.TRON BLK M-G2+ SERIES

## Mechanical Specification

Format	67.8 in × 44.6 in × 1.18 in (including frame) (1722 mm × 1134 mm × 30 mm)
Weight	46.7 lbs (21.2 kg)
Front Cover	0.13 in (3.2 mm) thermally pre-stressed glass with anti-reflection technology
Back Cover	Composite film
Frame	Black anodised aluminium
Cell	6 × 18 monocrystalline Q.ANTUM NEO solar half cells
Junction box	2.09-3.98 in × 1.26-2.36 in × 0.59-0.71 in (53-101 mm × 32-60 mm × 15-18 mm), Protection class IP67, with bypass diodes
Cable	4 mm <sup>2</sup> Solar cable; (+) ≥ 68.9 in (1750mm), (-) ≥ 68.9 in (1750mm)
Connector	Stäubli MC4; IP68




## Electrical Characteristics

POWER CLASS		405	410	415	420	425	430	
MINIMUM PERFORMANCE AT STANDARD TEST CONDITIONS, STC <sup>1</sup> (POWER TOLERANCE +5 W/-0 W)								
Minimum	Power at MPP <sup>1</sup>	$P_{MPP}$ [W]	405	410	415	420	425	430
	Short Circuit Current <sup>1</sup>	$I_{SC}$ [A]	13.33	13.41	13.49	13.58	13.66	13.74
	Open Circuit Voltage <sup>1</sup>	$V_{OC}$ [V]	37.91	38.19	38.47	38.75	39.03	39.32
	Current at MPP	$I_{MPP}$ [A]	12.69	12.76	12.83	12.91	12.98	13.05
	Voltage at MPP	$V_{MPP}$ [V]	31.93	32.13	32.34	32.54	32.74	32.94
	Efficiency <sup>1</sup>	$\eta$ [%]	≥20.7	≥21.0	≥21.3	≥21.5	≥21.8	≥22.0
MINIMUM PERFORMANCE AT NORMAL OPERATING CONDITIONS, NMOT <sup>2</sup>								
Minimum	Power at MPP	$P_{MPP}$ [W]	306.1	309.9	313.7	317.5	321.2	325.0
	Short Circuit Current	$I_{SC}$ [A]	10.74	10.81	10.87	10.94	11.00	11.07
	Open Circuit Voltage	$V_{OC}$ [V]	35.96	36.23	36.50	36.77	37.04	37.31
	Current at MPP	$I_{MPP}$ [A]	9.98	10.04	10.10	10.15	10.21	10.27
	Voltage at MPP	$V_{MPP}$ [V]	30.66	30.87	31.07	31.26	31.46	31.65

<sup>1</sup>Measurement tolerances  $P_{MPP} \pm 3\%$ ;  $I_{SC}$ ;  $V_{OC} \pm 5\%$  at STC; 1000 W/m<sup>2</sup>, 25 ± 2 °C, AM 1.5 according to IEC 60904-3 • <sup>2</sup>800 W/m<sup>2</sup>, NMOT, spectrum AM 1.5

## Qcells PERFORMANCE WARRANTY




At least 98.5% of nominal power during first year. Thereafter max. 0.33% degradation per year. At least 95.53% of nominal power up to 10 years. At least 90.58% of nominal power up to 25 years.

All data within measurement tolerances. Full warranties in accordance with the warranty terms of the Qcells sales organisation of your respective country.

\*Standard terms of guarantee for the 5 PV companies with the highest production capacity in 2021 (February 2021)

## PERFORMANCE AT LOW IRRADIANCE



Typical module performance under low irradiance conditions in comparison to STC conditions (25 °C, 1000 W/m<sup>2</sup>).

## TEMPERATURE COEFFICIENTS

Temperature Coefficient of $I_{SC}$	$\alpha$ [%/K]	+0.04	Temperature Coefficient of $V_{OC}$	$\beta$ [%/K]	-0.24
Temperature Coefficient of $P_{MPP}$	$\gamma$ [%/K]	-0.30	Nominal Module Operating Temperature	NMOT [°F]	109 ± 5.4 (43 ± 3 °C)

## Properties for System Design

Maximum System Voltage	$V_{SYS}$ [V]	1000 (IEC)/1000 (UL)	PV module classification	Class II
Maximum Series Fuse Rating	[A DC]	25	Fire Rating based on ANSI/UL 61730	C / TYPE 2
Max. Design Load, Push/Pull <sup>3</sup>	[lbs/ft <sup>2</sup> ]	113 (5400 Pa)/50 (2400 Pa)	Permitted Module Temperature on Continuous Duty	-40 °F up to +185 °F (-40 °C up to +85 °C)
Max. Test Load, Push/Pull <sup>3</sup>	[lbs/ft <sup>2</sup> ]	169 (8100 Pa)/75 (3600 Pa)		

<sup>3</sup> See Installation Manual

## Qualifications and Certificates

UL61730-1 & UL61730-2, CE-compliant, Quality Controlled PV - TÜV Rheinland, IEC 61215:2016, IEC 61730:2016, U.S. Patent No. 9,893,215 (solar cells).



\*Contact your Qcells Sales Representative for details regarding the module's eligibility to be Buy American Act (BAA) compliant.

Qcells pursues minimizing paper output in consideration of the global environment.

Note: Installation instructions must be followed. Contact our technical service for further information on approved installation of this product.

Hanwha Q CELLS America Inc. 400 Spectrum Center Drive, Suite 1400, Irvine, CA 92618, USA | TEL +1 949 748 59 96 | EMAIL hqc-inquiry@qcells.com | WEB www.qcells.com

qcells

# Powerwall 3

## Power Everything

—  
Powerwall 3 is a fully integrated solar and battery system, designed to accelerate the transition to sustainable energy. Customers can receive whole home backup, cost savings, and energy independence by producing and consuming their own energy while participating in grid services. Once installed, customers can manage their system using the Tesla App to customize system behavior to meet their energy goals.

Powerwall 3 achieves this by supporting up to 20 kW DC of solar and providing 11.5 kW AC of continuous power per unit. It has the ability to start heavy loads up to 150 A LRA, meaning a single unit can support the power needs of most homes. Powerwall 3 is designed for mass production, fast and efficient installations, easy system expansion, and simple connection to any electrical service.



# Powerwall 3 Technical Specifications

## System Technical Specifications

Model Number	1707000-xx-y
Nominal Grid Voltage (Input & Output)	120/240 VAC
Grid Type	Split phase
Frequency	60 Hz
Overcurrent Protection Device	Configurable up to 60 A
Solar to Battery to Grid Round Trip Efficiency	89% <sup>1,2</sup>
Solar to Grid Efficiency	97% <sup>3</sup>
Supported Islanding Devices	Backup Gateway 2, Backup Switch
Connectivity	Wi-Fi (2.4 and 5 GHz), Dual-port switched Ethernet, Cellular (LTE/4G <sup>4</sup> )
Hardware Interface	Dry contact relay, Rapid Shutdown (RSD) certified switch and 2-pin connector, RS-485 for meters
AC Metering	Revenue Grade (+/- 0.5%)
Protections	Integrated arc fault circuit interrupter (AFCI), Isolation Monitor Interrupter (IMI), PV Rapid Shutdown (RSD) using Tesla Mid-Circuit Interrupters
Customer Interface	Tesla Mobile App
Warranty	10 years

## Solar Technical Specifications

Maximum Solar STC Input	20 kW
Withstand Voltage	600 V DC
PV DC Input Voltage Range	60 – 550 V DC
PV DC MPPT Voltage Range	150 – 480 V DC
MPPTs	6
Maximum Current per MPPT ( $I_{mp}$ )	13 A <sup>5</sup>
Maximum Short Circuit Current per MPPT ( $I_{sc}$ )	15 A <sup>5</sup>

## Battery Technical Specifications

Nominal Battery Energy	13.5 kWh AC <sup>2</sup>
Maximum Continuous Discharge Power	11.5 kW AC
Maximum Continuous Charge Power	5 kW AC
Output Power Factor Rating	0 - 1 (Grid Code configurable)
Maximum Continuous Current	48 A
Maximum Output Fault Current	10 kA
Load Start Capability (1 s)	150 A LRA
Power Scalability	Up to 4 Powerwall 3 units supported

<sup>1</sup> Typical solar shifting use case.

<sup>2</sup> Values provided for 25°C (77°F), at beginning of life. 3.3 kW charge/discharge power.

<sup>3</sup> Tested using CEC weighted efficiency methodology.

<sup>4</sup> Cellular connectivity subject to network service coverage and signal strength.

<sup>5</sup> Where the DC input current exceeds the MPPT rating, a jumper can be used to combine two MPPTs into a single input to intake DC current up to 26 A  $I_{mp}$  / 30 A  $I_{sc}$ .

# Powerwall 3 Technical Specifications

## Environmental Specifications

Operating Temperature	-20°C to 50°C (-4°F to 122°F) <sup>6</sup>
Operating Humidity (RH)	Up to 100%, condensing
Storage Temperature	-20°C to 30°C (-4°F to 86°F), up to 95% RH, non-condensing, State of Energy (SOE): 25% initial
Maximum Elevation	3000 m (9843 ft)
Environment	Indoor and outdoor rated
Enclosure Rating	NEMA 3R
Ingress Rating	IPX7 (Battery & Power Electronics) IPX5 (Wiring Compartment)
Pollution Rating	PD3
Operating Noise @ 1 m	< 50 db(A) typical < 62 db(A) maximum


<sup>6</sup> Performance may be de-rated at operating temperatures above 40°C (104°F).

## Compliance Information

Certifications	UL 1642, UL 1699B, UL 1741, UL 1741 SA, UL 1741 SB, UL 3741, UL 1973, UL 1998, UL 9540, IEEE 1547-2018, IEEE 1547.1, UN 38.3
Grid Connection	United States
Emissions	FCC Part 15 Class B
Environmental	RoHS Directive 2011/65/EU
Seismic	AC156, IEEE 693-2005 (high)
Fire Testing	Meets the unit level performance criteria of UL 9540A

## Mechanical Specifications

Dimensions	1099 x 609 x 193 mm (43.25 x 24 x 7.6 in)
Weight	130 kg (287 lb)
Mounting Options	Floor or wall mount



# Solar Shutdown Device Technical Specifications

The Solar Shutdown Device is a Mid-Circuit Interrupter (MCI) and is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with Powerwall 3, solar array shutdown is initiated by any loss of AC power.

Electrical Specifications	Model	MCI-1	MCI-2
	Nominal Input DC Current Rating ( $I_{MP}$ )	12 A	13 A
	Maximum Input Short Circuit Current ( $I_{SC}$ )	19 A	17 A
	Maximum System Voltage (PVHCS)	600 V DC	1000 V DC <sup>7</sup>
	<sup>7</sup> Maximum System Voltage is limited by Powerwall to 600 V DC.		
RSD Module Performance	Maximum Number of Devices per String	5	5
	Control	Power Line Excitation	Power Line Excitation
	Passive State	Normally Open	Normally Open
	Maximum Power Consumption	7 W	7 W
	Warranty	25 years	25 years
Environmental Specifications	Operating Temperature	-40°C to 50°C (-40°F to 122°F)	-45°C to 70°C (-49°F to 158°F)
	Storage Temperature	-30°C to 70°C (-22°F to 158°F)	-30°C to 70°C (-22°F to 158°F)
	Enclosure Rating	NEMA 4X / IP65	NEMA 4X / IP65
Mechanical Specifications	Electrical Connections	MC4 Connector	MC4 Connector
	Housing	Plastic	Plastic
	Dimensions	125 x 150 x 22 mm (5 x 6 x 1 in)	173 x 45 x 22 mm (6.8 x 1.8 x 1 in)
	Weight	350 g (0.77 lb)	120 g (0.26 lb)
	Mounting Options	ZEP Home Run Clip M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw	Wire Clip
Compliance Information	Certifications	UL 1741 PVRSE, UL 3741, PVRSA (Photovoltaic Rapid Shutdown Array)	
	RSD Initiation Method	External System Shutdown Switch or Powerwall 3 Enable Switch	

## UL 3741 PV Hazard Control (and PVRSA) Compatibility

The following categories of solar module meet the UL 3741 PVHCS listing when installed with Powerwall 3 and Solar Shutdown Devices.

Tesla Solar Roof	<a href="#">PV Hazard Control System: BIPV compliance document</a>
Tesla or Hanwha (Q.Peak Duo BLK or BLK-G6+) Modules certified for use with ZEP racking	<a href="#">PV Hazard Control System: ZS PVHCS compliance document</a>
Other module and racking combinations	<a href="#">PV Hazard Control System: Generic PV Array compliance document</a>

# Backup Gateway 2

Backup Gateway 2 controls connection to the grid when paired with Powerwall 3, automatically detecting outages and providing seamless transition to backup power. Backup Gateway 2 also provides energy metering for solar self-consumption, time-based control, and backup operation.

In this system configuration, Powerwall 3 acts as the Site Controller, with the Backup Gateway 2 Site Controller disabled.

## Performance Specifications

<b>Model Number</b>	1232100-xx-y
<b>AC Voltage (Nominal)</b>	120/240 V
<b>Feed-in Type</b>	Split phase
<b>Grid Frequency</b>	60 Hz
<b>Current Rating</b>	200 A
<b>Maximum Supply Short Circuit Current</b>	10 kA <sup>8</sup>
<b>Overcurrent Protection Device</b>	100 - 200 A, Service entrance rated <sup>8</sup>
<b>Overvoltage Category</b>	Category IV
<b>Internal Primary AC Meter</b>	Revenue accurate (+/- 0.2%)
<b>Internal Auxiliary AC Meter</b>	Revenue accurate (+/- 2%)
<b>Primary Connectivity</b>	Ethernet, Wi-Fi
<b>Secondary Connectivity</b>	Cellular (3G, LTE/4G) <sup>9</sup>

<b>User Interface</b>	Tesla App
<b>Operating Modes</b>	Support for solar self-consumption, time-based control, and backup
<b>Backup Transition</b>	Automatic disconnect for seamless backup
<b>Modularity</b>	Supports up to 10 AC-coupled Powerwalls
<b>Optional Internal Panelboard</b>	200 A 6-space / 12 circuit breakers Siemens QP or Square D HOM breakers rated 10 - 80A or Eaton BR breakers rated 10 - 125A
<b>Warranty</b>	10 years

<sup>8</sup> When protected by Class J fuses, Backup Gateway 2 is suitable for use in circuits capable of delivering not more than 22kA symmetrical amperes.

<sup>9</sup> The customer is expected to provide internet connectivity for Backup Gateway 2; cellular should not be used as the primary mode of connectivity. Cellular connectivity subject to network operator service coverage and signal strength.

## Environmental Specifications


<b>Operating Temperature</b>	-20°C to 50°C (-4°F to 122°F)
<b>Operating Humidity (RH)</b>	Up to 100%, condensing
<b>Maximum Elevation</b>	3000 m (9843 ft)
<b>Environment</b>	Indoor and outdoor rated
<b>Enclosure Type</b>	NEMA 3R

## Compliance Information

<b>Certifications</b>	UL 67, UL 869A, UL 916, UL 1741 PCS, CSA 22.2 0.19, CSA 22.2 205
<b>Emmissions</b>	FCC Part 15, ICES 003

## Mechanical Specifications

<b>Dimensions</b>	660 x 411 x 149 mm (26 x 16 x 6 in)
<b>Weight</b>	20.4 kg (45 lb)
<b>Mounting options</b>	Wall mount, Semi-flush mount





# Backup Switch

The Tesla Backup Switch controls connection to the grid in a Powerwall system, and can be easily installed behind the utility meter or in a standalone meter panel downstream of the utility meter.

The Backup Switch automatically detects grid outages, providing a seamless transition to backup power. It communicates directly with Powerwall, allowing home energy usage monitoring from any mobile device with the Tesla app.

## Performance Specifications

<b>Model Number</b>	1624171-xx-y
<b>Continuous Load Rating</b>	200 A, 120/240 V split phase
<b>Maximum Supply Short Circuit Current</b>	22 kA with breaker <sup>10</sup>
<b>Communication</b>	CAN
<b>AC Meter</b>	Revenue accurate (+/- 0.5%)
<b>Expected Service Life</b>	21 years
<b>Warranty</b>	10 years

<sup>10</sup> Breaker maximum supply short circuit current rating must be equal to or greater than the available fault current.

## Environmental Specifications

<b>Operating Temperature</b>	-40°C to 50°C (-40°F to 122°F)
<b>Storage Temperature</b>	-40°C to 85°C (-40°F to 185°F)
<b>Enclosure Rating</b>	NEMA 3R
<b>Pollution Rating</b>	PD3


## Compliance Information

<b>Safety Standards</b>	USA: UL 414, UL 2735, UL 916, CA Prop 65
<b>Emmissions</b>	FCC, ICES

## Mechanical Specifications

<b>Dimensions</b>	176 x 205 x 74 mm (6.9 x 8.1 x 2.9 in)
<b>Weight</b>	2.8 lb
<b>Meter and Socket Compatibility</b>	ANSI Type 2S, ringless or ring type
<b>External Service Interface</b>	Contactor manual override <sup>11</sup> Reset button
<b>Conduit Compatibility</b>	1/2-inch NPT


<sup>11</sup> Manually overrides the contactor position during a service event.



# Powerwall 3 Example System Configurations


## Powerwall 3 with Backup Switch

Whole Home Backup



## Powerwall 3 with Backup Gateway 2

Partial Home Backup



# Tesla Solar Inverter with Solar Shutdown Device

Tesla Solar Inverter completes the Tesla home solar system, converting DC power from solar to AC power for home consumption. Tesla's renowned expertise in power electronics has been combined with robust safety features and a simple installation process to produce an outstanding solar inverter that is compatible with both Solar Roof and traditional solar panels. Once installed, homeowners use the Tesla mobile app to manage their solar system and monitor energy consumption, resulting in a truly unique ecosystem experience.

## KEY FEATURES

- Built on Powerwall technology for exceptional efficiency and reliability
- Wi-Fi, Ethernet, and cellular connectivity with easy over-the-air updates
- Designed to integrate with Tesla Powerwall and Tesla App
- 0.5% revenue-grade metering for Solar Renewable Energy Credit (SREC) programs included
- 3.8 kW and 7.6 kW models available



# Tesla Solar Inverter Technical Specifications

Electrical Specifications: Output (AC)	Model Number	1534000-xx-y	1538000-xx-y
	Output (AC)	3.8 kW	7.6 kW
	Nominal Power	3,800 W	7,600 W
	Maximum Apparent Power	3,328 VA at 208 V 3,840 VA at 240 V	6,656 VA at 208 V 7,680 VA at 240 V
	Maximum Continuous Current	16 A	32 A
	Breaker (Overcurrent Protection)	20 A	40 A
	Nominal Power Factor	1 - 0.9 (leading / lagging)	
	THD (at Nominal Power)	<5%	

Electrical Specifications: Input (DC)	MPPT	2	4
	Input Connectors per MPPT	1-2	1-2-1-2
	Maximum Input Voltage	600 VDC	
	DC Input Voltage Range	60 - 550 VDC	
	DC MPPT Voltage Range	60 - 480 VDC <sup>1</sup>	
	Maximum Current per MPPT ( $I_{MP}$ )	13 A <sup>2</sup>	
	Maximum Short Circuit Current per MPPT ( $I_{SC}$ )	17 A <sup>2</sup>	

<sup>1</sup> Maximum current.

<sup>2</sup> Where the DC input current exceeds an MPPT rating, jumpers can be used to allow a single MPPT to intake additional DC current up to 26 A  $I_{MP}$  / 34 A  $I_{SC}$ .

Performance Specifications	Peak Efficiency	98% at 208 V 98.1% at 240 V	98.4% at 208 V 98.6% at 240 V
	CEC Efficiency	97.5% at 208 V 97.5% at 240 V	97.5% at 208 V 98.0% at 240 V
	Allowable DC/AC Ratio	1.7	
	Customer Interface	Tesla Mobile App	
	Internet Connectivity	Wi-Fi (2.4 GHz, 802.11 b/g/n), Ethernet <sup>3</sup> , Cellular (LTE/4G) <sup>4</sup>	
	Factory-Installed Revenue Grade Meter	Revenue Accurate (+/- 0.5%) <sup>3</sup>	
	AC Remote Metering Support	Wi-Fi (2.4 GHz, 802.11 b/g/n), RS-485	
	Protections	Integrated arc fault circuit interrupter (AFCI), Rapid Shutdown	
	Supported Grid Types	60 Hz, 240 V Split Phase 60 Hz, 208 V Wye	

<sup>3</sup> Applicable to Tesla Solar Inverter with Site Controller (1538000-45-y) only.


<sup>4</sup> Cellular connectivity subject to network operator service coverage and signal strength.

# Tesla Solar Inverter Technical Specifications

## Mechanical Specifications

### Dimensions

660 mm x 411 mm x 158 mm (26 in x 16 in x 6 in)



### Weight

52 lb<sup>5</sup>

### Mounting Options

Wall mount (bracket)

<sup>5</sup> Door and bracket can be removed for a mounting weight of 37 lb.

## Environmental Specifications

### Operating Temperature

-30°C to 45°C (-22°F to 113°F)<sup>6</sup>

### Operating Humidity (RH)

Up to 100%, condensing

### Storage Temperature

-30°C to 70°C (-22°F to 158°F)

### Maximum Elevation

3000 m (9843 ft)

### Environment

Indoor and outdoor rated

### Enclosure Rating

Type 3R

### Ingress Rating

IP55 (Wiring compartment)

### Pollution Rating

PD2 for power electronics and terminal wiring compartment, PD3 for all other components

### Operating Noise @ 1 m

< 40 db(A) nominal, < 50 db(A) maximum

<sup>6</sup> For the 7.6 kW Tesla Solar Inverter, performance may be de-rated to 6.2 kW at 240 V or 5.37 kW at 208 V when operating at temperatures greater than 45°C.

## Compliance Information

### Grid Certifications

UL 1741, UL 1741 SA, UL 1741 SB, IEEE 1547-2018, IEEE 1547.1

### Safety Certifications

UL 1741 PVRSS, UL 1699B, UL 1998 (US), UL 3741

### Emissions

EN 61000-6-3 (Residential), FCC 47CFR15.109 (a)

# Solar Shutdown Device 1 Technical Specifications

The Solar Shutdown Device is a Mid-Circuit Interrupter (MCI) and is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with Tesla Solar Inverter, solar array shutdown is initiated by any loss of AC power.


Electrical Specifications	Nominal Input DC Current Rating ( $I_{MP}$ )	12 A
	Maximum Input Short Circuit Current ( $I_{SC}$ )	19 A
	Maximum System Voltage (PVHCS)	600 V DC

RSD Module Performance	Maximum Number of Devices per String	5
	Control	Power Line Excitation
	Passive State	Normally Open
	Maximum Power Consumption	7 W
	Warranty	25 years

Environmental Specifications	Ambient Temperature	-40°C to 50°C (-40°F to 122°F)
	Storage Temperature	-30°C to 70°C (-22°F to 158°F)
	Enclosure Rating	NEMA 4X / IP65

Compliance Information	Certifications	UL 1741 PVRSE, UL 3741, PVRSA (Photovoltaic Rapid Shutdown Array)
	RSD Initiation Method	PV System AC Breaker or Switch
	Compatible Equipment	See Compatibility Table below

Mechanical Specifications	Model Number	MCI-1
	Electrical Connections	MC4 Connector
	Housing	Plastic
	Dimensions	125 mm x 150 mm x 22 mm (5 in x 6 in x 1 in)
	Weight	350 g (0.77 lb)
	Mounting Options	ZEP Home Run Clip
		M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw



## UL 3741 PV Hazard Control (and PVRSA) Compatibility

Tesla Solar Roof and Tesla/Zep ZS Arrays using the following modules are certified to UL 3741 and UL 1741 PVRSA when installed with Tesla Solar Inverter and Solar Shutdown Devices. See [Tesla Solar Inverter Rapid Shutdown: Module Selection Based on PV Hazard Control System Listing](#) for guidance on installing Tesla Solar Inverter and Solar Shutdown Devices with other modules.

Brand	Model	Required Solar Shutdown Devices
Tesla	Solar Roof V3	1 Solar Shutdown Device per 10 modules
Tesla	Tesla TxxxS (where xxx = 405 to 450 W, increments of 5)	1 Solar Shutdown Device per 3 modules <sup>7</sup>
Tesla	Tesla TxxxH (where xxx = 395 to 415 W, increments of 5)	1 Solar Shutdown Device per 3 modules
Hanwha	Q.PEAK DUO BLK-G5 or Q.PEAK DUO BLK-G6+	1 Solar Shutdown Device per 3 modules


<sup>7</sup> **Exception:** Tesla solar modules installed in locations where the max Voc for three modules at low design temperatures exceeds 165 V shall be limited to two modules between Solar Shutdown Devices.

## One Clamp Anywhere

The Multi-Clamp works as mid- or end-clamp, and fits standard 30-40mm frames.


## Instant Bonding

The N-S Bonding Jumper bonds row to row with no tools.



## Lifetime Wire Management

Open rail channel holds and protects wires. Clamps won't pinch wires after tightening.



## Bonding Structural Splice

Connect rails instantly, without tools, interference or limitations.

## Next-Level Solar Mounting

A complete system for hassle-free rooftop installation, from watertight mounts to lifetime wire management.



### Simplicity

1/2" socket for everything.  
One clamp for mid or end.  
No tool splicing and bonding.  
Easy wire management.



### Code Compliant

UL 2703 listed  
LTR-AE-001-2012 listed  
Class A fire rating for any slope  
ASCE 7-16 PE Certified






### Premium Aesthetics

The narrowest panel gap available. Optional Hidden End Clamps and End Caps provide a flush look on the edge of the array.



### Watertight for Life

Secured on industry-leading Pegasus Mounts, for composite shingle and tile roofs. Backed by a 25-year warranty.



### Pegasus Rail

Available in 14' and 7' lengths for easy layout and shipping.  
Open-channel design holds MC4 connectors, PV wire and trunk cables.  
Black and Mill finish

### Pegasus Max Rail

Maximum-strength design.  
Meets specifications for high snow-load and hurricane zones.  
Black and Mill finish

### Splice and Max Splice

Installs by hand.  
Works over mounts.  
Structurally connects and bonds rails automatically; UL2703 listed as reusable.

### Dovetail T-bolt

Dovetail shape for extra strength.  
Uses 1/2" socket.



### Multi-Clamp

Fits 30-40mm PV frames, as mid- or end-clamp.  
Twist-locks into position; doesn't pinch wires in rail.  
Bonds modules to rail; UL2703 listed as reusable

### Hidden End Clamp



Offers premium edge appearance.  
Preinstalled pull-tab grips rail edge, allowing easy, one-hand installation.  
Tucks away for reuse.

### Ground Lug

Holds 6 or 8 AWG wire.  
Mounts on top or side of rail.  
Assembled on MLPE Mount.  
UL2703 listed as reusable.

### N-S Bonding Jumper

Installs by hand, eliminates row-to-row copper wire.  
UL2703 listed as reusable only with Pegasus Rail.



### MLPE Mount

Secures and bonds most micro-inverters and optimizers to rail.  
Connectors and wires easily route underneath after installation.  
UL2703 listed as reusable.

### Cable Grip

Secures four PV wires or two trunk cables.  
Stainless-steel backing provides durable grip.  
Eliminates sagging wires.

### Wire Clip

Hand operable.  
Holds wires in channel.  
Won't slip.

### End Cap and Max End Cap

Fits flush to PV module and hides raw or angled cuts.  
Hidden drain quickly clears water from rail.

#### Certifications:

- UL 2703, Edition 1
- LTR-AE-001-2012
- ASCE 7-16 PE certified
- Class A fire rating for any slope roof



Quickly calculate the most efficient layout, spans and materials needed to suit your job. Visit the Pegasus Customer Portal. [pegasussolar.com/portal](http://pegasussolar.com/portal)

LOAD		SPAN			
SNOW (PSF)	WIND (MPH)	32"	4'	6'	8'
0	120	PEGASUS RAIL			
	160	PEGASUS RAIL			PEGASUS MAX RAIL
	190	PEGASUS RAIL		PEGASUS MAX RAIL	
15	140	PEGASUS RAIL			PEGASUS MAX RAIL
	160	PEGASUS RAIL		PEGASUS MAX RAIL	
30	160	PEGASUS RAIL		PEGASUS MAX RAIL	
	190	PEGASUS RAIL		PEGASUS MAX RAIL	
45	190	PEGASUS RAIL		PEGASUS MAX RAIL	
70	190	PEGASUS RAIL		PEGASUS MAX RAIL	
110	190	PEGASUS RAIL		PEGASUS MAX RAIL	

For reference only. Spans above are calculated using ASCE 7-16 for a Gable Roof, Exposure Category B, 7-20deg roof angle, 30ft mean roof height with non-exposed modules. For PE certified span tables, visit [www.pegasussolar.com/spans](http://www.pegasussolar.com/spans).


Patents pending. All rights reserved. ©2021 Pegasus Solar Inc.



# COMP MOUNT

## One-Piece Flashing with Elevated Cone

No press-fits or deck-level EPDM washers to fail



## Encapsulating Design

Raises the water seal 0.9" Above roof deck



## Simple 3-Piece Design Watertight For Life

Pegasus solar's comp mounts are a cost effective, high-quality option for rail installations on composition shingle roofs. Designed to last decades, the one-piece flashing with elevated cone means there is simply nothing to fail.



### 25-Year Warranty

Manufactured with advanced materials and coatings to outlast the roof itself



### Code Compliant

Fully IBC/CBC Code Compliant  
Exceeds ASCE 7-16 Standards



### Superior Waterproofing

Tested to AC286 without sealant  
Water seal elevated 0.9" above




### All-In-One Kit Packaging


Flashings, L-Feet and SS lags with bonded EPDM washers are included in each 24-pack

**1**


Drill pilot hole in the center of the rafter.


**2**







Optional: Apply a "u-shape" of sealant to the underside of the flashing and position under 2nd shingle course, cone over pilot hole.


**3**

Place L-Foot over cone and install lag with washer through L-Foot.


**4**

Drive lag to required depth. Attach rail per rail manufacturer's instructions.



SPECIFICATIONS	COMP MOUNT INSTALL KITS				
SKU	PSCR-CBB0	PSCR-UBB0	SPCR-CBBH	PSCR-CMM0	PSCR-UMM0
Finish	Black L-Foot And Black Flashing			Mill	
L-Foot Type	Closed Slot	Open Slot	Closed Slot	Closed Slot	Open Slot
Kit Contents	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer and M10 Hex Bolt	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer	L-Foot, Flashing, 5/16" x 4 1/2" SS Lag with metalized EPDM washer
Roof Type	Composition Shingle				
Certifications	IBC, ASCE/SEI 7-16, AC286				
Install Application	Railed Systems				
Compatible Rail	Most				
Kit Quantity	24				
Boxes per Pallet	72				

Protected under US Patent: 10,998,847. Additional patents pending. All rights reserved. ©2021 Pegasus



## All-Terrain Mounting

The IronRidge Ground Mount System combines our XR100 or XR1000 rails with locally-sourced steel pipes or mechanical tubing, to create a cost-effective structure capable of handling any site or terrain challenge.

Installation is simple with only a few structural components and no drilling, welding, or heavy machinery required. In addition, the system works with a variety of foundation options—including concrete piers, ground screws, helical or driven piles, and above-ground ballast blocks.



### Rugged Construction

Engineered steel and aluminum components ensure durability.



### PE Certified

Pre-stamped engineering letters available in most states.



### UL 2703 Listed System

Meets newest effective UL 2703 standard.



### Design Software

Online tool generates engineering values and bill of materials.



### Flexible Architecture

Multiple foundation and array configuration options.



### 25-Year Warranty

Products guaranteed to be free of impairing defects.



360° Product Tour  
Visit [ironridge.com](http://ironridge.com)

## Substructure

### Top Caps




Connect vertical and cross pipes.

### Bonded Rail Connectors



Attach and bond Rail Assembly to cross pipes.

### Diagonal Braces



Optional Brace provides additional support.

### Cross Pipe & Piers



Steel pipes or mechanical tubing for substructure.

## Rail Assembly

### XR100/XR1000 Rails



Curved rails increase spanning capabilities.

### UFOs



Universal Fastening Objects bond modules to rails.

### Stopper Sleeves




Snap onto the UFO to turn into a bonded end clamp.

### CAMO



Bond modules to rails while staying completely hidden.

## Resources



### Design Assistant

Go from rough layout to fully engineered system. For free.

Go to [ironridge.com/design](http://ironridge.com/design)



### NABCEP Certified Training

Earn free continuing education credits, while learning more about our systems.

Go to [ironridge.com/training](http://ironridge.com/training)



## E-Series

with eccentric disc  
for precise alignment



## F-Series

with a flange ring  
for flexible assembly



## G-Series

with thread  
fastening






## K-Series

made from plastic




## M-Series

with central  
internal threads



## U-Series

for simple  
beam assembly



## V76

with a high load  
capacity option





## X-Series

delineator  
foundation




## V89

with a high load  
capacity option





## V114

with a high load  
capacity option




## V140

with a high load  
capacity option



ANCILLARY APPLICATIONS

CONSTRUCTION PRODUCTS



# SolaDeck

PV ROOF-MOUNT ENCLOSURE

**INTRODUCED AT  
*SOLAR POWER 2007***



**UL50 Type 3R Enclosure • Stamped 18 gauge gal. steel • Powder coated finish  
• Weather tight**



## **Enclosure Includes:**

- Dual ground lug
- Universal DIN rail
- 1/2", 3/4" & 1" knockouts
- Wire strain relief clip
- Complete hardware package

## **PV Roof-Mount Combiner/Enclosure**

### **Benefits**

- The ability to prep the building is now possible
- Replaces several parts used today
- Provides professional looking install
- Saves time on install
- Allows for easy access
- Guaranteed seal to roof
- Low profile design

***For product information contact us at  
(866) 367-7782***

**[www.commdeck.com](http://www.commdeck.com)**



RSTC Enterprises, Inc  
2219 Heimstead Road  
Eau Claire, WI 54703  
1 (866) 367 - 7782



## **SolaDeck Part # 780**

### **Specifications:**

**18 Gauge Steel Base (1) and Cover (2)**  
**Pre Punched 7 holes in base (1) for roof deck**  
**Pre Punched 4 holes in base (1) and cover (2) for match**  
**Draw Process both parts**  
**Powder Coated to withstand 1000 hours Salt Spray (Primer Gray)**  
**High UV resistance**  
**15" x 15" flashing dimension**  
**Cavity dimension 8"W x 9" L x 2.5"D**  
**Approx. 162 Cubic inch equipment cavity**  
**Norloked steel base plate (3) to drawn base (2)**  
**Three knockout locations .5", .75" and 1"**  
**3" DIN rail installed**  
**Grounding Lug- Installed (In Equipment Cavity)**  
**Wire Strain Relief Clip –Installed (In Equipment Cavity)**  
**Hardware pack withstands 500 hours Salt Spray**  
**7 - 2" Trusshead Screws**  
**4 - .5" 8-32 thread cutting screws**  
**4 - #10 Bonded Seal washers**  
**1 – Foam closed Cell Seal**  
**ETL Listed UL50 Type 3R**

**Total Weight 6.9 pounds each**

### **Packaging:**

**Individually bagged and boxed**  
**Box dimension 15.5"w x 16" L x 3" D**  
**White Carton labeled with Cut out template**  
**Print One Color - Black**

**Master Cartons of 6 Units each**  
**Master Carton dimension 18.75"x16"x16.375"**  
**Master Carton Weight – 42 pounds**  
**18 Master Cartons per skid Approx 800 pounds with skid**

# Eaton DG223URB

Catalog Number: DG223URB

Eaton General duty non-fusible safety switch, single-throw, 100 A, NEMA 3R, Rainproof, Painted galvanized steel, Two-pole, Two-wire, 240 V



Photo is representative

## General specifications

### Product Name

Eaton general duty non-fusible safety switch

### Catalog Number

DG223URB

### UPC

782114731154

### Product Length/Depth

7.38 in

### Product Height

19.25 in

### Product Width

9.13 in

### Product Weight

12 lb

### Warranty

Eaton Selling Policy 25-000, one (1) year NEC 230.62 (C) Compliant Barrier from the date of installation of the Product or eighteen (18) months from the date of shipment of the Product, whichever occurs first.

### Compliances

### Certifications

UL Listed

### Catalog Notes

WARNING! Switch is not approved for service entrance unless a neutral kit is installed.



## Type

Non-fusible, single-throw

## Amperage Rating

100A

## Number Of Poles

Two-pole

## Product Category

General duty safety switch

## Voltage rating

240V

## Enclosure

NEMA 3R

## Enclosure material

Painted galvanized steel

## Fuse configuration

Non-fusible

## Number of wires

2

## Catalogs

[Eaton's Volume 2—Commercial Distribution](#)

## Multimedia

[Double Up on Safety](#)

[Switching Devices Flex Center](#)

## Specifications and datasheets

[Eaton Specification Sheet - DG223URB](#)



Eaton Corporation plc  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2024 Eaton. All Rights Reserved.

Eaton is a registered trademark.

All other trademarks are property of their respective owners.



[Eaton.com/socialmedia](https://www.eaton.com/socialmedia)

# Eaton BR2100

Catalog Number: BR2100

Eaton BR Thermal magnetic circuit breaker, Type BR 1-Inch plug-on circuit breaker, 100 A, 10 kAIC, Two-pole, 120/240V, BR, Common breaker trip, #4-1/0 AWG Cu/Al, Q28, BR, Type BR Loadcenters

## General specifications



<b>Product Name</b>	<b>Catalog Number</b>
Eaton BR thermal magnetic circuit breaker	BR2100
	UPC
	786676363259
<b>Product Length/Depth</b>	<b>Product Height</b>
1.9 in	2.4 in
<b>Product Width</b>	<b>Product Weight</b>
2 in	0.6 lb
<b>Compliances</b>	<b>Certifications</b>
Federal Specifications Classification W-C375	UL 489

## defaultTaxonomyAttributeLabel

### Type

Type BR 1-Inch plug-on circuit breaker

### Special features

Used with Type BR Loadcenters

### Amperage Rating

100 A

### Voltage rating

120/240 V

### Trip Type

Common breaker trip

### Circuit breaker type

BR

### Used with

Type BR Loadcenters

### Mounting Method

Plug-on

### Interrupt rating

10 kAIC

### Main circuit breaker

BR

### Wire size

#4-1/0 AWG Cu/Al

### Number of poles

Two-pole

### Quantity

28

## Resources

### Brochures

[Loadcenters and Circuit Breakers](#)

### Catalogs

[Eaton's Volume 1—Residential and Light Commercial](#)

### Specifications and datasheets

[Eaton Specification Sheet - BR2100](#)



Eaton Corporation plc  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com  
© 2024 Eaton. All Rights Reserved.

Eaton is a registered trademark.

All other trademarks are property of their respective owners.



[Eaton.com/socialmedia](https://www.eaton.com/socialmedia)

# Product data sheet

Specifications

SQUARE D

Green Premium™



Load center, Homeline, 1 phase, 8 spaces, 16 circuits, 125A convertible main lugs, PoN, NEMA3R

HOM816L125PRB

Product availability: Stock - Normally stocked in distribution facility

Price\*: 267.84 USD

## Main

Product Type	Load Center
Marketing Trade Name	Homeline
Load Center Type	PoN Convertible Mains (lugs)
Rated Current	125 A
Number Of Spaces	8
Maximum Number Of Single Pole Circuits	16
Enclosure Rating	NEMA 3R outdoor
Cover Type	Surface cover
Electrical Connection	Lugs

## Complementary

Max Short Circuit Current Rating	10 kA
Maximum Number Of Tandem Breakers	8
Number Of Phases	1 phase
Voltage Rating	120/240 V AC
Wire Size	AWG 6...AWG 2/0 aluminium AWG 6...AWG 1 copper
Ground Bar	Grounding bar (ordered separately)
Wiring Configuration	3-wire
Busbar Material	Tin plated aluminium: busbar
Enclosure Material	Welded galvanized steel
Surface Finish	Baked enamel Gray
Box Number	3R
Bus Rated Current	125.0 A
Height	18.94 in (481 mm)
Width	14.76 in (375 mm)
Depth	4.53 in (115 mm)

## Environment

Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

<b>Ambient Air Temperature For Operation</b>	23 °F (-5 °C) 104 °F (40 °C)
<b>Product Certifications</b>	UL listed file E-6294

## Ordering and shipping details

<b>Category</b>	US1DE3C00149
<b>Discount Schedule</b>	DE3C
<b>Gtin</b>	785901973997
<b>Returnability</b>	Yes
<b>Country Of Origin</b>	US

## Packing Units

<b>Unit Type Of Package 1</b>	PCE
<b>Number Of Units In Package 1</b>	1
<b>Package 1 Height</b>	5.00 in (12.7 cm)
<b>Package 1 Width</b>	15.40 in (39.116 cm)
<b>Package 1 Length</b>	20.70 in (52.578 cm)
<b>Package 1 Weight</b>	20.40 lb(US) (9.253 kg)
<b>Unit Type Of Package 2</b>	PAL
<b>Number Of Units In Package 2</b>	45
<b>Package 2 Height</b>	45.00 in (114.3 cm)
<b>Package 2 Width</b>	40.00 in (101.6 cm)
<b>Package 2 Length</b>	48.00 in (121.92 cm)
<b>Package 2 Weight</b>	948.00 lb(US) (430.005 kg)

## Sustainability

**Green Premium™ label** is Schneider Electric's commitment to delivering products with best-in-class environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO<sub>2</sub> products.

**Guide to assessing product sustainability** is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

[Learn more about Green Premium >](#)

[Guide to assess a product's sustainability >](#)



Transparency RoHS/REACH

## Well-being performance

Toxic Heavy Metal Free

Mercury Free

Rohs Exemption Information Yes

## Certifications & Standards

Reach Regulation

[REACH Declaration](#)

Eu Rohs Directive

Compliant

[EU RoHS Declaration](#)

China Rohs Regulation

[China RoHS declaration](#)

Pro-active China RoHS declaration (out of China RoHS legal scope)

Environmental Disclosure

[Product Environmental Profile](#)

Circularity Profile

No need of specific recycling operations

California Proposition 65

WARNING: This product can expose you to chemicals including: Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)