



# Permit Inspections

## Harnett County

Permit Number: ERES2405-0029

Description: Electrical Wiring going to existing building

Applied: 5/20/2024

Approved: 5/20/2024

Site Address: 1340 JOEL JOHNSON RD

Issued: 5/20/2024

Finalized:

City, State Zip Code: LILLINGTON, NC 27546

Status: ISSUED

Applicant: HILL LAMONT A

Parent Permit:

Owner: HILL LAMONT A

Parent Project:

Contractor: HILL LAMONT A

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Steven Gazlay		
Notes:						
			RECONNECT W/O FINAL	Steven Gazlay		
Notes:						
	6/18/2024	6/18/2024	FINAL**	James T Hall	CANCELLED	
Notes:						
Cancel not ready needs roughin inspection						
	11/27/2024	11/27/2024	ROUGH IN	Daniel L Floyd	APPROVED	
Notes:						
	11/21/2025	11/21/2025	RECONNECT W/O FINAL	Brad Sutton	DISAPPROVED	
Notes:						
Must have overhead wire installed from meter base to weatherhead Breakers must be AFCI Uncover both ground rods for inspection Must use "acorn" style ground clamps on rods						