



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/20/2024

SUBJECT: ERES2407-0050
ELECTRICAL RESIDENTIAL

To: Viva Electric Enterprise LLC

Here are the results of all Inspections located at **106 COBBLESTONE DR:**

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: UNDERGROUND
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 8/7/2024
Completed Date/Time: 8/7/2024
Inspector: John B Kokoszka
Result: DISAPPROVED

Remarks:

Notes: This should have been an underground electrical. Need to uncover electrical wires