PHOTOVOLTAIC ROOF MOUNT SYSTEM 8.500kWDC,11.000kWAC 27.000kWh ENERGY STORAGE SYSTEM 20 BARN LOFT CT, FUQUAY-VARINA, NC 27526

AHJ:

COUNTY OF HARNETT

UTILITY:

DUKE ENERGY

GOVERNING CODES WITH NC AMENDMENTS:


2018 NORTH CAROLINA BUILDING CODE 2018 NORTH CAROLINA RESIDENTIAL CODE 2018 NORTH CAROLINA FIRE CODE 2017 NORTH CAROLINA ELECTRICAL CODE (NEC 2017)

WIND SPEED:116 MPH SNOW LOAD: 15 PSF

SCOPE OF WORK

- (N) 8.500KWDC,(N) 11.000KWAC ROOF MOUNTED PV SYSTEM
- (N) 27.000KWH ENERGY STORAGE SYSTEM
- (N) (20) QCELLS Q.TRON BLK M-G2+ 425W SOLAR MODULES
- (N) (7) MID-CIRCUIT INTERRUPTER
- (N) (2) TESLA 1707000-XX-Y (240V) BATTERIES WITH INTEGRATED INVERTER
- (N) (1) TESLA BACKUP GATEWAY 2
- (N) (1) EV OUTLET
- (N) (1) ESS DISCONNECT SWITCH
- (N) (1) 125A COMBINER PANEL

VICINITY MAP



CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

GENERAL NOTES

- 1. MODULES ARE LISTED UNDER UL 61730 / UL 1703 AND CONFORM TO THE STANDARDS.
- 2. INVERTERS ARE LISTED UNDER UL 1741 AND CONFORM TO THE STANDARDS.
- 3. DRAWINGS ARE DIAGRAMMATIC, INDICATING GENERAL ARRANGEMENT OF THE PV SYSTEM AND THE ACTUAL SITE CONDITIONS MAY VARY.
- 4. WORKING CLEARANCES AROUND THE NEW PV ELECTRICAL EQUIPMENT SHALL BE MAINTAINED IN ACCORDANCE WITH NEC 110.26.
- 5. ALL GROUND WIRING CONNECTED TO THE MAIN SERVICE GROUNDING IN MAIN SERVICE PANEL/ SERVICE EQUIPMENT.
- 6. ALL CONDUCTORS SHALL BE 600V, 90°C STANDARD COPPER UNLESS OTHERWISE NOTED.
- 7. WHEN REQUIRED, A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.
- 8. THE SYSTEM WILL NOT BE INTERCONNECTED BY THE CONTRACTOR UNTIL APPROVAL FROM THE UTILITY IS RECEIVED.
- 9. ROOF ACCESS POINT SHALL BE LOCATED IN AREAS THAT DO NOT REQUIRE THE PLACEMENT OF GROUND LADDERS OVER OPENINGS SUCH AS WINDOWS OR DOORS, AND LOCATED AT STRONG POINTS OF BUILDING CONSTRUCTION WHERE THE ACCESS POINT DOES NOT CONFLICT WITH OVERHEAD OBSTRUCTIONS SUCH AS TREES, WIRES OR SIGNS.
- 10.PV ARRAY COMBINER/JUNCTION BOX PROVIDES TRANSITION FROM ARRAY WIRING TO CONDUIT WIRING.
- 11. RACKING SYSTEM SHALL BE LISTED TO UL 2703.
- 12.FIRE RATING OF EXISTING ROOF ASSEMBLY SHALL BE MAINTAINED WITH ADDITION OF PHOTOVOLTAIC SYSTEM.

SHEET INDEX

PV-1 COVER SHEET

PV-2 SITE PLAN

PV-3 PROPERTY PLAN

PV-4 ROOF PLAN

PV-5 ATTACHMENT DETAIL

PV-6 SINGLE LINE DIAGRAM

PV-7 ELECTRICAL CALC. AND NOTES

PV-8 LABELS & PLACARD


PV-9 TO PV-14 SPEC SHEETS

ART
NTS

PV-1

COVER SHEET

LEGEND (E) UTILITY METER (E) 200A MAIN SERVICE PANEL MSP (E) 200A MAIN BREAKER (N) 200A FUSED AC DISCONNECT ACD VISIBLY OPEN, LOCKABLE 240V NEMA-3R (N) TESLA POWERWALL 3 BATTERY 1 ESS1 **EQUIPPED WITH INTEGRATED INVERTER** (N) TESLA POWERWALL 3 BATTERY 2 ESS2 **EQUIPPED WITH INTEGRATED INVERTER** (N) 125A COMBINER PANEL CP (N) EV OUTLET EVO (N) TESLA BACKUP GATEWAY 2 MID (N) ESS DISCONNECT SWITCH EDS (N) 7 MID-CIRCUIT INTERRUPTER MCI LADDER ACCESS LA (N) JUNCTION BOX 1 JB1 240V, NEMA 4X (ON ROOF) (N) JUNCTION BOX 2 JB2 240V, NEMA 4X (ON ROOF) (N) 20 QCELLS Q.TRON BLK M-G2+ **425W SOLAR MODULES** FIRE SETBACKS (E) ROOF OBSTRUCTIONS



CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

(N) 125A COMBINER PANEL (INTERIOR)

RESIDENCE

(N) (2) TESLA POWERWALL 3

BATTERIES EQUIPPED WITH

INTEGRATED INVERTER (INTERIOR)

FRONT OF

- (N) EV OUTLET (INTERIOR)

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF **MOUNT SYSTEM & ENERGY** STORAGE SYSTEM


8.500 kWDC, 11.000 kWAC PV **SYSTEM** 27.000kWh ENERGY STORAGE JAY BISSETT RESIDENCE 20 BARN LOFT CT, FUQUAY-VARINA, NC 27526

DATE	9/6/2024
CREATED BY	ART
SCALE	1/8" = 1'-0"

SITE PLAN

LEGEND

PROPERTY LINE



CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC PV SYSTEM 27.000kWh ENERGY STORAGE

JAY BISSETT RESIDENCE 20 BARN LOFT CT, FUQUAY-VARINA, NC 27526

DATE	9/6/2024
CREATED BY	ART
SCALE	1/32" = 1'-0"

PROPERTY PLAN



MODULE TYPE, DIMENSION & WEIGHT

NUMBER OF MODULES = 20 MODULES

MODULE TYPE = QCELLS: Q.TRON BLK M-G2+ 425W MODULES

MODULE WEIGHT = 46.7 LBS / 21.2KG


MODULE DIMENSIONS = 67.8"X 44.6" = 21.00 SF


51 ATTACHMENTS INSTALLED @ 48" O.C. MAX (TYP) NOTE: PENETRATIONS ARE STAGGERED.

	ROOF DESCRIPTION									
ROOF	ROOF LAYER 1 LAYER									
ROOF	# OF MODULES	ROOF PITCH	AZIMUTH		USS ZE	TRUSS SPACING	ROOF TYPE			
1	9	30°	274°	2" 2	X 4"	24"	COMPOSITION SHINGLE			
2	11	40°	184°	2" 2	X 4"	24"	COMPOSITION SHINGLE			

ARRAY & ROOF AREA CALC'S

TOTAL PV	TOTAL ROOF	ROOF AREA
ARRAY AREA	AREA	COVERED BY
(Sq. Ft.)	(Sq. Ft.)	ARRAY (%)
419.98	2334.29	18







LEGEND

- M (E) UTILITY METER
- (E) 200A MAIN SERVICE PANEL (E) 200A MAIN BREAKER
- (N) 200A FUSED AC DISCONNECT VISIBLY OPEN, LOCKABLE 240V NEMA-3R
- (N) TESLA POWERWALL 3 BATTERY 1
 EQUIPPED WITH INTEGRATED
 INVERTER
- (N) TESLA POWERWALL 3 BATTERY 2
 EQUIPPED WITH INTEGRATED
 INVERTER
- CP (N) 125A COMBINER PANEL
- (N) EV OUTLET
- MID (N) TESLA BACKUP GATEWAY 2
- EDS (N) ESS DISCONNECT SWITCH
- MCI (N) 7 MID-CIRCUIT INTERRUPTER
- LADDER ACCESS
- (N) JUNCTION BOX 1 240V, NEMA 4X (ON ROOF)
- JB2 (N) JUNCTION BOX 2 240V, NEMA 4X (ON ROOF)
- (N) 20 QCELLS Q.TRON BLK M-G2+ 425W SOLAR MODULES
- FIRE SETBACKS

(N) RAIL

- (E) ROOF OBSTRUCTIONS
- (N) ROOF ATTACHMENTS
- ---- TRUSS
- | | P

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537


PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM


8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE	9/6/2024
CREATED BY	ART
SCALE	3/32" = 1'-0"

ROOF PLAN

FOR DECK MOUNT:





CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617


PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE	9/6/2024
CREATED BY	ART
SCALE	NTS

ATTACHMENT DETAIL



TAG ID	CONDUIT SIZE	CONDUCTOR	NEUTRAL	GROUND		MODULE SPEC
TAGTE	OONDON SIZE	0011001011	NEOTTAL	anound	MODEL	: Q.TRON BLK M-G2+ 425W
1	OPEN AIR	(2) 10 AWG PV WIRE	NONE	(1) 6 AWG BARE COPPER, EGC	QTY: 2	0 WATT.: 425
_		(2) 10 AWAT V WITE		(1) 3 1 1 1 2 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2	Voc: 3	9.03 lsc: 13.66
2	3/4" EMT	(2) 10 AWG THHN/THWN-2, Cu	NONE	(1) 10 AWG THHN/THWN-2, EGC	Vmp: 3	2.74 Imp: 12.98
_	<u> </u>	,			INVERT	R SPEC
3	3/4"EMT	(2) 6 AWG THHN/THWN-2, Cu	(1) 6 AWG THHN/THWN-2, Cu	(1) 10 AWG THHN/THWN-2, EGC		TESLA POWERWALL 3
		. ,	. ,			BATTERY WITH
4	1-1/2"EMT	(2) 1/0 AWG THHN/THWN-2, Cu	(1) 1/0 AWG THHN/THWN-2, Cu	(1) 8 AWG THHN/THWN-2, EGC	MODEL:	INTEGRATED INVERTER
					- MODEL.	EQUIPPED WITH RAPID
5	2"EMT	(2) 3/0 AWG THHN/THWN-2, Cu	(1) 3/0 AWG THHN/THWN-2, Cu	NONE		SHUTDOWN
					MAX O/P VOLTAGE:	240V
6	3/4"EMT	(2) 8 AWG THHN/THWN-2, Cu	(1) 8 AWG THHN/THWN-2, Cu	(1) 10 AWG THHN/THWN-2, EGC	MAX O/P CURRENT:	45.83A
					DISCHARGE POWER:	11500W
7	2"EMT	(2) 3/0 AWG THHN/THWN-2, Cu	(1) 3/0 AWG THHN/THWN-2, Cu	(1) 6 AWG THHN/THWN-2, EGC	CHARGE POWER:	5000W
_	EVIOTINO		EVICTING	EVICTING	CURTAILMENT OUTPUT	11000W
Е	EXISTING	EXISTING	EXISTING	EXISTING	CEC EFF:	97.5% QTY. 1

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

SINGLE LINE DIAGRAM

WIRE SIZE CALCULATION MAX BRANCH DC REQUIRED CONDUCTOR AMPACITY (19)(1.25) = 23.75A AWG #10, DERATED AMPACITY: (40)x(0.91)x(1) = 36.40A FROM TABLE 310.15(B)(16),90°C COLUMN 36.40A>23.75A, THEREFORE DC WIRE SIZE IS VALID TAG ID 3

COMBINED SYSTEM AC REQUIRED CONDUCTOR AMPACITY

(1)(45.83)(1.25) = 57.2A PER NEC §690.8(A)

FROM TABLE 310.15(B)(16),75°C COLUMN

74.80A>57.29A, THEREFORE AC WIRE SIZE IS VALID

NOTE: CONDUIT SHALL BE INSTALLED MIN 7/8" ABOVE

AWG #6. DERATED AMPACITY:

(65)x(0.88)x(1) = 57.2A

ROOF SURFACE

TAG ID 4 COMBINED SYSTEM AC REQUIRED CONDUCTOR AMPACITY (2)(45.83)(1.25) = 114.58A PER NEC §690.8(A) AWG #1/0, DERATED AMPACITY: (150)x(0.88)x(1) = 132.00A FROM TABLE 310.15(B)(16),75°C COLUMN 132.00A>114.58A, THEREFORE AC WIRE SIZE IS VALID NOTE: CONDUIT SHALL BE INSTALLED MIN 7/8" ABOVE ROOF SURFACE

OCPD CALCULATION

INVERTER OVERCURRENT PROTECTION = INVERTER O/P CURRENT * CONTINUOUS LOAD(1.25)

= 91.66 * 1.25 = 114.58 A

ASHRAE 2021 -

HIGHEST MONTHLY 2% D.B. DESIGN TEMP.: 35.9°C

LOWEST MIN. MEAN EXTREME D.B.: -8.5°C

= 120A

THE DESIGNED INTERCONNECTION MEETS THE NEC 705.12(A) REQUIREMENTS.

= 200A

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

INTERCONNECTION NOTES:

- 1. INTERCONNECTION SIZING, LIMITATIONS AND COMPLIANCE DETERMINED IN ACCORDANCE WITH [NEC 705.12], AND [NEC 690.64].
- 2. GROUND FAULT PROTECTION IN ACCORDANCE WITH [NEC 215.9], [NEC 230.95] AND [NEC 690.5]
- 3. ALL EQUIPMENT TO BE RATED FOR BACKFEEDING.
- 4. PV BREAKER TO BE POSITIONED AT THE OPPOSITE END OF THE BUSBAR RELATIVE TO THE MAIN BREAKER.

DISCONNECT NOTES:

1. DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING LIVE ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS)

ALLOWABLE BACKFEED:

MAIN BREAKER RATING

MAIN SERVICE PANEL RATING = 200A

PV OVERCURRENT PROTECTION

INVERTER OVERCURRENT PROTECTION:

2. AC DISCONNECT MUST BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH

RACKING NOTE:

1. BOND AND GROUND RACKING AND MODULES IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION INSTRUCTIONS. MINIMUM ONE CONNECTION PER ARRAY

GROUNDING & GENERAL NOTES:

- 1. A SECOND FACILITY GROUNDING ELECTRODE IS NOT REQUIRED PER [NEC 690.47(C)(3)]
- 2. PV INVERTER IS UNGROUNDED, TRANSFORMER-LESS TYPE.
- 3. DC GEC AND AC EGC TO REMAIN UNSPLICED, OR SPLICED TO EXISTING ELECTRODE
- 4. ANY EXISTING WIRING INVOLVED WITH PV SYSTEM CONNECTION THAT IS FOUND TO BE INADEQUATE PER CODE SHALL BE CORRECTED PRIOR TO FINAL INSPECTION.
- 5. SOLADECK OR JUNCTION BOX QUANTITIES, AND PLACEMENT SUBJECT TO CHANGE IN THE FIELD SOLADECK OR JUNCTION BOX DEPICTED ON ELECTRICAL DIAGRAM REPRESENT WIRE TYPE TRANSITIONS.
- 6. AC DISCONNECT NOTED IN EQUIPMENT SCHEDULE OPTIONAL IF OTHER AC DISCONNECTING MEANS IS LOCATED WITHIN 10' OF SERVICE DISCONNECT
- 7. RACEWAYS AND CABLES EXPOSED TO SUNLIGHT ON ROOFTOPS SHOULD BE INSTALLED MORE THAN 7/8" ABOVE THE ROOF USING CONDUIT SUPPORTS.
- 8. TEMPERATURE RATINGS OF ALL CONDUCTORS, TERMINATIONS, BREAKERS, OR OTHER DEVICES ASSOCIATED WITH THE SOLAR PV SYSTEM SHALL BE RATED FOR AT LEAST 75 DEGREE C.
- 9. WIRE IS SIZED PER NEC 310.15(B)(16), 310.15(B)(2)(a) and NEC 310.15(B)(3)(a)
- 10. ALL ROOF CONDUIT WILL HAVE A HEIGHT OF 7/8"

DATE 9/6/2024
CREATED BY ART
SCALE NTS

ELECTRICAL CALC. AND NOTES

WARNING:PHOTOVOLTAIC **POWER SOURCE**

LABEL 1

AT DIRECT-CURRENT EXPOSED RACEWAYS, CABLE TRAYS, COVERS AND ENCLOSURES OF JUNCTION BOXES, AND OTHER WIRING METHODS; SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY ENCLOSURES. WALLS, PARTITIONS, CEILINGS, OR FLOORS. NEC 690.31(G)(3&4)

PHOTOVOLTAIC

LABEL 2 AT EACH PV DISCONNECTING MEANS NEC 690.13(B)

DC DISCONNECT

MAXIMUM VOLTAGE 600V AXIMUM CIRCUIT CURRENT 19.00A MAX RATED OUTPUT CURRENT OF THE CHARGE CONTROLLER OR DC-TO-DC CONVERTER

IF INSTALLED)

19A

LABEL 3 (FOR TESLA POWERWALL 3 WITH INTEGRATED INVERTER) AT DC PV SYSTEM DISCONNECTING **MEANS NRC 690.53**

PHOTOVOLTAIC

LABEL 4

AC DISCONNECT

LABEL 5 (FOR TESLA POWERWALL 3 WITH INTEGRATED INVERTER) AT AC DISCONNECTING MEANS NEC 690.54

PHOTOVOLTAIC AC DISCONNECT

RATED AC OUTPUT CURRENT: 48A NOMINAL OPERATING AC VOLTAGE: 240V

2 INVERTER X 48 AMP/INVERTER = 96,00AMP

AT AC DISCONNECT MEANS NEC 690.13(B)

> THE MAXIMUM OUTPUT CURRENT FROM THIS SYSTEM TOWARDS THE MAIN PANEL IS CONTROLLED ELECTRONICALLY, REFER TO THE MANUFACTURER'S INSTRUCTIONS FOR MORE INFORMATION.

CS CONTROLLED OUTPUT POWER SETTING: 11.000kWAC

PCS CONTROLLED CURRENT SETTING: 45.83A

LABEL 9

AT AC DISCONNECT NEC 690.56(C)(3)

RAPID SHUTDOWN SWITCH FOR SOLAR **PV SYSTEM**

⚠ WARNING

INVERTER OUTPUT CONNECTION

DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL 3

PLACED ADJACENT TO THE BACK-FED BREAKER FROM THE INVERTER IF TIE IN CONSISTS OF LOAD SIDE CONNECTION TO BUSBAR. NEC 705.12(B)(2)(3)(b)

WARNING: THREE POWER SOURCE

ECOND SOURCE IS PHOTOVOLTAIC SYSTEM IIRD SOURCE IS ENERGY STORAGE SYST

ENERGY STORAGE SYSTEM

NOMINAL ESS VOLTAGE: 240 VAC **OPERATING CURRENT: 48.00 AAC**

> LABEL FOR ESS BATTERY . OTY-2


PHOTOVOLTAIC POWER SOURCE

OPERATING AC VOLTAGE: 240 V MAXIMUM OPERATING AC OUTPUT **CURRENT: 96.00 AMPS**

LABEL FOR MAIN SERVICE PANEL COVER

CAUTION

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM MULTIPLE SOURCES OF POWER WITH SAFETY **DISCONNECTS AS SHOWN:**



20 BARN LOFT CT.FUQUAY-VARINA, NC 27526

DIRECTORY

PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM. (ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS OUTLINED WITHIN: NEC 690.56(B)&(C), [NEC 705.10])

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM

FOR PV SYSTEMS THAT SHUT DOWN THE ARRAY AND CONDUCTORS LEAVING THE ARRAY: SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT AWAY FROM SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATION OF ALL IDENTIFIED RAPID SHUTDOWN SWITCHES IF NOT AT THE SAME LOCATION. [NEC 690.56(C)(1)(A)]

CONTRACTOR INFORMATION

SOUTHERNENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH.

MOUNT SYSTEM & ENERGY

8.500 kWDC, 11.000 kWAC PV

27.000kWh ENERGY STORAGE

JAY BISSETT RESIDENCE

FUQUAY-VARINA, NC 27526

20 BARN LOFT CT.

SOUTHERN ENERGY

PHONE: +1 919 306 9537

STORAGE SYSTEM

PHOTOVOLTAIC ROOF

MANAGEMENT

NC, 27617

SYSTEM

DATE 9/6/2024 **CREATED BY ART SCALE** NTS

LABELS AND PLACARD

PV-8

AND REDUCE SHOCK HAZARD

> THIS IS THE COMBINED AMPERAGE OF **INVERTER AND BATTERY**

Q.TRON BLK M-G2+ SERIES



405-425Wp | 108 Cells 21.8% Maximum Module Efficiency

MODEL Q.TRON BLK M-G2+





High performance Qcells N-type solar cells

Q.ANTUM NEO Technology with optimized module layout boosts module efficiency up to 21.8%.



A reliable investment

Inclusive 25-year product warranty and 25-year linear performance warranty



Enduring high performance

Long-term yield security with Anti LeTID Technology, Anti PID Technology², Hot-Spot Protect.



Extreme weather rating

High-tech aluminium alloy frame, certified for high snow (5400 Pa) and wind loads (5400 Pa).



Innovative all-weather technology

Optimal yields, whatever the weather with excellent low-light and temperature behaviour.



The most thorough testing programme in the industry

Qcells is the first solar module manufacturer to pass the most comprehensive quality programme in the industry: The new "Quality Controlled PV" of the independent certification institute TÜV Rheinland.

The ideal solution for:



Rooftop arrays on residential buildings






Q.TRON BLK M-G2+ SERIES

■ Mechanical Specification

Format	67.8 in × 44.6 in × 1.18 in (including frame) (1722 mm × 1134 mm × 30 mm)
Weight	46.7 lbs (21.2 kg)
Front Cover	0.13 in (3.2 mm) thermally pre-stressed glass with anti-reflection technology
Back Cover	Composite film
Frame	Black anodised aluminium
Cell	6 × 18 monocrystalline Q.ANTUM NEO solar half cells
Junction box	2.09-3.98 in × 1.26-2.36 in× 0.59-0.71 in (53-101 mm × 32-60 mm × 15-18 mm), Protection class IP67, with bypass diodes
Cable	4 mm² Solar cable; (+) ≥68.9 in (1750mm), (-) ≥68.9 in (1750mm)
Connector	Stäubli MC4: IP68



36.50

10.10

36.77

10.15

31.26

37.04

10.21

31.46

■ Electrical Characteristics MINIMUM PERFORMANCE AT STANDARD TEST CONDITIONS, STC1 (POWER TOLERANCE +5 W / -0 W) Power at MPP 405 410 415 420 425 13.58 13.66 **Short Circuit Current** 13.33 13.49 Open Circuit Voltage V_{oc} 37.91 38.19 38.47 38.75 39.03 12.91 12.98 **Current at MPP** 12.69 12.76 12.83 I_{MPP} 32 54 3274 Voltage at MPP V_{MPP} 3193 3213 32 34 ≥21.3 ≥21.5 ≥21.8 ≥20.7 MINIMUM PERFORMANCE AT NORMAL OPERATING CONDITIONS, NMOT Power at MPP 309.9 321,2 Short Circuit Current 10.74 10.81 10.87 10.94 11.00

35.96

9.98

Qcells PERFORMANCE WARRANTY PERFORMANCE AT LOW IRRADIANCE At least 98.5% of nominal power during first year. Thereafter max. 0.33% degradation per year. At least 95.53% of nominal power up to 10 years. At least 90.58% of minal power up to 25 years. All data within measurement tolerances. Full warranties in erms of the Qcells sales organisation of your respective

 $^{1}\text{Measurement tolerances P_{MPP}\pm 3.8\%, I_{SC}$, V_{OC}\pm 5\% at STC: 1000 W/m^{2}, 25\pm 2^{\circ}\text{C}, AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT, spectrum AM 1.5 according to IEC 60904-3 · $^{2}800 W/m^{2}, NMOT,$

 V_{oc}

indard terms of guarantee for the 5 PV companies with the nest production capacity in 2021 (February 2021)

Current at MPP

10.04

TEMPERATURE COEFFICIENTS							
Temperature Coefficient of I _{sc}	α	[%/K]	+0.04	Temperature Coefficient of V _{oc}	β	[%/K]	-0.24
Temperature Coefficient of P _{MPP}	γ	[%/K]	-0.30	Nominal Module Operating Temperature	NMOT	[°F]	109±5.4 (43±3°C)

■ Properties for System Design

Maximum System Voltage	$V_{\rm sys}$	[V]	1000 (IEC)/1000 (UL)	PV module classification	Class II
Maximum Series Fuse Rating		[A DC]	20	Fire Rating based on ANSI/UL 61730	C / TYPE 2
Max. Design Load, Push/Pull ³		[lbs/ft²]	75 (3600 Pa)/75 (3600 Pa)	Permitted Module Temperature	−40°F up to +185°F
Max. Test Load, Push/Pull3		[lbs/ft²]	113 (5400 Pa)/113 (5400 Pa)	on Continuous Duty	(-40°C up to +85°C)
3 See Installation Manual					

■ Qualifications and Certificates

Quality Controlled PV -IEC 61215:2016; IEC 61730:2016 This data sheet complies with DIN EN 50380.







Qcells pursues minimizing paper output in consideration of the global environment. Note: Installation instructions must be followed. Contact our technical service for further information on approved installation of this product.

Hammha C CELLS America Inc. 400 Spectrum Center Drive, Suite 1400, Irvine, CA 92618, USA | TEL. +1 949 748 59 96 | EMAIL. hgc-inquiry@gcells.com | WEB www.qcells.com

ocells

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH. NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF **MOUNT SYSTEM & ENERGY** STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC PV **SYSTEM** 27.000kWh ENERGY STORAGE JAY BISSETT RESIDENCE 20 BARN LOFT CT,

FUQUAY-VARINA, NC 27526

DATE 9/6/2024 **CREATED BY ART** NTS SCALE

MODULE SPEC SHEET

 $^{^{1}}$ See data sheet on rear for further information. 2 APT test conditions according to IEC/TS 62804-1:2015, method A (–1500V, 96 h)

Powerwall 3

2023

Power Everything

Powerwall 3 is a fully integrated solar and battery system, designed to accelerate the transition to sustainable energy.

Customers can receive whole home backup, cost savings, and energy independence by producing and consuming their own energy while participating in grid services. Once installed, customers can manage their system using the Tesla App to customize system behavior to meet their energy goals.

Powerwall 3 achieves this by supporting up to 20 kW DC of solar and providing 11.5 kW AC of continuous power per unit. It has the ability to start heavy loads up to 150 A LRA, meaning a single unit can support the power needs of most homes. Powerwall 3 is designed for mass production, fast and efficient installations, easy system expansion, and simple connection to any electrical service.



Powerwall 3 Technical Specifications

System Technical Specifications

Model Number	1707000-xx-y	
Nominal Grid Voltage (Input & Output)	120/240 VAC	
Grid Type	Split phase	
Frequency	60 Hz	
Overcurrent Protection Device	Configurable up to 60 A	
Solar to Battery to Grid Round Trip Efficiency	89% 1.2	
Solar to Grid Efficiency	97% ³	
Supported Islanding Devices	Backup Gateway 2, Backup Switch	
Connectivity	Wi-Fi (2.4 and 5 GHz), Dual-port switched Ethernet, Cellular (LTE/4G 4)	
Hardware Interface	Dry contact relay, Rapid Shutdown (RSD) certified switch and 2-pin connector, RS-485 for meters	
AC Metering	Revenue Grade (+/- 0.5%)	
Protections	Integrated arc fault circuit interrupter (AFCI), Isolation Monitor Interrupter (IMI), PV Rapid Shutdown (RSD) using Tesla Mid-Circuit Interrupters	
Customer Interface	Tesla Mobile App	
Warranty	10 years	

Solar Technical Specifications

Maximum Solar STC Input	20 kW
Withstand Voltage	600 V DC
PV DC Input Voltage Range	60 – 550 V DC
PV DC MPPT Voltage Range	150 — 480 V DC
MPPTs	6
Maximum Current per MPPT (I _{mp})	13 A ⁵
Maximum Short Circuit Current per MPPT (I _{sc})	15 A ⁵

Battery Technical Specifications

Nominal Battery Energy	13.5 kWh AC ²	
Maximum Continuous Discharge Power	11.5 kW AC	
Maximum Continuous Charge Power	5 kW AC	
Output Power Factor Rating	0 - 1 (Grid Code configurable)	
Maximum Continuous Current	48 A	
Maximum Output Fault Current	10 kA	
Load Start Capability (1 s)	150 A LRA	
Power Scalability	Up to 4 Powerwall 3 units supported	
Power Scalability	Up to 4 Powerwall 3 units supported	

¹Typical solar shifting use case.

2023 Powerwall 3 Datasheet

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE 9/6/2024

CREATED BY ART

SCALE NTS

BATTERY &INVERTER SPEC SHEET

² Values provided for 25°C (77°F), at beginning of life. 3.3 kW charge/discharge power

³ Tested using CEC weighted efficiency methodology.

⁴Cellular connectivity subject to network service coverage and signal strength.

 $^{^{5}}$ Where the DC input current exceeds the MPPT rating, a jumper can be used to combine two MPPTs into a single input to intake DC current up to 26 A I_{MP} / 30 A I_{sc}.

Powerwall 3 Technical Specifications

Powerwall 3 Datasheet

Environmental Specifications

Operating Temperature	-20°C to 50°C (-4°F to 122°F) ⁶
Operating Humidity (RH)	Up to 100%, condensing
Storage Temperature	-20°C to 30°C (-4°F to 86°F), up to 95% RH, non- condensing, State of Energy (SOE): 25% initial
Maximum Elevation	3000 m (9843 ft)
Environment	Indoor and outdoor rated
Enclosure Rating	NEMA 3R
Ingress Rating	IPX7 (Battery & Power Electronics) IPX5 (Wiring Compartment)
Pollution Rating	PD3
Operating Noise @ 1 m	<50 db(A) typical <62 db(A) maximum
⁶ Performance may be de-rated at operating	ng temperatures above 40°C (104°F).


Compliance Information

Certifications	UL 1642, UL 1699B, UL 1741, UL 1741 SA, UL 1741 SB, UL 3741, UL 1973, UL 1998, UL 9540, IEEE 1547-2018, IEEE 1547.1, UN 38.3
Grid Connection	United States
Emissions	FCC Part 15 Class B
Environmental	RoHS Directive 2011/65/EU
Seismic	AC156, IEEE 693-2005 (high)
Fire Testing	Meets the unit level performance criteria of UL 9540A

Mechanical Specifications

2023

Dimensions	1099 x 609 x 193 mm (43.25 x 24 x 7.6 in)
Weight	130 kg (287 lb)
Mounting Options	Floor or wall mount



Solar Shutdown Device Technical Specifications

The Solar Shutdown Device is a Mid-Circuit Interrupter (MCI) and is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with Powerwall 3, solar array shutdown is initiated by any loss of AC power.

Electrical	Model	MCI-1	MCI-2
Specifications	Nominal Input DC Current Rating (I _{MP})	12 A	13 A
	Maximum Input Short Circuit Current (I _{sc})	19 A	17 A
	Maximum System Voltage (PVHCS)	600 V DC	1000 V DC 7
	⁷ Maximum System Voltage is limited by Powerwall t	to 600 V DC.	
RSD Module	Maximum Number of Devices per String	5	5
Performance	Control	Power Line Excitation	Power Line Excitatio
	Passive State	Normally Open	Normally Open
	Maximum Power Consumption	7 W	7 W
	Warranty	25 years	25 years
Environmental	Operating Temperature	-40°C to 50°C	-45°C to 70°C
Specifications		(-40°F to 122°F)	(-49°F to 158°F)
	Storage Temperature	-30°C to 70°C (-22°F to 158°F)	-30°C to 70°C (-22°F to 158°F)
	Enclosure Rating	NEMA 4X / IP65	NEMA 4X / IP65

Mechanical Specifications

Electrical Connections	MC4 Connector	MC4 Connector	
Housing	Plastic	Plastic	
Dimensions	125 x 150 x 22 mm (5 x 6 x 1 in)	173 x 45 x 22 mm (6.8 x 1.8 x 1 in)	
Weight	350 g (0.77 lb)	120 g (0.26 lb)	
Mounting Options	ZEP Home Run Clip M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw	Wire Clip	

Compliance Information

Certifications	UL 1741 PVRSE, UL 3741, PVRSA (Photovoltaic Rapid Shutdown Array)
RSD Initiation Method	External System Shutdown Switch or Powerwall 3 Enable Switch

UL 3741 PV Hazard Control (and PVRSA) Compatibility

The following categories of solar module meet the UL 3741 PVHCS listing when installed with Powerwall 3 and Solar Shutdown Devices.

Tesla Solar Roof	PV Hazard Control System: BIPV compliance document
Tesla or Hanwha (Q.Peak Duo BLK or BLK-G6+) Modules certified for use with ZEP racking	PV Hazard Control System: ZS PVHCS compliance document
Other module and racking combinations	PV Hazard Control System: Generic PV Array compliance document

2023 Powerwall 3 Datasheet

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

BATTERY &INVERTER SPEC SHEET

PV-10.1

Backup Gateway 2

Backup Gateway 2 controls connection to the grid when paired with Powerwall 3, automatically detecting outages and providing seamless transition to backup power. Backup Gateway 2 also provides energy metering for solar self-consumption, time-based control, and backup operation.

In this system configuration, Powerwall 3 acts as the Site Controller, with the Backup Gateway 2 Site Controller disabled.

Performance Specifications

Model Number	1232100-xx-y	Primary Connectivity	Ethernet, Wi-Fi
AC Voltage (Nominal)	120/240 V	Secondary Connectivity	Cellular (3G, LTE/4G) ⁹
Feed-in Type	Split phase	User Interface	Tesla App
Grid Frequency	60 Hz	Operating Modes	Support for solar self- consumption, time-based control, and backup
Current Rating	200 A	Backup Transition	Automatic disconnect for seamless backup
Maximum Supply Short Circuit Current	10 kA ⁸	Modularity	Supports up to 10 AC- coupled Powerwalls
Overcurrent Protection Device	100 - 200 A, Service entrance rated ⁸	Optional Internal Panelboard	200 A 6-space / 12 circuit Eaton BR circuit breakers
Overvoltage Category	Category IV	Warranty	10 years
AC Meter	Revenue accurate (+/- 0.2%)	⁹ The customer is expected to provide internet connectivity for Backup Gateway 2; cellular should no	

⁸ When protected by Class J fuses, Backup Gateway 2 is suitable for use in circuits capable of delivering not more than 22kA symmetrical amperes.

Environmental Specifications


Operating Temperature	-20°C to 50°C (-4°F to 122°F)
Operating Humidity (RH)	Up to 100%, condensing
Maximum Elevation	3000 m (9843 ft)
Environment	Indoor and outdoor rated
Enclosure Type	NEMA 3R

Compliance Information

Certifications	UL 67, UL 869A, UL 916, UL 1741 PCS, CSA 22.2 0.19, CSA 22.2 205
Emmissions	FCC Part 15, ICES 003

Mechanical Specifications

(26 x 16 x 6 in)
20.4 kg (45 lb)
Wall mount, Semi-flush mount



CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526


DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

BACKUP GATEWAY 2 SPEC SHEET

⁹ The customer is expected to provide internet connectivity for Backup Gateway 2; cellular should not be used as the primary mode of connectivity. Cellular connectivity subject to network operator service coverage and signal strength.


Powerwall 3 Example System Configurations

Powerwall 3 with Backup Switch



Powerwall 3 with Backup Gateway 2

Partial Home Backup



2023 Powerwall 3 Datasheet 7

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

BATTERY &INVERTER SPEC SHEET

PV-10.3

Tech Brief

QuickMount® HUG



IRONRIDGE

The Respect Your Roof Deserves

When integrating with a home, solar attachments must be dependable for the lifetime of the rooftop. Due to recent innovations, many asphalt shingles have bonded courses. A mount that protects without the need to pry shingles can really speed things up.

Halo UltraGrip®(HUG®) is here to respect the roof. Its Halo is a cast-aluminum barrier that encases the UltraGrip, our industrial-grade, foam-and-mastic seal. This allows HUG to accelerate the installation process and provide the utmost in waterproofing





Triple Rated & Certified to Respect the Roof UL 2703, 441 (27) TAS 100(A)-95

conforms and adheres to every nook

and cranny of composition shingles,

filling gaps and shingle step-downs

(up to 1/8" in height).



Rafter & Deck Mounting Options

Mount HUG® to the roof rafters, the roof deck, or both with our custom-engineered RD (rafter-or-deck) Structural Screw. The RD Structural Screw anchors HUG to the roof with an EPDM sealing washer, completing the stack of waterproofing barriers. See ackside for more installation information



Adaptive, Rafter-Friendly Installation









Still no luck? Install the rest. If more than 3 screws miss the rafter secure six screws to deck mount it.

Trusted Strength & Less Hassle



Structural capacities of HUG® were reviewed in many load directions, with racking rail running cross-slope or up-slope in relation to roof pitch.

For further details, see the HUG certification letters for attaching to rafters and decking.


IronRidge designed the HUG, in combination with the RD Structural Screw to streamline installs, which means the following:

- · No prying shingles
- · No roof nail interference
- · No pilot holes necessary
- · No sealant (in most cases)
- · No butyl shims needed

Attachment Loading

uplift and 368 (lbs)

of lateral load.



Structural Design


Parts are designed and certified for compliance with the International **Building Code &** ASCE/SEI-7.

Water Seal Ratings

HUG passed both the UL 441 Section 27 "Rain Test" and TAS 100(A)-95 "Wind Driven Rain Test" by Intertek.

UL 2703 System

Systems conform to UL 2703 mechanical and bonding requirements. See Flush Mount Manual for more info.



CONTRACTOR INFORMATION

SOUTHERNENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH.

MOUNT SYSTEM & ENERGY

8.500 kWDC, 11.000 kWAC PV

27.000kWh ENERGY STORAGE

JAY BISSETT RESIDENCE

FUQUAY-VARINA, NC 27526

20 BARN LOFT CT.

SOUTHERN ENERGY

PHONE: +1 919 306 9537

STORAGE SYSTEM

PHOTOVOLTAIC ROOF

MANAGEMENT

NC, 27617

SYSTEM

MOUNT SPEC SHEET


PV-11





© 2023 IronRidge, Inc. All rights reserved. Visit www.ir-patents.com for patent information. Version 1.03

// IRONRIDGE

QuickMount® Halo UltraGrip®







CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526


DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

MOUNT SPEC SHEET

PV-11.1



XR Rail® Family



Compatible with Flat & Pitched Roofs



compatible with FlashFoot® and other pitched roo



All XR Rails® are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing

Corrosion-Resistant Materials



XR Rail[®] Family

The XR Rail $^{\! (8)}$ Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail® to match.





- 10' spanning capabilityHeavy load capabilityClear & black anodized finish
- Internal splices available



XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications

- 12' spanning capabilityExtreme load capabilityClear anodized finish
- Internal splices available

Rail Selection

The table below was prepared in compliance with applicable engineering codes and standards.* Values are based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed certification letters.

Load		Rail Span					
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'	10'	12'
	90						
None	120						
None	140	XR10		XR100		XR1000	
	160						
	90						
20	120						
20	140						
	160						
30	90						
30	160						
40	90						
40	160						
80	160					·	
120	160			a aonoral rail canabilit			

Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved certification letters for actual design guidance



CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF **MOUNT SYSTEM & ENERGY** STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC PV **SYSTEM** 27.000kWh ENERGY STORAGE JAY BISSETT RESIDENCE 20 BARN LOFT CT, FUQUAY-VARINA, NC 27526

DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

RAIL SPEC SHEET

MODULE COMPATIBILITY Hanwha Q CELLS Modules with 32, 35, 40 mm frames aaYY-ZZ-xxx where "aa" can be Q, or B,; "YY" can be PLUS, PRO, PEAK, LINE PRO, LINE PLUS, PLUS DUO, PEAK DUO or Tron; and "ZZ" can be G3, G3.1, G4, G4.1, L-G2, L-G2.3, L-G3, L-G3.1, L-G3y, L-G4, L-G4.2, L-G4v, LG4, 2/TAA, BFR-G3, BLK-G3, BFR-G3, 1, BLK-G3, 1, BFR-G4, BFR-G4, 1, BFR, G4, 3, BLK-G4, 1, G4/SC, G4.1/SC, G4.1/TAA, G4.1/MAX, BFR G4.1/TAA, BFR G4.1/MAX, BLK G4.1/TAA, BLK G4.1/SC, EC-G4.4, G5, G5/SC, G5/TS, BLK-G5, BLK-G5/SC, BLK-G5/TS, L-G5, L-G5.1, L-G5.2, L-G5.2/H, L-G5.3, Hanwha Q CELLS G6, G6/SC, G6/TS, G6+/TS, G6+, BLK-G6, L-G6, L-G6.1, L-G6.2, L-G6.3, G7, BLK-G6+, BLK-G6+/AC, BLK-G6+/HL, BLK-G6+/SC, BLK-G6/TS, BLK-G6+/TS, BLK-G7, G7.2, G8, BLK-G8, G8+, BLK-G8+ L-G7, L-G7.1, L-G7.2, L-G7.3, L-G8, L-G8.1, L-G8.2, L-G8.3, L-G8.3/BFF, L-G8.3/BFG, L-G8.3/BGT, M-G2+, BLK M-G2+, ML-G9, BLK ML-G9, ML-G9+, BLK ML-G9+, BLK-G10, BLK-G10+, BLK G10+/AC, BLK-G10+/HL, ML-G10, BLK ML-G10, ML-G10+, BLK ML-G10+, ML-G10.a, BLK ML-G10.a, ML-G10.a+, BLK ML-G10.a+, BLK ML-G10 +/t, BLK ML-G10+/TS, XL-G9, XL-G9.2, XL-G9.3, XL-G9.3/BFG, XL-G10.2, XL-G10.3, XL-G10.3, XL-G10.4, TS, G10.c, XL-G10.d, XL-G10.d/BFG, XL-G10.3/BFG, XL-G11.2, XL-G11.3, XL-G11.3/BFG or XL-G11S.3/BFG Heliene modules with 35 and 40 mm frames YYZZxxxA Heliene Where "YY" can be 36, 60, 72, 96, 108, 120, 132, 144 or 156; "ZZ" can be HC, M, P, or MBLK; and "A" can be blank, HomePV, Bifacial, M10-SL, M10-SL-BLK, M10 Bifacial or M10 SL-Bifacial HT-SAAE modules with 35 and 40 mm frames HTyy-aaaZ-xxx HT-SAAE Where "yy" can be 60, 66, 72 or 78, "aaa" can be 18, 156 or 166, "Z" can be M, P, M-C, P-C, M(S), M(VS), M(V), P(V), M(V)-C, P(V)-C, or XHyperion modules with 30 and 35 mm frames Hyperion Solar HY-DHzzzA8-xxxB (Runergy) Where "zzz" can be 108 or 144; "A" can be N or P; and "B" can be blank or B Hyundai modules with 32, 33, 35 and 40 mm frames HiY-SxxxZZ Hyundai Where "Y" can be A, D or S; "S" can be M or S; and "ZZ" can be GI, HG, HI, KI, MI, MF, MG, PI, RI, RG, RG(BF), RG(BK), SG, TI, TG, YH(BK) or XG(BK) Itek Modules with 40 mm frames Itek IT-xxx-YY Where "YY" can be blank, HE, or SE, or SE72 JA Solar modules with 30, 35 and 40 mm frames JAyyzz-bbww-xxx/aa Where "yy" can be M, P, M6 or P6; "zz" can be blank, (K), (L), (R), (V), (BK), (FA), (TG), (FA)(R), (L)(BK), (L) JA Solar (TG), (R)(BK), (R)(TG), (V)(BK), (BK)(TG), or (L)(BK)(TG); "bb" can be 48, 54, 60, 66, 72 or 78; "ww" can be D09, D10, D20, D30, S01, S02, S03, S06, S09, S10, S12, S17, S20, S30 or S31; and "aa" can be BP, MB, MR, SI, SC, PR, 3BB, 4BB, 4BB/RE, 5BB Jinko modules with 35 and 40 mm frames JKMYxxx77-aa Where "Y" can either be blank or S; "ZZ" can be M, N, P, or PP; and "aa" can be blank, 54HL4-B, 60, Jinko 60B, 60H, 60L, 60BL, 60HL, 60HB, 60HBL, 6HBL-EP, 60-J4, 60B-J4, 60B-EP, 60(Plus), 60-V, 60-MX, 6RL3, 6RL3-B, 6TL3-B, 7RL3-V, 7RL3-TV, 72, 72B, 72-J4, 72B-J4, 72(Plus), 72-V, 72H-V, 72L-V, 72HL-V, 72HBL-V, 72HL4-V, 72HL4-BDV, 72HL4-TV, 72-MX, 72H-BDVP, 72HL-TV, or 72HL-V-MX3 KB Solar modules with 35 mm frames KB Solar KBS-xxx-Mono-YY Where "YY" can be blank or BF Kvocera Modules KÝxxxZZ-AA Where "Y" can be D or U; "ZZ" can be blank, GX, or SX; and "AA" can be LPU, LFU, UPU, LPS, LPB, LFB, Kyocera LFBS, LFB2, LPB2, 3AC, 3BC, 3FC, 4AC, 4BC, 4FC, 4UC, 5AC, 5BC, 5FC, 5UC, 6BC, 6FC, 8BC, 6MCA, or LA Solar modules with 35 mm frames LA Solar LSxxxYY

Where "YY" can be BF. BL. BLA. HC or ST

© 2023 IRONRIDGE, INC. VERSION 4.1

FLUSH MOUNT INSTALLATION MANUAL - 25

MODULE CO	MPATIBILITY ///
LG	LG modules with 35 and 40 mm frames LGxxxYaZ-bb Where "Y" can be A, E, M, N, Q, S; "a" can be A, 1, 2 or 3 "Z" can be C, K, T, or W; and "bb" can be A3, A5, A6, B3, B6, E6, E6.AW5, G3, G4, J5, K4, L5, N5, V5, V6
Longi	Longi modules with 30, 35 and 40 mm frames LRa-YYZZ-xxxM Where "a" can be 4, 5 or 6; "YY" can be blank, 54, 60, 66, or 72; and "ZZ" can be blank, BK, BP, HV, PB, PE PH, HBD, HIB, HIH, HPB, HPH, HIBD, HABB or HABD
Maxeon	Maxeon modules with 35, 40 and 46 mm frames SPR-AAAY-xxx-zzz Where "AAA" can be MAX, P or X; "Y" can be 3, 5, 6, 21 or 22; and "zzz" can be R, BLK, BLK-R, COM or UPP
Meyer Burger	Meyer Burger Modules with 35 mm frames Meyer Burger Black, White or Glass
Mission Solar (mSolar)	Mission Solar modules with 33, 35 and 40 mm frames YYYbb-xxxZZaa Where "YYY" can be MSE, TXI or TXS; "bb" can be blank, 6, 10 or 60A; "ZZ" can be blank, HT, MM, SE, SO SQ , SR, SX, TS, 108, 120 or 144; and "aa" can be blank, 0B, 2B, BB, BW, 1J, 4J, 4S, 5K, 5R, 5T, 60, 6J, 6S, 6W, 6Z, 8K, 8T, 9R, 9S or 9Z
Mitrex	Mitrex modules with 30 and 40 mm frames Mxxx-XYZ Where "X" can be A, B, I or L; "Y" can be 1 or 3; and "Z" can be F or H
Mitsubishi	Mitsubishi modules PV-MYYxxxZZ Where "YY" can be LE or JE; and "ZZ" can be either HD, HD2, or FB
Moltech	IM and XS series modules with 40 mm frames
Navitas	Navitas Modules with 35 mm frames NSMxxx-yyy Where "yyy" can be 120, 132 or 144
Next Energy Alliance	Next Energy Alliance modules with 35 and 40 mm frames yyNEA-xxxZZ where "yy" can be blank or US; "ZZ" can be M, MB or M-60
NE Solar	NE Solar modules with 30, 35 and 40 mm frames NESExxx-zzMHX-yy Where "zz" can be 54, 60 or 72; "X" can be blank or B; and "yy" can be M6 or M10
Neo Solar Power	Neo Solar Power modules with 35 mm frames D6YxxxZZaa Where "Y" can be M or P; "ZZ" can be B3A, B4A, E3A, E4A, H3A, H4A; and "aa" can be blank, (TF), ME or ME (TF)
Panasonic (HIT)	Panasonic modules with 35 and 40 mm frames VBHNxxxYYzzA Where "YY" can be either KA, RA, SA or ZA; "zz" can be either 01, 02, 03, 04, 06, 06B, 11, 11B, 15, 15B, 16 16B, 17, or 18; and "A" can be blank, E, G, or N
Panasonic (EverVolt)	Panasonic modules with 30 mm frames EVPVxxxA Where "A" can be blank or H, K, HK or PK
Peimar	Peimar modules with 40 mm frames SbxxxYzz Where "b" can be G, M or P; "Y" can be M or P; and "zz" can be blank, (BF) or (FB)
Philadelphia Solar	Philadelphia modules with 30, 35 and 40 mm frames PS-YzzAA-xxxW Where "Y" can be M or P; "zz" can be 60, 72, 108 or 144; "AA" can be blank, (BF), (HC) or (HCBF); and "W" can be blank or W

© 2023 IRONRIDGE, INC. VERSION 4.1

USH WOUNT INSTALLATION MANUAL - 26

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF MOUNT SYSTEM & ENERGY STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC **PV SYSTEM**27.000kWh **ENERGY STORAGE**JAY BISSETT RESIDENCE
20 BARN LOFT CT,
FUQUAY-VARINA, NC 27526

DATE	9/6/2024	
CREATED BY	ART	
SCALE	NTS	

INSTALLATION MANUAL




UFO® Family of Components

The UFO® family of components eliminates the need for separate grounding hardware by bonding solar modules directly to IronRidge® XR Rails®. All system types that feature the UFO® family-Flush Mount®, Tilt Mount® and Ground Mount®—are fully listed to the UL 2703 standard.

Simplified Grounding for Every Application

UFO® hardware forms secure electrical bonds with both the module and the rail, resulting in many parallel grounding paths throughout the system. This leads to safer and more reliable installations.

Only for installation and use with IronRidge products in accord with written instructions. See IronRidge.com/UFO



BOSS® Splice


Bonded Structural Splice connects rails with built-in bonding teeth. No tools or



Grounding Lug A single Grounding Lug connects an entire row of PV modules to the

Bonded Attachments The bonding bolt attaches and bonds the L-foot® to the rail. It is installed with the same socket as the rest of the

System Diagram



Approved Enphase microinverters can provide equipment grounding of IronRidge systems, eliminating the need for grounding lugs and field installed equipment ground conductors (EGC). A minimum of two microinverters mounted to the same rail and connected to the same Engage cable is required. Refer to installation manuals for additional details.

UL Certification

The IronRidge® Flush Mount®, Tilt Mount®, and Ground Mount Systems have been listed to UL 2703 by Intertek Group plc.

UL 2703 is the standard for evaluating solar mounting systems. It ensures these devices will maintain strong electrical and mechanical connections over an extended period of time in extreme outdoor environments.

Go to IronRidge.com/UFO

Cross-System Compatibility				
Feature	Flush Mount	Ground Mount		
XR Rails®	✓	~		
UFO®/Stopper	✓	✓		
BOSS® Splice	✓	· ·		
Grounding Lugs	1 per Row 1 per Row		1 per Array	
Microinverters & Power Optimizers	Compatible with most MLPE manufacturers. Refer to system installation manual.			
Fire Rating	Class A	Class A	N/A	
Modules	Tested or Evaluated with over 400 Framed Modules Refer to installation manuals for a detailed list.			

CONTRACTOR INFORMATION



SOUTHERN ENERGY MANAGEMENT

5908 TRIANGLE DRIVE, RALEIGH, NC, 27617

PHONE: +1 919 306 9537

PHOTOVOLTAIC ROOF **MOUNT SYSTEM & ENERGY** STORAGE SYSTEM

8.500 kWDC, 11.000 kWAC PV **SYSTEM** 27.000kWh ENERGY STORAGE JAY BISSETT RESIDENCE 20 BARN LOFT CT, FUQUAY-VARINA, NC 27526

DATE	9/6/2024
CREATED BY	ART
SCALE	NTS

INSTALLATION MANUAL