



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/12/2024

**SUBJECT: ERES2407-0055
ELECTRICAL RESIDENTIAL**

To: Sarah Davis

Here are the results of all Inspections located at **20 BARN LOFT CT:**

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 9/5/2024
Completed Date/Time: 9/5/2024
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes: See attachment pictures

Number 6 installed coming out of combiner panel, plan states #4 wire. Outside fuses should be 120amp there are 125 installed

Inspection Type: FINAL**
Scheduled Date/Time: 9/12/2024
Completed Date/Time: 9/12/2024
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes: Engineer revised plans to match install.