



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/29/2024

SUBJECT: ERES2408-0007
ELECTRICAL RESIDENTIAL

To: Ruiz Ruby Ortiz

Here are the results of all Inspections located at **281 BOONE TRAIL DR:**

Inspection Type: RE-CONNECT**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 8/7/2024
Completed Date/Time: 8/7/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: lock box code is 0000
Open wires thought out the house

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 8/28/2024
Completed Date/Time: 8/28/2024
Inspector: Ricardo D Honrada
Result: FAIL W/ PENALTY
Remarks:
Notes: Need cover plate in gfci receptacle in bathroom left and receptacle dryer.

