

Date: 10/02/2024
Permit #: 1010349
Project Name: Kelly Davis
Address: 817 COKESBURY PARK LN FUQUAY VARINA, NC 27526

To whom it may concern,

PV2, PV3, and PV5 updated to show that we are interconnecting through a supply side breaker in the exterior MSP.

Revision Tags and Clouds have been added where changes have been made.

Please reach out to me directly if you have any questions.

Michael Honey
Quality Control Technician
Michael.Honey@blueravensolar.com
Quality.control@blueravensolar.com
385-273-1105

Trenton Rock
Quality Control Manager
Trenton.Rock@blueravensolar.com
Quality.control@blueravensolar.com
385-273-1105