



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

12/16/2024

SUBJECT: ERES2409-0046
ELECTRICAL RESIDENTIAL

To: ALVAREZ EFRAIN MARTINEZ JT W/ROS

Here are the results of all Inspections located at **5876 US 421 N:**

Inspection Type: RE-CONNECT**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 9/20/2024
Completed Date/Time: 9/20/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: Wasn't able to locate. Address need to be at the rd where we need to come in and direction

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 9/23/2024
Completed Date/Time: 9/23/2024
Inspector: Ricardo D Honrada
Result: DISAPPROVED
Remarks:
Notes: All existing electrical works are hazardous. Wiring in electrical boxes are exposed, Romex cables wires not protected to EMT pipes. Need to hire Licensed Electrical Contractor.

Inspection Type: RE-CONNECT**
Scheduled Date/Time: 12/16/2024
Completed Date/Time: 12/16/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks:
Notes: Can not turn farm build into habitable space No ground rods exposed Sheetrock hung in half of the barn No power approved for this building

