



11/26/2024

Freedom Forever LLC  
 43445 Buisness Park Dr., Suite 110  
 Temecula, CA 92590

Job Number: 495493  
 Project Name: Raymond Patterson  
 Project Address: 118 Oleander Lane , Sanford, NC

**Design Criteria:**

Applicable Code = ASCE 7-16  
 Design Wind Speed = 130 mph (3 Second Gust)  
 Exposure Category = B  
 Ground Snow Load = 15 psf 11.55 psf  
 Module Type = SILFAB SOLAR: SIL-430QD  
 Module Quantity = 18

To whom is may concern,

The above mentioned residential rooftop solar project has been designed to the specifications shown above. The team at Freedom Forever LLC has visited the site to observe the roof and its framing as well as gather other required information for the project. During this observation they did not see any signs of damage or distress to the roof structure which would preclude solar from being installed. Based on that review and the information provided, the calculations on the following pages were completed to determine the adequacy of the roof framing as well as the allowable attachment spacing for the PV panels. The calculations show that the roof can support the proposed PV system without structural modifications.

	1	2	3	4	5	6	7	8	9	10
Mounting Plane										
Roof Type	Comp Shingle	Comp Shingle								
Framing Type	Truss	Truss								
Framing Size	2x4 @ 24	2x4 @ 24								
Upgrade Size	NA	NA								
Attachment Type	Ecofasten Rocklt Smart Slide	Ecofasten Rocklt Smart Slide								
Lag Count	2	2								
Embedment Depth	2	2								

Sincerely,

Taqi Khawaja, PE  
 Freedom Forever LLC





**Down Force**

Mounting Plane	1		2		3		4		5	
Module Location	EM	IM	EM	IM	EM	IM	EM	IM	EM	IM
D+S (psf)	8.37	8.37	8.37	8.37						
D+06W (psf)	12.44	9.16	12.44	9.16						

Mounting Plane	6		7		8		9		10	
Module Location	EM	IM	EM	IM	EM	IM	EM	IM	EM	IM
D+S (psf)										
D+06W (psf)										

**Lateral Parallel to Roof**

Mounting Plane	1	2	3	4	5
D+S (psf)	4.83	4.83			

Mounting Plane	6	7	8	9	10
D+S (psf)					

**Framing Check**

Lumber Species: DF

PV Load = 3 psf

Mounting Plane	1	2	3	4	5
Framing Type	Truss	Truss			
Framing Size	2x4	2x4			
Framing Spacing (in)	24	24			
Span (ft)	8	8			
Moment (lb-ft)	246	246			
Shear (lbs)	123	123			
Upgrade Size	NA	NA			

Mounting Plane	6	7	8	9	10
Framing Type					
Framing Size					
Framing Spacing (in)					
Span (ft)					
Moment (lb-ft)					
Shear (lbs)					
Upgrade Size					



**Array Attachment Spacing**

Module = SILFAB SOLAR: SIL-430QD

Mounting Plane	1	2	3	4	5
Roofing Material	Comp Shingle	Comp Shingle			
Attachment Type	Ecofasten Rockit Smart Slide	Ecofasten Rockit Smart Slide			
Lag Count Per Attachment	2	2			
Min Lag Embedment (in)	2	2			
Landscape	72	72			
Portrait	48	48			

Mounting Plane	6	7	8	9	10
Roofing Material					
Attachment Type					
Lag Count Per Attachment					
Min Lag Embedment (in)					
Landscape					
Portrait					