



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

11/4/2024

**SUBJECT: ERES2410-0036
ELECTRICAL RESIDENTIAL**

To: J M POPE ELECTRIC

Here are the results of all Inspections located at **501 TURLINGTON RD:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: RECONNECT W/O FINAL
Scheduled Date/Time: 10/18/2024
Completed Date/Time: 10/18/2024
Inspector: Brad Sutton
Result: APPROVED
Remarks:
Notes: Pull meter at 8-8:30. If you could go about between 1-2 pm.

Inspection Type: GAS PIPING
Scheduled Date/Time: 10/25/2024
Completed Date/Time: 10/25/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 10/31/2024
Completed Date/Time: 10/31/2024
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Bond neutral and ground in transfer switch. Need to bury/protect ground wire in flower bed. Circuit in panel needs ground and neutral separated.