
SCOPE OF WORK	GOVERNING CODES		SITE PLAN		
INSTALL A ROOF-MOUNTED PV SYSTEM: • (17) CERTAINTEED CT370HC11-06 MODULES • (6) TESLA SOLAR SHUTDOWN DEVICES • (01) TESLA POWERWALL 3 (11.5KW, 13.5KWH) • (01) TESLA GATEWAY 3 • (01) UNFUSED AC DISCONNECT	ALL WORK TO COMPLY WITH: • 2018 INTERNATIONAL BUILDING CODE • 2018 INTERNATIONAL RESIDENTIAL COI • 2017 NATIONAL ELECTRICAL CODE • 2013 INTERNATIONAL FIRE CODE	DE			
TOTAL PV SIZE: 6.29KW DC, 11.500KW CEC AC					
TABLE OF CONTENTS	GENERAL NOTES				
PV-1 COVER SHEET PV-2 ROOF PLAN & MODULES PV-2A ROOF, MODULES & ATTACHMENT DETAILS PV-3A STRINGING PAGE PV-4 THREE-LINE DIAGRAM PV-4A DESIGN TABLES PV-5 LABELS & PLACARD PV-6+ EQUIPMENT DATASHEETS PV-12 MAPPING SHEET	ALL WORK SHALL CONFORM TO APPLICE ELECTRICAL CODE AND ANY LOCALLY AT DRAWINGS ARE DIAGRAMMATIC, SITE OF PREVAIL. IF NO SCALE IS GIVEN, DRAWING SCALE. ALL DIMENSIONS SHALL BE VERIFUS CONTRACTOR IN THE FIELD UPON COMMICONSTRUCTION. ALL CONDUIT AND WIRE RUNS ARE DIATO FIELD CONDITIONS ROUTING OF RACE FINALIZED BY THE CONTRACTOR. IF THE RUNS ARE DIFFERENT THAN AS SHOWN, SHALL NOTIFY THE DESIGN TEAM TO VAIL ALL EQUIPMENT SHALL BE LISTED AND	COPTED ORDINANCES. CONDITIONS SHALL GS ARE NOT TO FIED BY THE IENCEMENT OF GRAMMATIC, SUBJECT EWAYS SHALL BE DISTANCES FOR WIRE THE CONTRACTOR LIDATE THE WIRE SIZE. LABELED BY A	BARNSLEY		
AERIAL PHOTO	RECOGNIZED TESTING LABORATORY AN LISTING AND MANUFACTURER'S REQUIR • ALL EQUIPMENT SHALL BE INSTALLED I WITH REQUIRED ACCESS AND WORKING PER CEC ARTICLE 110. • ALL NEW MAIN SERVICE PANELS AND SAPPROPRIATE FIELD IDENTIFICATION PE • ALL EQUIPMENT WILL BE INSTALLED WITH TO PHYSICAL DAMAGE PER CEC110.27(B)	EMENTS. N ACCORDANCE CLEARANCES UBPANELS WILL HAVE R CEC 408.4. HERE IT IS NOT EXPOSED			
	SITE DETAILS				7
	ASHRAE MIN TEMP ASHRAE 2% HIGH TEMP BUILDING OCCUPANCY TYPE OF CONSTRUCTION SPRINKLERS SYSTEM PER NFPA 13D # OF STORIES WIND SPEED (ASCE 7-10) WIND EXPOSURE RISK CATEGORY GROUND SNOW LOAD	-11.1°C 37.1°C R-3 V-B NO 1 115 MPH B II			
	SQUARE FOOTAGE UTILITY PROVIDER	1316 SQ FT DUKE ENERGY	0 16' 32'		
RENU ENERGY SOLUTIONS, LLC	NC GC #76615 PREPARED BY: NC ELE #U.34519 RENU ENERGY SOLUTIONS	SCALE: 1/32" = 1'-0"	AHJ: HARNETT COUNTY	DONNA ALTIERI	PV-1
801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217	JACKSON HAGER	SHEET SIZE: 11" x 17"	APN: 0662-35-4608.000	46 BARNSLEY ROAD	COVER
704-525-6767 RENUENERGYSOLUTIONS.COM		TEMPLATE V2.0	DATE: 10/16/2024	ANGIER, NC 27501	SHEET

PV ROOF COVERAGE									
(E) PV AREA [SQ FT]	(N) PV AREA [SQ FT]	TOTAL PV AREA [SQ FT]	TOTAL ROOF AREA [SQ FT]	PERCENTAGE COVERED BY PV					
0	343.75	343.75	2332	15%					


LEGEND

○□ -ROOF OBSTRUCTION









٠	A
1	R

RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519 PREPARED BY:
RENU ENERGY SOLUTIONS
JACKSON HAGER
S

SCALE: 1/8" = 1'-0"	AHJ:	HARNETT COUNTY
SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
ΓΕΜΡLΑΤΕ V2.0	DATE:	10/16/2024

DONNA ALTIERI


46 BARNSLEY ROAD ANGIER, NC 27501 PV-2
ROOF PLAN
& MODULES

LEGEND

--- - RAFTER OR TRUSS


- ROOF ATTACHMENT

	ROOF DESCRIPTION								
ROOF	ROOF TILT	AZIMUTH	ROOF MATERIAL	TRUSS SIZE	TRUSS SPACING	MAX SPAN			
#1	27°	203°	HIGH-DEF	2" X 4"	24" O.C.	90"			



STRUCTURAL INFORMA	ATION	
NUMBER OF MODULES	17	
MODULE WEIGHT	45.19	LBS
TOTAL MODULE (ARRAY) WEIGHT	768.23	LBS
NUMBER OF ATTACHMENT POINT	26	
MOUNTING SYSTEM WEIGHT (PER MODULE)	0.55	LBS
MOUNTING SYSTEM WEIGHT	14.30	LBS
TOTAL SYSTEM WEIGHT	782.53	LBS
WEIGHT AT EACH ATTACHMENT POINT	29.55	LBS
MODULE AREA (69.13"X40.90")	19.63	SQFT
TOTAL ARRAY AREA	343.75	SQFT
DISTRIBUTED LOAD	2.28	PER SQFT

ROOF ATTACHMENT DETAIL







801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519 PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

 SCALE: 1/8" = 1'-0"
 AHJ: HARNETT COUNTY

 SHEET SIZE: 11" x 17"
 APN: 0662-35-4608.000


 TEMPLATE V2.0
 DATE: 10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501

MODULE : CERTAINTEED CT370HC11-06 (370W)

> PV-2A ROOF, MODULES & ATTACHMENT DETAILS







D	8
	`

RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519 PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER


SCALE: 1/4" = 1'-0"	AHJ:	HARNETT COUNTY
SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-3A STRINGING PAGE

ID	TYPICA	L CONDUCTOR	NEUTRAL	EGC	CONDUIT	CURRENT-CARRYING CONDUCTORS IN CONDUIT	OCPD	TEMP. CORR. FACTOR	CONDUIT FILL FACTOR	CONT. CURRENT	MAX CURRENT (125%)	BASE AMP.	DERATED AMP.	TERM TEMP. RATING	AMP. @ TERMINAL
1	1	4/0 AWG XHHW, ALUMINUM	4/0 AWG XHHW, ALUMINUM	N/A	2" DIA	2	200A	0.96 (35°C)	1	-	200.0A	205A	196.8A	75°C	180A
2	1	4/0 AWG SER, ALUMINUM	4/0 AWG SER, ALUMINUM	2/0 SER, ALUMINUM	2" DIA	2	N/A	0.96 (35°C)	1	-	200.0A	205A	196.8A	75°C	180A
3	1	6 AWG THHN, COPPER	6 AWG THHN, COPPER	10 AWG THHN, COPPER	1" DIA	2	60A	0.96 (35°C)	1	48.0A	60.0A	75A	72.0A	75°C	65A
4	1	6 AWG THHN, COPPER	6 AWG THHN, COPPER	10 AWG THHN, COPPER	1" DIA	2	N/A	0.96 (35°C)	1	48.0A	60.0A	75A	72.0A	75°C	65A
5	1	10 AWG THHN, COPPER	N/A	10 AWG THHN, COPPER	1" DIA	4	N/A	0.96 (35°C)	0.8	10.87A	13.59A	40A	30.72A	75°C	35A
6	1	10 AWG PV WIRE, COPPER	N/A	6 AWG BARE, COPPER	FREE AIR	2	N/A	0.96 (35°C)	1	10.87A	13.59A	55A	52.8A	75°C	50A

NEW SOLAR PROJECT 6.29 KW DC, 11.50 KW AC





RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519

PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

3	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-4

THREE-LINE DIAGRAM

MODULES										
REF.	QTY.	MAKE AND MODEL	PMAX	PTC	ISC	IMP	VOC	VMP	TEMP. COFF. OF VOC	FUSE RATING
(N) PV MODULES	17	CERTAINTEED CT370HC11-06	370W	337.80W	11.81A	10.87A	40.80V	34.06V	-0.29%/°C	25A

DISCONNECTS					
REF.	QTY.	MAKE AND MODEL	FUSES	RATED CURRENT	MAX RATED VOLATGE
(N) DISCONNECT	1	EATON OR EQUIVALENT	N/A	60A	240 V

			INVERTE	RS						
REF.	QTY.	MAKE AND MODEL	AC VOLTAGE	GROUND	OCPD RATING	RATED POWER	MAX OUTPUT CURRENT	MAX INPUT CURRENT	MAX INPUT VOLTAGE	CEC WEIGHTED EFFICIENCY
(N) INVERTERS	1	TESLA POWERWALL 3 (240V)	240V	FLOATING	60A	11500W	48.0A	90A	550V	99.0%

DESIGN TEMPERATURES		
ASHRAE EXTREME LOW	-11.1°C (12.0°F), SOURCE: HARNETT COUNTY (35.38°;-78.73°)	
ASHRAE 2% HIGH	37.1°C (98.8°F), SOURCE: HARNETT COUNTY (35.38°;-78.73°)	

INVERTER OUTPUT CALCULATIONS & 705.12 COMPLIANCE

		# OF				MINIMUM
INVERTER		INVERTERS /	CONTINUOUS	125% SAFETY	TOTAL	BREAKER
OUTPUT CIRCUIT	INVERTER OR ESS	ESS	OUTPUT	FACTOR	BACKFEED	SIZE
#1	PW3	1	48.00A	125%	60.00A	60A
TOTAL 60.00A				60A		

MODULE CT 370 # OF MODULES LARGEST STRING 9 ASHRAE MIN TEMP [°C] -11.1 VOC [V] 40.80 TEMP COEF VOC [%/°C] -0.29 TEMP ADJ VOC [V] 45.07 VOLTAGE OF LARGEST STRING [V] 405.63

VOC CALCULATION PER NEC 690.7(A)(1)

ELECTRICAL NOTES (APPLICABILITY BASED ON SCOPE OF WORK)

AS-BUILT CHANGES TO THE ABOVE WIRING ARE PERMISSIBLE AS LONG AS SUBSTITUTIONS ARE CODE COMPLIANT. FOR EXAMPLE, APPROPRIATELY SIZED NM-B MAY BE USED FOR MICROINVERTER OUTPUT CIRCUITS IF INSTALLED IN ACCORDANCE WITH NEC ARTICLE 334, OR MC CABLE MAY BE USED FOR DC SOLAR STRINGS IF INSTALLED IN ACCORDANCE WITH NEC ARTICLE 330.

ALL OUTDOOR EQUIPMENT SHALL BE RAINTIGHT & HOLD A MINIMUM NEMA 3R RATING, INCLUDING ALL ROOF MOUNTED TRANSITION BOXES AND SWITCHES. CONDUCTORS EXPOSED TO WET CONDITIONS SHALL BE SUITABLE FOR USE IN WET CONDITIONS PER NEC 310.10(C).

ALL TERMINAL TEMPERATURES OF EQUIPMENT WILL BE VERIFIED TO BE RATED FOR 75° C, OR THE WIRE WILL NEED TO BE RESIZED USING THE 60° C TERMINAL TEMPERATURE RATINGS FOR 100A OR LESS.

ALL NM-B SHALL BE INSTALLED AND PROTECTED PER NEC 334, AND ALL SER CABLE SHALL BE INSTALLED AND PROTECTED PER NEC 338.

ALL ROOFTOP RACEWAYS AND CABLES EXPOSED TO DIRECT SUNLIGHT WILL BE INSTALLED >7/8" ABOVE THE ROOF.

ALL EQUIPMENT SHALL BE PROPERLY GROUNDED AND BONDED IN ACCORDANCE WITH NEC ARTICLE 250. A SUPPLEMENTAL GROUND ROD WILL BE DRIVEN IN ACCORDANCE WITH NEC 250.53(A)(3) IF THE EXISTING GROUND ROD HAS A RESISTANCE TO EARTH THAT IS GREATER THAN 25 OHMS.

IF ANY EXISTING LOAD CONDUCTORS ARE EXTENDED BY MORE THAN 6', AFCI PROTECTION WILL BE PROVIDED PER NEC 210.12(D).

PER NEC 690.47(A) PV SYSTEMS THAT ARE NOT SOLIDLY GROUNDED, THE EQUIPMENT GROUNDING CONDUCTOR FOR THE OUTPUT OF THE PV SYSTEMS SHALL BE PERMITTED TO BE THE CONNECTION TO GROUND FOR GROUND-FAULT PROTECTION AND EQUIPMENT GROUNDING OF THE PV ARRAY.

THE ESS CIRCUIT BREAKER SHALL BE SECURED IN PLACE BY AN ADDITIONAL FASTENER PER NEC 408.36(D).

NO SINGLE BACK-UP LOAD WILL BE LARGER THAN THE MAXIMUM CONTINUOUS OUTPUT OF THE ESS PER NEC 710.15(A).

P

RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519

PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

NS	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-4A

DESIGN

TABLES

TURN RAPID SHUTDOWN SWICH TO THE "OFF" POSITION TO SHUTDOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY

WARNING

ELECTRIC SHOCK HAZARD

TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL 2

AT EACH DISCONNECTING MEANS FOR PHOTOVOLTAIC EQUIPMENT [NEC 690.15]

ALL SIGNAGE MUST BE PERMANENTLY ATTACHED AND BE WEATHER RESISTANT/SUNLIGHT RESISTANT AND CANNOT BE HAND-WRITTEN PER NEC 110.21(B)

LABEL 1

AT RAPID SHUTDOWN SYSTEM [NEC 690.56(C)(1)(A)].

WARNING ELECTRIC SHOCK HAZARD

THE DC CONDUCTORS OF THIS PHOTOVOLTAIC SYSTEM ARE UNGROUNDED AND MAY BE ENERGIZED

LABEL 3

AT POINT OF INTERCONNECTION; LABEL, SUCH AS LABEL 4 OR LABEL 5 MUST IDENTIFY PHOTOVOLTAIC SYSTEM [NEC 705.12(B)(4)]

PHOTOVOLTAIC SYSTEM **⚠** DC DISCONNECT **⚠**

MAX SYSTEM VOLTAGE: SHORT CIRCUIT CURRENT: 45 A

LABEL 4

AT EACH DC DISCONNECTING MEANS [NEC 690.53]

PHOTOVOLTAIC SYSTEM AC DISCONNECT /

RATED AC OUTPUT CURRENT: 48.00AAC NOMINAL OPERATING VOLTAGE: 240/480 V AC

LABEL 5

AT EACH DISCONNECTING MEANS FOR PHOTOVOLTAIC EQUIPMENT [NEC 690.15]

WARNING

DUAL POWER SUPPLY SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

LABEL 6

AT POINT OF INTERCONNECTION; LABEL, SUCH AS LABEL 4 OR LABEL 5 MUST IDENTIFY PHOTOVOLTAIC SYSTEM [NEC 705.12(B)(4)]

∕ WARNING

INVERTER OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL 7

AT POINT OF INTERCONNECTION; LABEL, SUCH AS LABEL 4 OR LABEL 5 MUST IDENTIFY PHOTOVOLTAIC SYSTEM [NEC 705.12(B)(4)]

WARNING: PHOTOVOLTAIC **POWER SOURCE**

LABEL 8

AT EXPOSED RACEWAYS, CABLE TRAYS, AND OTHER WIRING METHODS: SPACED AT MAXIMUM 10 FT SECTION OR WHERE SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS. [NEC 690.31(G)] LETTERS AT LEAST 3/8 INCH; WHITE ON RED BACKGROUND; REFLECTIVE [IFC 605.11.1.1]

RAPID SHUTDOWN PV ARRAY

LABEL 8

AT RAPID SHUTDOWN SWITCH INEC 690.56(C)1. LETTERS AT LEAST 3/8 INCH; WHITE ON RED [NEC 690.56(B)] BACKGROUND; REFLECTIVE [IFC 605.11.1.1]

DIRECTORY

PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM DISCONNECTING MEANS IF NOT IN THE SAME LOCATION WHERE THE PV SYSTEMS ARE REMOTELY LOCATED FROM EACH OTHER. A DIRECTORY IN ACCORDANCE WITH 705.10 SHALL BE PROVIDED AT EACH PV SYSTEM DISCONNECTING MEANS. PV SYSTEM EQUIPMENT AND DISCONNECTING MEANS SHALL NOT BE INSTALLED IN BATHROOMS [NEC 690.4(D),(E)]

LABELING NOTES

- 1.1 LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRICAL CODE, INTERNATIONAL FIRE CODE 605.11, OSHA STANDARD 1910.145, ANSI Z535
- 1.2 MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- 1.3 LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED.
- 1.4 LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8" AND PERMANENTLY AFFIXED.
- 1.5 ALERTING WORDS TO BE COLOR CODED. "DANGER" WILL HAVE RED BACKGROUND: "WARNING" WILL HAVE ORANGE BACKGROUND; "CAUTION" WILL HAVE YELLOW BACKGROUND. [ANSI Z535]

RENU ENERGY SOLUTIONS, LLC 801 PRESSLEY ROAD, SUITE 100

CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM

NC GC #76615 NC ELE #U.34519

PREPARED BY: **RENU ENERGY SOLUTIONS** JACKSON HAGER

SCALE: NTS SHEET SIZE: 11" x 17" **TEMPLATE V2.0**


HARNETT COUNTY AHJ: APN: 0662-35-4608.000


DATE: 10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501

PV-5 LABELS & **PLACARDS**





Mechanical Characteristics Laminate Glass: 3.2 high transmission,

Laminate
Glass: 3.2 high transmission, tempered, anti-reflective
Encapsulant: POE
Backsheet: Weatherproof film
(Black)


Frame
Anodized aluminum (Black)

Junction Box
IP68

Output Cables
4 mm² (12AWG) PV Wire, Length 1.2m (47.2")


Connectors
Polarized MC compatible
Weight
20.5 kg (45.19 lbs)





Operating Conditions

Nominal Operating Cell Temp.	44+/-2° C
Operating Temperature	-40 to 85° C
Maximum System Voltage	1,500V
Fire Performance	Class C / Type 1
Maximum Wind Load	210mph wind speed ₍₅₄₀₀ F
Maximum Snow Load	112 lbs/ft² (5400 Pa)





CertainTeed

CEILINGS • DECKING • FENCE • GYPSUM • INSULATION • RAILING • ROOFING • SIDING • TRIM

20 Moores Road Malvern, PA 19355 | Professional: 800-233-8990 | Consumer: 800-782-8777 | certainteed.com

© 2/20 CertainTeed, Printed in the USA, Code No. PV-01-020



RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519

PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

SAINT-GOBAIN

NS	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-6
EQUIPMENT
DATASHEET

Powerwall 3 Technical Specifications

System Technical Specifications

Model Number	1707000-xx-y
Nominal Grid Voltage (Input & Output)	120/240 VAC
Grid Type	Split phase
Frequency	60 Hz
Overcurrent Protection Device	Configurable up to 60 A
Solar to Battery to Home/Grid Efficiency	89% 1,2
Solar to Home/Grid Efficiency	97.5% ³
Supported Islanding Devices	Backup Gateway 2, Backup Switch
Connectivity	Wi-Fi (2.4 and 5 GHz), Dual-port switched Ethernet, Cellular (LTE/4 G^4)
Hardware Interface	Dry contact relay, Rapid Shutdown (RSD) certified switch and 2-pin connector, RS-485 for meters
AC Metering	Revenue Grade (+/- 0.5%)
Protections	Integrated arc fault circuit interrupter (AFCI), Isolation Monitor Interrupter (IMI), PV Rapid Shutdown (RSD) using Tesla Mid-Circuit Interrupters
Customer Interface	Tesla Mobile App
Warranty	10 years

Solar Technical Specifications

Maximum Solar STC Input	20 kW
Withstand Voltage	600 V DC
PV DC Input Voltage Range	60 – 550 V DC
PV DC MPPT Voltage Range	150 — 480 V DC
MPPTs	6
Maximum Current per MPPT (I _{mp})	13 A ⁵
Maximum Short Circuit Current per MPPT (I _{sc})	15 A ⁵

Battery Technical Specifications

Nominal Battery Energy	13.5 kWh AC ²
Maximum Continuous Discharge Power	11.5 kW AC
Maximum Continuous Charge Power	5 kW AC
Output Power Factor Rating	0 - 1 (Grid Code configurable)
Maximum Continuous Current	48 A
Maximum Output Fault Current	10 kA
Load Start Capability (1 s)	185 A LRA
Power Scalability	Up to 4 Powerwall 3 units supported

¹Typical solar shifting use case.

Powerwall 3 Technical Specifications

Environmental Specifications

Operating Temperature	-20°C to 50°C (-4°F to 122°F) ⁶
Operating Humidity (RH)	Up to 100%, condensing
Storage Temperature	-20°C to 30°C (-4°F to 86°F), up to 95% RH, non- condensing, State of Energy (SOE): 25% initial
Maximum Elevation	3000 m (9843 ft)
Environment	Indoor and outdoor rated
Enclosure Rating	NEMA 3R
Ingress Rating	IPX7 (Battery & Power Electronics) IPX5 (Wiring Compartment)
Pollution Rating	PD3
Operating Noise @ 1 m	<50 db(A) typical <62 db(A) maximum


⁶ Performance may be de-rated at operating temperatures above 40°C (104°F).

Compliance Information

Certifications	UL 1642, UL 1699B, UL 1741, UL 1741 SA, UL 1741 SB, UL 3741, UL 1973, UL 1998, UL 9540, IEEE 1547-2018, IEEE 1547.1, UN 38.3
Grid Connection	United States
Emissions	FCC Part 15 Class B
Environmental	RoHS Directive 2011/65/EU
Seismic	AC156, IEEE 693-2005 (high)
Fire Testing	Meets the unit level performance criteria of UL 9540A

Mechanical Specifications

Dimensions	1099 x 609 x 193 mm (43.25 x 24 x 7.6 in)	
Weight	130 kg (287 lb)	
Mounting Options	Floor or wall mount	



2024 Powerwall 3 Datasheet 2 2024 Powerwall 3 Datasheet

s	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501

² Values provided for 25°C (77°F), at beginning of life. 3.3 kW charge/discharge power.

³ Tested using CEC weighted efficiency methodology.

⁴Cellular connectivity subject to network service coverage and signal strength.

 $^{^{5}}$ Where the DC input current exceeds the MPPT rating, a jumper can be used to combine two MPPTs into a single input to intake DC current up to 26 A I $_{\rm MP}$ / 30 A I $_{\rm sc}$.

SOLAR SHUTDOWN DEVICE

The Tesia Solar Shutdown Device is a Mid-Circuit Interrupter (MCI) and is part of the PV system rapid shutdown (RSD) function in accordance with Article 690 of the applicable NEC. When paired with the Tesia Solar Inverter, solar array shutdown is initiated by any loss of AC power.



ELECTRICAL SPECIFICATIONS

Model Number	MCH1:	
Nominal Input DC Current Rating (I _{NP})	12 A	
Maximum Input Short Circuit Current (I _{sc})	15 A	
Maximum System Voltage	600 V DC	

RSD MODULE PERFORMANCE

Maximum Number of Devices per String	5
Control	Power Line Excitation
Passive State	Normally open
Maximum Power Consumption	7 W
Warranty	25 years

COMPLIANCE INFORMATION


Certifications	UL 1741 PVRSE, UL 3741, PVRSA (Photovoltaic Rapid Shutdown Array)	
RSD Initiation Method	PV System AC Breaker or Switch	
Compatible Equipment	See Compatibility Table below	

ENVIRONMENTAL SPECIFICATIONS

Ambient Temperature	-40°C to 50°C (-40°F to 122°F)	
Storage Temperature	-30°C to 70°C (-22°F to 158°F)	
Enclosure Rating	NEMA 4 / IPGS	

MECHANICAL SPECIFICATIONS

Electrical Connections	MC4 Connector	
Housing	Plastic	
Dimensions	125 mm x 150 mm x 22 mm (5 in x 6 in x 1 in)	
Weight	350 g (0.77 lb)	
Mounting Options	ZEP Hame Run Clip	
	M4 Screw (#10) M8 Bolt (5/16") Nail / Wood screw	



UL 3741 PV HAZARD CONTROL (AND PVRSA) COMPATIBILITY

Testa Solar Roof and Testa/Zep ZS Arrays using the following modules are certified to UL 3741 and UL 1741 PVPSA when installed with the Testa Solar Inverter and Solar Shutdown Devices. See the Testa Solar Inverter Installation Manual for detailed instructions and for guidance on installing Testa Solar Inverter and Solar Shutdown Devices with other modules.

Brand	Model	Required Solar Shutdown Devices	
Tesla	Solar Roof V3	1 Solar Shutdown Device per 10 modules	
Tesla	Testa TxxxS (where xxx = 405 to 450 W, increments of 5)	1 Solar Shutdown Device per 3 modules*	
Testa	Tesla TxxxH (where xxx = 395 to 415 W, increments of 5)	1 Solar Shutdown Device per 3 modules	
Hanwha	Q PEAK DUO BLK-G5	1 Solar Shutdown Device per 3 modules	
Hanwha	Q:PEAK DUO BLK-G6+	1 Solar Shutdown Device per 3 modules	

Exception: Testa solar modules installed in locations where the max Voc for three modules at low design temperatures exceeds 165 V shall be limited to two modules between Solar Shutdown Devices.

T E S L A NA 2022-05-06 TESLA COM/ENERGY

R


RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM NC GC #76615 NC ELE #U.34519 PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

3	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-8
EQUIPMENT
DATASHEET



	RENU ENERGY SOLUTIONS, LLC
R	801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 RENUENERGYSOLUTIONS.COM

NC	; GC	#76	615	
VС	ELE	#U.	3451	9

PREPARED BY:
RENU ENERGY SOLUTIONS
JACKSON HAGER

s	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501



Ultra Rail

AnchorFoot™



Deck Mounting, re-imagined.



Flexible direct to deck mounting & rafter mounting options



Compatible with proprietary DeckAnchor™ fasteners cutting the number of deck fasteners in half, from 4 to 2

Single Tool installation & snap-in features as with all SnapNrack products

Pre-installed butyl for easy

worry-free sealing

Start Installing AnchorFoot™ Today!



are the latest innovation designed to reduce the number of roof fasteners when mounting direct to deck and provide maximum flexibility to mount anywhere on the roof. Engineered with butyl, now installers do not have to add sealant to the bottom of the mount, simplifying the installation process and further protecting the roof.

AnchorFoot™

- Pre-installed butyl for easy peel & stick installation allows for no disruption to composition shingles
- Industry-leading .200" thick butyl allows installation over shingles without cutting pieces
- Flexible direct to deck mounting options with (2)
 DeckAnchors or (4) #14 wood screws
- Flexible rafter mounting options with (1) 5/16" lag or (2) #14 wood screws
- Ships pre-assembled with Ultra Rail Mounting Clamp for easy rail attachment
- Rated for UL2703 Bonding & Grounding with TAS 100A Wind Driven Rain Testing for waterproof certification





DeckAnchor

- Proprietary fastening technology to reduce the number of screws for direct to deck mounting
- Familiar ½" hex head to maintain the SnapNrack tradition of a single tool install
- Wide threads securely grip the wood deck and significantly reduces the potential for over-tightening
- TAS 100A Wind Driven Rain Testing + ASTM D1761 Screw Capacities

Quality. Performance. Innovation.

SnapNrack solutions are focused on simplifying the installation experience through intuitive products and the best wire management in the industry.

SnapNrack[®]

877-732-286

www.snapnrack.com

contact@snapnrack.com

23 by SnapNrack® Solar Mounting Solutions. All rights reserved



RENU ENERGY SOLUTIONS, LLC

NC GC #76615 NC ELE #U.34519

PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

SCALE: NTS AHJ: HARNETT COUNTY

SHEET SIZE: 11" x 17" APN: 0662-35-4608.000

TEMPLATE V2.0 DATE: 10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501 PV-10 EQUIPMENT DATASHEET

Gateway 3

Tesla Gateway 3 controls connection to the grid in a Powerwall system, automatically detecting outages and providing seamless transition to backup power. It provides energy monitoring that is used by Powerwall for solar self-consumption, time-based control, and backup operation.

Performance	
Specifications	

Model Number	1841000-x1-y	AC Meter	+/- 0.5%
Nominal Grid Voltage	120/240 V AC	Communication	CAN
Grid Configuration	Split phase	User Interface	Tesla App
Grid Frequency	60 Hz	Backup Transition	Automatic disconnect for seamless backup
Continuous Current Rating	200 A	Overcurrent	100–200 A
Maximum Supply Short Circuit Current	22 kA with Square D or Eaton main breaker 25 kA with Eaton main	Protection Device	Service entrance rated Eaton CSR, BWH, or BW, or Square D QOM breakers
	breaker ¹	Internal Panelboard	200 A
IEC Protective Class	Class I		8-space/16 circuit breakers Eaton BR, Siemens QP, or
Overvoltage Category	Category IV	_	Square D HOM breakers rated to 10–125A
Only Eaton CSR or BWH ma	ain breakers are 25 kA rated	Warranty	10 years

Environmental Specifications


–20°C to 50°C (–4°F to 122°F)		
Up to 100%, condensing		
3000 m (9843 ft)		
Indoor and outdoor rated		
NEMA 3R		

Compliance Information

Certifications	UL 67, UL 869A, UL 916, UL 1741 PCS, CSA 22.2 107.1, CSA 22.2 29
Emmissions	FCC Part 15, Class B, ICES 003

Mechanical **Specifications**

Dimensions	660 x 411 x 149 mm (26 x 16 x 6 in)	
Weight	16.3 kg (36 lb)	
Mounting options	Wall mount	



Gateway 3 Datasheet

RENU ENERGY SOLUTIONS, LLC

801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM


NC GC #76615 NC ELE #U.34519 PREPARED BY: RENU ENERGY SOLUTIONS JACKSON HAGER

s	SCALE: NTS	AHJ:	HARNETT COUNTY
	SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
	TEMPLATE V2.0	DATE:	10/16/2024

DONNA ALTIERI

46 BARNSLEY ROAD ANGIER, NC 27501

PV-11 EQUIPMENT DATASHEET



801 PRESSLEY ROAD, SUITE 100 CHARLOTTE, NORTH CAROLINA, 28217 704-525-6767 | RENUENERGYSOLUTIONS.COM

SCALE: NTS	AHJ:	HARNETT COUNTY
SHEET SIZE: 11" x 17"	APN:	0662-35-4608.000
TEMPLATE V2.0	DATE:	10/16/2024

ANGIER, NC 27501

MAPPING SHEET