



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

1/14/2025

SUBJECT: ERES2410-0060
ELECTRICAL RESIDENTIAL

To: POWERMASTER ELECTRIC INC.

Here are the results of all Inspections located at **187 GWENDOLYN WAY:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: RECONNECT W/O FINAL
Scheduled Date/Time: 11/14/2024
Completed Date/Time: 11/14/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 11/20/2024
Completed Date/Time: 11/20/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/19/2024 10:21 AM Valerie Galtieri

Contact Name: Valerie Galtieri
Site Address: 187 GWENDOLYN WAY
Phone: 9195574477
e-Mail: admin@powermasterelectric.com

Need gas piping installed and inspected before final

Inspection Type: GAS PIPING
Scheduled Date/Time: 11/21/2024
Completed Date/Time: 11/21/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/20/2024 2:49 PM Valerie Galtieri

Contact Name: Valerie Galtieri
Site Address: 187 GWENDOLYN WAY
Phone: 9195574477
e-Mail: admin@powermasterelectric.com

No gas piping installed

Inspection Type: FINAL**
Scheduled Date/Time: 11/21/2024
Completed Date/Time: 11/21/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/20/2024 2:49 PM Valerie Galtieri

Contact Name: Valerie Galtieri
Site Address: 187 GWENDOLYN WAY
Phone: 9195574477
e-Mail: admin@powermasterelectric.com

No gas piping installed





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: GAS PIPING

Scheduled Date/Time: 12/17/2024

Completed Date/Time: 12/17/2024

Inspector: Scott Guy

Result: FAIL W/ PENALTY

Remarks:

Notes: (Third gas inspection) gas line installed, put in service without inspection.

Inspection Type: GAS PIPING

Scheduled Date/Time: 1/8/2025

Completed Date/Time: 1/8/2025

Inspector: Justin Ryan McLeod

Result: DISAPPROVED

Remarks:

Notes: Gas piping is already connected. If gas company tested this please attach there test form to permit. If not unhook and put on test