

To Whom It May Concern

11/14/2024



Summary:

The inspector left the following notes during the previous inspection:

“Dc voltage lines must be ran in conduit romex is not approved.”

Please note that all our conductors in the attic and through our conduit are AC circuit (voltage) conductors. Blue Raven Solar installations virtually always use microinverters installed directly to each solar panel, and as such, the current traveling through our equipment is all AC. Romex should be appropriate for this use.

Please review the site plan, line diagram, and spec sheets located within our plan set for further details.

If you would like to discuss the matter further, or if there are other issues you wish to discuss, please feel free to contact us either by phone or by email.

Thank you.

Tanner Schulze
Quality Control Lead
Tanner.Schulze@blueravensolar.com
Inspections@blueravensolar.com
QualityControl@blueravensolar.com
385-273-1105

Homeowner: Koami Akligo
Address: 135 Van Winkle St Lillington, NC 27546
Permit #: ERES2410-0065
Project ID: 1052346