



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

1/3/2025

SUBJECT: ERES2410-0074
ELECTRICAL RESIDENTIAL

To: Red Top Electric

Here are the results of all Inspections located at **488 HALL RD:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/23/2024
Completed Date/Time: 12/23/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 12/31/2024
Completed Date/Time: 12/31/2024
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Ground rods not 6 foot minimum apart. Missing intersystem bonding connector. Doors locked, unable to inspect interior. House cannot have any unsafe electrical.

