



Dixie-Denning Supply Co.



705 South Wall Street

Benson, NC 27504

Ph. 919-894-3824

Fax 919-894-2871

TOP: Request for Inspection

Date: 11/6/2024

Harnett County Inspections

We have run a pressure test at **628 Tilghman Rd Coats, NC**
The pressure was held @ 50 psi for 15 mins.

Dixie Denning supplied carbon monoxide detector .
Customer already had a carbon monoxide detector X .

Sincerely,

Mike Denning
License # 21095

Permit # ERES2410-0076