



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

11/4/2024

SUBJECT: ERES2410-0078
ELECTRICAL RESIDENTIAL

To:

Here are the results of all Inspections located at **2138 HAYES RD:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 11/1/2024
Completed Date/Time: 11/1/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes:

If its for the underground forth doublets for the gate. It needs to 18 inches in the ground.plus need to see where it is tied in at.