

## Permit Inspections Harnett County

## Permit Number: ERES2502-0011

Description: Install 26 roof mounted solar panels.

| Applied: 2/5/2025 | Approved: 5/12/2025       | Site Address: 15 PAPER BIRCH WAY             |  |
|-------------------|---------------------------|--|--|
| Issued: 5/20/2025 | Finaled: <b>5/30/2025</b> | City, State Zip Code: FUQUAY-VARINA, NC 2752 |  |
| Status: FINALED   |                           | Applicant: Country Cable, Inc.               |  |
| Parent Permit:    |                           | Owner: CIOLEK MARK                           |  |
| Parent Project:   |                           | Contractor: Country Cable, Inc.              |  |

## Details:

| LIST OF INSPECTIONS   |                |                |          |                       |             |                            |  |
|---|----------------|----------------|----------|-----------------------|-------------|----------------------------|--|
| SEQ<br>ID   | SCHEDULED DATE | COMPLETED DATE | ТҮРЕ     | INSPECTOR             | RESULT      | REMARKS                    |  |
|   |                |                | ROUGH IN | Justin Ryan<br>McLeod |             |                            |  |
| Notes:  |                |                |          |                       |             |                            |  |
|   | 5/23/2025      | 5/23/2025      | FINAL**  | Justin Ryan<br>McLeod | DISAPPROVED | eTRAKiT Inspection Request |  |
| Please call Stacy with any questions 919-930-7403. Post Install Letter and Pictures have been uploaded<br>Contact Name: Country Cable, Inc.<br>Site Address: 15 PAPER BIRCH WAY<br>Phone: 3366392602<br>e-Mail: stacy@carolinaconnections.com<br>Plan that was approved at permitting on 5/12/25 shows conductors for number 3 and 4 circuits to be #6 gauge but #8 was installed. The original plan<br>that was rejected on 2/10/25 at permitting showed it as #8 gauge. I advised homeowner that she would not have to be home for the reinspection<br>because items needing addressed are outside. |                |                |          |                       |             |                            |  |
|   | 5/30/2025      | 5/30/2025      | FINAL**  | Daniel L Floyd        | APPROVED    | eTRAKiT Inspection Request |  |
| Notes:<br>5/29/2025 2:31 PM Country Cable, Inc.<br>Contact Name: Country Cable, Inc.<br>Site Address: 15 PAPER BIRCH WAY<br>Phone: 3366392602<br>e-Mail: stacy@carolinaconnections.com  |                |                |          |                       |             |                            |  |

TRAKIT