

June 11, 2025

Subject:Katie Hall Solar Panel Installation300 W C St Erwin NC 28339

Contractor Name:Phillips Energy SystemsContractor Address:7901 Allen Black Rd Mint Hill NC 28227

To Whom It May Concern,

This letter is submitted on behalf of my client, EnergyScape Renewables.

I am a North Carolina registered Professional Engineer. A field inspection of the installation has been performed by a person under my direct supervisory control. I hereby affirm the following:

- 1. The PV equipment's structural installation has been designed and inspected,
- 2. The equipment will not create a negative impact on the building's structural design, including any additional loads imposed (dead, snow, wind), and
- 3. The installation is in compliance with the North Carolina Residential Code.

#### **Limitations and Disclaimers**

Electrical design is excluded from this analysis. Structural design and analysis of the adequacy of solar panels, racks, mounts, rails, and other components is performed by each component's respective manufacturer. This letter and the opinions expressed herein are rendered solely for the benefit of the permitting authority (city or county building department) and my client's office and may not be utilized or relied on by any other party.

Sincerely,

Trevor Jones, P.E.





February 25, 2025

Phillips Energy Systems Contractor Address: 7901 Allen Black Rd, Mint Hill, NC 28227

Subject: Proposed Solar Panel Installation Katie Hall Residence, 300 W C St, Erwin, NC DC System Size: 4.860 kW PV Letters Job #004-19433

To Whom it May Concern,

We have reviewed information, provided by our client, related to the proposed solar panel installation at the above-referenced address. The purpose of the review was to determine if the existing roof is structurally adequate for the proposed installation. Based on our review and analysis of the given information, and in accordance with governing building codes, I certify that the capacity of the structural roof framing that directly supports the additional gravity loading due to the solar panel supports and modules had been reviewed and determined to meet or exceed the requirements in accordance with the Design Criteria.

#### **Design Parameter Summary**

Governing Building Code: 2018 North Carolina Residential Code Risk Category: II Wind Exposure: C Design Wind Speed: 120 mph Ground Snow Load: 15 psf

#### **Roof Information**

Roof Structure: 2x6 Rafters @ 16" O.C. Roofing Material: Asphalt Shingles (1 layer) Roof Slope: 25 degrees

#### **Roof Connection Details**

Framing Mount Wood Screws: (2) #14 Self-Drilling Screw with a minimum penetration depth of 1.75" into rafter only, at 64" O.C. max

Decking Mount Wood Screws: (6) #14 Self-Drilling Screw with a minimum penetration depth of 0.25", at 64" O.C. max *Note: Required installation of 75% / 25% between Framing and Decking Mounts.* 

#### Engineering Analysis

The proposed installation - including weight of panels, racking, mounts, and inverters where applicable - will be approximately 3 psf. In the areas where panels are installed, roof live loads will not be present. The reduction of roof live load is adequate to fully or partially compensate for the addition of the panel installation. Because the member forces in the area of the solar panels are not increased by more than 5%, and so per provisions in the adopted building codes, the structure need not be altered for gravity loading.

The proposed installation will be 6" max. above the roof surface (flush mounted) and parallel to the roof surface. Therefore, any increase in wind loading on the building structure from the solar panel installation is expected to be negligible. Wind is the governing lateral load case. Because the increase in lateral loading is not increased by more than 10%, per provisions in the adopted building codes, the structure need not be altered for lateral loading.

Wind uplift on the panels has been calculated in accordance with the relevant provisions of ASCE 7-10. This loading has been used to verify the adequacy of the connection specified above. Connection locations should be in accordance with design drawings.

IronRidge XR10 rails will support the modules and will fasten to the roof structure with IronRidge QuickMount Halo Ultragrip along the rail.

#### **Conclusion**

The roof structure need not be altered for either gravity loading (including snow) or lateral loading (including wind). Therefore, the existing structure is permitted to remain unaltered. Connections to the roof must be made per the "Roof Connection Details" section above. Copies of all relevant calculations are enclosed.

#### Limitations and Disclaimers

The opinion expressed in this letter is made in reliance on the following assumptions: the existing structure is in good condition; the existing structure is free from defects in design or workmanship; and the existing structure was code-compliant at the time of its design and construction. These assumptions have not been independently verified, and we have relied on representations made by our client with respect to the foregoing. The undersigned has not inspected the structure for defects, although we have reviewed the information provided by our client, including pictures where applicable.

Electrical design is excluded from this analysis. Waterproofing is the sole responsibility of the installer and is also excluded from this analysis. Solar panels must be installed per manufacturer specifications. Structural design and analysis of the adequacy of solar panels, racks, mounts, and other components is performed by each component's respective manufacturer; the undersigned makes no statement of opinion regarding such components. This letter and the opinions expressed herein are rendered solely for the benefit of the permitting authority (city or county building department) and your office, and may not be utilized or relied on by any other party.

If you have any questions or concerns, please contact us at (208)-994-1680, or by email at Projects@pvletters.com.

Sincerely,

N forg

Trevor A. Jones, P.E 2/25/2025





#### **Standard Loading Comparison**

This calculation justifies the additional solar load by comparing existing to proposed gravity loads in the location of the solar panels.

	Without Solar	With Solar	
Dead Load			
Asphalt Shingles	3	3	psf
1/4" Plywood	1	1	psf
Framing	2	2	psf
Insulation			psf
1/2" Gypsum Ceiling			psf
M,E, & Misc			psf
Solar Panel	0	3	psf
Total Dead Load	6	9	psf
Snow Load			
Ground Snow Load, $\mathrm{P}_{\mathrm{g}}$	15		psf
Exposure Factor, C <sub>e</sub>	1.0	0	
Thermal Factor, C <sub>t</sub>	1.1	l	
Importance Factor, I <sub>s</sub>	1		
Flat Roof Snow Load	12	·	ASCE 7 Eqn. 7.3-1 or jurisdiction min.
Slope	25		degrees
Unobstructed Slippery Surface?	No	No	
Slope Factor, C <sub>s</sub>	1.00	1.00	
Sloped Roof Snow Load	11.6	11.6	psf
Live Load			
Roof Live Load	20	0	psf
Load Combination			
D + Lr	26.0	9.0	psf
D + S	17.6	20.6	psf
Max. Load	26.0	20.6	psf
% of original		79.04%	
Result:	Because the total fe	orces are decrea	ased, per the relevant code

Because the total forces are decreased, per the relevant code provisions stated in the body of the letter, the existing roof structure is permitted to remain unaltered.



#### Wood Screw Calculation (per ASCE 7-10)

This calculation justifies the connection of the solar panels to existing roof members, by showing the connection capacity is equal to or greater than the uplift force demands.

#### **Connection Demand**

Spacing perpendicular to rail, in Roof Angle, degrees Roof Layout Wind Speed, mph Exposure Coefficient,  $K_z$ Topographic Factor,  $K_{zt}$ Directionality Factor,  $K_d$ Elevation Factor,  $K_e$ Velocity Pressure  $q_z$ , psf

Zones:
Spacing parallel to rail, in
GC <sub>p</sub> (max)(Figure 29.4-7)
Exposed Panels? ( $\gamma_E = 1.5$ ) (Fig. 29.4-7)
Effective Wind Area on each con., ft <sup>2</sup>
Pressure Equalization Factor, $\gamma_a$ (Figure 29.4-8)
Uplift Force, psf (Equation 29.4-7)
Max. Uplift Force / Connection (0.6 WL), lbs
Solar Dead Load (0.6 DL). Lbs
Max. Uplift Force (0.6 WL - 0.6 DL), lbs

#### **Connection Capacity**

Attachment FTG
Attachment location
Fastener Type
Fastener Diameter, in
Embedment Length, in
Lumber Species & Grade
Nominal Withdrawal Capacity W, lbs
# of Screws
Load Duration Factor $C_d$
Screw Adj. Withdrawal Cap. W', lbs
Attachment FTG Strength with Cd, lbs
Assumed attachment distribution
Max applied load, lbs
Max allowable load, lbs

34	
25	
Hip	
120	
0.85	(Table 26.10-1)
1.00	(Table 26.8.1)
0.85	(Table 26.6-1)
1.00	(Table 26.9-1)
26.5	(Table26.10-1)

<u>1</u>	<u>2</u>	<u>3</u>
64	64	64
0.90	2.20	2.60
No	No	No
15.1	15.1	15.1
0.73	0.73	0.73
17.4	42.5	50.2
157.1	384.1	453.9
27.1	27.1	27.1
130.0	357.0	426.8

IronRidge QuickMount Halo Ultragrip

-		
Framing	Decking	
Wood Screw	Wood Screw	
0.242	0.242	
1.75	0.25	
SPF #2 (As	ssumed)	
213	30.4	
2	6	
1.6	1.6	
681	292	
1606	374	
75%	25%	
427		
584		

#### **Compare Adjusted Withdrawal Capacity to ASD Factored Demand**

Zones:	<u>1</u>	<u>2</u>	<u>3</u>
	O.K.	O.K.	O.K

# PHOTOVOLTAIC ROOF MOUNT SYSTEM

#### 12 MODULES-ROOF MOUNTED - 4.860 kW DC, 5.700 kW AC

#### 300 W C ST, ERWIN, NC 28339

PROJECT DATA	GENERAL NOTES	VIC
PROJECT 300 W C ST, ADDRESS: ERWIN, NC 28339 OWNER: KATIE HALL DESIGNER: ESR SCOPE: 4.860 kW DC ROOF MOUNT SOLAR PV SYSTEM WITH 12 JA SOLAR: JAM54S31-405/MR 405W PV MODULES WITH	<ol> <li>ALL COMPONENTS ARE UL LISTED AND CEC CERTIFIED, WHERE WARRANTED.</li> <li>THE SOLAR PV SYSTEM WILL BE INSTALLED IN ACCORDANCE WITH ARTICLE 690 OF THE NEC 2017.</li> <li>THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION.</li> <li>ALL CONDUCTORS OF A CIRCUIT, INCLUDING THE EGC, MUST BE INSTALLED IN THE SAME RACEWAY, OR CABLE, OR OTHERWISE RUN WITH THE PV ARRAY CIRCUIT CONDUCTORS WHEN THEY LEAVE THE VICINITY OF THE PV ARRAY.</li> <li>WHERE METALLIC CONDUIT CONTAINING DC CONDUCTORS IS USED INSIDE THE BUILDING, IT SHALL BE IDENTIFIED AS "CAUTION: SOLAR CIRCUIT" EVERY 10FT.</li> <li>HEIGHT OF THE AC DISCONNECT SHALL NOT EXCEED 6'-7" PER NEC CODE 240.24.</li> </ol>	421 300 W C S 28339, Ur
12 SOLAREDGE: S440 POWER OPTIMIZERS AND 01 SOLAREDGE: SE5700H-US (240V/5700W) INVERTER 01 10 kWh SOLAREDGE ENERGY BANK AUTHORITIES HAVING JURISDICTION: BUILDING: HARNETT COUNTY ZONING: HARNETT COUNTY UTILITY: DUKE ENERGY PROGRESS	<ol> <li>A GROUNDING ELECTRODE SYSTEM IN ACCORDANCE WITH CEC 690.47 AND 250.50 THROUGH 60 AND 250-166 SHALL BE PROVIDED. PER NEC GROUNDING ELECTRODE SYSTEM OF EXISTING BUILDING MAY BE USED AND BONDED TO THE SERVICE ENTRANCE. IF EXISTING SYSTEM IS INACCESSIBLE OR INADEQUATE A SUPPLEMENTAL GROUNDING ELECTRODE WILL BE USED AT THE INVERTER LOCATION CONSISTING OF A UL LISTED 8 FT. GROUND ROD WITH ACORN CLAMP. GROUNDING ELECTRODE CONDUCTORS SHALL BE NO LESS THAN #8 AWG AND NO LARGER THAN #6 AWG COPPER AND BONDED TO THE EXISTING GROUNDING ELECTRODE TO PROVIDE FOR A COMPLETE SYSTEM.</li> <li>PHOTOVOLTAIC MODULES ARE TO BE CONSIDERED NON-COMBUSTIBLE.</li> <li>PHOTOVOLTAIC INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING. MECHANICAL, OR BUILDING ROOF VENTS.</li> <li>ALL WIRING MUST BE PROPERLY SUPPORTED BY DEVICES OR MECHANICAL MEANS DESIGNED AND LISTED FOR SUCH USE.</li> </ol>	HOL
SHEET INDEXPV-1COVER SHEETPV-2SITE PLANPV-3ROOF PLAN & MODULESPV-4ELECTRICAL PLANPV-5STRUCTURAL DETAILPV-6ELECTRICAL LINE DIAGRAMPV-7WIRING CALCULATIONSPV-8LABELSPV-9+EQUIPMENT SPECIFICATIONS	<ul> <li>WIRING MUST BE PERMANENTLY AND COMPLETELY HELD OFF THE ROOF SURFACE.</li> <li>11. ALL SINAGE TO BE PLACED IN ACCORDANCE WITH THE LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SINAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.</li> <li>12. INVERTER(S) USED IN UNGROUNDED SYSTEM SHALL BE UL 1741 LISTED.</li> <li>13. THE INSTALLATION OF EQUIPMENT AND ALL ASSOCIATED WIRING AND INTERCONNECTION SHALL BE PERFORMED ONLY BY QUALIFIED PERSONS [NEC 690.4(C)]</li> <li>14. ALL OUTDOOR EQUIPMENT SHALL BE NEMA 3R RATED (OR BETTER), INCLUDING ALL ROOF MOUNTED TRANSITION BOXES AND SWITCHES.</li> <li>15. ALL EQUIPMENT SHALL BE PROPERLY GROUNDED AND BONDED IN ACCORDANCE WITH NEC ARTICLE 250.</li> <li>16. SYSTEM GROUNDING SHALL BE IN ACCORDANCE WITH NEC 690.41.</li> <li>17. PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION IN ACCORDANCE WITH NEC 690.12</li> </ul>	
SIGNATURE	<ol> <li>DISCONNECTING MEANS SHALL BE LOCATED IN A VISIBLE, READILY ACCESSIBLE LOCATION WITHIN THE PV SYSTEM EQUIPMENT OR A MAXIMUM OF 10 FEET AWAY FROM THE SYSTEM [NEC 690.13(A)]</li> <li>ALL WIRING METHODS SHALL BE IN ACCORDANCE WITH NEC 690.31</li> <li>WORK CLEARANCES AROUND ELECTRICAL EQUIPMENT WILL BE MAINTAINED PER NEC 110.26(A)(1), 110.26(A)(2) AND 110.26(A)(3).</li> <li>ROOFTOP MOUNTED PHOTOVOLTAIC PANELS AND MODULES SHALL BE TESTED, LISTED &amp; IDENTIFIED IN ACCORDANCE WITH UL1703</li> <li>ELECTRICAL CONTRACTOR TO PROVIDE CONDUIT EXPANSION JOINTS AND ANCHOR CONDUIT RUNS AS REQUIRED PER NEC.</li> </ol>	2018 NORTH CAROLIN 2018 NORTH CAROLIN 2018 NORTH CAROLIN 2017 NATIONAL ELEC NOTCE TO CONTRACTOR Market Prediction of the CONTRACTOR Market Prediction of the CONTRACTOR Market Prediction of the CONTRACTOR Market Prediction of the Contractor of th





SITE PLAN 1 SCALE: 1/16" = 1'-0" PV-2

	7901 ALLEN BLACK RD, MINT HILL,			
	NC 28227, UNITED STATES			
	DESCRIPTION DATE REV			
	INITIAL DESIGN 02/25/2025			
	MGINEER STRUCTURAL ONLY 2/25/2025			
	PROJECT NAME & ADDRESS			
	KATIE HALL RESIDENCE 300 W C ST, ERWIN, NC 28339			
	SITE PLAN			
	SHEET SIZE			
	ANSI B			
	SHEET NUMBER			
R	PV-2			

GROUND SNOW LOAD: REFER STRUCTURAL LETTE WIND EXPOSURE: REFER STRUCTURAL LETTER WIND SPEED: REFER STRUCTURAL LETTER





TERIALS	
RIPTION	QTY
631-405/MR 405W MODULE	12
ROPTIMIZERS	12
40V/5700W) INVERTER	01
,	1
CT, 60A FUSED, )	1
BANK	1
UP INTERFACE <b>BI-NUSGN-01</b>	1
ET) CLEAR) (XR-10-168A)	10
11)	4
O-CL-01-A1)	18
80-40MM), MILL	12
	3
ENTS (QM-HUG-01-M1)	25
30-01-M1)	50
02-A1)	25
T (BHW-MI-01-A1)	12

SUB

INV

JB

- SUB PANEL

- INVERTER

- RAFTER

- CONDUIT

- JUNCTION BOX

- VENT, ATTIC FAN

(ROOF OBSTRUCTION)

- ROOF ATTACHMENT



#### PHILLIPS ENERGY SYSTEMS

7901 ALLEN BLACK RD, MINT HILL

NC 28227, UNITED STATES			
REVISIONS			
DESCRIPTION	DATE	REV	
INITIAL DESIGN	02/25/2025		
PROJECT NAME &	ADDRESS		
1.111	39		
Ц Ц Ц	83. 83.		
⊈ž	йN		
ΨШ	ပပ္		

**KATIE RESIDI** 

300 W ERWIN, N

DRAWN BY

ESR

SHEET NAME

ELECTRICAL PLAN

SHEET SIZE

ANSI B

11" X 17"

SHEET NUMBER

PV-4



	7901 ALLEN BLA	
	NC 28227, U	NITED STATES
	INITIAL DESIGN	02/25/2025
	STRUCTUR 2/25/2	A ROUNT AROUND AL ONLY 025
P ATTACHMENT	KATIE HALL RESIDENCE	300 W C ST, ERWIN, NC 28339
N/ TH A	DRAWN BY	
OF 1.75"	ESR	
	SHEET	[ NAME
	STRUCTURAL DETAIL	
	SHEET SIZE	
	ANSI B	
	P\	/-5



SOLAR	MODULE SPECIFICATIONS		INVERTE	RSPECIFICATIONS		AMBIENT TEMPERATURE SPEC	S
			MODEL #	SOLAREDGE: SE5700H-	US (240V/5700W)	AMBIENT TEMP (HIGH TEMP 2%)	38°
MANUFACTURER / MODEL ;	JA SOLAR: JAM54S31-405/MR 405W MODULE		MODEL #	INVERTER		RECORD LOW TEMPERATURE	-8°
		NOMINAL AC POW	ER	5.700 kW		MODULE TEMPERATURE COEFFICIENT OF Voc	-0.275%/°C
		NOMINAL OUTPUT	VOLTAGE	240 VAC			
VMP	31.21V	NOMINAL OUTPUT	CURRENT	24.00A		7	
IMP	12.98A				_		
VOC	37.23V	PERCENT OF	NUMB	ER OF CURRENT			
ISC	13 87A	VALUES	CARRYING	CONDUCTORS IN EMT			
TEMP COFFE VOC	0.275%/°C	.80		4-6			
		.70		7-9			
	01.19 L X 44.05 W X 1.18 D (IN INCH)	.50		10-20	]		

									1	DC FEEDER C	ALCULATION	s									
CIRCUIT ORIGIN		VOLTAGE (V)	FULL LOAD AMPS "FLA" (A)	FLA*1.25 (A)	OCPD SIZE (A)	GROUND SIZE	CONDUCTOR SIZE	75°C AMPACITY (A)	AMPACITY CHECK #1	AMBIENT TEMP. (°C)	TOTAL CC CONDUCT ORS IN	90°C AMPACITY (A	DERATION FACTOR FOR AMBIENT ) TEMPERATURE NEG	R DERATION FACTOR FOR CONDUCTORS C PER RACEWAY NEC	90°C AMPACITY DERATED (A)	AMPACITY CHECK #2	FEEDER LENGTH (FFFT)	CONDUCTOR RESISTANCE (OHM/KET)	VOLTAGE DROP AT FLA (%)		CONDUIT FILL (%)
			64					(**)			RACEWAY		310.15(B)(2)(a)	310.15(B)(3)(a)			(12217	(orm/kiri)			
STRING 1	JUNCTION BOX	380	15.00	18.75	20	BARE COPPER #6 AWG	CU #10 AWG	35	PASS	38	2	40	0.91	1	36.4	PASS	5	1.24	0.049	N/A	#N/A
JUNCTION BOX	INVERTER	380	15.00	18.75	20	CU #10 AWG	CU #10 AWG	35	PASS	38	2	40	0.91	1	36.4	PASS	20	1.24	0.196	3/4" EMT	11.87617
SOLAREDGE BANK	INVERTER	380	13.16	16.45	20	CU #10 AWG	CU #10 AWG	35	PASS	38	2	40	0.91	1	36.4	PASS	5	1.24	0.043	3/4" EMT	11.87617
																	String 1	L Voltage Drop	0.245	]	

										AC FEED	DER CALCULA	TIONS										
CIRCUIT ORIGIN	CIRCUIT DESTINATION	VOLTAGE (V)	FULL LOAD AMPS "FLA" (A)	FLA*1.25 (A)	OCPD SIZE (A)	NEUTRAL SIZE	GROUND SIZE	CONDUCTOR SIZE	75°C AMPACITY (A)	AMPACITY CHECK #1	AMBIENT TEMP. (°C)	TOTAL CC CONDUCTORS IN RACEWAY	90°C AMPACITY (A)	DERATION FACTOR FOR AMBIENT TEMPERATURE NEC 310.15(B)(2)(a)	DERATION FACTOR FOR CONDUCTORS PER RACEWAY NEC 310.15(B)(3)(a)	90°C AMPACITY DERATED (A)	AMPACITY CHECK #2	FEEDER LENGTH (FEET)	CONDUCTOR RESISTANCE (OHM/KFT)	VOLTAGE DROP AT FLA (%)		CONDUIT FILL (%)
INVERTER	BACKUP INTERFACE	240	24	30	40	CU #8 AWG	CU #10 AWG	CU #8 AWG	50	PASS	38	2	55	0.91	1	50.05	PASS	5	0.778	0.078	3/4" EMT	24.5591
BACKUP INTERFACE	BACKUP LOAD PANEL	240	60	60	60	CU #4 AWG	CU #6 AWG	CU #4 AWG	85	PASS	38	2	95	0.91	1	86.45	PASS	5	0.308	0.077	1" EMT	34.4792
BACKUP INTERFACE	AC DISCONNECT	240	24	30	30	CU #4 AWG	CU #6 AWG	CU #4 AWG	85	PASS	38	2	95	0.91	1	86.45	PASS	5	0.308	0.031	1" EMT	34.4792
AC DISCONNECT	MAIN SERVICE PANEL	240	24	30	30	CU #4 AWG	N/A	CU #4 AWG	85	PASS	38	2	95	0.91	1	86.45	PASS	5	0.308	0.031	1" EMT	28.6111
																		CUMULATIVE V	OLTAGE DROP	0.186	1	

#### ELECTRICAL NOTES

- 1. ALL EQUIPMENT TO BE LISTED BY UL OR OTHER NRTL, AND LABELED FOR ITS APPLICATION.
- 2. ALL CONDUCTORS SHALL BE RATED UPTO 600V FOR RESIDENTIAL AND 1000V FOR COMMERCIAL AND 90 DEGREE C WET ENVIRONMENT.
- 3. WIRING, CONDUIT, AND RACEWAYS MOUNTED ON ROOFTOPS SHALL BE ROUTED DIRECTLY TO, AND LOCATED AS CLOSE AS POSSIBLE TO THE NEAREST RIDGE, HIP, OR VALLEY.
- WORKING CLEARANCES AROUND ALL NEW AND EXISTING ELECTRICAL EQUIPMENT SHALL COMPLY WITH NEC 110.26. 4.
- 5. DRAWINGS INDICATE THE GENERAL ARRANGEMENT OF SYSTEMS. CONTRACTOR SHALL FURNISH ALL NECESSARY OUTLETS, SUPPORTS, FITTINGS AND ACCESSORIES TO FULFILL APPLICABLE CODES AND STANDARDS.
- 6. WHERE SIZES OF JUNCTION BOX, RACEWAYS, AND CONDUITS ARE NOT SPECIFIED, THE CONTRACTOR SHALL SIZE THEM ACCORDINGLY.
- 7. ALL WIRE TERMINATIONS SHALL BE APPROPRIATELY LABELED AND READILY VISIBLE.
- 8. MODULE GROUNDING CLIPS TO BE INSTALLED BETWEEN MODULE FRAME AND MODULE SUPPORT RAIL, PER THE GROUNDING CLIP MANUFACTURER'S INSTRUCTION.
- MODULE SUPPORT RAIL TO BE BONDED TO CONTINUOUS COPPER G.E.C. VIA WEEB LUG OR ILSCO GBL-4DBT LAY-IN 9. LUG.
- 10. TEMPERATURE RATINGS OF ALL CONDUCTORS, TERMINATIONS, BREAKERS, OR OTHER DEVICES ASSOCIATED WITH THE SOLAR PV SYSTEM SHALL BE RATED FOR AT LEAST 75 DEGREE C.



#### PHILLIPS ENERGY SYSTEMS

		INC 20227, UNI	IED STATES	
		REVISIO	ONS	
		DESCRIPTION	DATE	REV
		INITIAL DESIGN	02/25/2025	
ONDUIT				
SIZE	FILL (%)			
N/A	#N/A			
8/4" EMT	11.87617			
5/4° EIVIT	11.8/61/			
	CONDUIT			
SIZE	FILL (%)			
	24 55 01			
1" EMT	34.4792			
1" EMT	34.4792			
1" EMT	28.6111			
		PROJECT NAME	& ADDRESS	
			_	
		1 111	30	
		L I B	ЗЭ́-Т	
		III≦≯	is si	
			ပပ	
		ШО	≥ Z	
			οŹ	
		ĽΎ	<u>8</u> 2	
		$  $ $\times \overline{\alpha}$	Ϋ́Υ Ϋ́	
			Ш	
		DRAWN	BY	
		ESF	२	
		SHELTN		
		WIRING CALC	ULATION	VS
		SHEET S	SIZE	
			R	
		11" X	17"	
		SHEET NU	MBER	
			,	
		PV-7	,	

#### PHOTOVOLTAIC POWER SOURCE

#### EVERY 10' ON CONDUIT & ENCLOSURES

LABEL- 1: <u>LABEL LOCATION:</u> DC/EMT CONDUIT RACEWAY SOLADECK / JUNCTION BOX CODE REF: NEC 690.31 (D)(2)

#### 

#### ELECTRIC SHOCK HAZARD

TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL- 2: <u>LABEL LOCATION:</u> AC DISCONNECT CODE REF: NEC 690.13(B)

#### 

**DUAL POWER SUPPLY** 

SOURCE: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

LABEL- 3: <u>LABEL LOCATION:</u> MAIN SERVICE PANEL CODE REF: NEC 705.12(C) & NEC 690.59

#### SOLAR PV BREAKER:

#### BREAKER IS BACKFED DO NOT RELOCATE

LABEL-4: <u>LABEL LOCATION:</u> MAIN SERVICE PANEL CODE REF: NEC 705.12(C) & NEC 690.59



LABEL- 5:

LABEL LOCATION: MAIN SERVICE PANEL (ONLY IF SOLAR IS BACK-FED) SUBPANEL (ONLY IF SOLAR IS BACK-FED) CODE REF: NEC 705.12(B)(3)(2)

#### SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



LABEL- 6: <u>LABEL LOCATION:</u> AC DISCONNECT CODE REF: [NEC 690.56(C)(1)(A)]

#### RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

LABEL- 7: <u>LABEL LOCATION:</u> AC DISCONNECT MAIN SERVICE PANEL (ONLY IF SOLAR IS BACK-FED) CODE REF: NEC 690.56(C)(2)

#### DC DISCONNECT

LABEL- 8: LABEL LOCATION: INVERTER CODE REF: NEC 690.13(B)



LABEL- 9: <u>LABEL LOCATION:</u> AC DISCONNECT CODE REF: NEC 690.54

	480 V
MAXIMUM CIRCUIT CURRENT	30.50 A
MAXIMUM RATED OUTPUT CURRENT OF THE CHARGE CONTROLLER OR DC-TO-DC CONVERTER (IF INSTALLED)	

LABEL- 10: <u>LABEL LOCATION:</u> ON THE RIGHT SIDE OF THE INVERTER (PRE-EXISTING ON THE INVERTER) CODE REF: NEC 690.53



#### PHILLIPS ENERGY SYSTEMS

REV	ISION	IS	
DESCRIPTION		DATE	REV
INITIAL DESIGN		02/25/2025	
		02.20.2020	
PROJECT NA	ME &	ADDRESS	
		0	
— ш		ŝ	
טר ו		93,⊣	
l ⊈ž		S Q	
∣		ပဋ	
ШО		≥∠.	
I I IS		οZ	
l ∢ŭ		<u> </u>	
$  \times \alpha$		Ŕ	
		ш	
DRA	WN B	Y	
F	SR		
SHEE	INA	VIE	
		S	
SHE	ET SU	7F	
AN	ISL	В	
11"	X 1	7"	
SHEET	NUM	BÉR	
	10		
II P'	v - o		
P'	v-0		

#### Harvest the Sunshine

#### DEEP BLUE 3.0 Light,



#### Introduction

Mono

Assembled with 11BB PERC cells, the half-cell configuration of the modules offers the advantages of higher power output, better temperature-dependent performance, reduced shading effect on the energy generation, lower risk of hot spot, as well as enhanced tolerance for mechanical loading.

Higher output power ~







Less shading and lower resistive loss



Lower LCOE

Better mechanical loading tolerance

#### Superior Warranty

JASOLAR



#### **Comprehensive Certificates**

- IEC 61215, IEC 61730, UL 61215, UL 61730
- . ISO 9001: 2015 Quality management systems
- ISO 14001: 2015 Environmental management systems
- · ISO 45001: 2018 Occupational health and safety management systems
- IEC TS 62941: 2016 Terrestrial photovoltaic (PV) modules -Guidelines for increased confidence in PV module design qualification and type approval







Remark: customized frame color and cable length available upon repuest

ELECTRICAL PARAMETERS A	T STC					
ТҮРЕ	JAM54S31 -380/MR	JAM54S31 -385/MR	JAM54S31 -390/MR	JAM54S31 -395/MR	JAM54S31 -400/MR	JAM54S31 -405/MR
Rated Maximum Power(Pmax) [W]	380	385	390	395	400	405
Open Circuit Voltage(Voc) [V]	36.58	36.71	36.85	36.98	37.07	37.23
Maximum Power Voltage(Vmp) [V]	30.28	30.46	30.64	30.84	31.01	31.21
Short Circuit Current(Isc) [A]	13.44	13.52	13.61	13.70	13,79	13.87
Maximum Power Current(Imp) [A]	12.55	12.64	12.73	12.81	12.90	12.98
Module Efficiency [%]	19.5	19.7	20.0	20.2	20.5	20.7
Power Tolerance			±2%			
Temperature Coefficient of Isc(a_Isc)			+0.045%°C			
Temperature Coefficient of $Voc(\beta_Voc)$			-0.275%/°C			
Temperature Coefficient of Pmax(y_Pmp)			-0.350%/°C			
STC		Irradiance 1000	W/m², cell temperatu	re 25°C, AM1.5G		

Remark: Electrical data in this catalog do not refer to a single module and they are not part of the offer. They only serve for comparison among different module types.

ELECTRICAL PARA	METERS	AT NOC	Т				OPERAT
ТҮРЕ	JAM54S31 -380/MR	JAM54S31 -385/MR	JAM54S31 -390/MR	JAM54S31 -395/MR	JAM54S31 -400/MR	JAM54S31 -405/MR	Maximum S
Rated Max Power(Pmax) [W]	286	290	294	298	302	306	Operating Te
Open Circuit Voltage(Voc) [V]	34,36	34.49	34.62	34.75	34.88	35.12	Maximum S
Max Power Voltage(Vmp) [V]	28.51	28.68	28.87	29.08	29.26	29.47	Maximum S Maximum S
Short Circuit Current(Isc) [A]	10.75	10.82	10.89	10.96	11.03	11.10	NOCT
Max Power Current(imp) [A]	10.03	10.11	10.18	10.25	10.32	10.38	Safety Class
NOCT	Irradian	ce 800W/m²,	ambient tem	perature 20°0	,wind speed	1m/s, AM1.5G	Fire Perform

#### CHARACTERISTICS

Current-Voltage Curve JAM54S31-405/MR





Premium Cells, Premium Modules



#### PHILLIPS ENERGY SYSTEMS

7901 ALLEN BLACK RD, MINT HILL, NC 28227, UNITED STATES

REVISION	REVISIONS					
DESCRIPTION	DATE	REV				
INITIAL DESIGN	02/25/2025					

PROJECT NAME & ADDRESS

KATIE HALL RESIDENCE

ST, 28339 300 W C S ERWIN, NC 2

DRAWN BY

ESR

SHEET NAME EQUIPMENT **SPECIFICATION** 

SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

PV-9

#### JAM54S31 380-405/MR Series

ſ	1	0	N	S

	Mono
	21.5kg±3%
	1722±2mm×1134±2mm×30±1mm
lion Size	4mm² (IEC) , 12 AWG(UL)
	108(6x18)
	IP68, 3 diodes
	MC4-EVO2(1500V)
ctor)	Portrait: 300mm(+)/400mm(-); Landscape: 1200mm(+)/1200mm(-
guration	36pcs/Pallet, 864pcs/40ft Containe







# **Residential Power Optimizer**

### For North America

S440 / S500B / S650B



# POWER OPTIMIZER

#### PV power optimization at the module level

- I Specifically designed to work with SolarEdge residential inverters
- J Detects abnormal PV connector behavior, preventing potential safety issues
- Module-level voltage shutdown for installer and firefighter safety
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch loss, from manufacturing tolerance to partial shading

- I Faster installations with simplified wire management and easy assembly using a single bolt
- I Flexible system design for maximum space utilization
- I Compatible with bifacial PV modules
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)

#### / Residential Power Optimizer For North America

S440 / S500B / S650B

	S440	S500B	S650B	
INPUT				
Rated Input DC Power <sup>10</sup>	440 <sup>(2)</sup>	500(3)	650	W
Absolute Maximum Input Voltage (Voc)	60	125	85	Vdc
MPPT Operating Range	8-60	12.5 - 105	12.5 - 85	Vdc
Maximum Input Current (Maximum Isc of Connected PV Module) <sup>(2)</sup>	14.5	1	5	Adc
Maximum Input Short Circuit Current <sup>(4)</sup>		18.75		Adc
Maximum Efficiency		99.5		%
Weighted Efficiency		98.6		%
Overvoltage Category		11		
OUTPUT DURING OPERATION (POWER OPTIMIZER CO	ONNECTED TO OPERATII	NG SOLAREDGE INVE	ERTER)	
Maximum Output Current		15		Adc
Maximum Output Voltage	60	8	0	Vdc
OUTPUT DURING STANDBY (POWER OPTIMIZER DISC	CONNECTED FROM SOLA	REDGE INVERTER OF	R INVERTER OFF)	
Safety Output Voltage per Power Optimizer		1 ± 0.1		Vdc
STANDARD COMPLIANCE				
Photovoltaic Rapid Shutdown System	CS	A C22.2#330, NEC 2014 - 20	23	
EMC	FCC Part 1	5 Class B; IEC 61000-6-2; IEC	61000-6-3	
Safety	CSA C22.2#1	07.1; IEC 62109-1 (Class II Saf	ety); UL 1741	
Material		UL 94 V-0, UV Resistant		
RoHS		Yes		
Fire Safety		VDE-AR-E 2100-712:2013-05	2	
INSTALLATION SPECIFICATIONS				
Maximum Allowed System Voltage		1000		Vdc
Dimensions (W x L x H)	129 x 155 x 30 / 5.07 x 6.10 x 1.18	129 x 165 x 45 /	5.07 x 6.49 x 1.77	mm / in
Weight	720 / 1.6	790/	( 1.74	gr / lb
Input Connector		MC4		
Input Wire Length		0.1/0.32		m/ft
Output Connector		MC4		
Output Wire Length	(+	23, (-) 0.10 / (+) 7.54, (-) 0.5	32	m/ft
Operating Temperature Range <sup>51</sup>		-40 to +85		°C
Protection Rating		IP68 / NEMA6P		-
Relative Humidity		0 - 100		%

(1) Rated power of the module at STC will not exceed the power optimizer Rated input DC Power. Modules with up to +5% power tolerance are allowed. (2) For S440 with part number S440-IGM4MRNP, the Rated Input DC Power is 650W, and the Maximum Input Current is ISA.

(3) For installations after Aug. 1st, 2024, the Rated Input D.C. Power for S500B is 650W

(4) The Maximum Input Short Circuit Current is adjusted for worst case conditions of ambient temperature, irradiance, bifadal gain, and so on, in accordance with NEC and CSA. (5) Power derating is applied for ambient temperatures above +85°C / +185°F for S440, and for ambient temperatures above +75°C / 167°F for S500B and 5650B. Refer to the Power Optimizers Temperature. Derating technical note for more details.

PV System Design Using a SolarEdge Inverter®		SolarEdge Home Wave/Hub Single Phase	Three Phase for 208V Grid	Three Phase for 277/480V Grid	
Minimum String Length (Power	5440	8	10	18	
Optimizers)	S500B, S650B	6	8	14	
Maximum String Length (Power Optimizers)		25	6+	50(7)	-
Maximum Usable Power Delivered per String		5700	6000	12,750	W
	Inverters with Rated AC Power ≤ 5700W	Per the inverter's maximum input DC power <sup>(a)</sup>			
Maximum Allowed Connected Power per String <sup>9)00</sup>	Inverters with Rated AC Power of 6000W	5700	One string: 7200 Two strings or more: 7800	15,000	W
	Inverters with Rated AC Power ≥ 7600W	6800, only when connected to at least two strings			
Parallel Strings of Different Lengths or Orientations			Yes		

(6) It is not allowed to mix 5-series and P-series Power Optimizers in new installations in the same string.

(7) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement

Refer to the <u>Single String Design Guidelines</u> application note for details.
 For the 208V grid, the maximum is permitted only when the difference in connected power between strings is 1,000W or less.

(10) For the 240V or 277/480V grids, the maximum is permitted only when the difference in connected power between strings 2,000W or less.



© SolarEdgeTechnologies, Ltd. All rights reserved. SOLAREDGE: the SolarEdge logs. OPTIMIZED BY SOLAREDGE are trademarks or registered trademarks of SolarEdge Techn All other trademarks mentioned herein are trademarks of their respective owners. Date: September 17, 2024 DS-000018-NA. Subject to change without notice.



#### PHILLIPS ENERGY SYSTEMS

REVISIONS					
DESCRIPTION	DATE	REV			
INITIAL DESIGN	02/25/2025				
PROJECT NAME 8	ADDRESS				
1 111	39				
1 1 8	83. 33. ⊣				
l ⊈ ž	N N				
	≤ <u> </u>				
2 記	с >				
	Ш				
DRAWN E	BY				
ESR					
	ME				
SPECIFICATION					
SHEET SIZE					
ANSI B					
11" X 17"					
SHEET NUM	IBER				
	0				
PV-1	0				
L					



# SolarEdge Home Hub Inverter

Single Phase, for North America For Inverters Assembled in the USA

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US / SE11400H-US



# HOME BACKUP

#### Single phase inverter for storage and backup applications

- I The ultimate home energy manager in charge of PV production, battery storage, backup operation during a power outage\*, EV Charging, and smart energy devices
- Record-breaking 99% weighted efficiency with 1 up to 300% DC oversizing
- Supports LRA can provide the required energy for HVAC systems starting during backup operation
- Integrates seamlessly with the complete 1 SolarEdge Home Smart Energy Ecosystem, through SolarEdge Home Network
- Module-level monitoring and visibility of 1 battery status, PV production, and selfconsumption data
  - \*Requires additional hardware and Timware version upgrade.

- Fast and easy installation small and lightweight, with reduced commissioning time
- A scalable solution that supports future homeowner needs through easy connection to a growing ecosystem of products
- Advanced safety features with integrated arc 1 fault protection and rapid shutdown for 690.11 and 690.12
- 1 Advanced reliability with automotive-grade components
- Embedded revenue grade production data, 1 ANSI C12.20 Class 0.5
- IP65-rated, for indoor and outdoor installations



### / SolarEdge Home Hub Inverter Single Phase, for North America

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US / SE11400H-US

Model Number <sup>(6)2)</sup>	SE3800H-US	SE5700H-US	SE7600H-US	SE10000H-US	SE11400H-US	Unit
OUTPUT - AC ON GRID						
Rated AC Power	3800 @ 240V 3300 @ 208V	5760 @ 240V 5000 @ 208V	7600	10000	11,400 @ 240V 10,000 @ 208V	w
Maximum AC Power Output	3800 @ 240V 3300 @ 208V	5760 @ 240V 5000 @ 208V	7600	10000	11,400 @ 240V 10,000 @ 208V	W
AC Output Voltage (Nominal)			208 / 240		1	Va
AC Output Voltage (Range)	183 - 264					Va
AC Frequency Range (min - nom - max)		59	3 - 60 - 60 5(1)			Hz
Maximum Continuous Output Current	16	24	32	42	48	A
GFDI Threshold			1			A
Total Harmonic Distortion (THD)			< 3			98
Power Factor		1, adju	stable -0.85 to 0.85	ç		1.00
Utility Monitoring, Islanding Protection, Country Configurable Thresholds			Yes			
Charge Battery from AC (if allowed)			Yes			-
Typical Nighttime Power Consumption			< 2.5			W
OUTPUT – AC STAND-ALONE (BACKUP) <sup>(4)(5)</sup>						
Rated AC Power in Stand-alone Operation			11,400(6)			W
Maximum Stand-alone Capacity			11,400			W
AC L-L Output Voltage Range in Stand-alone Operation			211 - 264			Va
AC L-N Output Voltage Range in Stand-alone Operation			105 - 132			Va
AC Frequency Range in Stand-alone (min - nom - max)			55 - 60 - 65			H
Maximum Continuous Output Current in Stand-alone Operation			48			A
GFDI			1			A
THD			× 5			%
OUTPUT - SOLAREDGE HOME EV CHARGER AC						
Rated AC Power			9600			W
AC Output Voltage Range			211 - 264			Va
On-Grid AC Frequency Range (min - nom - max)		5	9.3 - 60 - 60.5			H
Maximum Continuous Output Current @240V (grid, PV and battery)			40			Aa
INPUT – DC (PV AND BATTERY)						
Transformer-less, Ungrounded			Yes			1
Max Input Voltage			480			Vd
Nom DC Input Voltage			380			Vd
Reverse-Polarity Protection			Yes			
Ground-Fault Isolation Detection		60	00kΩ Sensitivity			1
INPUT – DC (PV)						-
Maximum DC Power @ 240V	11.400	11,520	15.200	20.000	22,800	w
Maximum DC Power @ 208V	6600	10.000	-	-	20.000	W
Maximum Input Current <sup>(7)</sup> @ 240V	20	30.5	40	53	60	Ad
Maximum Input Current <sup>(7)</sup> @ 208V	17.5	27		-	53	Ad
Maximum Input Short Circuit Current			45	1		Ad
Maximum Inverter Efficiency			99.2			96
CEC Weighted Efficiency	98	5	g	9	99 @ 240V	%
2-pole Disconnection			Ves		98.3 @ 2087	-
These specifications apply to inverters with part numbers SExxxdH-USMNUxxdS Inverters with part number SExxxdH-USMNDxxdS are interided for upgrade inst For other regional settings please refer to the <u>SolarEdge Inverters</u> . <u>Power Cont</u> Not designed for non-grid connected applications and requires AC for commi- for URA (Locked Rotor Amperage) values please refer to the <u>LRA for NAM App</u> For models SE7600H-US and below, the rated AC stand-alone power is config A higher current source may be used. The inverter will limit its input current to	and SExxxxH-USMNFxxx allations only, as part of th col Options Application N isioning. Stand-alone (bac alication Note, urable between 7600W or the values stated	5 and connection unit more the "Re-Energize" program ots. Skup) functionality is only s (11,400W from CPU version)	del number DCD-1PH-U Use on non-upgrade l aupported for the 240V in 4.20.xx.	JS-PxH-F+x installations will revoke grid.	the product warranty.	

solaredge.com



#### PHILLIPS ENERGY SYSTEMS

7901 ALLEN BLACK RD, MINT HILL NC 28227, UNITED STATES

REVISION	IS	
DESCRIPTION	DATE	REV
INITIAL DESIGN	02/25/2025	
PROJECT NAME &	ADDRESS	
	_	
ш ш	39	
GL	3T,	
ΗZ		
ШШ	≥ Ž	
I IS	o Z	
Ϋ́	S S S	
<u>т</u>	Ш	
DRAWN B	Y	
FSR		
	ME	
EQUIPMI	ENT	
SPECIFICA	TION	
SHEET SIZ	ZE	
ΔΝΟΙ	R	
ANOI 11" V 1	ט די	
	1	
SHEET NUM	BER	
PV-1	1	

CE .

# / SolarEdge Home Hub Inverter

SE3800H-US / SE5700H-US / SE7600H-US / SE10000H-US / SE11400H-US

Model Number <sup>(1)(2)</sup>	SE3800H-US	SE5700H-US	SE7600H-US	SE10000H-US	SE11400H-US	Units
OUTPUT - DC (BATTERY)						
Supported Battery Types		SolarEdge Ho	ome Battery, LG RES	U Prime		
Number of Batteries per Inverter		Up to 3 SolarEdge Ho	ome Battery, up to 2	LG RESU Prime		
Continuous Power <sup>(8)</sup>	11,400 @ 240V 3800 @ 208V	11,400 @ 240V 5000 @ 208V	11400	@240V	11,400 @ 240V 10,000 @ 208V	w
Peak Power <sup>(0)</sup>	11,400 @ 240V 3800 @ 208V	11,400 @ 240V 5000 @ 208V	11400	@240V	11,400 @ 240V 10,000 @ 208V	W
Maximum Input Current		1	30		group. Fill's flat strations	Adc
2-pole Disconnection		Up to the inver	ter's rated stand-alc	ne power		
SMART ENERGY CAPABILITIES						
Consumption Metering			Built-in <sup>(9)</sup>			
Stand-alone & Battery Storage	With Backup I	nterface (purchased s	eparately) for service	up to 200A; up to	3 inverters	
EV Charging		Direct connection to	o the SolarEdge Hor	ne EV Charger		
ADDITIONAL FEATURES						
Supported Communication Interfaces	RS485, Ethe	R\$485, Ethernet, Cellular <sup>00</sup> , Wi-Fi (optional), SolarEdge Home Network (optional)				
Revenue Grade Metering, ANSI C12:20		Buit-in®				
Integrated AC, DC and Communication Connection Unit		Yes				
Inverter Commissioning	With the SetAp	With the SetApp mobile application using built-in Wi-Fi Access Point for local connection				
DC Voltage Rapid Shutdown (PV and Battery)		Yes, NEC 690.12				
STANDARD COMPLIANCE						
Safety	UL 1741, UL 17415A, U	JL 1741SB, UL 1699B, C	SA 22.2#107.1, C22.	2#330, C22.3#9, At	VSI/CAN/UL 9540	
Grid Connection Standards		IEEE1547 and IEEE-1547.1. Rule 21. Rule 14H				
Emissions		FC	C Part 15 Class B			
INSTALLATION SPECIFICATIONS						
AC Terminals	L1,	1, L2, N terminal bloc L2 terminal blocks, PE	ks, PE busbar for inv busbar for EV Char	erter connection ger AC connection		
DC Terminals	4 x termi	nal block pairs for PV	input; 1 s terminal b	lock pair for battery	input	
AC Output and EV AC Output Conduit Size / AWG Range		1 <sup>th</sup> ma	aximum / 14-4 AWG			
DC Input (PV and Battery) Conduit Size / AWG Range	1" maximum / 14-6 AWG					
Dimensions with Connection Unit (H x W x D)		21.06 x 14.	6 x 8.2 / 535 x 370 >	208		in/mm
Weight with Connection Unit			44.9 / 20.3			lb / kg
Noise			< 50			dBA
Cooling		N	atural Convection			
Operating Temperature Range		-40 to	+140 / -40 to +600	-		*F / *C
Protection Rating	NEMA 4X				1	

(B) Discharge power is limited up to the inverter's rated AC power for on-grid and stand-alone applications, as well as up to the installed batteries' rating.
 (9) For consumption metering current transformers should be ardered separately; SECT-SPL-225A-T-20 or SEACT1250-400NA-20. Revenue grade metering is only for production metering.
 (10) Information concerning the data plan terms & conditions is available in <u>SolarEdge Communication Plan Terms and Conditions</u>.
 (11) Full power up to at least 50°C / 122°F; for power derating information refer to the <u>Temperature Derating Technical Note for North America</u>.



#### PHILLIPS ENERGY SYSTEMS

REVISIO	NS	
DESCRIPTION	DATE	REV
INITIAL DESIGN	02/25/2025	
PROJECT NAME 8	& ADDRESS	
KATIE HALL RESIDENCE	300 W C ST, ERWIN, NC 28339	
DRAWN ESF	BY C	
SHEET NA EQUIPM SPECIFICA	ENT ATION	
SHEET S ANSI 11" X	ze B 17"	
SHEET NUN PV-1	IBER	

# Backup Interface

BI-EUSGN-01 / BI-NUSGN-01



#### Backup Interface for Flexible Backup

- Automatically provides backup power to home loads in the event of grid interruption
- Full flexibility in which loads to backup the entire home or selected loads
- Scalable solution to support higher power & higher capacity<sup>(\*)</sup>
- (\*) Requires supporting inverter firmware

I Built-in Auto Transformer and Energy Meter for easier and faster installation

- Seamless integration with the Energy Hub Inverter with Prism Technology to manage and monitor both PV generation and energy storage
- J Generator connection support<sup>(\*)</sup>

# solaredge

STOREDG

# **/ Backup Interface** for North America

BI-EUSGN-01 / BI-NUSGN-01

The second s	BI-EUSGN-01	BI-NUSGN-01	
INPUT FROM GRID		State State State	
AC Current Input	200		A
AC Output Voltage (Nominal)	240		Vac
AC Output Voltage Range	211 - 264	4	Vac
AC Frequency (Nominal)	60		Hz
AC Frequency Range	59.3 - 60	.5	Hz
Microgrid Interconnection Device Rated Current	200		A
Service Side AC Main Circuit Breaker Rated Current	200	N/A	A
Service Side AC Main Circuit Breaker Interrupt Current	10k	N/A	A
Grid Disconnection Switchover Time	<100		ms
OUTPUT TO MAIN DISTRIBUTION PANEL			1.1.5
Aaximum AC Current Output	200		A
AC I -I. Output Voltage (Nominal)	240		Vac
AC L-L Output Voltage Range	211 - 26	4	Vac
AC Frequency (Nominal)	60		Hz
AC Frequency Panna	59.3 - 60	5	Hz
Asymum Investors AC Current Output in Backup Operation	59.3 - 55		<u>م</u>
maximum inventers Ac Current Output in Backup Operation	/8		A
AC L-N Output Voltage in Backup (Nominal)	5000		V
AC LIN Output Voltage In Backup (Norminal)	100 120	120	
AC E-N Output voltage kange in backup	105 - 132		V
	C0 + CC		HZ
Number of Inverter Inputs	3		
Rated AC Power	7,600		W
Maximum Continuous Input Current @ 240V	32		A
Rated AC Power in Continuous Backup Operation	6,700		W
Maximum Continuous Input Current in Backup Operation	26		A
Peak AC Power (<10 sec) in Backup Operation	7,000		W
Peak AC Current (<10 sec) in Backup Operation	30		A
Inventer Input AC Circuit Breaker	40 Lip to 3 X 63	A CBO	A
GENERATOR <sup>(2)</sup>	GP 10 3 X 63	100	
Maximum Rated AC Power	15 000		W
Maximum Continuous Input Current	63		Adc
Dry Contact Switch Voltage Rating	250/30		VarAk
Dry Contact Switch Current Rating	5		A
2 wire Start Switch	Vac		
	165		
	Cuitable for use as service as incoment	For main live only	
nstanation type Number of Communication Institut	Suitable for use as service equipment	For main lug only	
Number of communication inputs			
commonication	R\$485		
nergy meter (for Import/Export)	1% accura	icy	
Manual Control Over Microgrid Interconnection Device	Yes		dia kaominina

(1) Each 40A CB supports up to one 7.6kW inverter, with each 63A CB supporting one 10kW and one 11.4kW inverter. The CB upgrade kit is available with the following part numbers: for 40A CB, CB-UPG-40-01; for 63A, CB CB-UPG-63-01 (2) Requires supporting inverter firmware

solaredge.com



#### PHILLIPS ENERGY SYSTEMS

REV	ISION	S	
DESCRIPTION		DATE	REV
INITIAL DESIGN		02/25/2025	
PROJECT NA	ME &	ADDRESS	
		6	
U T U	I	833	
H H H	(	5 0 0 0	
ШШ		≥ Ž	
		N.	
II X K	ĺ	ж Х	
		Ξ	
	WN R	Y	
E	SR	-	
SHEE		ME	
EQUI	PME	ENT	
	FICA	TION	
SHE	ET SIZ	ΖE	
AN	ISI I	В	
11"	X 1	7"	
SHEET	NUM	BER	
P	V-1	3	
11			

# **/ Backup Interface** for North America

BI-EUSGN-01 / BI-NUSGN-01

Construction of the constr	BI-EUSGN-01	BI-NUSGN-01	
STANDARD COMPLIANCE			
F-41.	UL1741, CSA	22.2 NO. 107	
Safety	UL869A	N/A	
Emissions	FCC par	t 15 class B	
INSTALLATION SPECIFICATIONS			
Supported Inverters	StorEdge singl Single phase Energy Hub in	e phase inverter, iverter with Prism technology	
AC From Grid Conduit Size / AWG Range	2" conduits / #0 - 4/0 AWG		
AC Inverter Conduit Size / AWG Range	1" conduit / 14 - 4 AWG		
AC Generator Input Conduit Size / AWG Range	1" conduit / 8 - 3 AWG		
Communication Conduit Size / AWG Range	3/4" / 24 - 10 AWG		
Weight	73	/ 33	lb / Kg
Cooling	Fan (user	replaceable)	
Noise	< 50		dBA
Operating Temeprature Range	-40 to +122 / -40 to +50		"F / "C
Protection Rating	NEMA 3R, IP44		
Dimensions (HxWxD)	20.59 x 13.88 x 8.62 / 523.5 x 352.5 x 219		



© SolarEdge Technologies, Ltd. All rights reserved. SOLAREDGE, the SolarEdge logo, OPTIMIZED BY SOLAREDGE are trademarks or registered trademarks of SolarEdge Technologies, inc. All other trademarks mentioned herein are trademarks of their respective owners 10/2020/V01/ENG NA. Subject to change without notice.



#### PHILLIPS ENERGY SYSTEMS

REV	ISION	IS	
DESCRIPTION		DATE	REV
INITIAL DESIGN		02/25/2025	
			I
PROJECT NA	ME &	ADDRESS	
		6	
		333 333	
<b>₽</b> Z		й ССС	
		≥ Z	
SII		Z Q	
Ϋ́		ж 30	
		Ш	
DRA	WN B	Y	
E	SR		
SHEE			
	⊑⊤ 51⊿ I <b>CI</b> I		
	101	D 7"	
		1	
SHEET	NUM	BER	
P	V-1	4	

# SolarEdge Energy Bank **10kWh Battery**

## For North America



# HOME BACKU

#### Optimized for SolarEdge Energy Hub Inverters<sup>(1)</sup>

- Maximized system performance, gaining more energy to store and use for on-grid and backup power applications
- / Integrates with the complete SolarEdge residential offering, providing a single point of contact for warranty, support, training, and simplified logistics & operations
- / DC coupled battery featuring superior overall system efficiency, from PV to battery to grid
- I Scalable solution for increased power and capacity with multiple SolarEdge inverters and batteries

\* Backup application are subject to local regulation and may require additional components and firmware upgrade

- / Solar, storage, EV charging, and smart devices all monitored and managed by a single app to optimize solar production, consumption and backup\* power
- / Wireless communication to the inverter, reducing wiring, labor and installation faults
- / Simple plug and play installation, with automatic SetApp-based configuration
- Includes multiple safety features for battery protection

#### / SolarEdge Energy Bank **10kWh Battery** For North America

	BAT-10K1P <sup>(2)</sup>
BATTERY SPECIFICATION	
Usable Energy (100% depth of discharge)	9700
Continuous Output Power	5000
Peak Output Power (for 10 seconds)	7500
Peak Roundtrip Efficiency	>94.5
Warranty <sup>m</sup>	10
Voltage Range	350-450
Communication Interfaces	Wireless*
Batteries per Inverter	Up to 3'4'
STANDARD COMPLIANCE	
Safety	UL1642, UL1973, UL9540, UN38.3
Emissions	FCC Part 15 Class B
MECHANICAL SPECIFICATIONS	
Dimensions (W x H x D)	31.1 x 46.4 x 9.84 / 790 x 1179 x 250
Weight	267 / 121
Mounting <sup>(5)</sup>	Floor or wall mount®
Operating Temperature <sup>(7)</sup>	+14 to +122 / +10 to +50
Storage Temperature (more than 3 months)	+14 to +86 / -10 to +30
Storage Temperature (less than 3 months)	-22 to + 140 / -30 to +60
Altitude	6562 / 2000
Enclosure Protection	IP55 / NEMA 3R - indoor and outdoor (water and o
Cooling	Natural convection
Noise (at 1m distance)	<25

e Energy Net Plug-in (more details below). Using RS485 could reduce the usable energy to 9500Wh. (1) Please refer to the SolarEdge Energy Bank battery connections and configuration application note for compatible inverters.

(2) These specifications apply to part number BAT-10K1PS0B-01

(a) The appendix of the solar days that be solar days the solar days that be solar days that the solar days the s

(6) The floor stand is purchased separately. One floor stand is required per SolarEdge Energy Bank battery. Please refer to the Accessories' PN table below

(7) Please note that operating the SolarEdge Energy Bank at extreme temperatures for extended durations of time may void the Energy Bank's warranty coverage. Please see the Energy Bank Limited Product Warranty for additional details.

#### SolarEdge Energy Bank Battery – Accessories (purchased separately)

Accessory	PN
Floor stand	IAC-RBAT-FLRSTD=01
Branch connectors set (includes a pair of DC + and DC - connectors) Required for installations with multiple SolarEdge Energy Bank batteries with a single inverter	IAC-RBAT-USYCBL-01
Handles	IAC-RBAT-HANDLE-01
SolarEdge Energy Net Plug-in	ENET-HBNP-01
Battery inverter extension cable 2m long (MC4 to terminal block)	IAC-RBAT-10M420-01



SolarEdge Technologies Ltd. All rights reserved. SOLAREDGE: the SolarEdge logo. (DPTIMIZED BY SOLAREDGE are trademarks or registered trademarks of SolarEdge Technologies. Ltd.
 All other trademarks mentioned herein are trademarks of their respective owners. Date: 11/2021 D5-000026-3.6-NA. Subject to change without notice.

solaredge.com



#### PHILLIPS ENERGY SYSTEMS

7901 ALLEN BLACK RD, MINT HILL NC 28227, UNITED STATES

REV	REVISIONS				
DESCRIPTION		DATE	REV		
INITIAL DESIGN		02/25/2025			
PROJECT NA	ME &	ADDRESS			
		•			
		30			
15		83.			
l⊈ž	ĺ	ທີ່ຕັ			
上 🔟	(	ပပ			
ШО		≥∠.			
E S		οZ			
ĬЧШ́		B≥			
× 2		Ŕ			
		Ш			
DRAWN BY					
E	SR				
SPECIFICATION					
SHEE	SHEET SIZE				
	SI I	$\prec$			
AN AN	SH	3 7"			

Wh W W Years Vdc in/mm lb/kg °F/°C °F/°C °F/°C ft/m ust protection) dBA

KATIE HALL RESIDENCE	300 W C ST, ERWIN, NC 28339
DRA	
	.or
EQUI	ET NAME PMENT
SPECII	FICATION
SHE	ET SIZE
	KATIE HALL KATIE HALL RESIDENCE EQUI SHEI SHEI

CE RoHS

SHEET NUMBER

PV-15



#### Solar Is Not Always Sunny

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails<sup>®</sup> are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



#### Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails® is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

#### **Compatible with Flat & Pitched Roofs**







#### **Corrosion-Resistant Materials**

All XR Rails® are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



#### **XR Rail® Family**

**Tech Brief** 

#### XR Rail<sup>®</sup> Family

The XR Rail® Family offers the strength of a curved rail in three targeted sizes. E design loads, while minimizing material costs. Depending on your location, there



**Rail Selection** 

The table below was prepared in compliance with applicable engineering codes a based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for

Load		Rail Span			ipan
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'
	90				
None	120				
	140	XR10		XR100	
	160				
	90				
20	120				
20	140				
	160				
20	90				
30	160				
40	90				
40	160				
80	160				
120	160				

'Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved





		Tech Briet	•			
s Fach	n size suppor	ts specific		7901 ALLEN BLAC	RGY SYSTE	<u>MS</u> 
ere is a	an XR Rail <sup>®</sup> t	o match.		NC 28227, UN	ITED STATES	····,
				REVIS		DEV
		E		INITIAL DESIGN	02/25/2025	REV
XR100	00					
XR1000 solar me extreme feet for 12' sp Extre Clear Intern les and pnes 1	is a heavyweight bunting rails. It's b climates and spa commercial applic panning capability me load capability anodized finish al splices availabi standards.* & 2e, Exposu detailed certii	among uitt to handle ns up to 12 ations. e Values are ure B, Roof fication letters				
		ioution letters.		PROJECT NAM	E & ADDRESS	
5	10'	12'				
	XR1000			KATIE HALL RESIDENCE	300 W C ST, ERWIN, NC 28339	
			_	DRAW	N BY R	
				SHEET EQUIP SPECIFI	NAME MENT CATION	
proved cer	tification letters for a	ctual design guidance.		SHEET SIZE ANSI B 11" X 17"		
				SHFFT N	UMBER	
				PV	-16	
				1		





#### UFO<sup>®</sup> Family of Components

#### Simplified Grounding for Every Application

The UFO® family of components eliminates the need for separate grounding hardware by bonding solar modules directly to IronRidge® XR Rails®. All system types that feature the UFO® family-Flush Mount®, Tilt Mount® and Ground Mount®-are fully listed to the UL 2703 standard.

UFO® hardware forms secure electrical bonds with both the module and the rail, resulting in many parallel grounding paths throughout the system. This leads to safer and more reliable installations.

**Stopper Sleeve** 

The Stopper Sleeve snaps

into a bonded end clamp.

onto the UFO®, converting it

Only for installation and use with IronRidge products in accord with written instructions. See IronRidge.com/UFO



Universal Fastening Object (UFO®) The UFO® securely bonds solar modules to XR Rails<sup>®</sup>. It comes assembled and lubricated, and can fit a wide range of module heights.

**Bonded Attachments** 

and bonds the L-foot® to the

same socket as the rest of the

The bonding bolt attaches

rail. It is installed with the

system.

**BOSS®** Splice Bonded Structural Splice connects rails with built-in bonding teeth. No tools or

hardware needed



**Grounding Lug** A single Grounding Lug connects an entire row of PV modules to the grounding conductor.



The IronRidge® Flush Mount®, Tilt Mount®, and Ground Mount 2703 by Intertek Group plc.

UL 2703 is the standard for evaluating solar mounting will maintain strong electrical and mechanical connections over an extended period of time in extreme outdoor environments.

Cross-System Comp				
Feature	Flush Mount	Tilt		
XR Rails <sup>®</sup>	~			
UFO <sup>®</sup> /Stopper	~			
BOSS <sup>®</sup> Splice	~	4		
Grounding Lugs	1 per Row	1 pe		
Microinverters & Power Optimizers	Compatible with most Refer to system i			
Fire Rating	Class A	Cla		
Modules	Tested or Evaluated with Refer to installation ma			



CutSheet	PHILLIPS ENERGY SYSTEMS           7901 ALLEN BLACK RD, MINT HILL, NC 28227, UNITED STATES           REVISIONS           DESCRIPTION         DATE		
	INITIAL DESIGN	02/25/2025	
	PROJECT NAME & RESIDENCE BRAWN E	ADDRESS ERWIN, NC 28339 ERWIN, NC 28339	
	ESR		
MHUG-01-B1 or QM-HUG-01-M1 Cut Sheet Rev 1.0	SHEET NA EQUIPM SPECIFICA SHEET SI	ME ENT ATION ZE B	
	11" X 1	7"	
	SHEET NUM PV-1	BER 8	



#### **IRONRIDGE** QuickMount<sup>®</sup> RD Structural Screw



© 2022 IronRidge, Inc. All rights reserved. Visit www.ir-patents.com for patent information.

QM-RD-1430-01-M1 Cut Sheet Rev 1.0



#### PHILLIPS ENERGY SYSTEMS

REV	ISION	IS	
DESCRIPTION		DATE	REV
INITIAL DESIGN		02/25/2025	
			1
PROJECT NA	ME &	ADDRESS	
		39	
U T U	I	83. 83. T	
∥ ¥ Z		S N C C	
	:	≥ Z	
		N N	
II A H		N N N	
		Ш	
DRA		Y	
li <u>E</u>	<u>5</u> K		
	T NAI <b>PM</b>	ME <b>FNT</b>	
SPFCIF			
SHFF	ET SIZ	ZE	
	<u> SI</u>	B	
11"	X 1	7"	
SHEET NUMBER			
PV-19			
Г	v - I	0	



#### PHONE: 385-202-4150 WWW.EZSOLARPRODUCTS.COM



ITEM NO.	PART NUMBER	DESCRIPTION	QTY
1	JB-1.2 BODY	POLYCARBONATE WITH UV INHIBITORS	1
2	JB-1.2 LID	POLYCARBONATE WITH UV INHIBITORS	1
3	#10 X 1-1/4" PHILLIPS PAN HEAD SCREW		6
4	#8 X 3/4" PHILLIPS PAN HEAD SCREW		6

size <b>B</b>	JB-1.2			REV
SCALE: 1:2	WEIGHT	WEIGHT: 1.45 LBS SHEE		T 1 0F 3
TORQUE SPEC	TORQUE SPECIFICATION: 15		5-20 L	.BS
CERTIFICATION:		UL 174 CSA C2	1, NE 2.2 N	MA 3R 0. 290
WEIG	HT:	1.45 LBS		S











\_ [72.53mm] \_ 2.86in


































































Contorms to UL Std 61730-1/-2. UL Std 61215-1/-1/-2 Centiled to CSA Std C22.2 #61730-1/-2 Field Winig: Copper only 12AWG min Insulated for 90°C min. Connector mating: See modulo installation natructions for appropriate mating connectors All technical data at standard test condition: All technical data at standard test condition: All 5 = 1000/Win<sup>T</sup> Toye37C System Fire Class Rating See Installation Instructions for Installation Requirements to Achieve a Specified System Fire Class Rating with this Product.

TYPE Peak power (Pmax) Open circuit voltage (Voc) Max.power voltage (Vmp) Short circuit current (Isc) Max.power current (Imp) Power Selection

## JAM54S31-405/MR

405 W 37.23 V 31.21 V 13.87 A 12.98 A ±2 %

Power production tolerance: ±3% Open circuit voltage tolerance: ±3% Short circuit current tolerance: ±4% Maximum system voltage: 1500 V

Module f Safety cl Maximu
































DC Outsputs 440W/5-60V/15A DC input: 8-60V/14.5A Open Cincuit Johager 1V NA03 SM2623-0180315A7-D7 Mexico S440-1GM4MRM





SolarEdge Technologies Ltd. Power Optimizer

Solaredge Technologies GmbH/ Werner-Eckert-Straße 6/81829 Munich/Germany

CAUTION HOT SURFACES-TO REDUCE THE RISK OF BURNS-DO NOT TOUCH. RISK OF BURNS-DO NOT TOUCH. UGHT, IT SUPPLIES A DE VOLTAGE TO PHOTOVOLTAIC ARRAY IS EXPOSED TO LIGHT, IT SUPPLIES A DE VOLTAGE TO EQUIPMENT. COVER PV MODULE WITH OPAQUE MATERIAL BEFORE CONNECTING OR DISCONNECTING THIS OPTIMIZER. DURING FAULT, ZERO CURRENT IS SOURCED INTO DC ARRAY BY CONVERTER.

# WARNING ELECTRIC SHOCK HAZARD. THE DC CONDUCTORS OF THIS PHOTOVOLTAIC SYSTEM ARE UNGROUNDED AND MAY BE ENERGIZED.



AVDED AND MAY BE ENERGIZED. AVERTISSEMENT RISQUE DE CHOC ELECTRIQUE: QUAND LE CHAMP PHOTOVOTAIQUE EST EXPOSE A LA LUMIERE, UNE TENSION CC EST FOURNIE A CET EQUIPEMENT. SUBRACES CHAUDES: NE PAS TOUCHER, AFIN DE REDUIRE LES RISQUES DE BRULURES LE COURANT DE RETOUR INJECTE PAR LE CONVERTISSEUR EN CAS DE DEFAILLANCE DANS LE MODULE PV EST TOUJOURS NUL.



10U





















# solaredge

### **StorEdge Connection Unit**

Max DC Voltage (PV/Battery) Max DC Current (PV) Max DC Power (PV) Max Continuous DC Current (Battery) Max Continuous DC Power (Battery) Max AC Voltage AC-Single Phase Frequency Max AC Current (Grid) For more details refer to the installation guide Patent marketing notice: see WWW.SOLAREDGE.COM/patent

DCD-1PH-US-P2H-F-C PN: SB0125-191D2BAA6-C3 SN: MADE IN THE U.S.A FROM IMPORTED PARTS 480 Vdc 62 Adc 23.2 kWdc 31 Adc 11.6 kWdc 264 Vac 50/60 Hz 48 Aac



# solaredge

# **StorEdge Connection Unit**

Max AC Current (Smart EV Charger) Max Continuous Output Power (Smart EV Charger) Max Battery Energy Storage Number of AC phases Maximum AC short circuit current Weight Ambient Temperature: Enclosure Rating: For more details refer to the installation guide Patent marketing notice: see WWW.SOLAREDGE.COM/patent

Use 90°C copper PV Wires only. Revenue Grade ANSI C12.20 PHOTOVOLTAIC RAPID SHUTDOWN SYSTEM





40 Aac 9600 W 32 kWh L1, L2, N 74 Aac 30.2/ 13.7 lbs/kg - 40°C ...60°C IP65 / Type 4X





4004590



Ø

information. www.nerer to manufacturer's

### solar, and

ITO SUMMER SOF	
hoto pport 0E57	0
Ptrain Oltain Utility	HOU
lav in Volland Invest	911-110
input Curse Range Tier W	ACTIVE N.
HEX Continues	in stand on -leas
ar Continuous Output n.	alone alone
Output Dutput Power Grid	270-Ba Mode
ollans an	nnetled 31 Ad.
Nom - Nom	land-sine 5760m
have at	7.5 WW 8240V
and alone o	11 4 MA 32A
lax Continue Capacity	211 - 94 484
In o sugar output o	183 - 264 Var
and Output Fault Contrent Grid C	11 4 WW - 229 Var
lax Uniting a	annecled
rand oackleed Current	K 4 AM
requency Min - Nor	74 Am
ulput Parme - Max	11.
In a wwer Faclor	
vax Ambient Tempor	39.3-60.0-50.0-
nclosure	+/-0.85
Fith interest	F0 - 1
integrated ground laut	of C
The I Photovoltain And Protection	POSINEMA IN
TTENTION: The mail Are - Fault Circuit	Part HEC 690.35 (C)
lectronically Discounting operating curve	relection
Heler to manufacture	ni of this system may be seen
R-Cin.	instructions for more la
browster - 1907	Tal's and information.
ributi	
Livalina:	LE RUNAL SA

9+r BovS IOFF eSrS Texb 1M6v rt4= 1Fi MAC: 4:06:CS:A3:40:03 N: USE5700H - USMNBL75 N: SB0125 - 0750F1D42 - E3

solaredge

蹨

**PHOTOVOLTAIC RAPID** SHUTDOWN SYSTEM















### **BI-N Backup Interface**

Voltage Min-Nom-Max:	211Vac
	240Vac
	264Vac
AC Single Phase Nominal Frequency:	60Hz
Max grid current:	200Aac
Max service panel output current:	200Aac
Max Continuous Inverter Input current (per inverter):	48Aac
Max Continuous Generator Input current:	94Aac
Ambient Temperature:	- 4050°C
Enclosure:	IP44/NEMA 3

For more details refer to the installation guide













#### Made In China







2 A DANGER	2 A PELIGRO	A DANGER		
HAZARDIUS VOLTAGE WILL CAUSE SEVERE WARRY OF DEATH	VOCTAJE PELIORDSO, PUEDE CAUSAR HERIDAS SEVERAS IT LA MUERTE	TENSION DANGEREUSE PEUT CAUSER OCT BLITISUNER DIRVES DULA MOTT		
Never appendies and the other sport	Numia symme e) mäery upder som ta cutvertis ablertis.	Ne partials mantesyster finterruptese tertopel te servicide and surveys.		
If house, turn 2017 switch before removing at metalling free.	Si el interruptor esa favitia, base su patanca a la pecialm forte "OFT" antes de referer o instalar facilies.	Sili est mon d'un humile, mettre l'interrupteur tore securi (SFF) avent d'emerar es d'instalier un familie		
Always use a property raised vallage sensing device a lati line and used one have often (rhaved) or load a de terminale (if rem-baled) to cardine switch in DP	Meda el vestaje con un dispositivo de medición adecuada en lado de carga de los clan de fectoria (al los osal eren las terminales de carga (casode no sea fectoria) para compresar que el interruptor esta desentergiasilo	Toxyours, utiliser un diagnetité de délection de la tambien dans les valours nomination sant a presiden, et le câté charge du jecte-facilite imuni d'un fue tété) eu les berres câté charge (sans facilité) peur cardinteur que l'intervadaux sei fore cardia (DIP).		
Turn DFF power almost of switch testars doing any work incide. Replace all parts: Class cover before turning power SR	Desseyrerclar la alimentiación del interruptor artine de trabajar devine del minum. Reessejazar tedas ses partes Cerrar la cubitria antes de energivar at interruptor	Conyer l'automitation en amont de l'inférnation yvant foute intervention. Rostolacar les pièces. Fermer le couvercle avant de ramettre-socia latinair		

#### DG222NRB

E.T.N

DENERAL DUTY SAFETY SWITCH Type 38 Enclosure - Rainpreef

TERMINALS SUITABLE FOR AL-CU WIRE. INTERRUPTOR DE SERVICIO DENERAL Sabinete NEMA 38 - A Prueba De Llavia

TERMINALES ADECUADAS PARA CONDUCTORES DE AL-CU. N INTERRUPTEUR DE SÉCURITÉ À USAGE CÉNÉRAL Enveloppe De Type 3R - A C'épravve De La Plaie

BORNES CONVENANT POUR CONDUCTEURS AL-CU. 60 Amperes 120/240, 240, 127/220 V ~ 50Hz 3W 5/M

Horsepower Ratings	KW(Catrailus de potencia)		encia) A	Régimes "Horsepower"	
Volts / Tension / Voltaje	3 Phase/1 Fase		3 Phate/3 Fase *		2 Pole/2 Polo =
	Shit. / Exc	Max.	Stri. / Ext.	Max	A DESCRIPTION OF THE OWNER.
.120/327=	1.95 (1.119)	3 (2,238)	3 (2, 238)	7 12 (5,50)	-
240	3 (2,238)	10 (7,45)	7.8 (5.60)	15 (11.19)	-

\*For grounded B Phase systems only

Maximum Tuss eize 60A

The starting current of motors of more then the standard horsepower ratings may require the use of fuses with eporopriate time-delay characteristics. Continuous load current not to exceed 50% of the rating of fuses employed in other than motor circuits.

other than motor circuits. Suitable for use as service equipment. Suitable for use on a circuit capable of delivering not more than 100,000 RMS symmetrical emperes, 240 V - maximum, when Class R fuses are used. Fuse kit DSMFK is required for R fuses. DANGER-Unless Class R fuses are used, this switch may present a risk of fire and personal injury If installed on circuits capable of delivering more than 10,000 RMS symmetrical emperes. When used with Class K or H fuses, suitable for use on a circuit capable of delivering not more than 10,000 RMS symmetrical emperes, 240 volts maximum.

maximum. Experience has shown that renewable fuses can cause overheating problems and thus the tas of renewable fuses is not recommended. Use 60°C or 75°C wire.

Lug torque / Pex across Flats / 5/32 / 100 LE - In Wirerange

14 - 1/D AWE, 7.1 a 535 mm" AL - DU

Accessories Install per testructions supplied with kit Drose kit. OSSARK Drosent log kit. DG00008 3/4\* (FS.DSmm) Hub size OS075H1 7 (25.40mm) Hub size OS075H1 7 (25.40mm) Hub size OS075H1 7 (25.40mm) Hub size OS075H1 7 (26.80mm) Hub size OS150H1 2\* (50.80mm) Hub size OS200H1

Accesorios Indialar de acuardo a instrucciones incluidas en las accesorios. Juego eldeptador para fusible tipo "R" DSIAFK Juego de neutro - DGRONE Juego de neutro - DGRON

Accessions Installier Chritermännant aus directives fournies evec l'ememble. Ensemble pour fusible R. OSI6FK Ensemble de neutres. OOID080 3/4\* (IP.Comm) Calibre des manchens. OSI00HI 1/4\* (IP.Comm) Calibre des manchens. DSI00HI 1/4\* (IP.Comm) Calibre des manchens. DSI20HI Vivy med -/ Adecuado para usarse como equipo de acomelida Tamaño máximo de fusibla de 40 amperios La corriente de arranque de motores con capacidad mayor a los cabellos de potencia estándar puede requerir del uso de fusibles con

\*Sólo para sistemas con falla a tierra en fase 🗄

de potencia estándar puede requerir del uso de fusibles con características de retardo de tiempo apropiadas. La corriente de carga continua no debe escadar el 80% de la capacidad del fusible emplaado, con excepción de los circuitas de motores. Adecuado para usarse en circuitos capaces de entregar només de 100 000 A RCM simétricos, con 240 V- máximo, cuando se utilizan fusibles clase R. El juego adaptador de fusibles OSI6FK se requiere para fusibles clase R. PELIGRO-a menos que se utilican fusibles clase R, este interruptor puede presentar riesgos de incendio y daño personal si es instalada en circuitos con capacidad de entregar más de 10 000 A RCM simétricos. Cuando se utiliza con fusibles clase K o H, es adecuado para usarse en circuitos con capacidad de entregar nomás de 10 000 A RCM simétricos cuando se utiliza con fusibles clase K o H, es adecuado para usarse en circuitos con capacidad de entregar nomás de 10 000 A RCM simétricos con 240 V- máximo.

La experiencia muestra que los fusibles renovables pueden causar problemas de sobrecalentamiento, por lo tanto, el uso de fusibles renovables no es recomendable Usar conductores para 60° C 6 75° C.

Par de apriele de tarminales / Tornillo de cabeza hexagonal / 3.97 mm / 11.3 Nm

Rango de la seccion transversal del conductor 14 - 1/D AWC, Z. 1 e 53.5 mm² AL - CU

"Seulement pour des systèmes de phase & MALT. Approprié comme équipement d'entrée de service Calibre maximum du lusible 60A

Calibre maximum du fusible 40A L'intensite de démorrage des moteurs plus élavée que pour les "horsepow er" standards peut exigér fuirlis attoir de funities ayant des caracteristiques de temporisation appropriées. Toute charge continue ne devra pas excéder 60% du calibre ses fusibles utilisés saus s'il s'agil de circuits de moteurs. Convient a un circuit de 150,000 ampéres efficares symétriques eu plus. 240 V - maximum, lorsque des fusibles de classe R sont attimes Ensemble de fusible DS16FK reque pour fusibles R. DANGER - A moins d'utiliser des fusibles de classe R, cet interrupteur peut présenter des risques d'incendie et de blessures corporaties s'il est installé dans un circuit de plus 10,000 ampères efficaces symetriques. Si intallé dans un circuit de plus 10,000 ampères efficaces symetriques. Si utilisé avec des fusible K ou H. Unierrupieur sera approprié pour utilisation sur un circuit ne délivrant pas plus de 10.000 ampar es RMS aymetriques, 240V maximum.

L'expérience démontre que l'utilistation de funities reneuvelables peut causer des problémes de surchauffe et par conséguient, ces fusibles in sont pas recommendés.

Ubliser conducteur 40°C oc 75°C Torque aux bornes / Vis à léte six pans / 5/32" / 100Lb - Ho Plage de conducteurs 14 - I/O AWG, 2, la 535 mm<sup>2</sup> AL - CU

THE P. L.

80111

PUB53724





172

# F.T.N

General Duty Safety Switch Interrupteur de sécurité à usage général Interruptor de seguridad de servicio général

60 A, 240 V=, 60 Hz Complete ratings inside Valeurs nominales complètes à l'intérieur Información completa de capacidades en el interior

Further instructions inside Autres instructions à l'intérieur Instrucciones adicionales en el interior



# SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY

# RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

FIC

122





# solaredge



### BAT-10K1P

Nominal Energy Rated capacity Output Voltage (Min-Nom-Max) Continuous Output Power Max Continuous Output current

Peak Output Power in Backup / duration

Max short circuit current / duration

Enclosure

**Operating Temperature Range** - 30°C to +60°C Storage Temperature Range Battery Designation ICP/46/174/134/[1P30S]E/-10+50/95

Li lon rechargeable battery



Scan this code for Emergency contact











9.7 kWh 94Ah 350-400-450 Vdc 5.0 kWdc 14.3 Adc 7.5 /10 kWdc / sec

1k/10 Adc/msec

NEMA 3R / IP55 - 10°C to +50°C









## BATTERY DC DISCONNECT RAPID SHUTDOWN











1

ENCLOSED PANELBOARD

LUG-ON NEUTRAL

1-3

1

0

PASS THROUGH BRANCH CIRCUIT OVER CURRENT PROTECTION LOCATED AT BACK UP LOADS PANEL

ESSENTIAL LOADS PANEL












## SOLAR POINT OF INTERCONNECTION

# **ACAUTION**

TRI POWER SOURCES

SECOND SOURCE IS DC BATTERY, THIRD SOURCE IS PV SYSTEM

> MARNING POWER SOURCE OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE

CAUTION: MULTIPLE SOURCES OF POWER THE PV DISCONNECT IS LOCATED BESIDE THE SERVICE METER











































CAUTION

TRI POWER SOURCES SECOND SOURCE IS DC BATTERY, THIRD SOURCE IS PV SYSTEM

A FACE

0

6



#### TRI POWER SOURCES

SECOND SOURCE IS DC BATTERY, THIRD SOURCE IS PV SYSTEM

### 

POWER SOURCE OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE







### solaredge



The maximum operating current of this system may be controlled electronically. Refer to manufacturer's instructions for more information.

> solar sole SES700H-US rid Support Utility Interactive Non-Isolated hotovoltaic Inverter With stand alone Mode peraling Voltage Range perating Voltage Range tax Continuous Output Power Grid connected tax continuous output rower and connected lax Continuous Output Power and Current stand-alone 11.4 KVA 48A 211-240-264 Vac lax Input Current 183-208-229 Vac 11.4 KVA ollage Nin - Nom - Max 24480 lax Continuous Output Current Grid Connected lax stand-alone Capacity 74 A86 59.3-60.0-60.5 Hz O Asc tax Output Fault Current +1-0.85-1 lax Utility Backdeed Current requency Min-Nom-Max 60 C IP65INEMA 4X nclosure filh integrated ground fault protection per NEC 690.35 (C) utput Power Factor JUE I MULUVOIRAIE ARE-FAUL CIRCUIL - MOLECION TENTION: The maximum operating current of this system may be controlled TENTION: The maximum operating current e instructione for more information between control of the monutacture of the instruction of the more information lax Ambient Temperature The 1 Pholovollaic Arc -Fault Circuit - Protection I EN LIUR: The maximum operating current of this system may be lectronically. Refer to manufacturer's instructions for more ECTORS clivation: a+r Bgvs IOFF eSrS Texb IM6v rt4= a+r MAG: JFF MAG: Locetre Astan.03 li-Fi Password: 2E8Fbc9 4.06:05:43:40:03 N: USE5700H-USMNBL75 N: 580125-0750F1042-E3

1:HE



Sub feed

Off/C 0n/l 0n/l Off/O

Off/O 0n/l 30 6 C/HO ()n/] 30 Off/O 00/1 30 00/1 C/JJO

H20 fleat

#### SOLAR PV BREAKER

BREAKER IS BACKFED DO NOT RELOCATE














A DANGER	A PELIGRO	TENSION DANSEREUSE PEUT CAUSER DES BLESSURES ORAVES OU LA MORT. Ne jamais manoeuvror l'inferruptieur langue le' couvercie est ouvert.	
HAZARDOUS VOLTAGE, WILL CAUSE SEVERE INJURY OR DEATH.	VOLTAJE PELIGROSO, PUEDE CAUSAR HERIDAS SEVERAS O LA MUERTE		
Never operate switch with cover open.	Nunca opere el interruptor con la cubierta abierta.		
It fused, turn OFF switch before removing or installing fuse.	Si el interruptor usa fusible, baje su palanca a la posición fuere "DFF" antes de retirar o instatar fusibles.	S?l est muni d'un fusible, mettre l'interrupteur nors circuit (OFF) avant d'enlaver ou d'installer un fusible.	
Always use a properly rated voltage sensing device at all line and load side fuse clips (if fused) or load side terminals (if non-fused) to confirm switch is DFF.	Mida el voltaje con un dispositivo de medición adecuado en lado de carga de los clips de fusibles (si los usa) o en las terminales de carga (cuando no usa fusibles) para comprobar que el interruptor está desenergizado.	Toujours utiliser un dispositif de détection de la tension dont les valeurs nominales sont apropriées, et la côté charge du porte-fuible (muni d'un fusible) ou les bornes côté charge (sans touble) peur confirmer que l'interrupteur est pors circuit (DFF).	
Turn OFF power ahead of switch before doing any work inside. Replace all parts. Close cover before turning power ON.	Desconectar la alimentación del interruptor antes de trabajar dentro del mismo. Reemplazar fodas las partes. Cerrar la cubierta antes de energízar el inferruptor.	Couper l'alimentation en amont de l'interrupteur avant foute intervention. Remplacer les pièces. Former le couvercle avant de remettre sous terainer.	

## DG222NRB Series R

E-T-N

**GENERAL DUTY SAFETY SWITCH** Type 3R Enclosure - Rainproof

TERMINALS SUITABLE FOR AL-CU WIRE.

INTERRUPTOR DE SEGU RIDAD DE SERVICIO GENERAL Gabinete NEMA 3R - A Prueba De Lluvia

## TERMINALES ADECUADAS PARA CONDUCTORES DE AL-CU. Interrupteur de sécurité à usage général

Enveloppe De Type 3R - A L'épreuve De La Pluie

## BORNES CONVENANT POUR CONDUCTEURS AL-CU.

60 Amperes 120/240, 240, 127/220 V ~ 60Hz 3W S/N, 3H N/S, 3F N/S

Horsepower Ratings	KW(Caballos de potencia)			Régimes "Horsepower"	
	1 Phase/1 Fase		3 Phase/3 Fase *		2 Pole/2 Polo =
Volts / Tension / Voltaje	Std. / Est	Max.	Std. / Est	Max.	
120 / 127 ~	1 1/2 (1,119)	3 (2,238)	3 (2,238)	7 1/2 (5,60)	<i>c</i>
240~	3 (2,238)	10 (7,46)	7 1/2 (5,60)	15 (11,19)	-

\*For grounded B Phase systems only.

Maximum fuse size 60A The starting current of motors of more than the standard horsepower ratings may require the use of fuses with appropriate time-delay characteristics. Continuous load current not to exceed 80% of the rating of fuses employed in other than motor circuits.

Suitable for use as service equipment. Suitable for use on a circuit capable of delivering not more than 100,000 RMS symmetrical amperes, 240 V - maximum, when Class R fuses are used. Fuse kit DS16FK is required for R fuses. DANGER-Unless Class R fuses are used, this switch may present a risk of fire

DANOCK-UNLESS CLASS K TUSES are used, this switch may present a risk of fi and personal injury if installed on circuits capable of delivering more than 10,000 RMS symmetrical amperes. When use with Class K or H fuses, suitable for use on a circuit capable of delivering not more than 10,000 RMS symmetrical amperes, 240 volts

maximum Experience has shown that renewable fuses can cause overheating problems and thus the use of renewable fuses is not recommended.

Use 60°C or 75°C wire. Lug torque / Hex across flats / 5/32" / 100 LB. - In

Wire range

14 - 1/D AWG, 2,1 a 53,5 mm\* AL - CU

Accessories Install per instructions supplied with kit. R fuse kit DS16FK Ground lug kit DG030GB Neutral kit DG100NB 3/4 " (19.05mm) Hub size DS075H1 1" (25.40mm) Hub size DS100H1 1% " (31.75mm) Hub size DS125H1 1% " (38.10mm) Hub size DS150H1 2 " (50.80mm) Hub size DS200H1 Accessories

Accesorios Instalar de acuerdo a instrucciones incluidas en los accesorios. Juego adaptador para fusible tipo "R" DS16FK Juego de partes para terminal de tierra DG030GB Juego de neutro DG100NB 3/4" (19.05mm) Tamano de cople DS075H1 1" (25.40mm) Tamano de cople DS100H1 11" (21.75mm) Tamano de cople DS100H1

1½ " (31.75mm) Tamano de cople DSI05H1 1½ " (38.10mm) Tamano de cople DS150H1 2" (50.80mm) Tamano de cople DS120H1

11

Accessoires Installer conformément aux directives fournies avec l'ensemble Ensemble de bornes de MALT DG0300B Ensemble de neutres DG100NB 3/4\* (19.05mm) Calibre des manchons DS075H1 1\* (25.40mm) Calibre des manchons DS100H1 1X\* (3.75mm) Calibre des manchons DS125H1 \* (31.75mm) Calibre des manchons DS105H1 \* (38.10mm) Calibre des manchons DS155H1 (50.80mm) Calibre des manchons DS150H1 29

"Sólo para sistemas con falla a tierra en fasa 8.

Adecuado para usarse como equipo de acometida Tamaño máximo de fusible de 60 amperios

La corriente de arranque de motores con capacidad mayor a los caballos de potencia estándar puede requerir del uso de fusibles con-

E-5239 (

ENGIN

ED SWITCH

INTERRUPTOR EN CABINETE INTERRUPTEUR SOUG COFFILE

ISSUE NO. AL-72

características de retardo de tiempo apropiadas. La corriente de carga continua no debe exceder et 80% de la capacidad del fusible empleado, con excepción de los circuitos de motores

Adecuado para usarse en circuitos capaces de entregar no más de 100 000 A RCM simétricos, con 240 V- máximo, cuando se utilizan fosibles. clase R. El juego adaptador de fusíbles OS16FK se requiere para fusibles clase R.

PELIGRO-a menos que se utilicen fusibles class R, este interruptor puede presentar riesgos de incendio y daño personal al es instalado am circuitos con capacidad de entregar más de 10 000 A RCM simétricos Cuando se utiliza con fusibles clase K o H, es adecuado para usarse an circuitos con capacidad de entregar no más de 10 000 A RCM similificas, con 240 V- máxima.

La experiencia muestra que los fusibles renovables pueden causar problemas de sobrecalantamiento, por la tanto, el uso de fusibles renovables no es recomendable.

Usar conductores para 60° C ó 75° C.

Par de apriete de terminales / Tornillo de cabeza hexagonal /3/97mm/ 11.3 N.m

Rango de la sección transversal del conductor 14 - 1/0 AWG, 2, 1a 53.5 mm<sup>2</sup> AL - CU

"Seulement pour des systèmes de phase 8 MALT.

Approprié comme áquipement d'entrée de service

Calibre maximum du fusible 60A

L'intensite de démarrage des moteurs plus élevés que pour les "harsepower" standards peut exiger l'utilisation de fusibles ayant des

caracteristiques de temporisation appropriées. Toute charge continue ne devra pas excéder 80% du calibre des fusibles. utilisés saul s'il s'agit de circuits de moleure.

Convient a un circuit de 100,000 ampères afficaces symétriques au plea.

240 V - maximum, forsque des fusibles de classe R sont utilises. Ensemble de fusible DS16FK requis pour fusibles R DANGER - A moins d'utilis er des fusibles de classe R, cet interrugieur. peut présenter des risques d'incendie et de blassures corporaties s'Rest. installé dans un circuit de plus 10,000 ampères afficaces symétriques. Si utilisé avec des fusible Kau K. Melerrupteur sera approprié pour utilisation sur un circuit ne délivrant pas plus de 10.000 ampares Réés

s ym etriques, 240V maximum. L'expérience démontre que l'utilisation de fusibles removedation pout couser des problémes de surchauffe al, par conséquent, ces lucities ne

- 4

sont pas recommandés. Utiliser conducteur 60°C au 75°C.

Tarque aux barnes / Via à lite six pans / 5/32" / 1601.b. - Pa

Plage de conducteurs 14 - VO AVKG, 2 la 53.5 mm<sup>2</sup> AL - Dà

10000000

100 38.17

1UP

FIJB53724



