



Permit Inspections

Harnett County

Permit Number: **ERES2508-0057**

Description: **1st floor and kitchen renovation from fire**

Applied: **8/22/2025**

Approved: **8/22/2025**

Site Address: **2817 CAROLINA WAY**

Issued: **8/22/2025**

Finalized:

City, State Zip Code: **SANFORD, NC 27332**

Status: **ISSUED**

Applicant: **GEDDES BRIAN**

Parent Permit: **BRES2508-0032**

Owner: **GEDDES BRIAN**

Parent Project:

Contractor: **SHOWCASE RESTORATION NC INC**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ROUGH IN	James T Hall		
Notes:						
			FINAL**	James T Hall		
Notes:						
	8/25/2025	8/25/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes:						
Electrical cables under crawl space need supported and fireblock.						
	8/29/2025	8/29/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes:						
Missing receptacle in hallway half bathroom						
	10/3/2025	10/3/2025	ROUGH IN	Ricardo D Honrada	DISAPPROVED	
Notes:						
Inspector JTH changed the inspection assignment from JTH to RH						
Behind the stove cable penetration needs sealed.Garbage disposal cable penetration to the wall needs to be sealed						
	10/3/2025	10/3/2025	FINAL**	Ricardo D Honrada	DISAPPROVED	
Notes:						
Inspector JTH changed the inspection assignment from JTH to RH						
Behind the stove cable penetration needs sealed.Garbage disposal cable penetration to the wall needs to be sealed.						