



Permit Inspections

Harnett County

Permit Number: ERES2509-0075

Description: re hook pump for septic

Applied: 9/25/2025

Approved: 9/25/2025

Site Address: 46 S BRENDA ST

Issued: 9/25/2025

Finalized:

City, State Zip Code: SPRING LAKE, NC 28390

Status: ISSUED

Applicant: Austin Electrical

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Austin Electrical

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	James T Hall		
Notes:						
	9/26/2025	9/29/2025	FINAL**	James T Hall	DISAPPROVED	
Notes:						
Please come around lunch and contact 910.495.5631 if any issue						
This a service for a pump system Need 2 ground rods 6' apart						