



RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources - Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 3238

1. WELL CONTRACTOR:
 TONY SULLIVAN
 Well Contractor (Individual) Name
 CENTRAL CAROLINA WELL DRILLING
 Well Contractor Company Name
 STREET ADDRESS PO BOX 686
PITTSBORO N-C 27332
 City or Town State Zip Code
919-542-8021
 Area code - Phone number

2. WELL INFORMATION:
 SITE WELL ID # (if applicable) _____
 STATE WELL PERMIT # (if applicable) _____
 DWQ or OTHER PERMIT # (if applicable) _____
 WELL USE (Check Applicable Box): Residential Water Supply
 DATE DRILLED 4-19-13
 TIME COMPLETED 10:30 AM PM

3. WELL LOCATION:
 CITY: LILLINGTON COUNTY: HARNETT
750 CORTEZ MORRISON RD
 (Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)
 TOPOGRAPHIC / LAND SETTING:
 Slope Valley Flat Ridge Other
 (check appropriate box)
 LATITUDE 3 _____
 LONGITUDE _____
 Latitude/longitude source: GPS Topographic map
 (location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. WELL OWNER
 OWNER'S NAME WAYLON KELLY BUCHANAN
 STREET ADDRESS 750 CORTEZ MORRISON RD
LILLINGTON NC
 City or Town State Zip Code
 Area code - Phone number _____

5. WELL DETAILS:
 a. TOTAL DEPTH: 320
 b. DOES WELL REPLACE EXISTING WELL? YES NO
 c. WATER LEVEL Below Top of Casing: 2.5 FT.
 (Use "+" if Above Top of Casing)
 d. TOP OF CASING IS 1 FT. Above Land Surface*
 *Top of casing terminated at or below land surface may require a variance in accordance with 15A NCAC 2C .0118.
 e. YIELD (gpm): 20 METHOD OF TEST JAR

6. DISINFECTION: Type SOCKET Amount 93

7. WATER ZONES (depth):
 From 285 To 290 From _____ To _____
 From _____ To _____ From _____ To _____
 From _____ To _____ From _____ To _____

8. CASING:
 Depth Thickness/Weight Material
 From 0 To 41 Ft. 6 _____ PVC
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

9. GROUT: Depth Material Method
 From 0 To 20 Ft. CEMENT BOB
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

10. SCREEN: Depth Diameter Slot Size Material
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____
 From _____ To _____ Ft. _____ in. _____ in. _____

11. SAND/GRAVEL PACK:
 Depth Size Material
 From 0 To 80 Ft. _____ _____
 From _____ To _____ Ft. _____ _____
 From _____ To _____ Ft. _____ _____

12. DRILLING LOG
 From To Formation Description
0 30 SAND - CLAY
30 40 BLDE ROCK

13. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.
 Tony S Sullivan 4-19-13
 SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE
 TONY S SULLIVAN
 PRINTED NAME OF PERSON CONSTRUCTING THE WELL