

Fire Marshal Division

August 28, 2018

Jason Wangelin Campbell University PO Box 535 Buies Creek, NC 27506

Re: Campbell University Tent

Barker Lane Stadium (180 Wade Stewart Circle)

Lillington, NC 27546

Application Number FMFW1808-0007

Mr. Wangelin,

Thank you for submitting the plans for the tent. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

• 2404.12 Fire Extinguishers.

 2A-10B: C fire extinguisher shall be placed at tents/canopies with a travel distance not to exceed 100' from any fire extinguisher.

• 2403.12.5.1 Arrangement of aisles.

 The arrangement of aisles shall be subject to the approval of the fire code official and shall be maintained clear at all times during occupancy.


2403.12.6 Exit Signs

 Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more.









 Smoking shall not be allowed under tents/canopies. "NO SMOKING "signs shall be conspicuously posted under the tent.

Thank you again for submitting the plans for the tent. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,

D. Banks Wallace

Chief Deputy Fire Marshal

D. Bands Walleve





Emergency Services Department

www.harnett.org

Reviewed For Code Compliance By: Fire Marshal Division D. Banks Wallace


1005 Edwards Brother Drive Lillington, NC 2756 910-893-7580 D. Banks Wallace
Chief Deputy Fire Marshal
08/28/2018 9:42:22 AM

2/ 10

Application for Tent/Canopy Permit

Application# FMFW1808-0007 Date: 0 /24 10
Applicant: Campbell University Inc.
Billing Address: 255 Dr. McKoy Rd
City Buies Creek NC Zip 27506
Contact Phone # 814-7331
Location of Tent/Canopy: 2000 WADE STEWART CIR
City LILLINGTON State NC Zip 27546
City LILLINGTON State NC Zip 27546 Set-up Date 8 29 18 Completion Date 8 30 18
This application must be completed and returned to Central Permitting, prior to the issuance of the permit. A site inspection will be conducted to verify compliance. Please allow (7) working days for processing. There will be a permit fee assessed for the tent(s). Permit fees shall be paid after reviewed has been completed. The following items are required to be submitted with this application:
Site plan showing location of tent/canopy on property and distance from buildings.
Number of tents/canopies including dimensions of each and whether the tent will be equipped with enclosed sides.
Proposed use of each tent/canopy.
4 Flame resistant certificate for each tent/canopy.
8 24 18
Applicant Signature Date

Harnett GIS



0.8 XDF

To: Harnett County Fire Marshall

From: Jason S. Wangelin

Assistant Director Facilities Management

Campbell University, Inc.

Please be advised that we are installing a 40x80-tent canopy at Barker Lane Football Stadium on Hwy. 421, Buies Creek, NC on 08/29/18 for use on 08/30/18 at our football game. This tent canopy will be used for a dinner gathering. There will be no cooking underneath the tent. This letter is in response as notification pursuant to North Carolina Fire Code, Chapter 24 – 20.19 Requirement.

Sincerely: Jason S. Wangelin