



## Fire Marshal Division

September 20, 2018

Jason Wangelin  
Campbell University  
PO Box 535  
Buies Creek, NC 27506

**Re: Campbell University Tent  
180 Wade Stewart Circle  
Buies Creek, NC 27506**

**Application Number FMFW1809-004**

Mr. Wangelin,

Thank you for submitting the plans for the tent. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **2404.12 Fire Extinguishers.**
  - 2A-10B: C fire extinguisher shall be placed at tents/canopies with a travel distance not to exceed 100' from any fire extinguisher.
  
- **2403.12.5.1 Arrangement of aisles.**
  - The arrangement of aisles shall be subject to the approval of the fire code official and shall be maintained clear at all times during occupancy.
  
- **2403.12.6 Exit Signs**



- Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more.
- **2404.4 Certification**
  - Provide a flame propagation certificate from the tent owner/company.
- **2404.6 Smoking**
  - Smoking shall not be allowed under tents/canopies. "NO SMOKING" signs shall be conspicuously posted under the tent.
- **2404.19 Generators**
  - Generators and other internal combustion power sources shall be separated from tents and canopies by a minimum of 20 feet and shall be isolated from contact with the public by approved means.
- **2404.16.2.1 LP Gas Containers**
  - Portable LP gas containers that are less than 500 gallons shall have minimum separation of 10 feet between the container and the tent/canopy.

Thank you again for submitting the plans for the tent. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,

Roger Sullivan  
Deputy Fire Marshal

# HCFM

Office of the Fire Marshal  
P.O. Box 370  
Lillington, N.C. 27546  
(910)-893-7580

## Permit Certificate

**Business Name:** CAMPBELL FOOTBALL FIELDHOUSE

**Address:** 180 WADE STEWART CIR  
LILLINGTON, NC 27546

**Phone:**

The following permit has been issued:

Permit No. FMFW1809-0004

**Type: 030 Tent and Air Supported Structure > 700 SQ.**

**Issued Date:** 09/20/2018  
**Effective Date:** 09/21/2018  
**Expiration Date:** 09/22/2018

This permit certificate has been issued for [ ] construction / [ ] operational purposes located at the above business location. This permit has been issued and will be enforced in accordance with section 105 of the N.C. State Fire Prevention Code. Please contact our office for any further questions regarding this permit.

---

**Inspector:** Christopher Scott Toler

**Date**



## Fire Marshal Division

1005 Edwards Brother Drive  
Lillington, NC 2756  
910-893-7580

### Application for Tent/Canopy Permit

Application# FMFW1809-00004 Date: 9 / 19 / 18

Applicant: Campbell University INC

Billing Address: 255 Dr. McKoy Rd

City Buies Creek State nc Zip 27506

Contact Phone # (910)814-7331


Location of Tent/Canopy: 180 WADE STEWAET CIR

City LILLINGTON State NC Zip 27546

Set-up Date 9 / 21 / 18 Completion Date 9 / 22 / 18

**This application must be completed and returned to Central Permitting, prior to the issuance of the permit.** A site inspection will be conducted to verify compliance. Please allow (7) working days for processing. There will be a permit fee assessed for the tent(s). Permit fees shall be paid after reviewed has been completed. The following items are required to be submitted with this application:

- 1 Site plan showing location of tent/canopy on property and distance from buildings.
- 2 Number of tents/canopies including dimensions of each and whether the tent will be equipped with enclosed sides.
- 3 Proposed use of each tent/canopy.
- 4 Flame resistant certificate for each tent/canopy.

  
Applicant Signature

9 / 19 / 18  
Date

# Harnett GIS



NOT FOR LEGAL USE .

**Harnett COUNTY**

GIS/E-911 Addressing  
September 19, 2018

Recycle Center  
Landfills  
Surrounding County Boundaries  
Federal Property

City Limits  
Address Numbers  
Airport  
Major Roads  
Interstate

NC  
US  
Roads  
Mile\_Markers  
Railroad

Parcels

1 inch = 94 feet

To: Harnett County Fire Marshall

From: Jason S. Wangelin  
Assistant Director Facilities Management  
Campbell University, Inc.

Please be advised that we are installing a 20X40-tent canopy at the football Field house located at 180 Wade Stewart Cir Lillington NC on 9/21/18 for the use at the home football game on 9/22/18 . There will be no cooking underneath the tent. This letter is in response as notification pursuant to North Carolina Fire Code, Chapter 24 – 20.19 Requirement.

Sincerely:  
Jason S. Wangelin