



Fire Marshal Division

October 23, 2018

Re: T.A.S Auto Sales
509 W. Front St.
Lillington, NC 27546

Application Number FMFW1810-0008

To Whom It May Concern,

Thank you for submitting the plans for the existing building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **506.1 Knox Box**
 - A Knox Box is required to be installed on the building. Please see the link below to order Knox box. Paper order form available upon request.
 - <https://www.knoxbox.com/store/Knox-Box-3200-Series.cfm>
- **505.1 Address Numbers**
 - The physical address shall be installed on the building so that it is visible from the approach side, minimum size of 6 inch.
 - The numbers shall be of contrasting colors.
- **906.1 Fire Extinguishers required.**
 - A minimum 2A10BC classification of fire extinguisher is required on each floor and located so that the maximum travel distance to reach an extinguisher does not exceed 75ft.
 - Fire Extinguishers shall be located in approved cabinets along corridors and hallways.
 - Also, a minimum 40BC classification fire extinguisher is required inside the elevator equipment room.
 - All fire extinguishers shall be mounted not higher than 5ft. above the finished floor and in accordance with NFPA 10.



- **1006 Illumination emergency power.**
 - In the event of power supply failure, an emergency electrical system shall automatically illuminate corridors.

- Comments
 - A final fire inspection is required.
 - Schedule all fire inspections through the Fire Marshal's Office.
(910) 984-4003

Thank you again for submitting the plans for the existing building. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal